




All-Island Ten Year  
Transmission  
Forecast  
Statement  
2015



### DISCLAIMER

EirGrid and SONI have followed accepted practice in the collection and analysis of data available. While all reasonable care has been taken in the preparation of this statement, EirGrid and SONI/NIE are not responsible for any loss that may be attributed to the use of this information. Prior to taking business decisions, interested parties are advised to seek separate and independent opinion in relation to the matters covered by this statement and should not rely solely upon data and information contained herein. Information in this document does not amount to a recommendation in respect of any possible investment. This document does not purport to contain all the information that a prospective investor or participant in the Single Electricity Market may need. Furthermore, all interested parties are strongly advised to channel any enquiries through EirGrid and SONI.

This document incorporates the Transmission System Capacity Statement for Northern Ireland and the Transmission Forecast Statement for Ireland.

For queries relating to this document or to request a copy contact [enquiries@soni.ltd.uk](mailto:enquiries@soni.ltd.uk) or [info@eirgrid.com](mailto:info@eirgrid.com).

### COPYRIGHT NOTICE

All rights reserved. This entire publication is subject to the laws of copyright. This publication may not be reproduced or transmitted in any form or by any means, electronic or manual, including photocopying without the prior written permission of EirGrid and SONI.

©SONI Ltd 2015  
12 Manse Rd, Belfast, BT6 9RT, N. Ireland

©EirGrid Plc 2015  
The Oval, 160 Shelbourne Road, Ballsbridge,  
Dublin 4, Ireland

## Foreword

EirGrid and SONI, as the transmission system operators (TSOs) for Ireland and Northern Ireland respectively, have collaborated to produce the latest all-island Ten Year Transmission Forecast Statement (TYTFS).



This 2015 statement has been prepared in accordance with the provisions of Section 38 of the Electricity Regulation Act, 1999 (EirGrid) and Condition 33 of the “Licence to participate in the Transmission of Electricity” (SONI).

The TYTFS 2015 presents the most up-to-date available transmission system information at the data freeze date of July 2015.

The statement shows that data centres now represent significant demand connections in Ireland. Based on customer enquiries, a large portion of these centres plan to connect in the Dublin area. If these data centres connect as predicted, new transmission system solutions may be required in the Dublin area.

Northern Ireland results presented in the TYTFS 2015 highlight new generation opportunities in the eastern region. The results also show that to allow future generation connections in the North-West region of Northern Ireland, network reinforcements would be required. The opportunities shown to connect new demand in Northern Ireland assume sufficient generation adequacy in Northern Ireland which is linked to the completion of the planned North – South 400 kV tie line.

This planned development will increase security of supply on the island. It will also support the development of renewable power generation and provide economic benefits to customers on the island.

Those who are considering connecting generation or demand to the transmission systems of Ireland or Northern Ireland should contact us at [info@eirgrid.com](mailto:info@eirgrid.com) or [enquiries@soni.ltd.uk](mailto:enquiries@soni.ltd.uk).

I hope you find this document informative and we welcome any feedback and suggestions.

A handwritten signature in purple ink that reads "Fintan Slye". The signature is written in a cursive, flowing style.

Fintan Slye

Chief Executive, EirGrid Group



## DOCUMENT STRUCTURE



The current. The future.

## Document Structure

This document contains Abbreviations and Glossary of Terms section, an Executive Summary, eight main sections and nine appendices. The structure of the document is as follows:

The **Abbreviations and Terms** provides a glossary of terms used in the document

The **Executive Summary** gives an overview of the main highlights of the document.

**Chapter 1: Introduction:** presents the purpose and context of the All-Island Transmission Forecast Statement. Our statutory and legal obligations are also introduced.

**Chapter 2: The Electricity Transmission System:** describes the existing all-island transmission system. A brief outline of transmission system development plans for both Ireland and Northern Ireland is also given.

**Chapter 3: Demand:** describes the demand forecast assumptions over the study period of 2015 – 2024.

**Chapter 4: Generation:** describes the projected generation connection assumptions over the study period of 2015 – 2024.

**Chapter 5: Transmission System Performance:** provides information on power flow and short circuit study results.

**Chapter 6: Overview of Transmission System Capability Analysis:** outlines the analysis methods used to carry out the demand and generation opportunities' analyses.

**Chapter 7: Transmission System Capability for New Generation:** describes the opportunities for connection of new generation on the all-island transmission system.

**Chapter 8: Transmission System Capability for New Demand:** describes the opportunities for connection of new demand on the all-island transmission system.

**Appendix A: Maps and Schematic Diagrams**

**Appendix B: Transmission System Characteristics**

**Appendix C: Demand Forecasts at Individual Transmission Interface Stations**

**Appendix D: Generation Capacity and Dispatch Details**

**Appendix E: Short Circuit Currents**

**Appendix F: Additional Information on Opportunities**

**Appendix G: References**

**Appendix H: Power Flow Diagrams**



## ABBREVIATIONS & GLOSSARY OF TERMS



The current. The future.

## Abbreviations and Glossary Terms

### Abbreviations

|       |  |
|-------|--|
| AC    | Alternating Current  |
| ACS   | Average Cold Spell   |
| ATR   | Associated Transmission Reinforcement                      |
| BSP   | Bulk Supply Point  |
| CAES  | Compressed Air Energy Storage                              |
| CCGT  | Combined Cycle Gas Turbine                                 |
| CER   | Commission for Energy Regulation                           |
| CHP   | Combined Heat and Power                                    |
| DC    | Direct Current / Double Circuit                            |
| DCENR | Department of Communications, Energy and Natural Resources |
| DETI  | Department of Enterprise Trade and Investment              |
| DO    | Distillate Oil   |
| DSM   | Demand Side Management                                     |
| DSO   | Distribution System Operator                               |
| ESB   | Electricity Supply Board                                   |
| ESRI  | Economic and Social Research Institute                     |
| EU    | European Union   |
| FAQ   | Firm Access Quantity                                       |
| GCS   | Generation Capacity Statement                              |
| GIS   | Gas Insulated Switchgear                                   |
| HFO   | Heavy Fuel Oil   |
| HVDC  | High Voltage Direct Current                                |
| IME   | Internal Market for Electricity                            |



|      |                                      |
|------|--------------------------------------|
| IMP  | Independent Market Participant       |
| IPP  | Independent Power Producer           |
| IRL  | Ireland                              |
| ITC  | Incremental Transfer Capability      |
| kV   | Kilo Volts                           |
| LFG  | Land Fill Gas                        |
| MCR  | Maximum Continuous Rating            |
| MEC  | Maximum Export Capacity              |
| MIC  | Maximum Import Capacity              |
| MVA  | Megavolt-Amperes                     |
| MW   | Megawatt                             |
| NI   | Northern Ireland                     |
| NIE  | Northern Ireland Electricity         |
| NTC  | Net Transfer Capacity                |
| PPB  | Power Procurement Business           |
| PU.  | Per Unit                             |
| PST  | Phase Shifting Transformer           |
| RES  | Renewable Energy Schemes             |
| RMS  | Root Mean Square                     |
| RP   | Review Period                        |
| SEM  | Single Electricity Market            |
| SONI | System Operator for Northern Ireland |
| SPS  | Special Protection Scheme            |
| SVC  | Static Var Compensator               |
| SP   | Summer Peak                          |
| SS   | Substation                           |

|       |  |
|-------|--|
| SV    | Summer Valley                            |
| TDP   | Transmission Development Plan            |
| TYTFS | Ten Year Transmission Forecast Statement |
| TRM   | Transfer Reserve Margin                  |
| TSO   | Transmission System Operator             |
| TTC   | Total Transfer Capacity                  |
| TX    | Transformer                              |
| WFPS  | Wind Farm Power Station                  |
| WP    | Winter Peak                              |

## Terms

|                                       |   |
|---------------------------------------|---|
| Active Power                          | The product of voltage and the in-phase component of alternating current measured in Megawatts (MW). When compounded with the flow of 'reactive power', measured in Megavolt-Amperes Reactive (Mvar), the resultant is measured in Megavolt-Amperes (MVA).  |
| Autumn Peak                           | This is the maximum Northern Ireland demand in the period September to October inclusive.   |
| Associated Transmission Reinforcement | Associated Transmission Reinforcements (ATRs) are all of the transmission reinforcements that must be completed in order for a generator to be allocated FAQ. ATRs include reinforcements such as line and busbar upratings, new stations and new lines.  |
| Bulk Supply Point                     | A point at which the Northern Ireland transmission system is connected to the distribution system.  |
| Busbar                                | The common connection point of two or more circuits.  |
| Capacitor                             | An item of plant normally utilised on the electrical network to supply reactive power to loads (generally locally) and thereby supporting the local area voltage.   |
| Commission for Energy Regulation      | The Commission for Energy Regulation (CER) is the regulator for the electricity and natural gas sectors in Ireland. The CER was initially established as the Commission for Electricity Regulation under the Electricity Regulation Act, 1999. The functions of the CER along with its name were changed by the Gas (Interim Regulation) Act, 2002. Under that Act, the remit of the CER was expanded to include the regulation of the natural gas sector and the name changed to the Commission for Energy Regulation. |
| Circuit                               | An element of the transmission system that carries electrical power.  |

|                            |   |
|----------------------------|---|
| Combined Cycle Gas Turbine | A collection of gas turbines and steam units; waste heat from the gas turbine(s) is passed through a heat recovery boiler to generate steam for the steam turbine(s).   |
| Combined Heat and Power    | A plant designed to produce both heat and electrical power from a single heat source.   |
| Constraint                 | A transfer limit imposed by finite network capacity.  |
| Contingency                | The unexpected failure or outage of a system component, such as a generation unit, transmission line, transformer or other electrical element. A contingency may also include multiple components, which are related by situations leading to simultaneous component outages. |
| Data Freeze Date           | The dates on which the Transmission Forecast Statement data was effectively “frozen” for both EirGrid and SONI. Changes to transmission system characteristics made after these dates do not feature in the analyses carried out for this Transmission Forecast Statement.    |
| Deep Reinforcement         | Refers to transmission system reinforcement additional to the shallow connection that is required to allow a new generator or demand to operate at maximum capacity.  |
| Demand                     | The peak demand figures in Table 1-1 in the introduction refer to the power that must be transported from transmission system-connected generation stations to meet all customers' electricity requirements. These figures include transmission losses.                       |
| Demand-Side Management     | The modification of normal demand patterns usually through the use of financial incentives.   |
| EirGrid                    | EirGrid plc is the state-owned company established to take on the role and responsibilities of Transmission System Operator in Ireland as well as market operator of the wholesale trading system.  |
| Embedded Generation        | Refers to generation that is connected to the distribution system or at a customer's site.  |

|                                 |   |
|---------------------------------|---|
| Firm Access Quantity            | The level of firm financial access available in the transmission network for a generator is that generator's Firm Access Quantity or 'FAQ'. Firm financial access means that if a generator is constrained on or off, it is eligible for compensation in the manner set out in the Trading & Settlement Code.   |
| Gate 2                          | The term given to the group-processing scheme that applies to approximately 1,300 MW of renewable generation seeking connection to the transmission and distribution systems.   |
| Gate 3                          | The term given to the group-processing scheme that applies to approximately 10,000 MW of generation seeking connection to the transmission and distribution systems.  |
| Generation Dispatch             | The configuration of outputs from the connected generation units.   |
| Grid Code (EirGrid)             | The EirGrid Grid Code is designed to cover all material technical aspects to the operation and use of the transmission system of Ireland. The code was prepared by the TSO (pursuant to Section 33 of the Electricity Regulation Act, 1999) and approved by the CER. The Grid Code is available on <a href="http://www.eirgrid.com">www.eirgrid.com</a> . |
| Grid Code (SONI)                | The SONI Grid Code is designed to permit the development, maintenance and operation of an efficient, co-ordinated and economical transmission system in Northern Ireland. It is prepared by the TSO (SONI) pursuant to condition 16 of SONI's Licence. The SONI Grid Code is available at <a href="http://www.soni.ltd.uk">www.soni.ltd.uk</a>            |
| Incremental Transfer Capability | A measure of the transfer capability remaining in the physical transmission system for further commercial activity over and above anticipated uses.   |
| Interconnector                  | The tie line, facilities and equipment that connect the transmission system of one independently supplied transmission system to that of another.   |

|                                  |  |
|----------------------------------|--|
| Loadflow                         | Study carried out to simulate the flow of power on the transmission system given a generation dispatch and system load.  |
| Maximum Continuous Rating        | <p>The maximum capacity (MVA) modified for ambient temperature conditions that the circuit can sustain indefinitely without degradation of equipment life.</p> <p>The MCR of a generator is the maximum capacity (MW) modified for ambient temperature conditions that the generation unit can sustain indefinitely without degradation of equipment life. All generation capacity figures in this Transmission Forecast Statement are maximum continuous ratings (defined as its MCR at 10°C), expressed in exported terms i.e., generation unit output less the unit's own load.</p> |
| Maximum Export Capacity          | The maximum export value (MW) provided in accordance with the generator's connection agreement. The MECs are contract values which the generator chooses to cater for peaking under certain conditions that are not normally achievable or sustainable e.g., a CCGT plant can produce greater output at lower temperatures.  |
| Node                             | Connecting point at which several circuits meet. Node and station are used interchangeably in this Transmission Forecast Statement.  |
| Parametric Analysis (P-V) curves | A parametric study involves a series of power flows that monitor the changes in one set of power flow variables with respect to another in a systematic fashion. In this Transmission Forecast Statement the two variables are voltage and ITC.  |
| Per Unit (p.u.)                  | Ratio of the actual electrical quantity to the selected base quantity. The base quantity used here for calculation of per unit impedances is 100 MVA.  |
| Phase Shifting Transformer       | An item of plant employed on the electrical network to control the flow of active power.   |

|                           |  |
|---------------------------|--|
| Power Factor              | The power factor of a load is a ratio of the active power requirement to the reactive power requirement of the load.   |
| Reactive Compensation     | The process of supplying reactive power to the network.  |
| Reactor                   | An item of plant employed on the electrical network to either limit short circuit levels or prevent voltage rise depending on its installation and configuration.  |
| Shallow Connection        | Shallow Connection means the local connection assets required to connect a customer to the Transmission System and which are for the specific benefit of that particular customer.   |
| Single Electricity Market | In November 2004 the governments of the Republic of Ireland and the UK announced the future establishment of a Single Electricity Market on the island of Ireland. This has replaced the previous bilateral trading model in Ireland. Further details can be found on the All Island Project website, <a href="http://www.allislandproject.org">www.allislandproject.org</a> . |
| SONI                      | System Operator for Northern Ireland (SONI) Ltd is owned by EirGrid plc. SONI ensures the safe, secure and economic operation of the high-voltage electricity system in Northern Ireland and in cooperation with EirGrid is also responsible for running the all-island wholesale market for electricity.  |
| Split Busbar              | Refers to the busbar(s) at a given substation which is operated electrically separated. Busbars are normally split to limit short circuit levels or to maintain security of supply.  |
| Static Var Compensator    | Device which provides fast and continuous capacitive and inductive reactive power supply to the power system.  |
| Summer Valley             | This is the minimum system demand. It occurs in the period March to September, inclusive in Ireland and May to August, inclusive in Northern Ireland   |

|                                |   |
|--------------------------------|---|
| Summer Peak                    | This is the maximum system demand in the period March to September, inclusive in Ireland and May to August, inclusive in Northern Ireland.  |
| Tee Connection                 | Un-switched connection into existing line between two other stations.   |
| Total Transfer Capability      | The total capacity available on cross-border circuits between Ireland and Northern Ireland for all flows, including emergency flows that occur after a contingency in either system.  |
| Transformer                    | An item of equipment connecting busbars at different nominal voltages. (see also Phase Shifting Transformer)  |
| Transmission Interface Station | A station that is a point of connection between the transmission system and the distribution system or directly-connected customers.  |
| Transmission Losses            | A small proportion of energy is lost mainly as heat whilst transporting electricity on the transmission system. These are known as transmission losses. As the amount of energy transmitted increases, losses also increase.  |
| Transmission Peak              | The peak demand that is transported on the transmission system. The transmission peak includes an estimate of transmission losses.  |
| Transmission Planning Criteria | The set of standards that the transmission system of Ireland is designed to meet.   |
| Transmission System            | The transmission system is a meshed network of high-voltage lines and cables (400 kV, 275 kV, 220 kV and 110 kV) for the transmission of bulk electricity supply around Ireland and Northern Ireland. The transmission system and network are used interchangeably in this Transmission Forecast Statement. |
| Uprating                       | To increase the rating of a circuit. This is achieved by increasing ground clearances and/or replacing conductor, together with any changes to terminal equipment and support structures.   |



Utility Regulator NI

UREGNI are an independent non-ministerial government department set up to ensure the effective regulation of the Electricity, Gas and Water and Sewerage industries in Northern Ireland

Winter Peak

This is the maximum annual system demand. It occurs in the period October to February, inclusive in Ireland and in the Period November to February in Northern Ireland.



## TABLE OF CONTENTS



The current. The future.

| <b>Contents</b>                |   | <b>Page</b> |
|--------------------------------|---|-------------|
| <b>Foreword</b>                |   |             |
| <b>Document Structure</b>      |   |             |
| <b>Abbreviations and Terms</b> |   |             |
| <b>Executive Summary</b>       |   |             |
| <b>1</b>                       | <b>Introduction</b>   | <b>1-1</b>  |
| 1.1                            | Grid Development Strategy   | 1-2         |
| 1.2                            | Governing Arrangements  | 1-2         |
| 1.3                            | Other Information   | 1-4         |
| 1.4                            | Data Management   | 1-5         |
| 1.5                            | Publication   | 1-6         |
| <b>2</b>                       | <b>The Electricity Transmission System</b>  | <b>2-1</b>  |
| 2.1                            | Overview of the All-Island Electricity Transmission System                        | 2-1         |
| 2.2                            | Existing Connections Between Ireland and Northern Ireland<br>Transmission Systems | 2-3         |
| 2.3                            | Interconnection with Great Britain and Europe                                     | 2-4         |
| 2.4                            | Ireland Transmission System Developments  | 2-8         |
| 2.5                            | Northern Ireland Transmission System Developments                                 | 2-19        |
| 2.6                            | Joint Ireland and Northern Ireland Approved Transmission System<br>Developments   | 2-27        |
| 2.7                            | Connection of New Generation Stations   | 2-28        |
| 2.8                            | Connection of New Interface Stations  | 2-32        |
| 2.9                            | Detailed Transmission Network Information   | 2-33        |
| <b>3</b>                       | <b>Demand</b>   | <b>3-1</b>  |
| 3.1                            | Forecasts of Transmission Peaks   | 3-1         |
| 3.2                            | Demand Data   | 3-6         |
| 3.3                            | Forecast Demand at Transmission Interface Stations in Ireland                     | 3-11        |
| 3.4                            | Northern Ireland Bulk Supply Point (BSP) Demand                                   | 3-12        |
| <b>4</b>                       | <b>Generation</b>   | <b>4-1</b>  |
| 4.1                            | Ireland Generation  | 4-2         |
| 4.2                            | Northern Ireland Generation   | 4-8         |
| <b>5</b>                       | <b>Transmission System Performance</b>  | <b>5-1</b>  |
| 5.1                            | Forecast Power Flows  | 5-1         |
| 5.2                            | Compliance with Planning Standards  | 5-2         |
| 5.3                            | Short Circuit Current Levels  | 5-3         |
| <b>6</b>                       | <b>Overview of Transmission System Capability Analysis</b>                        | <b>6-1</b>  |
| 6.1                            | All-Island Demand Opportunity Analysis  | 6-1         |
| 6.2                            | All-Island Generator Opportunity Analysis   | 6-10        |

|          |  |            |
|----------|--|------------|
| <b>7</b> | <b>Transmission Capability for New Generation</b>                                      | <b>7-1</b> |
| 7.1      | Background   | 7-1        |
| 7.2      | New Generation Capacity  | 7-2        |
| 7.3      | Regional Generation and Demand Balance   | 7-2        |
| 7.4      | Generation Locational Tariff Signals and Their Impact on Transmission Network Capacity | 7-6        |
| 7.5      | Looking to the Future  | 7-11       |
| <b>8</b> | <b>Transmission Capability for New Demand</b>  | <b>8-1</b> |
| 8.1      | Transmission System Demand Capability Obligations                                      | 8-1        |
| 8.2      | All-Island Transmission System Capability for New Demand                               | 8-2        |
| 8.3      | New Demand Opportunities for the Dublin Area   | 8-4        |
| 8.4      | Transmission System Capability for New Demand in Ireland                               | 8-14       |
| 8.5      | Controllable Demand  | 8-18       |
| 8.6      | Transmission System Capability for New Demand in Northern Ireland                      | 8-19       |
| 8.7      | How to Use the Information for Demand  | 8-22       |

## Appendices

|          |   |            |
|----------|---|------------|
| <b>A</b> | <b>Maps and Schematic Diagrams</b>                                    | <b>A-1</b> |
| A.1      | Network Maps  | A-1        |
| A.2      | Short Bus Codes   | A-4        |
| A.3      | Schematic Diagrams of the All Island Transmission System              | A-7        |
| <b>B</b> | <b>Transmission System Characteristics</b>                            | <b>B-1</b> |
| B.1      | Characteristics of the Existing Transmission System                   | B-4        |
| B.2      | Changes in Transmission System Characteristics                        | B-21       |
| <b>C</b> | <b>Demand Forecasts at Individual Transmission Interface Stations</b> | <b>C-1</b> |
| <b>D</b> | <b>Generation Capacity and Dispatch Details</b>                       | <b>D-1</b> |
| D.1      | Generation Dispatch Details   | D-18       |
| <b>E</b> | <b>Short Circuit Currents</b>   | <b>E-1</b> |
| E.1      | Background of Short Circuit Currents                                  | E-1        |
| E.2      | The Nature of Short Circuit Currents                                  | E-2        |
| E.3      | Duty of Circuit Breakers  | E-4        |
| E.4      | Short Circuit Current Calculation Methodology                         | E-5        |
| E.5      | Short Circuit Currents in Ireland                                     | E-6        |
| E.6      | Short Circuit Currents in Northern Ireland                            | E-36       |
| <b>F</b> | <b>Additional Information on Opportunities</b>                        | <b>F-1</b> |
| F.1      | EirGrid Draft Approach to Consultation                                | F-1        |
| <b>G</b> | <b>References</b>   | <b>G-1</b> |
| <b>H</b> | <b>Power Flow Diagrams</b>  | <b>H-1</b> |
| H.1      | Guide to the Power Flow Diagrams                                      | H-1        |



## EXECUTIVE SUMMARY



The current. The future.

## Executive Summary

The All-Island Ten Year Transmission Forecast Statement (TYTFS) 2015 provides the following information:

- network models and data of the All-Island transmission system,
- forecasted generation capacity and demand growth,
- maximum and minimum fault levels at transmission system stations,
- predicted transmission system power flows at different points in time, and
- demand and generation opportunities on the transmission system.

The TYTFS 2015 is prepared in accordance *with Section 38 of Ireland's Electricity Regulation Act, 1999*. The TYTFS 2015 is also prepared in accordance with *Condition 33, Part 1 of SONI's Licence to Participate in the Transmission of Electricity*.

The information in the TYTFS 2015 is shown for the island of Ireland from 2015-2024. EirGrid and SONI have jointly prepared the TYTFS 2015 which supersedes the All-Island Transmission Forecast Statement 2014-2023.

We have updated previously published information in light of modified transmission system developments over the period covered by the TYTFS 2015.

The TYTFS 2015 presents the most up-to-date available all- island transmission system information at the data freeze date of July 2015. Where applicable, data provided on transmission system projects under development have been provided in accordance with EirGrid's draft grid development strategy<sup>1</sup>.

Data for transmission system projects under development is provided such that no particular preference is given to one solution<sup>2</sup>.

---

<sup>1</sup> EirGrid recently published a discussion paper on Ireland's draft grid development strategy. The review outlines our proposed strategy for the long-term development of the network. <https://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid-Draft-Grid-Development-Strategy.pdf>

<sup>2</sup> Strategy Statement 2 "Consider all practical technology options for network development" from EirGrid's Discussion Paper on Ireland's Draft Grid Development Strategy.

For our analysis the current demand forecast utilised in this TYTFS represents an average annual increase in winter peak demand of 0.5% between 2015 and 2024<sup>3</sup>. The forecast in demand is taken from the *All-Island Generation Capacity Statement 2015-2024 (GCS)*<sup>4</sup>.

Since the freeze date there has been an increase in activity in the demand sector. We have therefore provided additional information this year due to the considerable interest and enquiries for data centre connections to the grid.

All-island renewable generation capacity is expected to increase rapidly up to 2020 reaching circa 7000 megawatts (MW) of generation capacity. In this TYTFS onshore wind contributes to the majority of renewable generation, however, since the freeze date there has been a significant increase in solar generation applications<sup>5</sup>. Some large conventional plants are expected to retire/divest from 2015-2024, a total capacity of 1788MW.

TYTFS 2015 includes maximum and minimum short circuit current levels<sup>6</sup> at transmission system stations. This information is given at each 110kilovolt (kV), 220kV, 275kV and 400kV transmission system station. Short circuit levels at each transmission system station are given for the following years; – 2015, 2018 and 2021.

Results show that several stations in Northern Ireland are approaching, or would exceed, their rated short circuit current level. This typically occurs under times of high generation. We will manage the transmission system to mitigate possible risks while investment plans are in place to resolve these issues. Further details of short circuit studies can be seen in Chapter 5.

Interconnection with neighbouring countries enhances the transmission system security of supply through access to a broader generation base.

Interconnection also allows greater competition and the potential for prices to be reduced.

---

<sup>3</sup> [http://www.eirgridgroup.com/site-files/library/EirGrid/Eirgrid\\_Generation\\_Capacity\\_Statement\\_2015.-2024.pdf](http://www.eirgridgroup.com/site-files/library/EirGrid/Eirgrid_Generation_Capacity_Statement_2015.-2024.pdf)

<sup>4</sup> The TYTFS 2015 references documents that were published at the July 2015 data freeze date. The All-Island Generation Capacity Statement 2016-2025 is due to be published at the beginning of March 2016. The information in the 2016 GCS however does not fundamentally impact studies presented in the 2015 TYTFS.

<sup>5</sup> See Chapter 4 for more information on the increase in solar generation applications post the June 2015 data freeze date.

<sup>6</sup> A description of short circuit levels is given in Chapter 5 and Appendix E



Our analysis includes the Moyle and EWIC high voltage direct current (HVDC) interconnectors. These interconnectors connect the all-island transmission system to the UK transmission system.

The generation adequacy of Northern Ireland is dependent on the completion of the planned North – South 400kV tie line. The planned North – South 400kV tie line will increase security of supply on the island. It will also support the development of renewable power generation and provide economic benefits to customers on the island. Information on the North - South 400kV tie line can be viewed in Chapter 2.

TYTFS 2015 presents information on generation and demand opportunities for interested parties. This information is based on assessments and studies carried out on an all-island basis.

The methodology applied to the all-island generation opportunities can be seen in Chapter 6, while the details of the assessment can be viewed in Chapter 7.

The all-island generation opportunities assessment provides information for generators wishing to connect to the transmission system. This is done through identifying regions where there is a generation capacity deficit and others where there is a surplus. In practice, regional generation levels will vary considerably, for example, depending on wind generation power output levels. Each region is interconnected by a meshed, high capacity transmission system. This is essential to maintain security and reliability of supply for demand customers across the Island of Ireland.

Regional changes in locational tariff signals are also described. This is done to help network users make informed decisions when exploring potential transmission network connection locations.

The main trend that emerges is there are high levels of generation, relative to local demand levels in Western regions and central Ireland, in comparison to regions along the Eastern seaboard. Dublin currently is the only region where demand exceeds generation.

Regions with surplus generation capacity in the South West, West and North West of Ireland have lower Transmission Loss Adjustment Factors and higher generator transmission use of system charges than Eastern regions with higher demand levels and less surplus generation.

In general, generation connections can be more readily accommodated in locations close to existing demand centres.

All-island Demand Opportunities calculated using an incremental transfer capability analysis of the 2020 transmission system are presented in Chapter 8. The study indicates that all stations studied across the island have the capability to accommodate demand connections, some to a lesser degree than others. This analysis assumes that the planned North-South 400 kV tie-line is in place by 2020. This new line improves the overall generation adequacy situation in Northern Ireland and is an important factor when considering the capacity of the system to connect significant amounts of additional demand in Northern Ireland.

Chapter 8 also includes a qualitative assessment of the demand capability in the Dublin area. This assessment has been included as a result of the recent large volume of data centre enquires in the Dublin area. The Dublin area assessment provides:

- A description of the Dublin transmission network
- Areas of focus for demand connections in Dublin and the scale of interest in each zone
- Planned transmission developments in Dublin

The results of demand and generation opportunity analysis are based on high level transmission network assessments. The results provide guidance, the actual connection capacity and possible connection solutions can only be determined following detailed individual connection studies. We will continue to examine innovative solutions and technologies in response to future connection enquiries.

It is advisable to consult us early in the project process. We are working to understand the needs of developers and their impact in terms of our grid development strategy.

Those who are considering connecting generation or demand to the transmission systems of Ireland or Northern Ireland should contact us. In Ireland customers can contact us at [info@eirgrid.com](mailto:info@eirgrid.com) while Northern Ireland customers can contact us at [enquiries@soni.ltd.uk](mailto:enquiries@soni.ltd.uk) for further information.



## 1 INTRODUCTION

- 1.1 Grid Development Strategy
- 1.2 Governing Arrangements
- 1.3 Other Information
- 1.4 Data Management
- 1.5 Publication



The current. The future.

## 1 Introduction

The transmission system is a network of 400kV, 275kV, 220kV and 110kV high-voltage lines and cables. It is the backbone of the power system, efficiently delivering large amounts of power from where it is generated to where it is needed.

Electricity supply is essential, and a reliable network is the means by which we move electricity around the country. The development of transmission network infrastructure is therefore of national strategic importance.

EirGrid is the Transmission System Operator (TSO) in Ireland, while SONI is the TSO in Northern Ireland. As TSOs, we jointly prepare and publish the all island Ten Year Transmission Forecast Statement (TYTFS) on an annual basis.

In Ireland, EirGrid plan and develop<sup>1</sup> the transmission system to ensure it meets forecasted transmission system operating conditions. In Northern Ireland SONI are responsible for planning the transmissions system. We must also ensure the transmission system is planned and operated to maintain its performance within defined security standards.

The TYTFS 2015 provides information on planned developments for the transmission system. It also provides information on electricity demand growth, generation capacity and interconnection with other electricity transmission systems. The appendices provide the reader with transmission system data to enable the reader to perform power flow analysis.

Readers should also consider other documents we produce when using data provided by the TYTFS 2015<sup>2</sup>, including the All-Island Generation Capacity Statement 2015-2024 (GCS)<sup>3</sup> published in February 2015.

The GCS assesses the generation adequacy of the island of Ireland from 2015 to 2024. Where possible the TYTFS 2015 complements the demand information presented in the GCS.

---

<sup>1</sup> EirGrid recently published a discussion paper on Ireland's draft grid development strategy. This review is available at <http://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid-Draft-Grid-Development-Strategy.pdf>. The review outlines our proposed strategy for the long-term development of the network.

<sup>2</sup> The TYTFS 2015 references documents that were published at the July 2015 data freeze date

<sup>3</sup> The All-Island Generation Capacity Statement 2016-2025 is due to be published at the beginning of March 2016. The information in the 2016 GCS however does not fundamentally impact studies presented in the 2015 TYTFS.

For Ireland, EirGrid also publish a Transmission Development Plan (TDP) annually. The most recent TDP (2015-2025)<sup>4</sup> was recently consulted on by the Commission for Energy Regulation. It provides details of the transmission system developments expected to be progressed in the period up to 2025. The final version is awaiting approval and will be published shortly.

### 1.1 Grid Development Strategy

EirGrid recently published a discussion paper on Ireland's draft grid development strategy<sup>5</sup>. The review outlines our proposed strategy for the long-term development of the network. The proposed grid development strategy was developed in consideration of our three new strategy statements:

- Strategy statement 1: Open engagement and inclusive consultation with local communities and stakeholders will be central to our approach to network development.
- Strategy statement 2: All practical technology options will be considered for network development.
- Strategy statement 3: The network will be optimised to minimise requirements for new infrastructure.

The proposed grid development strategy aims to achieve a balance between the costs and impact of new infrastructure, while maximising the capability of the existing network.

### 1.2 Governing Arrangements

#### 1.2.1 Duty to Prepare a Statement

EirGrid is the Transmission System Operator (TSO) in Ireland, while SONI is the TSO in Northern Ireland. As TSO's, we are each required to publish a Transmission Forecast Statement. Following agreement from the Regulatory Authorities<sup>6</sup> in Ireland and Northern Ireland, we have jointly prepared and published a single document for the island of Ireland since 2012.

In Ireland this is set out in Section 38 of the Electricity Regulation Act 1999 (as amended). Similarly for Northern Ireland, this is done in accordance with Condition 33 of the Licence to participate in the Transmission of Electricity.

---

<sup>4</sup> [www.cer.ie](http://www.cer.ie)

<sup>5</sup> <http://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid-Draft-Grid-Development-Strategy.pdf>

<sup>6</sup> The Commission for Energy Regulation (Ireland) and the Utility Regulator (Northern Ireland)

TYTFS 2015 has been prepared in accordance with and in fulfilment of these obligations. The format was approved by the Commission for Energy Regulation (Ireland) and the Utility Regulator (Northern Ireland).

### 1.2.2 Single Electricity Market

A Single Electricity Market (SEM) has been operating on the island of Ireland, since 2007. The all-island wholesale electricity market allows customers in both Ireland and Northern Ireland to benefit from increased competition. This in turn also allows customers to benefit from reduced energy costs and improved reliability of supply.

The transmission systems of Ireland and Northern Ireland are electrically connected by means of a 275kV interconnector.

The existing 275kV interconnector connects Louth station in Co. Louth (Irl) to Tandragee station, in Co. Armagh (NI). There are an additional two 110kV connections between:

- Letterkenny station in Co. Donegal (Irl) and Strabane station in Co. Tyrone (NI)
- Corraclassy station in Co. Cavan (Irl) and Enniskillen station in Co. Fermanagh (NI)

The transmission systems of Northern Ireland and Ireland were assessed with generation dispatched on an all-island basis in the network models. This is done to reflect the way in which the all-island transmission system is operated.

### 1.2.3 Roles and Responsibilities (Governance)

#### Northern Ireland

Under our licence in Northern Ireland, held by SONI, we are required to plan<sup>7</sup> and operate the Northern Ireland Transmission System.

In doing so we must comply with both the SONI Transmission System Security and Planning Standards and the SONI Grid Code.

---

<sup>7</sup> Under the direction of the Utility Regulator (NI), investment planning functions are now the responsibility of SONI as of May 2014 (ref: Commission Decisions 12.4.2013 pursuant to Article 3(1) of Regulation (EC) No 714/2009 and Article 10(6) of Directive 2009/72/EC – United Kingdom (Northern Ireland) – SONI / NIE).

## Ireland

Under our licence in Ireland, held by EirGrid, we are required to, operate, develop and ensure the maintenance of the Irish Transmission System.

In doing so we must comply with both the Transmission Planning Criteria and the EirGrid Grid Code.

### 1.3 Other Information

Potential users of the transmission system should also be aware of the following key documents:

- SONI Grid Code<sup>8</sup>
- EirGrid Grid Code<sup>9</sup>
- SONI Transmission System Security and Planning Standards<sup>10</sup>
- The Electricity Safety, Quality and Continuity Regulations (Northern Ireland) 2012<sup>11</sup>
- EirGrid Transmission Planning Criteria<sup>12</sup> and Operating Security Standards<sup>13</sup>
- SONI Transmission Connection Charging Methodology Statement<sup>14</sup>
- EirGrid Transmission Connection Charging Methodology Statement 2008<sup>15</sup>
- Final Statement of Charges For Use of Northern Ireland Electricity Ltd Transmission System<sup>16</sup>
- EirGrid Statement of Charges 2015-2016<sup>17</sup>
- All-Island Generation Capacity Statement 2015-2023<sup>18</sup>

---

<sup>8</sup> <http://www.soni.ltd.uk/Operations/GridCodes/>

<sup>9</sup> <http://www.eirgrid.com/operations/gridcode/>

<sup>10</sup> <http://www.soni.ltd.uk/media/documents/Projects/Publications/Northern%20Ireland%20TSSPS%20-%20September%202015.pdf>

<sup>11</sup> [http://www.legislation.gov.uk/nisr/2012/381/pdfs/nisr\\_20120381\\_en.pdf](http://www.legislation.gov.uk/nisr/2012/381/pdfs/nisr_20120381_en.pdf)

<sup>12</sup> <http://www.eirgrid.com/media/Transmission%20Planning%20Criteria.pdf>

<sup>13</sup> <http://www.eirgrid.com/media/Operating%20Security%20Standards%20December%202011.pdf>

<sup>14</sup> <http://www.soni.ltd.uk/media/documents/Archive/SONI%20Charging%20Methodology%20Statement%20December%202009%20-%20Approved%2022%20December%202010.pdf>

<sup>15</sup> <http://www.eirgrid.com/media/Connection%20Charging%20Statement.pdf>

<sup>16</sup> <http://www.soni.ltd.uk/media/documents/Customers/TUOS/Final%20TUoS%20Statement%20of%20Charges%202015-16.pdf>

<sup>17</sup> [http://www.eirgrid.com/media/2013-2014StatementofChargesCERApproved\(180913\)v20.pdf](http://www.eirgrid.com/media/2013-2014StatementofChargesCERApproved(180913)v20.pdf)

## 1.4 Data Management

Transmission system development is continuously evolving. We froze all data for analysis at the beginning of July 2015. This was done to carry out analyses and to update system models and appendices for the TYTFS 2015.

All data for system model files, and sequence data for use with short circuit current level analysis, was collected on this date.

Since the data freeze, a number of changes in the following areas have emerged. The capital approval (CP) numbers enable readers to cross reference transmission projects in Ireland with the TDP.

The following transmission system developments have been initiated as projects:

- CPo740 Letterkenny 110kV station - Relocation of Trillick bay
- CPo840 Ballynahulla 220kV station – 2<sup>nd</sup> Transformer
- CPo868 Knockraha Raffeen 220kV Line Refurbishment
- CPo867 Flagford Louth 220kV Line RefurbishmentCPo871 Galway 110kV busbar refurbishment and uprate
- CPo928 Cloghran 110kV Station Project Phase 3
- CPo904 Kells & Hannahstown 275kV Substation Developments(NI)
- CPo934 Ballynahulla 220/110kV Station – STATCOM
- CPo935 Ballyvouskil 220/110kV Station – STATCOM
- CPo933 Thurles 110kV Station - STATCOM
- CPo936 Knockanure 220/110kV Station – Reactor
- CPo941 Moneypoint Windfarm Shallow Connection
- CPo951 Garvagh 110kV Station Shallow Works

The expected completion date of the following transmission system developments has shifted out by in excess of one year:

- CPo688 Moneypoint 400kV GIS station 2018
- CPo839 Moy 110kV Station reconfiguration and busbar uprate 2019

---

<sup>18</sup> <http://www.eirgrid.com/media/Generation%20Capacity%20Statement%202014.pdf>



The following transmission system development has been terminated as projects:

- CPo673 Knocknagreenan Pumped Storage connection project

The following transmission system developments have been completed:

- CPo507 Arklow 220kV Station - New 20 MVA Transformer (T102)
- CPo728 Kill Hill 110kV Station Shallow Connection Works
- CPo657 Ikerrin - Thurles 110kV Line Uprate (Including Thurles 110kV Busbar Uprate)
- CPo697 Carrick-on-Shannon 110kV Station Busbar Uprate
- CPo709 Dunmanway 110kV Station Busbar Uprate
- CPo716 Carrigadrohid - Macroom 110kV Line Uprate
- CPo736 Cunghill - Sligo 110kV Line Uprate
- CPo744 Cahir - Tipperary 110kV Line Uprate (Including Tipperary 110kV Busbar Uprate)
- CPo747 Maynooth - Ryebrook 110kV Line Uprate
- CPo761 Bruckana 110kV Windfarm Connection
- CPo851 Kilbarry 110kV Station Replacement of three 110kV Circuit Breakers

The assumptions/parameters of following transmission system developments have changed:

- CPo732 Grid Link – *Now Regional Solution*

The following transmission system developments are under review:

- CPo624 Killonan 220kV station refurbishment

## 1.5 Publication

The TYTFS 2015 is available in pdf format on our websites ([www.eirgridgroup.com](http://www.eirgridgroup.com)) (<http://www.soni.ltd.uk/>).

Transmission system model files are also available on the websites.



## 2 THE ELECTRICITY TRANSMISSION SYSTEM

- 2.1 Overview of the Electricity Transmission System
- 2.2 Existing Connections Between Ireland and Northern Ireland Transmission Systems
- 2.3 Interconnection with Great Britain and Europe
- 2.4 Ireland Transmission System Developments
- 2.5 Northern Ireland Transmission System Developments
- 2.6 Joint Northern Ireland and Ireland Approved Transmission System Developments
- 2.7 Connection of New Generation Stations
- 2.8 Connection of New Interface Stations
- 2.9 Detailed Network Information



The current. The future.

## 2 The Electricity Transmission System

### 2.1 Overview of the All-Island Electricity Transmission System

The transmission system in Ireland and Northern Ireland plays a vital role in the supply of electricity. It provides the means to transport energy from generators to demand centres across the island.

The transmission system in Northern Ireland is operated at 275kV and 110kV. The transmission system in Ireland is operated at 400kV, 220kV and 110kV. The two transmission systems are connected by means of one 275kV double circuit.

That connection is from Louth station in Co. Louth (Irl) to Tandragee station in Co. Armagh (NI). There are also two 110kV connections<sup>1</sup>:

- Letterkenny station in Co. Donegal (Irl) to Strabane station in Co. Tyrone (NI); and
- Corraclassy station in Co. Cavan (Irl) to Enniskillen station in Co. Fermanagh (NI)

The 400kV, 275kV and 220kV networks form the backbone of the transmission system. They have higher power carrying capacity and lower losses than the 110kV network.

In Ireland, the 400kV network provides a high capacity link between the Moneypoint generation station on the west coast and Dublin on the east. We are planning a new 400kV cross-border circuit. For the purposes of the 2015 TYTFS analysis it is anticipated to be installed by the end of 2019.

The 275kV network is comprised of a double circuit ring in Northern Ireland. There is also a double circuit spur to Coolkeeragh Power Station and another double circuit spur southwards into Co. Louth, in Ireland.

In Ireland the transmission network is comprised of single circuit lines which are interconnected to cover the wider geographical distances between stations. Typically large generation stations (greater than 100MW) are connected to the 220kV, 275kV or 400kV networks.

---

<sup>1</sup> Eirgrid and SONI together operate the transmission systems - North and South- on an all island basis.

The 110kV<sup>2</sup> circuits provide parallel paths to the 220kV, 275kV and 400kV networks and is the most extensive element of the all-island transmission system, reaching into every county on the island of Ireland.

The transmission system is generally comprised of overhead lines. There are exceptions to this, such as in the city centres of Belfast, Cork and Dublin, where underground cables are used. Table 2-1 presents the total lengths of overhead lines<sup>3</sup> and cables at the different voltage levels. Revision of individual line lengths may change following completion of network development projects.

Table 2-1 Total Length of Existing Transmission System Circuits as at the Data Collection Freeze Date (July 2015)

| Voltage Level | Total Line Lengths (km) | Total Cable Lengths (km) |
|---------------|-------------------------|--------------------------|
| 400kV         | 439                     | 0                        |
| 275kV         | 825                     | <1                       |
| 220kV         | 1786                    | 129                      |
| 110kV         | 5877                    | 372                      |

Transformers located sub stations are required to link the different voltage networks, providing paths for power to flow from the higher to the lower voltage networks. The total transformer capacity between the different voltage levels is presented in Table 2-2.

Table 2-2 Total Transmission System Transformer MVA Capacity as at the Data Collection Freeze Date<sup>4</sup> (July 2015)

| Voltage Level | Capacity (MVA) | Number of transformers |
|---------------|----------------|------------------------|
| 400/220kV     | 3,050          | 6                      |
| 275/220kV     | 1,200          | 3                      |
| 275/110kV     | 3,840          | 16                     |
| 220/110kV     | 11,679         | 58                     |

<sup>2</sup> A number of radial 110kV circuits in Ireland and the 110kV lines and cables within Dublin City are operated by the Distribution System Operator (DSO). The DSO licence is held by ESB Networks. Details of the distribution network in Dublin are not included in this All-Island Transmission Forecast Statement.

<sup>3</sup> Some lines may contain short sections of cable.

<sup>4</sup> Transformer details are provided in Tables B-6, B-7, B-8, B-9 and B-10 in Appendix B.

Reactive compensation devices are used to improve transmission system voltages in local areas. Existing reactive devices connected to the transmission system include shunt capacitors, static var compensators (SVCs) and shunt reactors. Table 2-3 shows the total amounts of each type. Capacitors and SVCs help to support local voltages in areas where low voltages may otherwise occur. Shunt reactors suppress voltages in areas where they would otherwise be too high, most likely during periods of low demand and/or high wind.

Table 2-3 Total Reactive Compensation as at as at the Data Collection Freeze Date<sup>5</sup> (July 2015)

| Voltage Level | Type                                    | Capacity (Mvar) | Number of Devices |
|---------------|---|-----------------|-------------------|
| 400kV         | Line Shunt Reactor                      | 160             | 2                 |
|               | Voltage Source Converter Interconnector | +/- 175         | 1                 |
| 275kV         | Shunt Capacitor                         | 236             | 4                 |
| 220kV         | Shunt Reactor                           | 100             | 1                 |
| 110kV         | Static Var Compensator                  | 90              | 2                 |
|               | Shunt Capacitor                         | 921             | 42                |
| 33kV          | Shunt Capacitor                         | 29              | 5                 |
| 22kV          | Shunt Reactor                           | 210             | 7                 |
|               | Shunt Capacitor                         | 125             | 5                 |

## 2.2 Existing Connections between Ireland and Northern Ireland Transmission Systems

As illustrated in Figure 2-1, the transmission systems of Ireland and Northern Ireland are connected via a double circuit 275kV line. This line directly connected to the Northern Ireland transmission system at Tandragee runs to Louth in Ireland. There are three 275/220kV transformers in Louth station, one 600MVA unit and two ganged<sup>6</sup> 300MVA units.

In addition to the main 275/220kV double circuit, there are two 110kV connections. One is between Letterkenny in Co. Donegal and Strabane in Co. Tyrone, and the other between Corraclassy in Co. Cavan and Enniskillen in Co. Fermanagh.

<sup>5</sup> Details of existing reactive compensation devices are provided in Table B-12 in Appendix B

<sup>6</sup> Plant connected in parallel through common switchgear.

The purpose of these 110kV circuits is to provide support to either system for certain conditions or in the event of an unexpected circuit outage. Phase shifting transformers in Strabane and Enniskillen are used to control the power flow under normal conditions.

The design capacity of each of the 275/220kV cross-border circuits is 600MVA. However the actual capacity of the circuits to accommodate transfers between the two systems at any time depends on the prevailing system conditions on either side of the border. This includes the ability to deal with system separation.




Figure 2-1 Existing Cross-Border Circuits

### 2.3 Interconnection with Great Britain and Europe

Power is imported from Scotland and Wales across the Moyle Interconnector and the East-West Interconnector respectively. This has caused conventional generation in Northern Ireland and Ireland to be displaced by these non-synchronous power sources.

This reduces the all-island system inertia; which is also reduced by the increased wind penetration, which is another form of non-synchronous generation.

This has implications for the system frequency and transmission system stability and operation. Frequency changes are faster in transmission systems with low rotational inertia, making frequency control and system operation more challenging.

The Moyle Interconnector also increases the dynamic reactive support required by the transmission system; as the link does not have dynamic reactive power export capability.

The East West Interconnector however does have dynamic reactive power export capability. SONI acts as Interconnector Administrator (IA) for the East West and Moyle interconnectors.

Interconnector capacity is auctioned by the IA on behalf of EirGrid Interconnector Limited (EIL)<sup>7</sup> and Moyle Interconnector Limited (MIL)<sup>8</sup>. The capacity is purchased by market participants and utilised in the Single Electricity Market (SEM). Figure 2-2 shows the location of the Moyle interconnector and EirGrid East-West Interconnector.



Figure 2-2 Existing Interconnectors

<sup>7</sup> <http://www.eirgridgroup.com/customer-and-industry/interconnection/>

<sup>8</sup> <http://www.mutual-energy.com/mutual-energy-continues-to-contribute-to-lower-electricity-prices/>

The amount of power that can currently be traded between Northern Ireland and Scotland across the Moyle Interconnector is constrained (due to an ongoing outage/fault<sup>9</sup>) to 250MW<sup>10</sup> all year (see section 2.3.1 for details).

The amount of power that is permitted to be traded between Ireland and Wales across the East-West Interconnector is 500MW all year. This is measured at the SEM and BETTA (British Electricity Trading and Transmission Arrangements) market reference point in Deeside 400kV station in Wales. Table 2-4 below details the available capacity of the interconnectors.

Table 2-4 Available Capacity on Existing Interconnectors

| Interconnector     | Direction              | Summer | Winter |
|--------------------|------------------------|--------|--------|
| Moyle              | SCO – NI <sup>11</sup> | 250MW  | 250MW  |
|                    | NI – SCO <sup>12</sup> | 250MW  | 250MW  |
| EWIC <sup>13</sup> | WAL – IRL              | 500MW  | 500MW  |
|                    | IRL – WAL              | 500MW  | 500MW  |

### 2.5.1 Moyle Interconnector

The Northern Ireland transmission system is currently connected to Great Britain via a 500MW High Voltage Direct Current (HVDC) link, the Moyle interconnector. The Moyle Interconnector commenced commercial operation in 2002.

It is constructed as a dual monopole HVDC link with two coaxial sub-sea cables from Ballycronan More in Islandmagee, Northern Ireland to Auchencrosh in Ayrshire, Scotland. The link has a physical installed capacity of 500MW. An emergency flow of up to 75MW is available should the frequency on the island drop below 49.4Hz.

The convertor station at Ballycronan More is looped into one of the 275kV Ballylumford to Hannahstown circuits. The Moyle Interconnector is a Line

<sup>9</sup> <http://www.mutual-energy.com/moyle-link-to-be-restored-ahead-of-schedule/>

<sup>10</sup> As of the publication date of the 2015 TYTFS, the Moyle interconnector has returned to full capacity on an interim basis (<http://www.mutual-energy.com/project-update-8>). At the data freeze date and for the purposes of the 2015 TYTFS studies the Moyle Interconnector is assumed to be constrained to 250MW.

<sup>11</sup> The Moyle Interconnector import capacity increases to 450MW in winter 2016 due to repair works being completed.

<sup>12</sup> The Moyle Interconnector export capacity is expected to increase to 295MW in winter 2016 due to repair works being completed. However this export capacity is expected to be limited to 80MW from winter 2017 due to network limitations in Scotland.

<sup>13</sup> Power delivered to connection point at receiving power system.



Commutated Converter (LCC) HVDC link. The Moyle link is self-compensating for reactive power losses. There are 4 x 59Mvar capacitor banks at the Ballycronan More converter station with three of these capacitor banks acting as filters.

Where there are faults on the transmission system, effects are limited to a brief distortion of the HVDC 50Hz ac synchronous waveform in import mode. The rapid response means that the HVDC link can have a net stabilising effect on the transmission system in the event of generation loss.

At present a cable fault on Pole 1 of the Moyle Interconnector means that 250MW of the capacity is unavailable. Moyle Interconnector Limited (MIL)<sup>14</sup> believes the fault is due to movements of the seabed, causing cracks which allowed seawater to enter and create an electrical short circuit. MIL has indicated a prudent base case assumption would be to assume that Pole 1 will return to operation in winter 2016.

The export capacity of the Moyle Interconnector will however be limited to 295MW from winter 2016 onwards. This is due to the commissioning of a large wind farm in Scotland which will use up capacity on the single circuit from Auchencrosh to Coylton.

### 2.5.2 East-West Interconnector

The East-West Interconnector is a 500MW HVDC link which runs between Woodland, County Meath in Ireland and Deeside in North Wales. The link comprises approximately 186km of sub-sea cable and 70km of land underground cable.

The East-West Interconnector is built using Voltage Source Converter (VSC) technology. VSC technology offers independent and rapid control of active and reactive power. It does not suffer from commutation failures, and is capable of offering emergency power control in the event of low or high frequency events.

---

<sup>14</sup> [http://www.uregni.gov.uk/publications/letter\\_from\\_utility\\_regulator\\_to\\_moyle\\_interconnector\\_ltd\\_5\\_february\\_2015/](http://www.uregni.gov.uk/publications/letter_from_utility_regulator_to_moyle_interconnector_ltd_5_february_2015/)

In addition, due to the VSC technology, the East-West Interconnector provides black start capability. The link can operate in either voltage control or reactive power control mode independently in both converter stations. It can supply or absorb up to 175Mvar at Portan 400kV station which is connected directly to Woodland 400kV station. The East-West Interconnector commenced commercial operation in December 2012.

### 2.5.3 Future European Interconnection

Eirgrid are currently working with RTE, the French TSO, on a joint project investigating the business case for an interconnector between Ireland and France. The potential connection point is expected to be in the south of the country. The main drivers of this future potential project are market integration and generation integration.

## 2.4 Ireland Transmission System Developments

### 2.5.4 Grid Development Strategy

We published “Your Grid, Your Views, Your Tomorrow”, a discussion paper on Ireland’s Grid Development Strategy in March 2015<sup>15</sup>. Three main factors have influenced our strategy to develop the national transmission grid:

- Feedback received during the consultation process on major projects<sup>16</sup>
- Advances in technology
- Changes in the external economic environment

These factors are the basis for EirGrid’s three new strategy statements:

- Open engagement and inclusive consultation with local communities and stakeholders will be central to EirGrid’s approach to network development
- All practical technology options will be considered for network development
- The network will be optimised to minimise requirements for new infrastructure

A secure supply of electricity is the lifeblood of any economy. Our transmission system must remain stable and secure under a broad range of possible circumstances.

---

<sup>15</sup> <http://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid-Draft-Grid-Development-Strategy.pdf>

<sup>16</sup> <http://www.eirgridgroup.com/site-files/library/EirGrid/Reviewing-and-Improving-Our-Public-Consultation-Process.pdf>

Patterns of power-flow across the transmission grid can change over time. Such as when there is significant growth in demand, or following requests to connect new generators to the grid. Like other major infrastructure, electricity transmission assets have a finite lifespan and need to be upgraded and refurbished.

Reinforcing and upgrading the transmission system is required in order to maintain a safe, secure, reliable, economical and efficient electricity transmission system into the future. We carry out regular assessments of the country's energy needs, based on future economic and demand projections, as well as Government and EU policy.

#### 2.5.5 Reviewing and Improving our Public Consultation Process

In December 2014, EirGrid published a commitment paper – Reviewing and Improving our public consultation process<sup>17</sup>.

This paper is a response to feedback received on our public consultations and took into consideration the following four inputs:

- A review of public feedback;
- A review of international best practice in public consultation;
- An independent external expert review carried out by SLR Consulting Limited; and
- An independent external expert review carried out by the Chartered Institute of Arbitrators.

Three common themes emerged from the examination of our public consultation process:

- A need to develop a participative approach;
- Change our Culture and Processes; and
- Encourage Leadership & Advocacy.

In response to the stakeholder feedback, we proposed 12 commitments<sup>18</sup> intended to improve the way we engage with the public and stakeholders in the development of network projects.

---

<sup>17</sup> <http://www.eirgridgroup.com/site-files/library/EirGrid/Reviewing-and-Improving-Our-Public-Consultation-Process.pdf>

<sup>18</sup> The 12 commitments can be found in the commitment paper - Reviewing and Improving our public consultation process

In line with our ongoing policy of assessment and review, we will continue to take into account the most up-to-date information available when we are developing the transmission system.

Appendix B of this TYTFS outlines Transmission System developments which have received capital approval. These projects are currently scheduled to be completed by 2024. Table 2-5 shows the level of transmission system developments delivered by EirGrid (in conjunction with ESB Networks and independent contestable build contractors) over the past five years.

Table 2-5 Recent Historical Level of Transmission Developments

| Year | Circuit Uprate (km) | New Line Build (km) | New Station Build |
|------|---------------------|---------------------|-------------------|
| 2009 | 168                 | 104                 | 7                 |
| 2010 | 215                 | 37                  | 5                 |
| 2011 | 340                 | 76                  | 3                 |
| 2012 | 215                 | 128                 | 2                 |
| 2013 | 225                 | 38                  | 3                 |
| 2014 | 167                 | 79                  | 2                 |

#### 2.5.6 Transmission Development Plan in Ireland

EirGrid's Transmission Development Plan<sup>19</sup> (TDP), details the transmission system development projects that have been initiated by us. It also discusses further developments that may arise in the period of the plan.

The transmission system development plan includes projects that are required to facilitate demand growth, new generation and demand connections<sup>20</sup>. This is done in compliance with the Transmission Planning Criteria (TPC).

The planned transmission system developments presented in this statement are based on those projects that have received capital approval by the data freeze date. All information presented on transmission system transfer capabilities and opportunities is contingent on the completion of these development projects in the assumed timeframe.

<sup>19</sup> The latest TDP can be obtained from the EirGrid website <http://www.eirgridgroup.com/>

<sup>20</sup> For example data centres or large industrial sites

It should be noted that the information presented here is a snapshot of an evolving transmission system development plan. While we are considering other reinforcements, these are not at the stage of maturity required for inclusion in this statement. In addition, the connection of new generation or an increase in demand could drive further development requirements.

The Transmission Development Plan 2015-2025 includes details of major transmission system developments planned for the transmission system of Ireland. An overview of these major transmission system developments planned for the transmission system of Ireland on July 1<sup>st</sup> 2015, when data was frozen.

This was in order to facilitate the completion of the TYTFS and is detailed in the next pages of this section. Each planned development is illustrated on the maps in Appendix A. New generation connections and new transmission interface stations are described in Sections 3.7 and 3.8 respectively.

#### 2.5.7 Project Delivery

By its very nature, development of the transmission system is subject to risk. Project completion dates in the TYTFS are forecasts based on the best project information available at the time of the data freeze date. Certainty with regard to completion dates increases as a project moves through the various phases in its lifecycle, as represented below in Figure 2-3.

The project schedule at the concept stage is developed based on standard lead times for generic project types. As a project moves forward, a detailed schedule is developed, milestones are achieved and greater certainty as to the completion date exists.



Figure 2-3 Relationship between project lifecycle and completion date certainty

The level of certainty or risk in a project is also dependent on the project type as shown in Figure 2-4.



Figure 2-4 Project certainty dependent on project constituents

We have differentiated between moderate and high-risk projects based on project type and project status. Thus, line and station busbar upgrade projects which are due to be completed by 2018 are considered to be within the moderate risk category. Those large-scale linear developments scheduled to be completed post 2018 have a higher level of risk.

Projects due for completion in the near-term are inherently less risky than those due for completion in later years. It should be kept in mind that the completion dates are subject to change and that the level of change typically depends on the type of project and the stage the project is at in its lifecycle.

All developments included in this section have received capital approval.

#### Kilpaddoge 220kV Development<sup>21</sup>

Kilpaddoge 220kV station, in north Co. Kerry, will be connected into the existing Clashavoon-Tarbert and Killonan-Tarbert 220kV lines. All existing 110kV circuits currently connecting at the existing Tarbert 220kV station will be transferred to Kilpaddoge 220kV station. This will make Kilpaddoge a new hub for power flows into the south-west. The Kilpaddoge 220/110kV project is needed to replace Tarbert 220kV station as the main transmission station in north Co. Kerry. This is because the location was restricting further access and development of the transmission station. For the purpose of the 2015 TYTFS analysis, this project is expected to be completed in 2016.

<sup>21</sup> <http://www.eirgridgroup.com/the-grid/projects/north-kerry/the-project/>

### Finglas 220kV Redevelopment

The 220kV and 110kV busbars in the existing Finglas 220kV station will be reconfigured and redeveloped into a ring busbar arrangement. This project will address issues regarding the stations ability to: accommodate future load growth; security of supply to north Dublin; asset condition of existing equipment; inadequate circuit breaker ratings and the need for upgrade of the protection systems. The project will also increase operational flexibility, improve maintainability of station equipment and allow for future 220kV expansion. For the purpose of the 2015 TYTFS analysis, this project is expected to be completed in 2016.

### Belcamp 220kV Development<sup>22</sup>

Belcamp 220kV station, in north Co. Dublin, will be connected to the 220kV network by an underground cable from Finglas. A number of the existing 110kV circuits in the area will be connected to the new Belcamp station. This development will offload demand from Finglas 220kV station. It will also ensure compliance with the transmission and distribution system planning standards as new demand connects to the system in the North East Dublin area. For the purpose of the 2015 TYTFS analysis, this project is expected to be completed in 2018.

### Knockraha 220kV Reconfiguration

The 220kV busbar in Knockraha 220kV station will be reconfigured from the existing double busbar configuration to a ring busbar arrangement. The third Knockraha 220/110kV transformer will be decommissioned resulting in the station having two 220/110kV transformers. The project will resolve issues regarding security of supply, operational flexibility and improve maintainability of station equipment. For the purpose of the 2015 TYTFS analysis, this project is expected to be completed in 2017.

---

<sup>22</sup> <http://www.eirgridgroup.com/the-grid/projects/dublin-north-fringe/the-project/>

### Laois-Kilkenny Reinforcement Project<sup>23</sup>

A new 400/110kV station to be located near Portlaoise, Co. Laois, with an associated 110kV circuit to Kilkenny 110kV station via Ballyragget station. The 400/110kV station will be looped into the existing Moneypoint-Dunstown 400kV line and the existing Portlaoise-Athy 110kV line. The proposed infrastructure will improve quality of supply to south-east. It will also increase capacity in the region. For the purpose of the 2015 TYTFS analysis, this project is expected to be completed in 2017.

### Inchicore 220kV Redevelopment

The oldest section of the existing Inchicore 220kV station, in Co. Dublin will be replaced with a new GIS compound. This project will address issues with the condition of existing equipment, inadequate circuit breaker ratings, and the need for upgrade of the protection systems. The new GIS compound will increase operational flexibility, improve maintainability of station equipment and allow for future 220kV expansion. For the purpose of the 2015 TYTFS analysis, this project is expected to be completed in 2018.

### Aghada 220kV Development

The 220kV busbar in Aghada 220kV station will be reconfigured from the existing double busbar into a 'C' configuration. The 110kV busbar will also be updated. The project will increase security of supply, increase operational flexibility and improve maintainability of station equipment. For the purpose of the 2015 TYTFS analysis, this project is expected to be completed in 2018.

### Louth Development

Louth station comprises three voltage levels, 275kV, 220kV and 110kV. The station will undergo a major refurbishment of assets at all three voltage levels. The 110kV busbar will be reconfigured from the existing double busbar configuration to ring busbar arrangement.

---

<sup>23</sup> <http://www.eirgridgroup.com/the-grid/projects/laois-kilkenny/the-project/>



### Moneypoint-Kilpaddoge 220kV Circuit

There is a planned new submarine cable across the Shannon estuary from Moneypoint in Co. Clare to Kilpaddoge in north Co. Kerry. This will create a new path for power out of the Dublin-Moneypoint group of generators into the South West. It will also create a path for power out of the South West to the 400kV network. At the data freeze date and for the purpose of the 2015 TYTFS analysis, this project is expected to be completed by winter 2015.

### Ballyvouskill 220kV Development

Ballyvouskill 220kV station will be looped into the existing Clashavoon-Tarbert 220kV line. The station will be linked to the existing Garrow 110kV station by one new 110kV underground cable. The Ballyvouskill 220/110kV project is needed to accommodate renewable generation in the south-west. At the data freeze date and for the purpose of the 2015 TYTFS analysis, this project is expected to be completed by winter 2015.

### Knockanure 220kV Development<sup>24</sup>

Knockanure 220kV station will be looped into the existing Clashavoon-Tarbert 220kV line as well as the existing Trien-Tarbert 110kV circuit and the planned Trien-Athea 110kV circuit. The Knockanure 220/110kV project is needed to accommodate renewable generation in the south-west. At the data freeze date and for the purpose of the 2015 TYTFS analysis, this project is expected to be completed by winter 2015.

### Ballynahulla 220kV Development

Ballynahulla 220kV station will be looped into the existing Clashavoon-Tarbert 220kV line. The station will be linked to the existing Glenlara 110kV station by a new 110kV circuit. The Ballynahulla 220/110kV project is needed to accommodate renewable generation in the south-west. At the data freeze date and for the purpose of the 2015 TYTFS analysis, this project is expected to be completed by winter 2015. This station was formerly known as Kishkeam but has been renamed.

---

<sup>24</sup> <http://www.eirgridgroup.com/the-grid/projects/millstreet/the-project/>

### Clogher 110kV Development

Clogher 110kV GIS station will be looped into the existing Cathaleen's Fall – Drumkeen and Cathaleen's Fall – Golagh T – Letterkenny 110kV lines. Mulreavy and further gate 3 wind farms will connect at 110kV into the new Clogher 110kV station. This 110kV transmission station is being built contestably. For the purpose of the 2015 TYTFS analysis, this project is expected to be completed in 2016.

### Poolbeg 220kV Development

Two 50Mvar shunt reactors will be installed in Poolbeg 220kV station, in Co. Dublin. There has been an increase in the number of cable circuits and a reduction in the usage of the conventional generation in Dublin. This has made it more difficult to control voltage during low-demand periods. These reactors will help to adequately control the voltages by alleviating the operational constraint of running generators outside of merit order. For the purpose of the 2015 TYTFS analysis, the reactors are expected to be completed in the latter half of 2016.

### Moneypoint Redevelopment

A new 400kV substation will replace the existing Moneypoint 400kV substation, which will be retired. The existing Moneypoint-Oldstreet and Moneypoint-Dunstown 400kV circuits and Moneypoint 400/220kV transformer will be transferred to the new Moneypoint 400kV busbar. The station will also accommodate a second 400/220kV transformer.

The project also involves the relocation of the existing capacitor bank from the A1/B1 110kV busbar section to the A2/B2 110kV busbar section. The project will address 110kV busbar capacity issues and short circuit problems, increase operational flexibility and improve maintainability of station equipment. For the purpose of the 2015 TYTFS analysis, this project is expected to be completed in 2019.

### Moneypoint – Kilpaddoge - Knockanure 220kV Development

There is a planned new 220kV cable from Moneypoint in Co. Clare to Knockanure in north Co. Kerry, via Kilpaddoge also in north Co. Kerry. This will create a new path for power out of the South West to the existing 400kV network. The project will comprise a submarine 220kV cable under the Shannon and a 21 km 220kV land cable. It is expected to be completed in 2019.

### Grid West Project<sup>25</sup>

We conducted a comprehensive analysis on both underground and overhead solutions for the Grid West Project. We submitted a report on this analysis to the Government appointed Independent Expert Panel<sup>26</sup>.

The report, based on this detailed analysis, considers three options:

- A HVDC underground cable and associated convertor stations;
- A 400kV overhead line; and
- A 220kV overhead line which may incorporate sections of underground AC cable.

The report was published in July 2015.

Grid West will create a new path for power out of the North Mayo region to the meshed 220kV transmission system at the existing Flagford 220kV station.

The preferred location of the substation sites in the North Mayo and Flagford areas and will undergo further investigation before any final decision is made. The substation locations shown in the geographical maps are only indicative.

For the purpose of the 2015 TYTFS analysis, all three options have been studied and are assumed to be completed in 2019.

### Regional Solution (formerly Grid Link) Project<sup>27</sup>

We conducted a comprehensive analysis on both underground and overhead solutions for the Grid Link Project. In addition to this, we analysed a new and innovative technical solution, referred to as the ‘Regional Option’, based on technology which is capable of improving the existing grid infrastructure. This meets the needs of the project without building new large scale overhead infrastructure. In September 2015 we submitted a report on this analysis to the Government appointed Independent Expert Panel.

In October 2015 we announced the Regional Option as our preferred solution. We are now moving forward with this option.

The Regional Solution uses a technology called ‘series compensation’. This would be the first time it will be deployed on the Irish transmission grid. It technology that will enable more power to flow through existing lines.

---

<sup>25</sup> <http://www.eirgridgroup.com/the-grid/projects/millstreet/the-project/>

<sup>26</sup> <http://www.eirgridgroup.com/site-files/library/EirGrid/Summary-of-IEP-Report-Grid-West.pdf>

<sup>27</sup> <http://www.eirgridgroup.com/the-grid/projects/grid-link/the-project/>

Therefore, previously proposed new 400kV overhead lines are not required. To complete this solution, an underwater cable across the Shannon estuary is required in addition to some upgrade works to existing transmission lines.

The Regional Solution will facilitate the integration of renewable and conventional generation in the south of Ireland. It will also facilitate potential future interconnection with Great Britain or France and ensure security of supply is maintained for the south east and south midlands in Ireland.

For the purpose of the 2015 TYTFS analysis, it is assumed to be completed in 2020.

### North Connaught 110kV Reinforcement

This project is under review. Confirmation of the need is required. Should it progress, an investigation of overhead and underground options utilising various technologies will be undertaken in line with our strategy statements.

For the purpose of the 2015 TYTFS analysis, both an 110kV overhead line and underground option has been presented<sup>28</sup>. It is assumed that both options will connect the existing Castlebar 110kV station to the existing Moy 110kV station. It is assumed to be completed in 2020.

### Finnstown 220kV Development

This project has been cancelled. However, a new West Dublin 220kV station has been initiated to reinforce the transmission and distribution systems. This is in order to facilitate the connection of a significant volume of new load in the area, see details below.

### West Dublin 220kV Development

West Dublin 220kV station, in west Co. Dublin, will be connected into the existing Inchicore-Maynooth No. 1 and No. 2 220kV lines. A number of the existing 110kV circuits in the area will be connected to the new West Dublin station. This development will offload demand from Inchicore 220kV station. It will also ensure compliance with the distribution system planning standards as new demand connects to the system in the West Dublin area.

---

<sup>28</sup> This project is under review and therefore generic models have been provided in Appendix B for information. As the project certainty increases and detailed studies of solutions become available, data in future TYTF's will be updated accordingly.

### North-West Project

The cross-border Renewable Integration Development Project (RIDP) identified that the existing network in the north west of the island is insufficient to accommodate the future wind generation in the area. The original preferred solution option involved progressing the North-West project as the first element of RIDP. The timing of the progression of the elements is now under review.

Should the North-West progress, an investigation of overhead and underground options utilising various technologies will be undertaken in line with our strategy statements. For the purpose of the 2015 TYTFS analysis both an 220kV overhead line and underground options have been presented<sup>29</sup>. Both options will connect the existing Srananagh 220kV station to the planned Clogher 110kV station in Donegal. It is assumed to be completed in 2022.

### 2.5 Northern Ireland Transmission System Developments

This section details the transmission system projects that are planned to take place in Northern Ireland over the period covered by this forecast statement. Unapproved projects have been included using provisional completion dates provided by NIE at the time of the data freeze (1st July 2015). In considering this plan it should be noted that:

- The majority of projects have still to go through EirGrid/SONI governance process to secure both internal and regulatory approval.
- The plan is based on assumptions relating to the forecast growth of demand and generation.
- With regard to the majority of the projects, there has been only a limited level of optioneering. As part of the more detailed planning process, closer consideration of a wider range of potential solutions may result in a development that differs from that detailed in this plan.
- Whilst studies have concluded that, subject to the forecast growth in demand and generation, the projects are required to address non-compliance with standards, no cost benefit analysis at this stage been carried out.

---

<sup>29</sup> As this project is at an early stage, generic models have been provided in Appendix B for information. As the project certainty increases and detailed studies of solutions become available, data in future TYTF's will be updated accordingly.

- This will also form part of the more detailed planning process and may result in alternative solutions, or perhaps operational interventions, that could avoid the need for development.

### Coleraine-Kells 110kV Circuit

The uprating of the section of the Coleraine-Kells circuit between Kells and the connection point to the proposed Rasharkin cluster substation is presently ongoing. The wood pole section of the circuit has been restrung with high temperature conductor. The tower line section (one side of the double-circuit between Terrygowan and Kells) is being replaced with gap conductor. For the purpose of the 2015 TYTFS analysis it is expected that this work will be completed by winter 2016

### Knock Main

It is planned to replace the two 60MVA transformers at Knock Main with two 90MVA units. For the purpose of the 2015 TYTFS this work is expected to be completed by winter 2016.

### Tamnamore/Dungannon/Omagh Developments

#### (i) Tamnamore Main 275kV Substation - Phase 2

The Tamnamore Phase 2 project is a further development of the Tamnamore 275/110kV substation. It is proposed to extend the existing 275kV and 110kV double busbars at Tamnamore and to connect a second 275kV transformer. It is also proposed to connect in the Dungannon-Drumnakelly and Dungannon-Creagh 110kV circuits. Dungannon Main will be supplied by two radial circuits from Tamnamore Main (one of these circuits is already constructed). It is proposed to divert the remaining 275kV Magherafelt-Tandragee circuit into the substation. This work is ongoing; for the purpose of the 2015 TYTFS analysis, this work is expected to be completed by winter 2016.

#### (ii) Dungannon-Omagh 110kV Circuits

Both of the Omagh-Dungannon 110kV circuits will be diverted into Tamnamore Main. The current Omagh-Dungannon '2' circuit, which is planned to be connected into the Tremoge cluster, will connect directly into Tamnamore. The Omagh-Dungannon '1' circuit will use a mesh corner at Dungannon Main to connect through to Tamnamore. This design will provide resilience to Dungannon Main against N-2 contingencies. For the purpose of the 2015 TYTFS analysis, this work is expected to be completed by winter 2016.

(iii) **Dungannon-Tamnamore Restrung**

The section of 110kV tower line from Dungannon Main to Tamnamore is planned to be restrung with high temperature conductor. As part of the Tamnamore Phase 2 project the Dungannon – Tremoge circuit will bypass Dungannon Main and be connected directly to Tamnamore. For the purpose of the 2015 TYTFS analysis, this work is expected to be complete by winter 2016.

(iv) **Omagh-Tamnamore New 110kV Circuit**

It is proposed to construct a new circuit from Omagh-Tamnamore 110kV. This circuit will be approximately 57km in length on Portal construction with Zebra conductor (with a DOT of 750C). The circuit will also be used to connect the proposed Gort cluster substation. For the purpose of the 2015 TYTFS, the work is expected to be completed by winter 2016.

(v) **Dungannon Main refurbishment**

The 110kV mesh at Dungannon Main is currently undergoing refurbishment. All switchgear is being replaced with 40kA equipment. For the purpose of the 2015 TYTFS this work is expected to be completed by winter 2017.

**Windfarm Clusters Development**

(i) **Tremoge 110kV Cluster**

It is proposed to establish a 110/33kV windfarm cluster substation at a site adjacent to the existing 110kV Omagh – Dungannon circuit '2'. This circuit will supply the new cluster substation. For the purpose of the 2015 TYTFS, Tremoge cluster is expected to be complete by winter 2016.

(ii) **Rasharkin 110kV Cluster (formally Mid-Antrim)**

It is proposed to establish a 110/33kV substation at a site adjacent to the existing Coleraine-Kells 110kV circuit. This circuit will supply the new cluster substation. For the purpose of the 2015 TYTFS, this cluster substation is expected to be complete by winter 2016.

(iii) **Gort 110kV Cluster**

It is proposed to establish a 110/33kV substation at a site adjacent to the proposed new 110kV Omagh-Tamnamore circuit. This circuit will supply the new cluster substation. For the purpose of the 2015 TYTFS, the Gort cluster substation is expected to be complete by winter 2016.

(iv) **Curraghmulkin 110/33kV Cluster (formerly Drumquin)**

It is planned to establish a new 110/33kV cluster substation close to Drumquin village. The Curraghmulkin cluster is to be connected to the existing Enniskillen - Omagh 110kV circuits by means of a new switching station (Omagh South) north of Dromore village. A single portal overhead line will be built from the new station to the cluster site. For the purpose of the 2015 TYTFS, this project is planned to be complete by summer 2019.

(v) **Garvagh 110kV Cluster**

It is planned to establish a 110/33kV cluster substation near Garvagh, connected to the proposed Rasharkin cluster via a portal overhead line. For the purpose of the 2015 TYTFS, this work is planned to be complete by 2020.

(vi) **Newtownstewart 110kV Cluster**

It is planned to establish a 110/33kV cluster substation near Newtownstewart, connected to the 110kV circuits between Omagh and Strabane. For the purpose of the 2015 TYTFS, this work is planned to be complete by 2020.

(vii) **Cam 110kV Cluster**

It is planned to establish a 110/33kV cluster substation near to Cam, Coleraine, connected to the existing Coleraine station via an overhead line. For the purpose of the 2015 TYTFS, this work is planned to be complete by 2020.

(viii) **Kells Wind 110kV Cluster**

It is planned to establish a 110/33kV cluster substation near to Kells, connected to the existing Kells station via an overhead line. For the purpose of the 2015 TYTFS, this work is planned to be complete by 2020.

**Belfast North Main**

A new 110/33kV substation at Whitla Street is to be established. This will allow for the decommissioning of the 110/33kV substation at Belfast Power Station West (PSW). The existing Whitla Street 33/6.6kV substation site is to be redeveloped allowing room for a new 33kV switchboard and pair of 90MVA transformers. This work is ongoing; for the purpose of the 2015 TYTFS, this project is expected to be complete by winter 2016.



### Donegal Main (North)

The 60MVA transformer TxB at Donegal North is to be replaced by a new 90MVA unit. For the purpose of the 2015 TYTFS this work is expected to be complete by winter 2016.

### Castlereagh-Rosebank 110kV Circuits

It is planned to replace the two existing 110kV cable circuits between Castlereagh and Rosebank substations, increasing the rating of each circuit to a minimum of 144MVA. For the purpose of the 2015 TYTFS, this work is expected to be complete by winter 2016.

### Castlereagh 275kV IBTX 1

The interbus transformer IBTX 1 at Castlereagh is to be replaced. The replacement transformer will have a 240MVA primary winding and a 60MVA tertiary winding. For the purpose of the 2015 TYTFS analysis, the asset replacement is expected to be installed and commissioned by 2017.

### Omagh Main – Omagh South restrung

With the connection of Curraghmulkin cluster substation to Omagh South it will be necessary to restrung the Omagh Main – Omagh South tower line with high temperature conductor. This work is planned to be completed by winter 2018.

### Compressed Air Energy Storage Scheme (CAES)

A developer has planned the construction of a Compressed Air Energy Storage facility close to Larne. For the purposes of including the scheme in the TYTFS, the connection of the plant is modelled on the assumption that it will be supplied by installing a pair of 275/110kV transformers close to the existing Ballylumford 275kV switch house, and laying duplicate 110kV 200MVA cables to the CAES plant. For the purpose of the 2015 TYTFS, the connection is planned to be installed and commissioned by winter 2018.

### Reactive Compensation

#### (i) Omagh-South Reactive Compensation

It is planned to install reactive support at either the proposed Omagh South switching station or adjacent to Omagh Main. For the purpose of the 2015 TYTFS, a static var compensator (SVC) or Statcom is planned at the proposed Omagh South switching station connected to the 110kV bus from 2019.

(ii) Tamnamore Reactive Compensation

It is planned to install reactive support at Tamnamore. For the purpose of the 2015 TYTFS, it is planned that the reactive compensation scheme will be a static var compensator (SVC) or statcom. This scheme is planned to be connected to the 110kV bus and is to be complete by 2020.

(iii) Coleraine Reactive Compensation

It is planned to install reactive support at Coleraine. For the purpose of the 2015 TYTFS, it is proposed that the reactive compensation scheme will be a static var compensator (SVC) or statcom. This scheme is planned to be connected to the 110kV bus and is to be completed by 2020. The existing 36Mvar Capacitor at Coleraine is to be recovered.

Airport Road Main

It is planned to construct a new 110/33kV substation including 2 x 60MVA transformers and a 33kV switchboard at Airport Road. The substation will be connected as a teed transformer feeder arrangement from Rosebank Main 110kV. The substation will supply both Airport Road and Queens Road 33kV substations which are to be transferred from Cregagh Main. Additionally, Ballymacarrett 33kV substation is also to be transferred from Knock Main. For the purpose of the 2015 TYTFS, this work is planned to be completed by winter 2019.

Ballylumford Switchgear

The existing 110kV switchgear at Ballylumford is to be replaced with a new 110kV GIS double busbar and the 110kV circuits diverted accordingly. For the purpose of the 2015 TYTFS, this project is planned to be completed by winter 2019. Currently one 275/110kV interbus transformer at Ballylumford is operated out of service to ensure the fault level is kept within existing switchgear fault rating. After this work is complete, this restriction can be removed.

Brockaghboy 110kV Windfarm

It is planned that the Brockaghboy windfarm will be connected to the proposed Garvagh cluster via an overhead line. For the purpose of the 2015 TYTFS, this work is planned to be complete by 2020.

### Coolkeeragh-Limavady-Coleraine 110kV Circuits

As a result of increasing growth in renewable generation it is anticipated that there will be a need to uprate the Coolkeeragh-Limavady, Coleraine-Limavady and Coleraine-Coolkeeragh 110kV circuits to a minimum of 185MVA. For the purpose of the 2015 TYTFS, this work is planned to be complete by winter 2020.

### Coolkeeragh-Magherafelt 275kV Circuits

It is planned to replace the conductor on the existing double circuit tower line. The rating of the replacement conductor will be defined as part of the redesign of the circuit. This work is expected to be complete by winter 2020.

### Tidal Scheme

Developers are planning to establish two 100MW tidal generation schemes off the County Antrim coast close to Torr Head and Fair Head. For the purposes of including the schemes in the TYTFS (connection method is subject to change), the connection is modelled as a new 110kV circuit from Kells to a collector station close to the coastline. For the purpose of the 2015 TYTFS, this project is planned to be complete by winter 2020.

### Coolkeeragh-Killymallaght-Strabane 110kV Circuits

It is planned to uprate the Coolkeeragh-Killymallaght, Killymallaght-Strabane and Coolkeeragh-Strabane 110kV circuits. When works are complete, the circuits will be uprated to a minimum of 185MVA. For the purpose of the 2015 TYTFS, this work is planned to be complete by winter 2020.

### Turleenan-Tamnamore 275kV

With the connection of Turleenan substation it will be necessary to restring the Turleenan-Tamnamore tower line with high temperature conductor. For the purposes of the 2015 TYTFS, this work is planned to be complete by winter 2020.

### Kells-Rasharkin New 110kV Circuit

It is planned to construct a second 110kV circuit between Kells and Rasharkin 110/33kV cluster substation. This circuit will have a minimum rating of 88MVA. For the purpose of the 2015 TYTFS, this project is planned to be complete by 2022.

### Armagh Main

Due to capacity limitations on the distribution system that supplies Armagh identified by the DSO, it is proposed to establish a new 110/33kV substation to the south of Armagh city. For the purposes of the 2015 TYTFS, this project is planned to be completed by 2022.

The following projects have not been included in the 2015 TYTFS analysis. The projects are however under consideration and are included for information

#### (i) Omagh South-Turleenan 275kV Circuit

It is planned to extend the proposed Omagh South switching station site (see Curraghmulkin cluster) to accommodate a 275/110kV substation. A 275kV single circuit is planned from Omagh South to Turleenan. However this 2015 forecast statement does not make provision for this development.

#### (ii) Castlereagh 275kV IBTX 4

Taking account of future growth in demand, consideration is also presently being given to the need for a 4th transformer at Castlereagh. However this 2015 forecast statement does not make provision for this development.

#### (iii) Coolkeeragh-Trillick 110kV Circuit

It is planned to develop a new circuit from Trillick in Co Donegal, Ireland to Coolkeeragh in Northern Ireland. This new circuit is anticipated to be the optimal reinforcement to provide for the connection of renewable generation in Co. Donegal. The proposal will be considered alongside the overall programme of developments in Northern Ireland to cater for increased renewable generation.

#### (iv) Ballylumford-Eden 110kV Circuit

It is planned to restring the above circuit in conjunction with asset replacement works that are under consideration by the TAO. Consideration is also being given to the restring of the circuits from Eden-Carnmoney and Carnmoney-Castlereagh. In this statement, the existing ratings are applied to these circuits.

## 2.6 Joint Ireland and Northern Ireland Approved Transmission System Developments

This section includes transmission system developments which both Eirgrid and SONI have identified the need for. We are proposing a new 400kV circuit rated at 1500MVA which will connect Woodland 400kV station in County Meath (Irl) and Turleenan 400/275kV station in County Tyrone (NI). A new 400kV station at Turleenan is required.

In the event of a loss of the existing 275kV double circuit connecting the transmission system of Ireland and the Northern Ireland transmission system, the post-fault transfers would be directed across the Letterkenny-Strabane and Corraclassy-Enniskillen 110kV cross-border circuits.

In this instance, to guard against damage to these lines, protection equipment will switch out the 110kV circuits, resulting in separation of the two systems.

This may result in a generation surplus on one system and a deficit on the other. The system with a supply deficit may be required to disconnect demand customers.

The system with the supply surplus may have difficulty stabilising the system frequency. The risk of impact of potential system separation on each system has resulted in constraints on the amount of power that can be transferred between the two systems.

For the purpose of the 2015 TYTFS analysis, this project is planned to be installed and commissioned by winter 2019. Once this connection is established, the constraints on the existing Tandragee-Louth 275kV double circuit will be significantly reduced.

## 2.7 Connection of New Generation Stations

Chapter 4 describes the future generators that are included in this TYTFS.

Table 2-6 Planned Connection Methods of Future Generators

| Generator                       | MEC  | Planned Connection Method   |
|---------------------------------|------|---|
| Altamuskin                      | 14.1 | Connected to a new Gort 110/33kV cluster substation, itself looped into the future Omagh-Tamnamore 110kV circuit  |
| Altaveedan                      | 18   | Connected into the future Rasharkin 110/33kV substation looped into the Coleraine-Kells 110kV circuit   |
| Athea Wind Farm (Extension)     | 99   | Connected into the planned Athea 110kV substation   |
| Aught                           | 45   | Connected into Springtown 110/33kV substation at 33kV   |
| Ballykeel                       | 10   | Connected into the future Kells 110/33kV cluster substation, itself tail-connected into Kells 275/110kV switching station at 110kV                      |
| Ballyreagh Tempo                | 2.5  | Connected into Enniskillen 110/33kV substation at 33kV  |
| Barnadivane                     | 60   | New Barnadivane 110kV Station, looped into the Dunmanway-Macroom 110kV circuit  |
| Beltonanean                     | 2.3  | Connected to a new Tremoge 110/33kV substation, itself looped into the existing Omagh-Dungannon 'B' circuit   |
| Bessy Bell 3                    | 23   | Assumed connected into the future Newtownstewart 110/33kV cluster substation, itself looped into the existing Omagh-Strabane 110kV circuits 'A' and 'B' |
| Bessy Bell 4                    | 9.2  | Assumed connected into the future Newtownstewart 110/33kV cluster substation, itself looped into the existing Omagh-Strabane 110kV circuits 'A' and 'B' |
| Bindoo Wind Farm (Extension)    | 22   | Connected into the existing Ratrussan 110kV substation  |
| Boggeragh 2                     | 47.7 | Connected into the existing Boggeragh 110kV substation  |
| Booltiagh Wind Farm (Extension) | 103  | Connected into the existing Booltiagh 110kV substation  |
| Brackagh Quarry                 | 6    | Connected into Ballymena 110/33kV substation at 33kV  |
| Brockaghboy                     | 56.5 | Connected at 110kV into a new Garvagh 110/33kV cluster substation, itself connected into the future Rasharkin 110/33kV substation                       |
| Bunkimalta                      | 46.5 | Connected into the planned Cureeny 110kV substation   |
| CAES                            | 268  | Connected into existing Ballylumford 275kV substation.  |
| Carnalbanagh                    | 28.5 | Connected into the future Kells 110/33kV cluster substation, itself tail-connected into Kells 275/110kV switching station at 110kV                      |

Table 2-6 Planned Connection Methods of Future Generators (continued)

| Generator                     | MEC   | Planned Connection Method   |
|-------------------------------|-------|---|
| Castlecraig                   | 25    | Connected into the future Curraghamulkin 110/33kV cluster substation, itself tail-connected into Omagh South 110kV substation                           |
| Castlegore                    | 10    | Connected into the future Kells 110/33kV cluster substation, itself tail-connected into Kells 275/110kV switching station at 110kV                      |
| Clahane Wind Farm (Extension) | 13.8  | Connected into the existing Clahane 110kV substation  |
| Cloghinarney                  | 13.8  | Connected into the future Kells 110/33kV cluster substation, itself tail-connected into Kells 275/110kV switching station at 110kV                      |
| Clunahill                     | 15    | Connected into the future Curraghamulkin 110/33kV cluster substation, itself tail-connected into Omagh South 110kV substation                           |
| Connaught Road                | 1.7   | Connected into Antrim 110/33kV substation at 33kV   |
| Coomataggart                  | 172.4 | Connected into the planned Ballyvouskill 220kV substation   |
| Cordal                        | 176.6 | Construction of the new Cordal 110kV station tailed out of Ballynahulla.  |
| Corkey Extension              | 5     | Connected into Ballymena 110/33kV substation at 33kV  |
| Cornavarrow                   | 36    | Connected into the future Curraghamulkin 110/33kV cluster substation, itself tail-connected into Omagh South 110kV substation                           |
| Craiggorr                     | 34    | Connected into the future Garvagh 110/33kV cluster substation, itself tail-connected into Rasharkin 110/33kV cluster substation                         |
| Craignagapple                 | 20.7  | Assumed connected into the future Newtownstewart 110/33kV cluster substation, itself looped into the existing Omagh-Strabane 110kV circuits 'A' and 'B' |
| Cregganconroe                 | 13.8  | Connected to a new Tremoge 110/33kV substation, itself looped into the existing Omagh-Dungannon 'B' circuit   |
| Crockandun                    | 18    | Connected to a new Tremoge 110/33kV substation, itself looped into the existing Omagh-Dungannon 'B' circuit   |
| Crockbaravally                | 7.5   | Connected to a new Gort 110/33kV cluster substation, itself looped into the future Omagh-Tamnamore 110kV circuit  |
| Crockdun                      | 15    | Connected to a new Tremoge 110/33kV substation, itself looped into the existing Omagh-Dungannon 'B' circuit   |
| Croghan                       | 12.5  | Connected into the future Cam 110/33kV cluster substation, itself looped into the existing Coolkeeragh-Coleraine 110kV circuit                          |
| Cronacarkafree                | 105   | Connected into the proposed Clogher 110kV substation  |

Table 2-6 Planned Connection Methods of Future Generators (continued)

| Generator                     | MEC  | Planned Connection Method   |
|-------------------------------|------|---|
| Cuilleen                      | 98.4 | Connected to a new Cuilleen 110kV substation, itself tail-connected into Athlone 110kV substation   |
| Cureeny                       | 94   | Connected into the existing Nenagh-Killonan 100kV circuit   |
| Drumadarragh                  | 3.6  | Connected into the future Kells 110/33kV cluster substation, itself tail-connected into Kells 275/110kV switching station at 110kV                      |
| Dunmore 2                     | 24   | Connected into the future Cam 110/33kV cluster substation, itself looped into the existing Coolkeeragh – Coleraine 110kV circuit                        |
| Eglish                        | 18   | Connected into Killymallaght 110/33kV substation at 33kV  |
| Elginny Hill                  | 23   | Connected into Ballymena 110/33kV substation at 33kV  |
| Eshmore                       | 6.9  | Connected to a new Tremoge 110/33kV cluster substation, itself looped into the future Omagh-Tamnamore 110kV circuit                                     |
| Glanlee Wind Farm (Extension) | 6    | Connected into the existing Glanlee 110kV substation  |
| Glenbuck 1                    | 9.2  | Connected into the future Rasharkin 110/33kV substation looped into the Coleraine-Kells 110kV circuit   |
| Gortfinbar                    | 15   | Connected to a new Tremoge 110/33kV substation, itself looped into the existing Omagh-Dungannon 'B' circuit   |
| Innishative                   | 13.8 | Connected to a new Tremoge 110/33kV substation, itself looped into the existing Omagh-Dungannon 'B' circuit   |
| Killyglen                     | 10   | Connected into the future Kells 110/33kV cluster substation, itself tail-connected into Kells 275/110kV switching station at 110kV                      |
| Knockacummer                  | 87   | Permanent connection of the new Knockacummer 110kV substation, tailed out of Glenlara.  |
| Knockavanna                   | 27   | Construction of a new Knockavanna 110kV station, looped into Agannygal-Derrybrien 110kV circuit   |
| Knockranny                    | 54   | Connected into the existing Salthill-Screen 100kV circuit   |
| Koram Hill                    | 13.8 | Assumed connected into the future Newtownstewart 110/33kV cluster substation, itself looped into the existing Omagh-Strabane 110kV circuits 'A' and 'B' |
| Lisnahrney                    | 42   | Assumed connected into the future Newtownstewart 110/33kV cluster substation, itself looped into the existing Omagh-Strabane 110kV circuits 'A' and 'B' |
| Long Mountain                 | 27.6 | Connected into the future Rasharkin 110/33kV substation looped into the Coleraine-Kells 110kV circuit   |



Table 2-6 Planned Connection Methods of Future Generators (continued)

| Generator        | MEC   | Planned Connection Method   |
|------------------|-------|---|
| Mayo             | 49    | Mayo Renewable Power Biomass (Shallow Connection)   |
| Moneypoint       | 21.9  | Connected into existing Moneypoint substation at 110kV  |
| Mount Lucas      | 79.2  | Construction of Mount Lucas 110kV substation, looping into the Cushaling-Thornsberry 110kV circuit  |
| Mullynaveagh     | 2.6   | Connected into Drumnakelly 110/33kV substation at 33kV  |
| Mulreavy         | 128.4 | New Mulreavy 110kV substation tail-connected into the planned Clogher 110kV substation  |
| Nore Power       | 98    | Construction of Nore 110kV substation, tailed out of Kilkenny 110kV station   |
| Ora More         | 15    | Connected into Enniskillen 110/33kV substation at 33kV  |
| Oriel            | 210   | Connected into the existing Louth-Woodland 220kV circuit  |
| Oweninney        | 370.9 | Connected to a new Bellacorick 400kV substation, itself tail-connected into the new Flagford 400kV substation   |
| Rathsherry       | 21.5  | Connected into Ballymena 110/33kV substation at 33kV  |
| Reamore          | 98.5  | Connected into the existing Tralee 110kV substation   |
| Rhode Biomass    | 14.6  | Rhode Biomass (Shallow Connection)  |
| Shantavny Scotch | 16.1  | Connected to a new Gort 110/33kV cluster substation, itself looped into the future Omagh-Tamnamore 110kV circuit  |
| Slieveard        | 17.5  | Assumed connected into the future Newtownstewart 110/33kV cluster substation, itself looped into the existing Omagh-Strabane 110kV circuits 'A' and 'B' |
| Slieve Divena 2  | 20    | Connected to a new Gort 110/33kV cluster substation, itself looped into the future Omagh-Tamnamore 110kV circuit  |
| Slieveglass      | 6.9   | Connected into the future Curraghmulkin 110/33kV cluster substation, itself tail-connected into Omagh South 110kV substation                            |
| Sliabh Bawn      | 58    | New Sliabh Bawn 110kV station tailed out of Lanesboro 110kV station   |
| Smulgedon        | 16.1  | Connected into a Limavady Main 110/33kV substation at 110kV   |
| Suir             | 98    | Construction of Suir 110kV substation, tailed out of Cahir 110kV station  |
| Teiges           | 12.5  | Connected to a new Gort 110/33kV cluster substation, itself looped into the future Omagh-Tamnamore 110kV circuit  |
| Thornog          | 20    | Connected into the Magherakeel 110/33kV cluster substation, itself tail-connected into Omagh 110kV substation   |

Table 2-6 Planned Connection Methods of Future Generators (continued)

| Generator        | MEC  | Planned Connection Method  |
|------------------|------|--|
| Tidal            | 210  | Assumed connected into Kells 275/110kV substation at 110kV.  |
| Tievenameenta    | 34.5 | Connected into the Magherakeel 110/33kV cluster substation, itself tail-connected into Omagh 110kV substation                      |
| Tullynageer      | 11.5 | Connected into Newry 110/33kV substation at 33kV   |
| Whappstown       | 9.2  | Connected into the future Kells 110/33kV cluster substation, itself tail-connected into Kells 275/110kV switching station at 110kV |
| Windy Hill       | 52   | Connected into the future Cam 110/33kV cluster substation, itself looped into the existing Coolkeeragh-Coleraine 110kV circuit     |
| Uggool and Secon | 169  | Connected into the planned Uggool 110kV substation, itself tail-connected into the planned Knockranny 110kV substation             |

## 2.8 Connection of New Interface Stations

Transmission interface stations are the points of connection between the transmission system and the distribution system, or connecting 110kV connected customers.

Table 2-7 lists the planned new 110kV stations connecting the distribution system or connecting 110kV customers to the transmission system, for the period covered by this statement. These stations are included in the appropriate network models according to their expected connection date. Details of the connections and dates are given in Section B.2 in Appendix B.

Table 2-7 Planned 110kV Stations

| Station            | Code | Transformer Size (MVA) | Nearest Main Town or Load Centre | County   |
|--------------------|------|------------------------|----------------------------------|----------|
| Adamstown          | ADM  | 2 x 20                 | Lucan                            | Dublin   |
| Airport Road       | AIR  | 2 x 90                 | Belfast                          | Down     |
| Ardnagappary       | AGY  | 31.5                   | Derrybeg                         | Donegal  |
| Armagh             | ARM  | 2 x 90                 | Armagh                           | Armagh   |
| Ballyragget        | BGT  | 31.5                   | Ballyragget                      | Kilkenny |
| Barnakyle          | BKY  | 2 x 38                 | Inchicore                        | Dublin   |
| Belfast North Main | BNM  | 2 x 90                 | Belfast                          | Antrim   |
| Bracklone          | BRA  | 2 x 20                 | Portarlinton                     | Laois    |

Table 2-7 Planned 110kV Stations (continued)

| Station          | Code | Transformer Size (MVA) | Nearest Main Town or Load Centre | County |
|------------------|------|------------------------|----------------------------------|--------|
| Cherrywood       | CHE  | 2 x 20, 2 x 63         | Loughlinstown                    | Dublin |
| Corkagh          | CKG  | 2 x 38                 | Grange Castle                    | Dublin |
| Castletownmoor   | CTO  | 2 x 120                | Kells                            | Meath  |
| Hartnett's Cross | HTS  | 20                     | Macroom                          | Cork   |
| Newbury          | NBY  | 2 x 28                 | Clonshaugh                       | Dublin |
| North Mayo       | NMO  | 63                     | Ballina                          | Mayo   |
| Rasharkin        | RSK  | 90                     | Ballymena                        | Antrim |

## 2.9 Detailed Transmission Network Information

The all-island schematic network diagrams in Appendix A show snapshots of the existing and planned transmission developments at the end of 2015 and 2024. The diagrams indicate stations, circuits, transformers, generation, reactive devices and phase shifting transformers.

- Figure A-1 in Appendix A presents a geographical map of the all-island transmission system at the beginning of July 2015.
- Figure A-2 in Appendix A presents a geographical map of the all-island transmission system as forecast in 2024, including the planned developments.

The electrical characteristics and capacity ratings of the existing transmission system are included in the following tables in Section B.1 of Appendix B:

- Tables B-2 to B-5 list the electrical characteristics of the existing overhead lines and underground cables at the different voltage levels. Equipment ratings for Ireland's transmission system are shown in MVA for winter and for summer reference temperature conditions, 5°C and 25°C respectively. The ratings of the Northern Ireland transmission system equipment are shown in MVA for winter, autumn and summer.

- Tables B-6 to B-10 list data for each existing transmission system connected transformer. The data includes impedance values, nameplate ratings and tap ranges. The voltage tapping range for each transformer is given as the percentage deviation from the nominal voltage ratio at the two extreme tap positions.
- Table B-11 lists details of the phase shifting transformers throughout the island.
- Table B-12 includes the Mvar capacity data for existing reactive compensation devices.

The electrical characteristics and capacity ratings of planned transmission system developments are included in the following tables in Section B.2 of Appendix B:


- Tables B-13 to B-17 contains data for new lines and cables and planned changes to existing line and cable data on an annual basis. These tables include a column to indicate whether each listed item of plant is being added, amended or deleted. Changes relating to a particular development project are grouped together and headed by a project description. This includes the Capital Project (CP) number with respect to Ireland and a SONI description heading for Northern Ireland.
- Tables B-18 to B-31 list the details of the planned network transformers.
- Tables B-32 to B-33 include the Mvar capacity data for planned reactive compensation devices.

Electrical characteristics of future transmission system plant or changes to the electrical characteristics brought about by planned transmission system developments are subject to change. These will be reviewed when the plant is commissioned.



### 3 DEMAND

- 3.1 Forecasts of Transmission Peaks
- 3.2 Demand Data
- 3.3 Forecast Demand at Transmission Interface Stations in Ireland
- 3.4 Northern Ireland Bulk Supply Point (BSP) Demand



The current. The future.

### 3 Demand

This chapter provides information on forecasts for the all-island demand on the transmission system. The forecast is taken from the All-Island Generation Capacity Statement 2015-2024 (GCS) <sup>1</sup> which was published by EirGrid and SONI in February 2015.

The 2015 GCS contains forecasts of future energy consumption and demand between 2015 and 2024. It concludes that there should be sufficient generation plant on the island to meet the forecasted demand during these years.

Provided the North-South interconnector is completed in 2019, the GCS states that there will be no significant transmission constraints between Ireland and Northern Ireland after this interconnection.

This chapter also provides an introduction to the anticipated large demand increases in the Dublin area. This anticipated increase in demand is associated primarily with the connection of data centres. The impact of these data centres on the future all-island demand forecast will also be discussed.

#### 3.1 Forecasts of Transmission Peaks

Table 3-1 presents the median winter peak transmission demand forecasts over the period 2015-2024, as published in the GCS.

Table 3-1 also compares the most recent winter peak forecasts with those from the previous GCS. The current demand forecast shows an average annual increase in winter peak demand of 0.5% between 2015 and 2024.

This is less than the predicted demand increase of 1% in the All-Island Generation Capacity Statement 2014-2025. This change is mostly due to changing economic predictions and increasing levels of energy efficiency.

---

<sup>1</sup> The TYTFS 2015 references documents that were published at the July 2015 data freeze date. The All-Island Generation Capacity Statement 2016-2025 is due to be published at the beginning of March 2016. The information in the 2016 GCS however does not fundamentally impact studies presented in the 2015 TYTFS.

Table 3-1 Comparison of Peak Demand Forecast with Previous GCS

|                  | 2015  | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
|------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| GCS2015-2024(MW) | 6,505 | 6,532 | 6,561 | 6,585 | 6,614 | 6,646 | 6,678 | 6,729 | 6,788 | 6,847 |
| GCS2014-2023(MW) | 6,510 | 6,571 | 6,628 | 6,696 | 6,765 | 6,849 | 6,925 | 7,002 | 7,078 | N/A   |
| Difference (MW)  | -5    | -39   | -67   | -111  | -151  | -203  | -247  | -273  | -290  | N/A   |

It is difficult to accurately predict a peak demand figure for a particular year in the future. This is due to a number of factors that can cause fluctuations in the forecast. These factors include weather conditions, economic activity, electricity usage patterns and government policy.

The forecasts in Table 3-1 may be taken as indicative of a general trend in demand growth. These forecasts are based on the current information available. In Table 3-2, four demand values are presented for each year: the winter peak; summer peak; summer valley; and autumn peak.

### 3.1.1 All-Island Transmission Peaks

The winter peak figures represent the expected annual peak demand to occur during the winter period of each year. For example, the 2015 forecast of 6,505 megawatts (MW) is the maximum demand projected to occur in winter 2015/16. The Northern Ireland and Ireland winter peaks generally do not occur at the same time. The Northern Ireland winter peak usually occurs earlier in the evening than in Ireland.

The summer peak refers to the average peak demand levels that are forecast to occur during the summer period of each year. The Ireland and Northern Ireland summer peaks are combined to produce an all-island summer peak.

The overall transmission system power flows are often lower in summer than in winter. However, this may not be the case for flows on all circuits. The capacity of overhead lines is lower during the summer period because of higher ambient temperatures.

Network maintenance is also usually carried out during the summer/autumn period. Both of these factors can restrict the network, reducing its capability to transport power.

The annual minimum is referred to as the summer valley. It represents the expected annual demand valleys that are forecast to occur during the summer period of each year.

The Ireland and Northern Ireland summer valleys were combined to produce an all-island summer valley. The summer valley cases examine the impact of less demand and less conventional generation dispatched.

This minimum condition is of particular interest when assessing the capability of the transmission system to connect new generation. This is because with local demand at a minimum, the connecting generator must export more of its power across the transmission system.

Table 3-2 Transmission Demand Forecast

| Year | All-Island Winter Peak (MW) |       | All-Island Summer Peak (MW) |       | All-Island Summer Valley (MW) |     | Autumn Peak(MW) |
|------|-----------------------------|-------|-----------------------------|-------|-------------------------------|-----|-----------------|
|      | Ireland                     | NI    | Ireland                     | NI    | Ireland                       | NI  | NI              |
| 2015 | 6,505                       |       | 5,240                       |       | 2,212                         |     | 1,472           |
|      | 4,831                       | 1,694 | 3,865                       | 1,290 | 1,691                         | 477 |                 |
| 2016 | 6,532                       |       | 5,262                       |       | 2,221                         |     | 1,473           |
|      | 4,856                       | 1,696 | 3,885                       | 1,291 | 1,700                         | 477 |                 |
| 2017 | 6,561                       |       | 5,285                       |       | 2,231                         |     | 1,477           |
|      | 4,881                       | 1,700 | 3,905                       | 1,294 | 1,708                         | 478 |                 |
| 2018 | 6,585                       |       | 5,304                       |       | 2,239                         |     | 1,483           |
|      | 4,898                       | 1,707 | 3,918                       | 1,300 | 1,714                         | 480 |                 |
| 2019 | 6,614                       |       | 5,328                       |       | 2,249                         |     | 1,491           |
|      | 4,919                       | 1,716 | 3,935                       | 1,306 | 1,722                         | 483 |                 |
| 2020 | 6,646                       |       | 5,353                       |       | 2,260                         |     | 1,500           |
|      | 4,939                       | 1,727 | 3,951                       | 1,315 | 1,729                         | 486 |                 |
| 2021 | 6,678                       |       | 5,379                       |       | 2,271                         |     | 1,511           |
|      | 4,959                       | 1,739 | 3,967                       | 1,324 | 1,736                         | 489 |                 |
| 2022 | 6,729                       |       | 5,420                       |       | 2,288                         |     | 1,520           |
|      | 4,999                       | 1,750 | 3,999                       | 1,332 | 1,750                         | 492 |                 |
| 2023 | 6,788                       |       | 5,468                       |       | 2,308                         |     | 1,531           |
|      | 5,045                       | 1,762 | 4,036                       | 1,341 | 1,766                         | 496 |                 |
| 2024 | 6,847                       |       | 5,515                       |       | 2,328                         |     | 1,541           |
|      | 5,093                       | 1,774 | 4,074                       | 1,351 | 1,783                         | 499 |                 |



### 3.1.2 Large Demand Increases in the Dublin Area

#### Background

Since the freeze date of data for this statement (July 2015), there has been an unprecedented level of enquiries for connection to the transmission system in the Dublin area. It was therefore decided to include greater detail on current demand connections and future demand opportunities in this year's statement. This assessment of demand opportunities is included in Chapter 8 with a particular focus on the Dublin area.

The level of enquiries in the Dublin area is principally driven by the need for Information, Communications and Technology (ICT) industries and high-tech manufacturing companies to connect to a high quality power supply in the Dublin area.

#### Data Centres

Ireland is an attractive business location and continues to attract world-class investments. The Industrial Development Authority (IDA) Ireland has cited access to a high-quality electricity grid as critically important for attracting new investment. This is particularly important in the ICT and high-tech manufacturing sectors.

Some of the world's best known companies have chosen Ireland as the location for their European data centre operations. Factors such as temperate, climate, stable power sources, internet connectivity and skilled workforce have influenced their decisions. This is emphasised by nine out of the top 10 global software companies and US ICT companies locating strategic business activities in Ireland<sup>2</sup>.

At present there is 250MW of connected data centres. Beyond this, there is significant interest in connecting other data centres to the grid in Ireland. There is approximately 550MW of data centres with either contracted capacity for connection to the grid or in the EirGrid connection offer process. In addition to this, there is approximately 1000MW of enquiries regarding further demand connections.

---

<sup>2</sup> <http://www.idaireland.com/business-in-ireland/industry-sectors/ict/>

To put this in context, the current winter peak demand on the all-island transmission system is approximately 6500MW. If all of these enquiries were to connect, the data centre load could account for 20% of the all-island system peak demand.

*What is a data centre?*

A data centre is a facility used to house computer systems and associated components, such as telecommunications and storage systems. They underpin the operations of companies in the broad ICT sector, particularly those in social media and cloud computing. The size of the individual electricity demand connections depends on the scale of the business operation. These have varied from 20MW with some possibly extending to 250MW in the final stages of development. Their use of electricity tends to be constant throughout the year. The modern world increasingly requires the retention and use of vast volumes of data, so this trend is likely to continue for the foreseeable future.

### Impact on System Demand Forecast

The all-island demand forecast used in this statement is based on an underlying growth rate trend of 0.5%. This includes a small amount of industrial block demand increases contracted in advance of this statement freeze date.

Clearly the potential connection of demand on this scale is equivalent to decades of natural demand growth. This will have an impact on the all island system demand forecast and generation capacity adequacy. This is assessed and discussed in the All-Island Generation Capacity Statement<sup>3</sup> (GCS).

The focus of the majority of the connection enquiries have been in the greater Dublin area. Depending on the number and scale of projects that materialise, new transmission solutions will be required to strengthen the grid to facilitate these connections.

These transmission solutions are now under initial investigations and could vary from short lead time to longer lead time developments. The impact of these Dublin demand connections are described in greater detail in Chapter 8, section 8.3.

---

<sup>3</sup> [http://www.eirgridgroup.com/site-files/library/EirGrid/Eirgrid\\_Generation\\_Capacity\\_Statement\\_2015-2024.pdf](http://www.eirgridgroup.com/site-files/library/EirGrid/Eirgrid_Generation_Capacity_Statement_2015-2024.pdf)

### 3.1.3 Northern Ireland Transmission Peaks

The winter period is defined as November to February and the 2015 forecast of 1,694MW is the maximum demand projected to occur in winter 2015/16.

The summer peak occurs between May and August and is typically 21% lower than the winter peak.

Summer valley demand forecasts in Table 3-2 assume a figure of 30% of the annual maximum demand. This figure is consistent with historical summer valley demand data.

The autumn peak refers to the average peak value in the spring-autumn season. The autumn peak occurs between September - October and March - April. This is typically 14% lower than the winter peak. The overall transmission system power flow is often lower in autumn than in winter. However, this may not be the case for flows on all circuits.

The capacity of overhead lines is lower because of higher ambient temperatures during this period. Network maintenance is also usually carried out during the summer/autumn period. Both of these factors can restrict the network, reducing its capability to transport power.

### 3.1.4 Ireland Transmission Peaks

The 2015 winter peak forecast is 4,831MW, ie the maximum demand projected to occur in winter 2015/16.

The summer peak refers to the average peak value between March and September. This is typically 20% lower than the winter peak.

The forecasted summer valley demands, in Table 3-2, assume a figure of 35% of the annual maximum demand. This is consistent with historical summer valley demand data.

## 3.2 Demand Data

Electricity usage follows some generally accepted patterns. For example, annual peak demand occurs between 17.00 and 19.00 on winter weekday evenings. Minimum usage occurs during summer weekend night-time hours.

### 3.2.1 Generated Peak Demand Profiles

Figure 3-1 shows the generated peak demand profiles of Ireland and Northern Ireland on the day of the 2014 winter peak. The Ireland and Northern Ireland peaks did not occur on the same day. Peak demand for Ireland occurred on 8 December 2014, while peak demand occurred in Northern Ireland on 14 January 2014.




Figure 3-1 Generated Peak Demand Profiles for 2014

### 3.2.2 All-Island Demand Profiles

Figure 3-2 shows the profiles of the 2014 all-island winter peak, summer peak and summer valley. The percentage demand attributable to each jurisdiction during the peak and valley scenarios is also shown.




Figure 3-2 All-Island Daily Demand Profiles for Year 2014

### 3.2.3 All-Island Weekly Demand Peaks

Figure 3-3 shows the profile for the all-island, Northern Ireland and Ireland weekly peaks across the year for 2014.




Figure 3-3 Weekly Demand Peak Values for Year 2014

### 3.2.4 Load Duration Curves

Figures 3-4 and 3-5 shows the Ireland and Northern Ireland 2014 load duration curves, respectively. The curves show the percentage of time in the year that a particular demand value was exceeded. For example, demand exceeded 3,000 MW for 51% of the year in Ireland. Demand in Northern Ireland exceeded 1,000 MW for 53% of the year.




Figure 3-4 Ireland Load Duration Curve 2014




Figure 3-5 Northern Ireland Load Duration Curve 2014

### 3.3 Forecast Demand at Transmission Interface Stations in Ireland

Transmission interface stations are the points of connection to the transmission system. These interfaces include connections between the transmission system and the distribution system or 110 kilovolts (kV) connected customers. The interfaces are mostly 110kV stations. In Dublin city, where the Distribution System Operator (DSO) operates the 110kV network, the interface is usually at 220kV stations.

Appendix C lists forecast demands at each transmission interface station. The forecast demands are given for winter peak, summer peak and summer valley for all years from 2015-2024. Demand projections at individual transmission stations are developed from the system demand forecasts on a top-down basis.

The forecasting process includes regular monitoring and review of consumption trends in all parts of the country. The allocation of the system demand forecast to each station is pro-rata. This is based on an up-to-date measurement of actual peak demand at each station. Account is taken of planned transfers of demand between stations, as agreed with ESB<sup>4</sup>. In this way, changes in the geo-diversity of electricity consumption are captured. This process provides a station demand forecast and by extension a regional demand forecast for the short to medium term.

The system-wide demand forecasts, presented in Table 3-1, include transmission losses whereas the individual station demand forecasts do not. Transmission losses therefore account for the difference between system-wide demand and the sum of the demand at each interface station. The demand at each interface is given in appendix C.

Demand forecasts for the small number of directly-connected customers are the current best estimates of requirements. In some cases, the estimates may be less than contracted maximum import capacity (MIC) values. These values are chosen to give a better projection of expected demand on a system-wide basis. However, when analysing the capacity for new demand in a particular area, the MIC values of local directly-connected customers are assumed. These values are assumed to ensure that the contracted MIC is preserved.

---

<sup>4</sup> ESB are the Distribution System Operator (DSO) in Ireland



A demand-side unit (DSU) consists of one or more demand sites that can be instructed by EirGrid to reduce electricity demand. DSUs are usually medium to large industrial premises. A DSU uses a combination of on-site generation or plant shutdown to deliver a demand reduction. Providing this dispatch availability means that the DSU is eligible for capacity payments in the Single Electricity Market (SEM).

It is noted that DSUs may reduce some customers' demands from time to time over winter peak hours. However, normal demand levels are included in the winter peak demand forecasts shown in Table C-1 in Appendix C.

Normal demand levels are also used in the power flow diagrams in Appendix I. These normal demand levels are used since they are more indicative of general power flows.

### 3.4 Northern Ireland Bulk Supply Point (BSP) Demand

The 110/33kV BSP demand forecasts are provided by NIE5. They are adjusted to align with the overall system average cold spell (ACS) forecasts. These demand forecasts are based on localised demand trends at individual nodal level. Consideration is given to future block load transfers from one BSP to another. Tables and information relating to demand forecasts are contained in Appendix C.

---

<sup>5</sup> NIE are the DSO in Northern Ireland



## 4 GENERATION

- 4.1 Ireland Generation
- 4.2 Northern Ireland Generation



The current. The future.

## 4 Generation

This chapter gives information about existing generation capacity. The chapter also defines future projections for the ten years 2015 to 2024. All generation capacity and dispatch figures in this statement are expressed in exported or net terms. This is the generation unit output less the unit's own auxiliary load.

In Ireland, renewable energy policy is driven by a binding European legal requirement. The requirement is for 16% of the country's total energy consumption to be met by renewable energy sources (RES) by 2020.

The Irish Government aims to achieve 40% renewable electricity, 12% renewable heat and 10% renewable transport to meet this overall requirement. 3,200 - 3,800MW of installed wind generation will be needed to meet approximately 37% of electricity demand in 2020.

The remaining 3% is expected to be sourced from hydro generation, solar, bio-energy and renewable Combined Heat and Power (CHP) energy production.

The Strategic Energy Framework (SEF)<sup>1</sup> 2010 for Northern Ireland sets the renewable energy policy in Northern Ireland. It states that 40% of electricity consumption in Northern Ireland should come from renewable sources by the year 2020. It should be noted that this figure is currently under review<sup>2</sup>.

Currently SONI, along with NIE, are working to facilitate the connection of the renewable generation required to meet the 40% target by the year 2020. This 40% government target translates into approximately 1,600MW of renewable generation capacity in Northern Ireland. The main contributing technology to this figure being wind (approximately 1,200MW).

The data was frozen on the 1st of July 2015 (Ireland and Northern Ireland). A data freeze was implemented to allow for TYTFS analyses to be carried out. Based on that freeze dates, 9,088MW of generation capacity was installed in Ireland. A further 3,201MW was installed in Northern Ireland.

---

<sup>1</sup> <https://www.detini.gov.uk/articles/strategic-energy-framework-2010>

<sup>2</sup> <https://www.detini.gov.uk/publications/review-costs-and-benefits-ni-executives-40-renewable-electricity-target>

## 4.1 Ireland Generation

### 4.1.1 Existing and Planned Transmission-Connected Generation

Of the 9,088MW of generation capacity, 7,741MW is connected to the Transmission System. The remaining 1,347MW is connected directly to the Distribution System. Sections 4.1.1 to 4.1.4 detail planned developments in generation in Ireland over the period covered by this TYTFS. The 7,741MW figure for Transmission System-connected generation capacity does not include the East West Interconnector.

On the 1<sup>st</sup> July 2015, 33 transmission connection agreements were executed for a total generation capacity of 2,111MW. These planned generators are listed in Table 4-1 with their expected connection dates at the time of the data freeze.

### 4.1.2 Demand Side Units

As at the data freeze date, in Ireland ten demand side units (DSU) had entered the Single Electricity Market. These DSUs have a combined dispatchable capacity of 221MW.

### 4.1.3 Planned Retirement/Divestiture of Generation Plant

The closure of generation plant could have a significant impact on the ability of the transmission system to comply with standards. The EirGrid Grid Code specifies the minimum length of notice a generator must give the TSO before retirement or divestiture.

The closure of a generator with capacity less than or equal to 50MW requires at least 24 months' notice. Generators with larger capacity than this must give at least 36 months' notice.

Some older generators will come to the end of their lifetimes over the next ten years. Great Island units 1, 2 and 3 were decommissioned in 2015 and Tarbert units 1, 2, 3 and 4 are expected to be decommissioned in 2022.

Other than the Great Island and Tarbert units listed, EirGrid has received no other notification of plant closures. However, we have assumed that some older generators will shut towards the latter end of the 10 year period. This is for the purposes of our studies.

Table 4-1 Contracted Transmission-Connected Generation as at 1<sup>st</sup> July 2015

| Generator                         | Description                     | Expected Connection Date |
|-----------------------------------|---------------------------------|--------------------------|
| Athea Phase 2                     | 19MW wind farm in Co. Limerick  | Jul-20 <sup>3</sup>      |
| Athea Phase 3                     | 20MW wind farm in Co. Limerick  | Sep-15                   |
| Athea Phase 4                     | 26MW wind farm in Co. Limerick  | Jul-20 <sup>2</sup>      |
| Barnadivane                       | 60MW wind farm in Co. Cork      | Oct-16                   |
| Boggeragh 2                       | 48MW wind farm in Co. Cork      | Nov-15                   |
| Cahernagh Mid Merit               | 101MW OCGT in Co. Limerick      | Aug-20 <sup>2</sup>      |
| Castletownmoor                    | 120MW wind farm in Co. Meath    | Aug-20 <sup>2</sup>      |
| Clahane Phase 2                   | 14MW wind farm in Co. Kerry     | Sep-15                   |
| Cloghboola Phase 2                | 10MW wind farm in Co. Kerry     | Jul-20 <sup>2</sup>      |
| Coomataggart (formerly Kilgarvan) | 62MW wind farm in Co. Cork      | Jul-20 <sup>2</sup>      |
| Cordal Phase1                     | 84MW wind farm in Co. Kerry     | Sep-15                   |
| Cordal Phase 2                    | 17MW wind farm in Co. Kerry     | Jul-20 <sup>2</sup>      |
| Cronacarkfree                     | 105MW wind farm in Co. Donegal  | Jun-17                   |
| Cuilleen                          | 98MW OCGT in Co. Westmeath      | Jul-20 <sup>2</sup>      |
| Dooray                            | 55MW wind farm in Co. Laois     | Jul-20 <sup>2</sup>      |
| Dromada Phase 2                   | 18MW wind farm in Co. Limerick  | Jul-20 <sup>2</sup>      |
| Garvagh Phase 2                   | 10MW wind farm in Co. Leitrim   | Jul-20 <sup>2</sup>      |
| Glanlee Phase 2                   | 6MW wind farm in Co. Cork       | Jul-20 <sup>2</sup>      |
| Keelderry                         | 27MW wind farm in Co. Clare     | Jul-20 <sup>2</sup>      |
| Kill Hill Phase 2                 | 23MW wind farm in Co. Tipperary | Sep-15                   |
| Loughaun North                    | 27MW wind farm in Co. Clare     | Apr-17                   |
| Moneypoint                        | 22MW wind farm in Co. Clare     | Dec-15                   |
| Mulreavy                          | 95MW wind farm in Co. Donegal   | Nov-16                   |
| Nore                              | 98MW OCGT in Co. Kilkenny       | Jul-20 <sup>2</sup>      |
| Oriel                             | 210MW wind farm in Co. Meath    | Jul-20 <sup>2</sup>      |
| Oweninney Power 1                 | 89MW wind farm in Co. Mayo      | Oct-16                   |
| Oweninney Power 2                 | 83MW wind farm in Co. Mayo      | Oct-16                   |
| Oweninney 5                       | 199MW wind farm in Co. Mayo     | Dec-20                   |
| Ratrussan Phase 2                 | 22MW wind farm in Co. Cavan     | Oct-16                   |
| Seecon                            | 105MW wind farm in Co. Galway   | May-16                   |
| Sliabh Bawn                       | 58MW wind farm in Co. Roscommon | Jun-16                   |
| Suir                              | 98MW OCGT in Co. Tipperary      | Jul-20 <sup>2</sup>      |
| Uggool                            | 64MW wind farm in Co. Galway    | May-16                   |

<sup>3</sup> At the date of the data freeze (July 2015), this generation project did not have an estimated energisation date available. As no additional information was available, we have assumed that this project would connect over this period for the purpose of TYTFS 2015 studies.

#### 4.1.4 Embedded Generation

On the 1<sup>st</sup> July 2015, there was approximately 1,554MW of embedded generation plant. This includes plant connected to the distribution system or to the system of a directly-connected demand customer. This figure comprises of small conventional and renewable units. Conventional units include CHP schemes and small industrial thermal units.

Renewable generation included in this figure consists of wind, small hydro, land-fill gas (LFG), tidal, biogas and biomass sources. Table 4-2 lists the existing embedded generation capacity totals by generation type. Table D-2 in Appendix D provides details of the existing embedded wind farms and their capacities.

Table 4-2 Existing Embedded Generation as at 1<sup>st</sup> July 2015

|                   | Wind | Small Hydro | Biomass/<br>LFG | CHP | Peaking | Total |
|-------------------|------|-------------|-----------------|-----|---------|-------|
| Net Capacity (MW) | 1254 | 26          | 70              | 71  | 131     | 1,552 |

Embedded generators reduce the demand supplied through Transmission Interface Stations. Forecasts of demand at the relevant Transmission Interface Stations is presented in Table 3-2 of chapter 3.

These forecasts take account of the contribution of the existing non-wind embedded generators<sup>4</sup>. The *All-Island Generation Capacity Statement 2015-2024 (GCS)* estimated biomass CHP to grow steadily to 150MW capacity by 2020. It is not expected that conventional CHP capacity will change significantly during this period.

As at 1<sup>st</sup> July 2015, seven generators have executed connection agreements committing to connecting to the distribution system. Table 4-3 shows details of the total amount of conventional generation capacity connected or committed to the distribution system.

<sup>4</sup> Because of the variability of wind, a fixed contribution from embedded wind farms is not taken into account in the calculation of the peak transmission flow forecasts. Rather a number of wind scenarios are considered in the TYTFS analyses.

Table 4-3 Connected and Committed Embedded Generation as at 1<sup>st</sup> July 2015

| Station     | Description                                       | Connection Date |
|-------------|---|-----------------|
| Bellacorick | 10MW Wave Energy generator in Co. Mayo            | Mar-16          |
| Thornsberry | 10MW Biomass generator in Co. Offaly              | Sep-15          |
| Blake       | 5MW LFG generator in Co. Kildare                  | Oct-13          |
| Ringsend    | 72MW Waste to Energy generator in Co. Dublin      | Aug-16          |
| Tawnaghmore | 49MW Biomass generator in Co. Mayo                | Jun-16          |
| Drybridge   | 20MW Waste to Energy generator in Co. Meath       | Feb-11          |
| Derryiron   | 15MW Biomass generator in Co. Offaly              | Feb-17          |
| Navan       | 13MW Biogas generator in Co. Meath                | Jun-16          |
| Tawnaghmore | Two 52MW Distillate Peaker generators in Co. Mayo | Jan-12          |
| Tullabrack  | 6MW Wave Energy generator in Co. Clare            | Dec-17          |

#### 4.1.5 Wind Generation

Over the past two decades wind power generation in Ireland has increased from 6MW to 2,129MW. This represents an increase from 1 wind farm to 176 wind farms, at the beginning of July 2015. The information presented in Figure 4-1 Figure 4-1 is a combination of connected and contracted wind generation. These figures are as presented in Tables D-1 and D-2 in Appendix D.

Energisation dates for contracted wind generation contained within Tables D-1 and D-2. These dates are based on the best information available at the time of the data freeze (1<sup>st</sup> July 2015).

As at 1<sup>st</sup> July 2015, 179 wind farms totalling 3,564MW have signed connection offers. These wind farms are committed to connecting to the Transmission or Distribution Systems over the next few years.

Table 4-4 shows the amount of existing and committed wind generation capacity expected to be connected each year. The individual wind farm details are included in Tables D-1 and D-2 of Appendix D.




Figure 4-1 Expected Growth in Wind Capacity, 2014 to 2024

Table 4-4 Existing and Committed Wind Capacity Totals, MW

| Connection   | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 |
|--------------|------|------|------|------|------|------|------|------|------|------|------|
| Transmission | 1013 | 1142 | 1713 | 1818 | 1818 | 1818 | 2507 | 2507 | 2507 | 2507 | 2507 |
| Distribution | 1254 | 1536 | 2117 | 2663 | 2821 | 2868 | 3345 | 3345 | 3345 | 3345 | 3345 |
| Total        | 2267 | 2678 | 3830 | 4481 | 4639 | 4686 | 5852 | 5852 | 5852 | 5852 | 5852 |

As at 1st July 2015, there are a total of 352 applications totalling 14,889MW in the applications queue. This includes 14 (370MW) Non-Group Processing Approach applications to the TSO and DSO.

In the period up to the 1<sup>st</sup> July 2015 data freeze date, eight Gate 3 applicants had connected. A further one hundred and twenty-four Gate 3 applicants were contracted to connect and eight applicants had live Gate 3 offers. Twelve offers had lapsed. The number of TSO and DSO offers associated with each grouping as well as the MWs associated with them are shown in Figure 4-2.






Figure 4-2 Gate 3 Offer Status

#### 4.1.6 Offshore Generation

Currently there is one offshore generation unit in Ireland. 25MWs of offshore wind generation is located on the Arklow bank. The offshore wind farm consists of seven 3.6MW turbines, operational since the end of 2003.

In February 2014, the Irish Government published an Offshore Renewable Energy Development Plan (OREDP)<sup>5</sup>. The aim of this work is to implement a framework for the sustainable development of offshore renewable generation in Ireland. The OREDP identifies three high level goals.

First, that Ireland harnesses the market opportunities presented by offshore renewable energy to achieve economic development, growth and jobs.

Second, to increase awareness of the value, opportunities and societal benefits of developing offshore renewable energy.

Third, that offshore renewable energy development does not adversely impact our rich marine environment and it's living and non-living resources<sup>5</sup>.

The OREDP will also provide a structure through which Ireland can input to the development of the European Blue Energy Strategy and the US/Ireland Memorandum of Understanding (MoU) on Ocean Energy.

<sup>5</sup> <http://www.dcenr.gov.ie/energy/en-ie/Renewable-Energy/Pages/OREDP-Landing-Page.aspx>

The Department of Communications, Energy and Natural Resources (DCENR) is leading the implementation of OREDP. It has developed a robust governance structure to deliver on the aims of the plan. EirGrid sits on the steering group and are on a number of OREDP working groups.

#### 4.1.7 Solar Generation

Since the data freeze date (June 2015) interest in the connection of solar generation has increased significantly. Solar generation applications for connection to the power system are currently in excess of 2,000MW<sup>6</sup>. The vast majority of these solar generation applications are seeking connection to the distribution system in the south-west and south-east of Ireland.

It should be noted that this solar generation has not been included in the study results presented in this TYTFS. However, should this level of solar generation connect to the distribution system, it would have a significant impact on the transmission system. As these solar generation projects progress, we will continue to monitor and revise assumptions presented in future versions of the TYTFS as necessary.

#### 4.2 Northern Ireland Generation

3,201MW of generation capacity is connected in Northern Ireland as at July 2015. 2,365MW is connected to the transmission system and 836MW is connected to the distribution system.

The 2,365MW of transmission connected generation capacity does not take into account the Moyle Interconnector capacity. It is mainly made up of conventional generation capacity along with Slieve Kirk, the only transmission connected wind farm power station (WFPS) which consists of a capacity of 73.6MW.

##### 4.2.1 Existing and Planned Transmission-Connected Conventional Generation

###### Existing Conventional Generation

In Northern Ireland, conventional thermal generation plant can be split into two contractual categories:

- Plant contracted to Power NI Energy Limited PPB (Contracted Plant)

---

<sup>6</sup> <http://www.eirgridgroup.com/site-files/library/EirGrid/Connection-Offer-Disclosure-of-Applications-as-published-31th-March-2016.pdf>

- Independent Market Participants (Non-Contracted Plant)

Table D-9 provides a list of contracted and non-contracted generators connected to the Northern Ireland Transmission System.

#### Contracted Conventional Generation

Plant contracted to Power NI Energy Limited via their Power Procurement Business (PPB) under pre-vesting contracts, or contracts negotiated thereafter, totals 577MW. It is measured as output capacity at generator terminals.

Details of capacity and contract information for individual generators can be seen in Tables D-1 and D-9. The contracts contain expiry dates, though the Utility Regulator may cancel contracts at earlier cancellation dates.

The Power Purchasing Agreements (PPA) or Generating Unit Agreements (GUAs) cover availability, operating characteristics, payments, metering etc. These agreements cover matters such as outage planning, emissions and fuel stocks.

#### Independent Market Participants (IMP)

The Utility Regulator has a duty to promote competition in the generation and supply of electricity. This is in line with the EU IEM Directive (concerning common rules for the internal market in electricity 2003/54/EC). This directive was introduced in June 2003. As at July 2015 there is 1,714MW of IMP capacity in Northern Ireland.

#### 4.2.2 Planned Retirement/Divestiture of Northern Ireland Generation Plant

In line with the latest information available to SONI, the following assumptions have been made:

At the data freeze date, AES Ballylumford had entered into a Local Reserve Services Agreement (LRSA) with SONI for the provision of 250MW of local reserve. This will see Ballylumford ST4 and ST5 remaining connected (at reduced capacity) until the end of 2018 with an option for SONI to extend this by a further 2 years if deemed required. Ballylumford ST6 will be decommissioned at end of 2016.

The generation output of Kilroot ST1 and ST2 is anticipated to be restricted. The restriction is due to the Industrial Emissions Directive (IED)<sup>7</sup>. The restriction includes limited emissions each year from 2016-2020, followed by severely restricted running hours from 2021-2022. Kilroot ST1 and ST2 are currently due to be decommissioned by 2024.

#### 4.2.3 Embedded Generation

##### Existing Embedded Generation

Table 4-5 shows a breakdown of the existing Northern Ireland Embedded Generation. There is a total of 89MW of Aggregated Generating Units (AGUs) in Northern Ireland registered in the SEM by 3 parties.

Two of these AGUs are made up of mainly distribution connected diesel generator sets located around Northern Ireland (iPower and EmPower). The third is made up from CHP gas generation (ContourGlobal). These units currently participate in the SEM.

There is 11MW of CHP plant connected to the Northern Ireland Distribution System. This 11MW is not expected to increase in the foreseeable future.

There is currently 4MW of small-scale hydro generation installed on the waterways of Northern Ireland. This is a mature technology. Due to the lack of suitable new locations, limited increase in the small-scale hydro is expected in the foreseeable future.

In Northern Ireland there is currently 15MW of landfill gas generation. It is assumed that by 2024 biogas generation capacity will increase to 22MW.

Table 4-5 Northern Ireland Embedded Generation

| Generation          | Net Capacity |
|---------------------|--------------|
| Large Scale Wind    | 561          |
| Small Scale Wind    | 74           |
| Large Scale Biomass | 17           |
| Small Scale Biomass | 5            |
| Small Scale Solar   | 59           |
| Small Scale Hydro   | 4            |
| Landfill Gas        | 15           |
| CHP                 | 11           |
| AGU                 | 89           |
| Tidal/Wave          | 1            |
| Total               | 836          |

---

<sup>7</sup> <http://ec.europa.eu/environment/industry/stationary/ied/legislation.htm>

A number of customers have been reducing energy consumption at times of peak demand. This is achieved by load shifting or by running private generation. SONI has tended to view this generation as non-permanent due to a number of factors:

- The operation of this plant is not as reliable as conventional contracted plant
- Variable generation costs, e.g. diesel and hire charges
- Variable tariff price signals

Based on winter 2014/15, generation of this type is estimated to total 9MW. This total figure is not anticipated to increase from 9MW in the foreseeable future.

#### 4.2.4 Northern Ireland Renewable Generation

##### Existing/Approved Renewable Generation

Renewable generation schemes that are connected to the Northern Ireland network, schemes approved by the planning service and schemes that are in construction at the time of the data freeze, are shown in Figure 4-3.

The map indicates points at which renewable generation is connected to or is assumed to connect to. These points include 110/33kV Bulk Supply Points (BSPs) and 110/33kV Clusters substations.

In line with the criteria set out in the NIE Distribution Charging Statement<sup>8</sup>, NIE, in its role as Distribution Network Owner (DNO), have identified a number of Clusters substations that they wish to develop. These Clusters substations consist of a 110/33kV substation in the vicinity of a number of distribution generator locations.

These distribution generators would connect into the cluster at the 33kV level. SONI would be responsible for the delivery of the transmission elements of the Cluster substation. One such Cluster substation already exists in NI at Magherakeel.

---

<sup>8</sup> Statement of Charges for Connection to the Northern Ireland Electricity Networks' Distribution System: <http://www.nienetworks.co.uk/documents/Connections/NIE-Distribution-Connection-Charging-Statement-ver.aspx>



Figure 4-3 Existing and Committed Northern Ireland Renewable Generation

### Unapproved Renewable Generation

A number of renewable generation projects are assumed to be commissioned in Northern Ireland between 2015-2024. These assumptions have been derived from a number of sources.

The sources include NIE, the Strategic Energy Framework for Northern Ireland<sup>9</sup>, the Strategic Environmental Assessment of offshore wind and marine renewable energy<sup>10</sup> and the Onshore Renewable Electricity Action Plan (OREAP)<sup>11</sup>. Renewable generation that has been included in the TYTFS study files are detailed in Table 4-6.

<sup>9</sup> <https://www.detini.gov.uk/articles/strategic-energy-framework-2010>

<sup>10</sup> <http://www.offshoreenergyni.co.uk/>

<sup>11</sup> <https://www.detini.gov.uk/publications/onshore-renewable-electricity-action-plan-publications>

Table 4-6 Capacity and Location of Renewable Generation by Year End

| Transmission Node | Northern Ireland Renewable Capacity (MW) |       |       |       |       |       |       |       |       |       |
|-------------------|--|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|                   | 2015                                     | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| Aghyoule          | 82.5                                     | 82.5  | 82.5  | 82.5  | 82.5  | 82.5  | 82.5  | 82.5  | 82.5  | 82.5  |
| Antrim            | 5  | 5     | 5     | 5     | 5     | 6.7   | 6.7   | 6.7   | 6.7   | 6.7   |
| Ballymena (Rural) | 5  | 11    | 55.5  | 55.5  | 55.5  | 58    | 58    | 58    | 58    | 58    |
| Brockaghboy       | -  | -     | 56.5  | 56.5  | 56.5  | 56.5  | 56.5  | 56.5  | 56.5  | 56.5  |
| CAM               | -  | -     | -     | -     | -     | 88.5  | 88.5  | 88.5  | 88.5  | 88.5  |
| Carnmoney         | 13.8                                     | 13.8  | 13.8  | 13.8  | 13.8  | 13.8  | 13.8  | 13.8  | 13.8  | 13.8  |
| Coleraine         | 108                                      | 108   | 108   | 108   | 108   | 108   | 108   | 108   | 108   | 108   |
| Coolkeeragh       | 29.6                                     | 29.6  | 29.6  | 29.6  | 29.6  | 29.6  | 29.6  | 29.6  | 29.6  | 29.6  |
| Curraghmulkin     | -  | -     | -     | -     | 103.6 | 103.6 | 103.6 | 103.6 | 103.6 | 103.6 |
| Drumnakelly       | -  | -     | -     | 2.6   | 2.6   | 2.6   | 2.6   | 2.6   | 2.6   | 2.6   |
| Dungannon         | 17.5                                     | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  |
| Eden              | 2.5                                      | 2.5   | 2.5   | 2.5   | 2.5   | 2.5   | 2.5   | 2.5   | 2.5   | 2.5   |
| Enniskillen       | 16.9                                     | 31.9  | 31.9  | 34.4  | 34.4  | 34.4  | 34.4  | 34.4  | 34.4  | 34.4  |
| Garvagh           | -  | -     | -     | -     | 50.1  | 50.1  | 50.1  | 50.1  | 50.1  | 50.1  |
| Gort              | -  | -     | 87.7  | 100.2 | 100.2 | 100.2 | 100.2 | 100.2 | 100.2 | 100.2 |
| Kells             | -  | -     | -     | -     | -     | 85.1  | 85.1  | 85.1  | 85.1  | 85.1  |
| Killymallaght     | 20.7                                     | 38.7  | 38.7  | 38.7  | 38.7  | 38.7  | 38.7  | 38.7  | 38.7  | 38.7  |
| Larne             | 15                                       | 15    | 15    | 15    | 15    | 15    | 15    | 15    | 15    | 15    |
| Limavady          | 37.7                                     | 37.7  | 37.7  | 37.7  | 37.7  | 37.7  | 37.7  | 37.7  | 37.7  | 37.7  |
| Lisaghmore        | 17.5                                     | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  |
| Lisburn           | -  | 25.2  | 25.2  | 25.2  | 25.2  | 25.2  | 25.2  | 25.2  | 25.2  | 25.2  |
| Loguestown        | 12                                       | 12    | 12    | 12    | 12    | 12    | 12    | 12    | 12    | 12    |
| Magherakeel       | 88.6                                     | 123.1 | 123.1 | 123.1 | 123.1 | 123.1 | 123.1 | 123.1 | 123.1 | 123.1 |
| Newry             | -  | 3.8   | 3.8   | 15.3  | 15.3  | 15.3  | 15.3  | 15.3  | 15.3  | 15.3  |
| Newtownstewart    | -  | -     | -     | -     | -     | 126.2 | 126.2 | 126.2 | 126.2 | 126.2 |
| Omagh             | 125.7                                    | 125.7 | 125.7 | 95.7  | 95.7  | 95.7  | 95.7  | 95.7  | 95.7  | 95.7  |
| Rasharkin         | -  | 74.7  | 74.7  | 74.7  | 74.7  | 74.7  | 74.7  | 74.7  | 74.7  | 74.7  |
| Rosebank          | -  | 17.6  | 17.6  | 17.6  | 17.6  | 17.6  | 17.6  | 17.6  | 17.6  | 17.6  |
| Slieve Kirk       | 74                                       | 82.8  | 82.8  | 82.8  | 82.8  | 82.8  | 82.8  | 82.8  | 82.8  | 82.8  |
| Springtown        | -  | -     | -     | -     | 45    | 45    | 45    | 45    | 45    | 45    |
| Strabane          | 27.4                                     | 27.4  | 27.4  | 27.4  | 27.4  | 27.4  | 27.4  | 27.4  | 27.4  | 27.4  |
| Tidal             | -  | -     | -     | 10    | 10    | 210   | 210   | 210   | 210   | 210   |
| Tremoge           | -  | 82.5  | 84.8  | 84.8  | 84.8  | 84.8  | 84.8  | 84.8  | 84.8  | 84.8  |
| Total             | 699                                      | 986   | 1177  | 1186  | 1384  | 1888  | 1888  | 1888  | 1888  | 1888  |

Figure 4-4 uses information from the list of renewable generation applications in the planning service<sup>12</sup>. The figure demonstrates where renewable generation may be located in 2020.

It is clear from Figure 4-4 that the majority of renewable connections are in the northern and western regions of the province. This coincides with some of the weakest areas of the transmission system. It can be concluded that for Northern Ireland to meet renewable targets, improvements will have to be made to the transmission network in these areas.

The Renewable Integration Development Project (RIDP)<sup>13</sup> investigated the optimum reinforcement of the transmission grid in the north and the north west of the island. RIDP identified a preferred scheme based on a set of underpinning assumptions.

As these assumptions have since changed, in the respect of the extent of off-shore generation as well renewables peak operating levels, the preferred scheme is now under review.

These reinforcements are advised to cater for expected power output from renewable energy sources. For more detailed information on network reinforcements in these areas and throughout Northern Ireland please see Chapter 2.

---

<sup>12</sup> In Northern Ireland the Utility Regulator determination (DET-572) occurred just after the TYTFS freeze date. This has led to an unexpected large scale increase in connection applications in Northern Ireland (approximately 900MW). This has resulted in NIE networks and SONI considering alternative connection process options. To this effect SONI and NIE Networks will shortly issue a public consultation.

<sup>13</sup>[http://www.uregni.gov.uk/uploads/publications/Renewable\\_integration\\_status\\_report\\_June13\\_2.pdf](http://www.uregni.gov.uk/uploads/publications/Renewable_integration_status_report_June13_2.pdf)






Figure 4-4 Northern Ireland Renewable Generation in 2020

### Offshore Renewable Generation

For the purpose of these studies we assume that by 2024 there will not be any offshore wind connected. A 600MW offshore wind farm was to be installed off the County Down coast, but has recently been withdrawn. Development rights are still in place for tidal sites in Northern Ireland’s coastal waters.

The development rights were also announced for two 100MW tidal developments along the north coast. The developers who were granted these developments rights have been in contact with SONI regarding the connection of off-shore renewable generation. SONI’s assumptions regarding the 2020 levels and location of offshore generation are based on best information available at the data freeze.

### Solar Generation

At the data freeze date there was approximately 45MW of solar generation planned to be connected to the distribution system in Northern Ireland (see Figure 4.3 and Appendix D, Table D-4). This generation has formed part of the 2015 TYTFS assumptions and has been modelled in our study files accordingly.

However, since the data freeze date there has been a significant increase in enquiries for connection of solar generation. The level of solar generation enquiries in the SONI/NIE connection process amounts to approximately 300MW. The majority of enquiries have expressed interest in locating solar projects in the east of Northern Ireland.

It should be noted that solar generation beyond the 45MW described above has not been included in the study results presented in this TYTFS. As these additional solar generation projects progress we will continue to monitor and revise assumptions presented in future versions of the TYTFS as necessary.

### Compressed Air Energy Storage

Gaelectric is proposing a Compressed Air Energy Storage (CAES) Plant in the Larne area, to be connected to the transmission system. SONI has an accepted an offer with Gaelectric Energy Storage for this project for the capacities noted in Table 4-7. Gaelectric is however designing the facility to realise 330MW of generation and 250MW of compression. This energy storage facility could provide ancillary services and balancing facilities for renewable generation.

A CAES plant uses a large compressor to store excess energy off the grid. It does this by converting the excess electric energy into compressed air which is stored in an underground geological cavern. This is then released through an electric generator for later use. This technology can be applied to store surplus renewable energy, whilst also enabling variability balancing on the transmission system.

CAES has gained Project of Common Interest (PCI) status. In the last 12 months it has seen considerable progress. It has been awarded Connecting Europe Facility (CEF) grant funding of up to €6.45 million to complete, among other things, the environmental impact assessment (EIA) and submission of planning application at the end of 2015.

Table 4-7 Minimum and Maximum Generation/Storage of CAES Units

| Unit        | Minimum (MW) | Maximum (MW) |
|-------------|--------------|--------------|
| Generator 1 | 13.4         | 134          |
| Generator 2 | 13.4         | 134          |
| Pumping 1   | 68           | 105          |
| Pumping 2   | 68           | 105          |

#### 4.2.5 Northern Ireland Generation Mix

The chart in Figure 4-5 shows all existing and planned generation over the ten year period covered by this TYTFS. Superimposed onto the chart is the median demand forecast from the All-Island Generation Capacity Statement 2015-2024. Figure 4-5 illustrates a surplus of generation in relation to the demand from a deterministic point of view. However, factors such as economic dispatch, wind variability, reserve requirements and actual HVDC interconnector flows are not taken into account. The chart also shows the relatively large increase in wind generation expected over the next ten years.





Figure 4-5 Northern Ireland Generation Mix



## 5 TRANSMISSION SYSTEM PERFORMANCE

- 5.1 Forecast Power Flows
- 5.2 Compliance with Planning Standards
- 5.3 Short Circuit Current Levels



The current. The future.

## 5 Transmission System Performance

This chapter describes the future performance of the transmission system in terms of compliance with planning standards. Performance levels are assessed using forecast power flows and short circuit current levels.

Analysis of short circuit current levels in the TYTFS 2015 is based on updated data. Updated data includes any changes to the existing and planned transmission system, demand projections and generation connections. Analysis is based on a data freeze date of July 2015 for both Ireland and Northern Ireland.

### 5.1 Forecast Power Flows

The power flow at any given time depends on transmission system configuration, demand levels and the output from each generator. There are many possible combinations of generator outputs (or dispatches) that can meet the transmission system demand requirements. At any given time there are also many possible demand scenarios.

Renewable generation connected to the transmission and distribution systems in Ireland and Northern Ireland has the effect of altering power flows. The increase in renewable generation is one of the main factors behind recent changes to power flows on the transmission system. Projected levels of renewable generation connections are detailed in Tables D-2 and D-3 in Appendix D.

In examining transmission system performance a range of economic generation dispatches are considered. Generation dispatches used in studies were prepared on an all-island basis.

Power flows across the existing 275kV and planned 400kV interconnectors where modelled to operate within transfer limits. Dispatches also considered imports and exports of power across the existing Moyle and East-West interconnectors.

Transmission system power flows are shown on the schematic diagrams found in Appendix H. The power flow diagrams display the flow of real and reactive power around the transmission system under normal conditions.

As shown in Appendix H, the amount of renewable generation increases over the ten year period. As renewable generation increases, power flows on circuits from the North West of Northern Ireland to the East of Northern Ireland are also increased.

This is due to power generated in the North West transferring to larger demand levels in the East. These increased power flows are more significant at times of minimum demand and high renewable generation output.

Another effect of increased renewable generation levels is the amount of reactive power support required on the Northern Ireland transmission system. Due to high levels of renewable generation, reactive power support is needed to keep voltages within transmission system planning standards.

In the 2015 winter case, 260Mvars of reactive power support was in service in Northern Ireland. In the winter 2024 case this figure increases to 380Mvars. This reactive power support is in addition to the reactive power assumed to be supplied by Northern Ireland generation.

## 5.2 Compliance with Planning Standards

The need for transmission system development is determined by assessing long-term future transmission system performance against the respective technical standards.

### Ireland

We issue the TDP annually, which is available at [www.eirgridgroup.com](http://www.eirgridgroup.com). The TDP indicates the areas of the transmission system likely to be outside thermal limits<sup>1</sup> and voltage standards. This information is presented over a ten year period and is based on assumed transmission system reinforcements, demand and generation scenarios.

We have plans in place to address many of these problems. We are also actively considering options<sup>2</sup> for addressing other future transmission system problems.

The TDP details transmission system development projects that have received capital approval. In addition to this further transmission system developments that may arise in the period of the plan are also discussed.

---

<sup>1</sup> A circuit's thermal limit influences its physical capability to carry electrical current.

<sup>2</sup> Eirgrid recently published a discussion paper on Ireland's grid development strategy. This review is available at [www.eirgridgroup.com](http://www.eirgridgroup.com). The review outlines our proposed strategy for the long-term development of the network.

The 5,500MW (see Chapter 4) of generation that received offers in Gate 3 may significantly impact on transmission system performance. This may potentially put some areas, in addition to those identified in the TDP, outside planning standards.

Similarly, other developments such as the connection of a new large generator or demand may put areas of the transmission system outside standards. In such cases, further investment may be required.

### Northern Ireland

The TYTFS 2015 is based on the transmission investment plan. Planned developments include load related and asset replacement projects. These projects mainly impact on the rating of switchgear<sup>3</sup> and circuits.

Details of these projects can be found in Chapter 2. Capital projects are mainly driven by increases in Northern Ireland demand and renewable generation connection levels.

The adequacy of the transmission system including planned projects is compared to transmission and distribution security and planning standards. These standards define the thermal limits and voltage stability under certain contingencies.

### 5.3 Short Circuit Current Levels<sup>4</sup>

Short circuit<sup>5</sup> currents may occur during a fault condition on the transmission system. Depending on the type of fault, these short circuit currents can be very high. All transmission system equipment must be capable of carrying these very high currents that may occur in the event of a fault.

Protection devices, in particular, circuit breakers must be capable of closing onto high currents created by a fault on the transmission system. They must also be capable interrupting high currents to isolate a fault.

Their correct operation is essential for minimising risk to personnel and preventing damage to transmission equipment. They are also necessary for maintaining system stability, security and quality of supply.

---

<sup>3</sup> Devices used to control, protect and isolate electrical equipment.

<sup>4</sup> A decision was made to use the term “Short Circuit Currents”. This is a change in terminology rather than a change in information when “Fault Levels” was previously used.

<sup>5</sup> A short circuit is an electrical circuit that allows a current to travel along an unintended path, often where essentially no (or a very low) electrical impedance is encountered. The currents generated by the short circuit can be extremely high and may cause harm to personnel or damage equipment.

The short circuit current level is a factor to be considered as the transmission system is developed. It must also be considered in the connection of new generation or demand.

The EirGrid Grid Code specifies short circuit levels at the transmission connection point. These values are shown in Table 5-7. Users connecting to the transmission system are required to design their plant and apparatus to the levels in Table 5-7. This also includes the design of equipment at lower voltage levels to withstand short circuit current levels.

Table 5-7 also applies to new users connecting to the Northern Ireland transmission system. They are recommended to, as a minimum, design their plant and apparatus to withstand short circuit current levels set out in Table 5-7. Design of a user's plant is also subject to detailed fault level assessment.

Changes to the transmission system or the addition of generation can increase the short circuit current levels at adjacent stations. Forecasted increases in short circuit current levels indicate circuit breakers or other equipment potentially exceeding their rating. Should this occur it may be necessary to replace circuit breakers or other equipment with higher rated plant. Risk mitigation measures may also be implemented to reduce short circuit current levels.

Table 5-7 Standard Equipment Rating and Maximum Design Short Circuit Currents

| Voltage Level | Standard Equipment Short Circuit Rating |                   |                  |
|---------------|---|-------------------|------------------|
|               | Ireland                                 |                   | Northern Ireland |
| 400kV         | 50kA                                    |                   | 50kA             |
| 275kV         | n/a                                     |                   | 40kA             |
| 220kV         | 40kA                                    |                   | n/a              |
| 110kV         | Countrywide                             | 25kA <sup>6</sup> | 40kA             |
|               | Designated sites                        | 31.5kA            |                  |

<sup>6</sup> New equipment installed at 110kV level must have a short circuit rating of 31.5kA (outside Dublin) or 40kA (Dublin).



Short circuit current levels were calculated for all transmission system nodes in accordance with engineering recommendation G74. Engineering recommendation G74 is based on international standards.

The analysis was carried out for single-phase and three-phase faults for winter peak and summer valley. This was completed for the years 2015, 2018 and 2021. A description of the calculation methods used and the results are given in Appendix E. Appendix E also provides as an explanation of terms used.

Winter peak analysis was carried out to represent the most onerous transmission system conditions. Winter peak represents the case where maximum short circuit currents on the transmission system are most likely to occur. Conversely, analysis of summer valley was carried out as results should indicate minimum short circuit currents based on intact network conditions.

In reality minimum short circuit current at each bus could be lower depending on actual generation dispatch and transmission system conditions. Those who require the expected minimum short circuit current level at a particular bus are advised to contact us directly.

The economic generation dispatches for the winter peak and summer valley studies are presented in Appendix D.

During winter peak analysis, generators that are not dispatched are switched on in the study and dispatched at 0MW. This measure ensures a high fault current infeed to faults from all generator sources in the studies. This means that the most onerous, but credible, conditions are used for the calculation of short circuit current levels at each bus. During summer valley analysis, generators that were not dispatched were not connected to the system.

The studies assume that the transmission system is in the normal intact condition (as indicated in the power flow diagrams). This means that all circuits connected to a bus contribute to the fault.

These results correspond to total busbar short circuit current levels. Short circuit current that could flow through each individual circuit breaker may be less than the total busbar short circuit current. This is however, dependent on network conditions.

### Assessment of Short Circuit Levels: Ireland

The transmission system in Ireland is designed and operated to maintain short circuit current levels below the standard equipment ratings. These are listed at each voltage level in Table 5-7.

In planning the system a 10% margin is applied. This is done so that 220kV short circuit currents, for example, will be kept below 36kA.

It should be noted that most 110kV stations are designated as 25kA. The EirGrid Grid Code, however, stipulates that certain 110kV stations may be designated as 31.5kA. This may happen for a new station which is designated as 31.5kA from the start. It may also occur when an existing 25kA station is changed to 31.5kA.

When a station changes from 25kA to 31.5kA, the equipment at that station may need to be modified. Station equipment at lower voltages will also need to be replaced in order to comply with this design rating.

The stations currently designated with a 31.5kA 110kV equipment rating are; Barnahely, Cloghran, College Park, Corduff, Finglas, Kilbarry, Knockraha, Louth, Marina, Raffeen, Tarbert and Trabeg. EirGrid will annually publish an updated list of designated stations.

In Appendix E, the results for Ireland include X/R ratios, transient AC ( $I_k'$ ) and subtransient AC ( $I_k''$ ) currents. In summary, these provide an indication of the strength of the transmission system and are defined in Appendix E.

### Assessment of Short Circuit Levels: Northern Ireland

The Northern Ireland transmission system is designed and operated to maintain short circuit current levels below the equipment ratings. These ratings are listed in Appendix E's tables. Individual ratings are applied to substations based on the equipment at the substation.

The Northern Ireland results in Appendix E include transmission substation ratings for;

- Initial Short Circuit Current ( $I''$ ),
- Peak Make Current ( $i_p$ ),
- RMS Break Current ( $I_B$ ) and,
- Asymmetrical Break Current (asym B).

I'' and ip are used to assess the rating of electrical equipment required to close onto short circuit currents. IB and asyMB assess the capability of the electrical equipment to open and break short circuit current.

### 5.3.1 Short Circuit Current Results

Short circuit results show that a number of Northern Ireland transmission nodes are experiencing increased short circuit current levels. If we do not manage these issues, these nodes may be in excess of 90% of their current rated capability.

In Ireland short circuit currents are relatively low. There are a number of stations in Dublin and Cork where short circuit current levels are above 80% of standard ratings.

We will continue to monitor short circuit current levels at all stations to ensure that they remain within safety standards.

Figure 5-1 indicates the locations where short circuit current levels are high, in 2021. Values shown represent a percentage of standard equipment rating for the transmission system of Ireland. Actual equipment ratings are shown in Figure 5-1 for the Northern Ireland transmission system.

Three percentage ranges are represented by different colours in Figure 5-1. Yellow dots represent substations where short circuit currents may be between 80% and 90% of the ratings. Orange dots represent substations where short circuit currents may exceed 90% of the ratings. Red dots indicate substations where the rating has been exceeded.

Several nodes have been found to experience short circuit current levels that exceed 100% of their current rated capability. Analysis indicates that the nodes at Ballylumford, Castlereagh, Coolkeeragh and Kells in Northern Ireland will exceed 100% of their current rated capability.

Table 5-2 provides a list of transmission nodes where the short circuit current level is approaching or would exceed their rating. This is presented for the study years of 2015, 2018 and 2021.

We have put in place plans to uprate equipment or mitigate risks. These plans are discussed below and are based on the best information available at the time of publishing.

In the interim risk mitigation measures such as system reconfiguration have been employed to maintain short circuit current levels at safe levels.




Figure 5-6 Short Circuit Current Levels for Winter Peak 2021

Table 5-8: Nodes Approaching or Exceeding Rating

| % Rating | 2015                       | 2018          | 2021          |
|----------|----------------------------|---------------|---------------|
| >100%    | BPS 110kV                  | BPS 110kV     | BPS 110kV     |
|          | CDU 110kV <sup>7</sup>     | CAS 110kV     | CPS 110kV     |
|          | KRA 110kV <sup>7</sup>     | CSH 110kV     | CAS 110kV     |
|          |                            | CDU 110kV     | KEL 110kV     |
|          |                            | KRA 110kV     | BLP 110kV     |
|          |                            |               | CSH 110kV     |
|          |                            |               | CDU 110kV     |
|          |                            |               | KBY 110kV     |
|          |                            |               | KPG 110kV     |
|          |                            |               | KRA 110kV     |
| >90%     | BPS 275kV                  | CPS 110kV     | BPS 275kV     |
|          | CAS 110kV                  | HAN 110kV     | BVG 110kV     |
|          | CPS 110kV                  | KNO 110kV     | HAN 110kV     |
|          | DUN 110kV                  | KEL 110kV     | KNO 110kV     |
|          | HAN 110kV                  | BPL 110kV     | TAN 110kV     |
|          | KEL 110kV                  | CLG 110kV     | BVG 110kV     |
|          | KNO 110kV                  | COL (I) 110kV | CLG 110kV     |
|          | TAN 110kV                  | KBY 110kV     | COL (I) 110kV |
|          | CLG 110kV <sup>8</sup>     | KLN 110kV     | KBY 110kV     |
|          | COL (I) 110kV <sup>7</sup> | KPG 110kV     | KLN 110kV     |
|          | KBY 110kV <sup>7</sup>     | MR 110kV      | KRA 110kV     |
|          | MR 110kV <sup>7</sup>      | TBG 110kV     | MR 110kV      |
|          | TBG 110kV <sup>7</sup>     |               | TBG 110kV     |

<sup>7</sup> Knockraha 220/110kV station is currently operated with a third transformer in hot-standby to mitigate short circuit current levels exceeding the 90% threshold.

<sup>8</sup> Short circuit current levels at Trabeg, Marina, Cloghran, College Park and Kilbarry 110kV stations exceed 90% of the standard equipment rating. The standard rating for 110kV equipment is 25kA, as per the EirGrid Grid Code. These 110kV stations are designated stations. A designated station, as per the EirGrid Grid Code, is a station with 110kV equipment designed to 31.5kA. Therefore, in actuality there is not an issue at these 110kV station, as the equipment is rated to 31.5kA.

### Stations where the rating has been exceeded

#### Ballylumford 110kV

Short circuit current levels at the Ballylumford 110kV node for both three-phase and single-phase faults exceed the substation ratings. This occurs under maximum generation conditions when both of the 275/110kV interbus transformers (IBTXs) are in service.

The substation is programmed to be replaced with a substation incorporating a new 110kV GIS switchboard. This work is planned to be completed by 2019. In the interim, we manage this risk by operating with one IBTX out of service. This reduces the short circuit current level below the equipment rating.

There will be an overall reduction in the short circuit current level at Ballylumford with the future decommissioning of plant. Ballylumford ST6 is expected to decommission after 2015, while ST4 and ST5 will be decommissioned after 2018. However, even with this reduction Ballylumford substation ratings are still exceeded in all years of study.

#### Castlereagh 110kV

The rating of Castlereagh 110kV substation is limited by the disconnectors which have a certified rating of 26.2kA. With all available generation in service, the single phase short circuit current level exceeds the rating of the substation equipment. The Castlereagh 110kV substation is planned to be refurbished with switchgear rated at 40kA. This will alleviate this risk in the long term.

#### Coolkeeragh 110kV

Single-phase short circuit current levels at Coolkeeragh 110kV substation exceed 100% of the substation assigned rating in 2020. This is a result of increased renewable generation levels. It is important that NIE put plans in place to address this issue at Coolkeeragh before 2020.

#### Kells 110kV

Single-phase short circuit current levels at Kells 110kV substation exceed 100% of the substation assigned rating in 2020. This is a result of increased renewable generation levels. The Kells 110kV substation is planned to be refurbished with switchgear rated at 40kA. This will alleviate this risk in the long term.

### Corduff 110kV

Short circuit current levels at Corduff 110kV station exceed 100% of the standard equipment rating for 110kV equipment. The standard rating for 110kV equipment is 25kA, as per the EirGrid Grid Code.

Corduff 110kV station is a designated station. A designated station, as per the EirGrid Grid Code, is a station with 110kV equipment designed to 31.5kA. Therefore, in actuality there is not an issue at Corduff 110kV station, as equipment is rated to 31.5kA.

### Knockraha 110kV

Short circuit current levels at Knockraha 110kV station exceed 100% of the standard equipment rating for 110kV equipment. The standard rating for 110kV equipment is 25kA, as per the EirGrid Grid Code.

Knockraha 110kV station is a designated station. A designated station, as per the EirGrid Grid Code, is a station with 110kV equipment designed to 31.5kA. Therefore, in actuality there is not an issue at Knockraha 110kV station, as equipment is rated to 31.5kA.

### Summer Minimum Results

As expected summer minimum short circuit current level results shown in Appendix E show that no station ratings are exceeded.

The Moyle Interconnector has a minimum operating requirement of 1,500 MVA. This is equivalent to a short circuit current level of 3.15kA. Below this short circuit current level the high voltage direct current (HVDC) interconnector fails to commute<sup>9</sup>. However, as shown in Appendix E, this is not an issue over the period covered by this TYTFS.


---

<sup>9</sup> Commutation is the process of reversing the direction of electric current. It is commonly used when turning alternating current to a direct current.



## 6 OVERVIEW OF TRANSMISSION SYSTEM CAPABILITY ANALYSES

- 6.1 All-Island Demand Opportunity Analysis
- 6.2 All-Island Generator Opportunity Analysis



The current. The future.



## 6 Overview of Transmission System Capability Analyses

This chapter describes analyses carried out to determine the capability of the transmission system to accommodate additional demand and generation. This additional demand and generation capability is tested at various parts of the transmission system. The results of these analyses, together with information in other chapters, provide the basis for the statements of opportunity. These statements are found in Chapter 7 and Chapter 8.

### 6.1 All-Island Demand Opportunity Analysis

This section describes the demand opportunity analysis carried out for the Ireland and Northern Ireland power system. This analysis is used to determine the capability of the transmission system to accommodate additional demand connections in certain areas. The results of this analysis, together with information in other chapters, provide the basis for the statements of opportunity. These statements are given in Chapter 8.

In previous versions of the TYTFS, Northern Ireland demand opportunities analysis was based on an assessment of forecast loading at bulk supply points (110/33kV) under single outage conditions. This analysis gave little indication of the Northern Ireland transmission system network capability to accept large demand customers.

In this TYTFS Northern Ireland has now been included in an all-island demand opportunity analysis. Results from the all-island analysis provide an indication of backbone transmission network capability in Northern Ireland.

The all-island demand opportunity analysis was carried out for one specific year:

**2020:** This year gives developers a useful indication as to the demand opportunities that exist in the medium-term on the transmission system.

Studies were carried out for the summer period and the winter period of 2020/2021.

The locations analysed for new demand have been carefully chosen based on feedback from industry sources. The chosen stations have been tailored to align with potential areas that are of interest to customers seeking connection to the transmission system.

It should be noted that the results of these studies are dependent on the assumptions made about generation and demand. The results are also dependent on the completion dates of transmission system development projects. Factors that may influence the results are discussed in Section 6.2.4.

### 6.1.1 Approach for Calculation of Demand Opportunity

The transmission system is planned to meet forecast demand levels at all stations on the island of Ireland. The demand forecast for each 110kV station is a proportion of the overall system demand forecast. This forecast is based on historical demand distributions. Future demand customers that have signed connection agreements are also included in station demand forecasts as presented in Chapter 3.

Additional demand connections above the forecast levels are not explicitly catered for in transmission system plans. However, there may be capacity for additional demand inherent in the transmission system at certain locations.

Alternatively, the addition of transmission system infrastructure generally provides a step increase in transmission system capacity. This addition may permit demand connections higher than forecast levels, as illustrated in Figure 6-1.




Figure 6-1 Illustration of Typical Step Change in Network Capacity

The blue line represents the required MW capacity at a particular point in the transmission system. The red line represents the installed transmission system capacity. Changes in installed capacity generally come in discrete steps following completion of a network development project, thus providing spare capacity for a period of time.

Figure 6-2 illustrates the demand profile for a representative station. The blue line represents the demand forecast at the station. The green bars represent a new step increase in demand. The analysis carried out for this TYTFS examines the transmission system's capability to accept such increased demand above forecast levels.

The capability is examined at selected 110, 220 and 275kV stations. These selected stations feed principal towns and demand centres distributed throughout the country. The selected 110, 220 and 275kV stations are shown in Figure 8-1 in Chapter 8. The results of this analysis are useful in identifying opportunities for the connection of new or increased demand.

The opportunity value calculated is a measure of the transfer capability remaining in the physical transmission system. It provides an indication of the flexibility of the transmission system to accommodate future demand increases before additional reinforcements are required.

The transfer analysis is intended as a pre-feasibility indication of opportunity for increased demands. The method for determining capacity closely aligns with pre-feasibility study techniques.

Transmission Planning Criteria (TPC)<sup>1</sup> standards have been applied for analyses of demand opportunities in Ireland. Unlike generators, demand stations are typically not dispatchable. It is therefore necessary to assess the transmission system performance against standards for maintenance-trip contingencies (N-1-1) in the analysis of increased demands in Ireland.

In Northern Ireland, Transmission System Security and Planning Standards (TSSPS)<sup>2</sup> have been applied for analyses of demand opportunities.

The transmission system was assessed for loss of any single item of transmission plant (N-1) and loss of a double circuit (N-dc). During the

---

<sup>1</sup> <http://www.eirgrid.com/media/Transmission%20Planning%20Criteria.pdf>

<sup>2</sup> <http://www.soni.ltd.uk/media/documents/Projects/Publications/Northern%20Ireland%20TSSPS%20-%20September%202015.pdf>

summer season the Northern Ireland transmission system was also assessed for a maintenance-trip (N-1-1) contingency.

It should be noted that as the North-West of Northern Ireland is supplied by a single double circuit 275kV, it requires specific assessment in line with the TSSPS.

Voltage analysis was performed as part of the demand capacity studies in both Ireland and Northern Ireland. This is because the addition of demand is likely to impact on local voltages levels.




Figure 6-2 Demand Profile at Typical Station

### 6.1.2 Method for Calculating Limits for Increased Demand Connections

An AC load flow linear algorithm was used to screen for critical contingencies and thermal overloads or voltage limitations.

#### *What is a load flow?*

A load flow is a numerical analysis of the flow of electric power in an interconnected system. The load flow analyses a power system model to determine steady-state (normal operation) values such as voltages, voltage angles, real power and reactive power.

#### *What is a linear algorithm?*

A linear algorithm uses an interactive approach to find the solution to a numerical problem, such as determining voltages on the power system. A linear algorithm is simple and robust method of finding a solution.

Power transfers were considered using dispatch scenarios typically experienced on the transmission system. While these dispatches are typical, the particular dispatches were aimed to stress the network differently in terms of power transfers.

By analysing different power transfer stresses on the transmission system, we can ensure that demand opportunities reported in our analysis will not breach our TPC standards in Ireland and TSSPS in Northern Ireland.

The conventional units selected for each dispatch scenario aligned with market projections for the study year 2020.

#### Modelling Details

Generators were modelled with their maximum output equivalent to their Maximum Export Capacity (MEC). As renewable generation is classified as a variable energy source, it cannot be relied upon to serve demand. As such, local wind generation was switched out in the vicinity of the test station.

This is for the purposes of assessing new demand that can be accommodated on the network. These dispatches, with wind generation local to the test station switched out, were used for single contingency (N-1) studies. For N-1-1 contingencies, some centrally-dispatchable generation local to the test station was maximised to its MEC value. This was implemented to create a more favourable dispatch for the maintenance case.

To calculate the opportunity, demand at 0.90 power factor was added at the test station in increasing amounts. This was balanced by an equivalent increase in generation output from existing generation according to the merit order. This is illustrated in Figure 6-3.

The limit for increased transfers from the generators to the test station was established. This was achieved by checking the post-contingency performance of the transmission system against thermal and voltage standards. This process was done for each dispatch scenario studied.

Problems on the transmission system were not considered limiting unless they were sensitive to the incremental transfers under examination.

The information from this analysis provides a single capability figure at each station by combining the results from each dispatch scenario to each of the selected stations. This provides an indication of the capabilities for increased demand at each station.

When considering single contingencies (N-1) on an intact transmission system the minimum capacity from the dispatches used was chosen. However, when considering maintenance-trip contingencies (N-1-1) in Ireland, the greater of the capacities from each dispatch was chosen.

This was based on the assumption that less onerous generation dispatches could be scheduled to accommodate maintenance outages. The results are presented in Section 8.2 of Chapter 8.




Figure 6-3 Illustration of Incremental Transfer Capability Study Method for Demand

### 6.1.3 Calculation of Capability for Demand at Any Station outside Dublin

This section provides a general example of the analysis of the capability of any of station studied in chapter 8. The station was tested to accommodate increased demand in summer peak 2020.

The assessment was carried out by simulating the transmission system for summer peak 2020. The relevant demand forecasts and generator dispatches were used.

Studies are carried out according to the dispatch scenario assumed. The extra demand in each study is met by increasing generation according to the merit order. For each study in turn, the AC loadflow linear technique was used to add a test demand. For example, 100MW to a station.

The analysis tested an exhaustive range of N-1 contingencies (individual circuit/transformer or generator outages) to identify any resultant thermal overloads or voltage violations and to thus identify a capacity limit. Some contingencies cause violations of thermal overload or voltage standards at the maximum capacity.

In these cases, the analysis reverted to 0MW and performed the test in increasing steps. Each step was 10MW in size. The test ran in increasing steps until a violation of thermal overload or voltage standards occurred. The preceding step value is then the calculated capacity value.

In assessing opportunities for new demand, the TYTFS considers the capability of the transmission system only. The capability of the distribution system of island of Ireland is not addressed. The implications for generation adequacy of demand growth above the median forecast levels are dealt with separately in the *All-Island Generation Capacity Statement 2015-2024 (GCS)*.

#### 6.1.4 Calculation of Capability for Demand in Dublin

The Dublin region is the largest demand centre on the all -island transmission network. It has and remains the focus of continual interest for the connection of large new demand.

There has been a significant upsurge in the number of enquiries and applications for new demand connections in the Dublin region and its environs since 2014. Many of these requests are for data centres which present relatively flat load profiles that would impact on both the minimum and maximum demand requirements in the region. If all of these enquiries were to materialise and connect, the maximum demand of Dublin could exceed 3000MW (see chapter 3 Demand).

The Dublin 220kV meshed transmission network is operated by EirGrid the transmission system operator (TSO). The radial 110kV circuits are operated by ESB Networks the distribution system operator (DSO). System development and operation requires both system operators to work closely to optimise power flows and facilitate new connections.

Due to the volume of enquiries and applications received and their potential interactions, EirGrid are providing additional information on demand opportunities and, in particular, in the Dublin area for this year's statement.



The Dublin region has been divided into three geographic zones (see fig 8-3 in Chapter 8), namely the North, West and South clusters, in order to give more useful insights into the connection capacity that is available.

This takes into account the three main corridors servicing the main bulk supply points, which act as the transmission to distribution interfaces in the region.

The methodology used to consider demand opportunities in the Dublin region is based on the existing transmission system. It also includes criteria such as how each zone is expected to develop and the associated lead times for project delivery. The Dublin methodology is applied in chapter 8 section 8.1.1.

### 6.1.5 Factors Impacting On Results

The results of the analyses described in this section are based on a set of assumptions. These assumptions are associated with future demand growth, generation connections and transmission system developments.

The key forecast factors on which the results depend are dynamic. Therefore, the reality that emerges will not exactly match the forecasts. Consequently, the results, while reasonably indicative, should not be interpreted as definitive projections.

The factors likely to have an impact on the outcomes include:

- the signing of a connection agreement by a new generator
- delays in connection of committed new generation stations
- closure/divestiture of existing generation stations
- changes in the economy which give rise to consequential changes in the overall demand for electricity
- changes in demand in a particular region or area, arising from new industry developments or closures
- delays in the provision of transmission system reinforcements
- selection and construction of new transmission system reinforcement developments which may significantly increase transmission system capacity

## 6.2 All-Island Generator Opportunity Analysis

### 6.2.1 Change in Approach

In previous years the TYTFS carried out detailed load flow analysis to determine the capability of the transmission system of Ireland and Northern Ireland to accommodate additional generation.

Generation was increased steadily at transmission nodes and the performance of the transmission system was tested against thermal and voltage standards. In doing so the capability of the transmission network to accept additional generation was determined for a number of power flow scenarios.

In the preparation of this statement there have been a number of developments that mean that this type of assessment at this point in time would not provide useful information to transmission system users.

- Since the 2013 TYTFS analysis was completed it is unlikely that many significant new opportunities have developed in the intervening period.
- In Ireland, we published our Grid Strategy “Your Grid, Your Views, Your Tomorrow.” a discussion paper on Ireland’s Grid Development Strategy for public consultation in March 2015. Since then the Grid West and Grid Link (Chapter 2) reports to the Independent Expert Panel (IEP) were published and are available on the EirGrid website. We are currently updating and finalising our Grid Development Strategy taking all comments and feedback received into consideration.
- The anticipated policy for energy in Ireland was not available at the data freeze date and could have an impact on the outcome of TYTFS capability analysis. Therefore, it was decided to wait until the outcome of the Department of Communications, Energy and Natural Resources white paper entitled “Ireland’s Transition to a Low Carbon Energy Future 2015-2030<sup>3</sup>” was known.

---

<sup>3</sup> As of the publication date of the 2015 TYTFS, the Department of Communications, Energy and Natural Resources white paper can be seen here: <http://www.dcenr.gov.ie/energy/SiteCollectionDocuments/Energy-Initiatives/Energy%20White%20Paper%20-%20Dec%202015.pdf>

- The CER had signalled their intention to review Grid Access Policy in Ireland and a proposed paper on the matter was anticipated at the TYTFY data freeze date. Again, it was decided to be prudent to await the outcome of this paper (CER/15/284) before assessing any new generation opportunities in Ireland.
- In Northern Ireland the Utility Regulator determination (DET-572) occurred just after the TYTFS freeze date. This unexpected large scale increase in connection applications in NI (approximately 900MW) has led to NIE networks and SONI to consider alternative connection process options. To this effect SONI and NIE Networks will shortly issue a public consultation.

When there is clarity around these points and the impact to the All Island transmission network is determined, there would be value in EirGrid and SONI carrying out detailed future load flow based generation capacity assessments.

### 6.2.2 All Island Generation Opportunity Analysis.

As an interim measure we have described changes that have occurred in terms of generation capacity connected and capacity that could connect depending on generation project completion rates.

We have also carried out a regional generation and demand balance analysis. Whilst we have not identified generation capacity at a transmission nodal level, it does give a view of those areas where there is a generation capacity surplus and those where there is a deficit.

It should be noted that each region in the generation and demand balance analysis is interconnected by a meshed, high capacity transmission network. This is essential to maintain security and reliability of supply for demand customers across the Island of Ireland.

The harmonised all-island transmission charge and losses arrangements in SEM have an objective amongst others to provide locational signals that reflect the costs they impose on the transmission system.

We have described the changing connection capacity locations, the impact on network power flows and the resulting effect on Transmission Use of System (TUoS) charges and Transmission Loss Adjustment Factors (TLAF). These TUoS and TLAF values have an impact on power generation costs.

It is intended that the results of this overall this methodology will help transmission network users make informed decisions when exploring potential transmission network connection locations.

This section and associated information is indicative only; EirGrid and SONI will provide guidance to transmission system users regarding the connection offer process and updates of any changes in policy that could influence generation connection opportunities on the all-island transmission grid.

We encourage generators wishing to connect to the transmission grid to consult with EirGrid and SONI on the proposed connection location as early as possible.



## 7 TRANSMISSION CAPABILITY FOR NEW GENERATION

- 7.1 Background
- 7.2 New Generation Capacity
- 7.3 Regional Generation and Demand Balance
- 7.4 Generation Locational Tariff Signals and Their Impact on Transmission Network Capacity
- 7.5 Looking to the Future



The current. The future.

## 7 Transmission System Capability for New Generation<sup>1</sup>

### 7.1 Background

In this chapter we provide information based on a 2020 forecast for the demand/generation capacity balance on a regional basis. From this assessment it is possible to identify regions where there is a generation capacity deficit and others where there is a surplus. This generation and demand balance has a resultant impact on power flow which in turn heavily influences transmission network capacity and investment.

As well as transmission network capacity there are many factors that influence the location of new generation, such as fuel sources for conventional generation or primary energy sources for renewable generation, as can be seen with the high level of wind generation found in the West of Ireland.

Significant changes to generation dispatch patterns and the geographical location of generation have had an impact on all-island transmission network power flows. As a consequence, generator transmission use of system<sup>2</sup> (GTUoS) tariff signals and transmission loss adjustment factors<sup>3</sup> (TLAF) have changed, resulting in an impact on the economics and location of power generation. Resulting regional changes in TUoS and TLAFs are also described to help network users make informed decisions when exploring potential transmission network connection locations.

As explained in Chapter 6, it is not practical to carry out a detailed generation capacity opportunity analysis in this statement. However, we do provide information on a regional basis to enable potential transmission system users to evaluate locations where there may be transmission network capacity available.

---

<sup>1</sup> This chapter of the TYTFS is published for EirGrid to meet its obligations in Section 38 of the 1999 Electricity Act and for SONI to meet condition 33 of the SONI TSO Licence. It is not intended to have any legal effect on the negotiation of contractual terms for transmission system connections. Before making any commercial decisions, developers should contact EirGrid for discussions on their proposed developments.

<sup>2</sup> Transmission use of system (TUOS) is the charge associated with transporting power in bulk across the transmission system (see <http://www.eirgridgroup.com/site-files/library/EirGrid/2015-2016-Statement-of-Charges-CER-Approved-final-290915.pdf> and <http://www.soni.ltd.uk/media/documents/Customers/TUOS/Final%20TUoS%20Statement%20of%20Charges%202015-16.pdf>)

<sup>3</sup> Transmission loss adjustment factors (TLAF) is a factor derived for the purpose of apportioning responsibility for transmission losses amongst users of the transmission system (see <http://www.eirgridgroup.com/site-files/library/EirGrid/2015-2016-Statement-of-Charges-CER-Approved-final-290915.pdf>)

The actual transmission network capacity can only be determined during the connection offer process. This process requires detailed network assessments to determine the optimal connection arrangement that complies with the Transmission Planning Criteria<sup>4</sup> in Ireland and the Transmission System Security and Planning Standards<sup>5</sup> in Northern Ireland.

## 7.2 New Generation Capacity

The level of generation expected to connect to the all-island transmission system is described in detail in Chapter 4 of this statement.

The largest recent generation capacity increase has been wind generation. At the freeze date of the 1 July 2015 there was circa. 2700MW connected to the all-island transmission system. Depending on project completion rates this all-island figure could increase to more than 7000MW of wind generation capacity by 2020 and beyond (see Chapter 4).

This generation is mainly connected in remote locations to the South-West, West and North-West of the island of Ireland. At times of high wind generation this can result in very high power flows on transmission circuits supplying power to the large demand centres on the East coast of Ireland and Northern Ireland.

In contrast there are a number of large conventional power stations due for retirement/divestiture or to have restricted output due to the EU Industrial Emissions Directive<sup>6</sup>.

## 7.3 Regional Generation and Demand Balance

Typically as generation builds up in a particular region, and is less than the local demand, it can normally be accommodated with little impact to the backbone transmission network.

As generation grows to a level that exceeds local demand, it is possible to accommodate this up to a point. This is largely dependent on the presence of adequate transmission network capacity to facilitate the flow of excess generated power to other regional demand centres.

---

<sup>4</sup> <http://www.eirgridgroup.com/site-files/library/EirGrid/Transmission%20Planning%20Criteria.pdf>

<sup>5</sup> <http://www.soni.ltd.uk/media/documents/Projects/Publications/Northern%20Ireland%20TSSPS%20-%20September%202015.pdf>

<sup>6</sup> [http://www.eirgridgroup.com/site-files/library/EirGrid/Eirgrid\\_Generation\\_Capacity\\_Statement\\_2015-2024.pdf](http://www.eirgridgroup.com/site-files/library/EirGrid/Eirgrid_Generation_Capacity_Statement_2015-2024.pdf)

A number of regions have reached the point where further generation cannot be accommodated due to limited transmission network capacity. A number of major projects identified in EirGrid's draft grid development strategy document published in 2015<sup>7</sup> or the current Transmission Development Plan (TDP)<sup>8</sup> address these future transmission network capacity needs, in Ireland.

It was felt that it would be beneficial to include a review of the regional demand and generation balance. This identifies areas where demand may potentially exceed generation, creating unfavourable transmission system scenarios whereby power has to flow over greater distances. This in turn can have significant impacts on generation economics and location as discussed in Section 7.4.

Figure 7-1 below shows the regional demand and generation balance across the island of Ireland for the year 2020.

2020 regional demand values are based on the summated demand forecasts of all transmission to distribution interface stations in that region (see appendix C). 2020 regional generation values are based on the summated existing and planned generation developments in each region (appendix D).

Generation figures shown in Figure 7-1 are based on installed MW capacity. For information purposes we have provided a breakdown of generation in both renewables and conventional generation categories.

It should be noted that wind generation which comprise the majority renewable generation figures shown in Figure 1 are based on installed MW capacity. As a capacity credit<sup>9</sup> exists for wind generation, the MW installed capacity of wind cannot be simply applied to generation adequacy studies as detailed in the 2015 Generation Capacity Statement (GCS)<sup>10</sup>.

In Figure 7-1 the generation capacity shown in each region represents the maximum possible capacity (installed MW) available.

---

<sup>7</sup> EirGrid Grid Development Strategy, Your Grid, Your Views, Your Tomorrow. A Discussion Paper on Ireland's draft grid development strategy: <http://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid-Draft-Grid-Development-Strategy.pdf>

<sup>8</sup> Transmission Development Plan 2015 available at <http://www.eirgridgroup.com>

<sup>9</sup> Contribution of wind generation to generation adequacy is referred to as the capacity credit of wind.

<sup>10</sup> [http://www.eirgridgroup.com/site-files/library/EirGrid/Eirgrid\\_Generation\\_Capacity\\_Statement\\_2015.-2024.pdf](http://www.eirgridgroup.com/site-files/library/EirGrid/Eirgrid_Generation_Capacity_Statement_2015.-2024.pdf)



In practice, regional generation levels will vary considerably depending on a number of conditions including;

- system demand levels,
- power system economics,
- wind power output,
- generation availability,
- interconnector imports and exports,
- and operating/market conditions.

Therefore the information provided here is intended to provide an indication of regional demand and generation balance only. Generation developers should consider the conditions above during project proposals.

Each region displayed in Figure 7-1 is interconnected by a meshed, high capacity transmission system. This is essential to maintain security and reliability of supply for demand customers across the Island of Ireland.

The main trend that emerges is there are high levels of generation, relative to local demand levels in Western regions and central Ireland, in comparison to regions along the Eastern seaboard.

In general, generation connections can be more readily accommodated in locations close to existing demand centres. This is due to the fact that generated power can be absorbed close to the demand centre. This means that power does not have to be transported over long distances from generation source to demand.

Historically, in Ireland and Northern Ireland, large conventional generation plants would be sited as close as practically possible to large demand centres. This reduced the need to transport power across the transmission network, reduced power transfer losses and improved the security and reliability of supply.

In recent times, large renewable energy resources, principally wind energy located to the South West, West and North West, has led to high penetrations of generation in these regions. As a consequence, we see much more widely dispersed generation. At times this results in high power flows and congestion on many transmission circuits that provide power to demand centres in the East.




Figure 7-1: All-island 2020 regional demand and generation balance

### Dublin Area

In contrast with other regions, Dublin currently is the only region where demand exceeds generation. This deficit will become more significant with approximately 550MW (see Chapter 3) of increased demand capacity that is either contracted or in the EirGrid connection offer process.

In addition to this, there is around 1000MW of potential demand connection enquiries, many of which are in the Dublin region (see Chapter 3). If all of these enquiries were to materialise and connect they would summate to around a 70% increase in the current Dublin peak demand.

Without new generation capacity located in Dublin, under these high demand conditions, Dublin would be dependent on substantial power flows into the region from remote generation sources.

### Northern Ireland

Not dissimilar to Ireland, Northern Ireland is connecting high levels of wind generation, with more planning to connect to the transmission and distribution systems. This generation in the North and West of Northern Ireland is greater than local demand and causes congestion on the transmission network.

In the East of Northern Ireland, opportunities for generation connection are possible, with a less congested transmission network and higher demand density. Connection studies would be required to determine the available capacity and connection arrangements<sup>11</sup>.

### 7.4 Generation Locational Tariff Signals and Their Impact on Transmission Network Capacity

The Single Electricity Market's (SEM) harmonised transmission arrangements<sup>12</sup> provide locational signals to users reflecting the costs they impose on the transmission system. TLAFs and GTUOS, as part of harmonised transmission arrangements, provide generators with locational signals informing their decision on where to connect to the grid.

Electrical losses<sup>13</sup> which occur as electricity is transported along transmission circuits are accounted for in the SEM settlement processes with the application of TLAFs.

Some units are responsible for proportionally more transmission losses than others, depending on their point of connection to the grid and use of transmission network capacity.

---

<sup>11</sup> In this TYTFS we are considering the capability of the transmission network to meet the needs of transmission network users. Care should be taken when interpreting these regional results; we are not evaluating the adequacy of generation capacity to meet peak demand. This is evaluated in the Generation Capacity Statement. As an example Figure 1 shows a generation capacity surplus in Northern Ireland (NI). However the largest component of generation capacity in NI is from wind generation. This generation is variable and is not always available to meet the peak demand. In addition, the generation capacity figure includes generation with restricted hours of running from 2021 as a result of EU Industrial Emissions Legislation (IEL). As a result of these capacity limitations in NI the security of supply would be at risk if the second North - South interconnector is delayed further.

<sup>12</sup> The development of harmonised all-island transmission charge and losses arrangements was an objective stated in the original SEM high level design.

<sup>13</sup> The transmission of electricity results in a proportion of energy being lost as heat.

The methodology used by the transmission system operators (TSOs) to calculate the TLAFs has been approved by the regulatory authorities <sup>(14 /15 /16 /17)</sup>.

Transmission losses are minimised when generation is located close to demand centres and a generation/demand balance is achieved. When this balance changes, and generation is in excess of local demand, power flows increase across the transmission system and transmission losses also increase.

The Transmission Use of System Charge (TUoS) is the main charge for transporting power in bulk across the power system. Generator Transmission Use of System Charge (G-TUoS) contains a locational component, in order to provide a signal of the costs associated with a generator's use of the network.

Such signals provide a commercial incentive for generators to make informed decisions (both siting/entry and exit decisions) concerning their use of the transmission system. This is intended to improve efficiency in respect of both the use of and investment in the transmission system.

The regional average 2015/16 TLAF values are shown in Figure 7-2. Values shown in Figure 7-2 are based on published 15/16 TLAF<sup>18</sup> values.

Generator TLAF's are reflective of their contribution to transmission losses. The principle is that market participants that contribute more to transmission losses due to their location should have a lower TLAF than those generators who contribute less to transmission losses

---

<sup>14</sup> The Single Electricity Market (SEM) High Level Design Decision Paper, 10 June 2005, AIP/SEM/42/05.

<sup>15</sup> Decision on all-island harmonised Transmission Loss Adjustment Factors (TLAFs), SEM-10-066, September 2010

<sup>16</sup> Decision Paper, Treatment of Losses in the SEM, SEM-11-067, Aug 2011

<sup>17</sup> Decision Paper Treatment of Losses in the SEM, SEM-12-049, 26 June 2012

<sup>18</sup> SEMO, Transmission Loss Adjustment Factors(TLAF): <http://www.sem-o.com/Publications/Pages/MarketParameters.aspx?documentarchivestatus=Active>




Figure 7-2: All-island 2015/16 regional average TLAF values

The regional average 2015/16 GTUoS values are shown in Figure 7-3. Values shown in Figure 7-3 are based on 15/16 GTUoS values<sup>19</sup>.

Higher GTUoS charges are reflective of transmission investment costs linked to a generator's use of the system. This promotes efficient use of the transmission system by generators, which should, in turn, facilitate efficient investment in the transmission system.




Figure 7-3: All-island 2015/16 regional average GTUoS values

<sup>19</sup> <http://www.eirgridgroup.com/site-files/library/EirGrid/2015-2016-Statement-of-Charges-CER-Approved-final-290915.pdf> and <http://www.soni.ltd.uk/media/documents/Customers/TUOS/Final%20TUoS%20Statement%20of%20Charges%202015-16.pdf>

As shown in Figure 7-2 and Figure 7-3, a clear trend emerges. Regions with surplus generation capacity in the South West, West and North West have lower TLAf and higher GTUoS values than Eastern regions with higher demand levels and less surplus generation. These trends should be taken into consideration by generators when considering options to connect to the all-island transmission system.

#### 7.4.1 How to Use the Information for Generation

Generation developers wishing to use the information on regional demand/generation balance and locational tariff signals when considering where to connect should follow these steps:

1. Consult the maps in Appendix A to find the nearest transmission station to the proposed development. Also, regions identified in Section 7.3 and 7.4 which are indicating optimal opportunities for generation connections.
2. Consult the forecasted increase and retirement/divestiture of generation within a region shown in Appendix D.
3. Review assumptions in Chapters 2 to 4 and consider the impact of changes to the transmission system since the analysis was carried out. Chapter 5 and Appendix E should also be considered to determine short circuit levels at the nearest transmission station.
4. Consult with EirGrid and SONI on the proposed location as early as possible as well as consulting the EirGrid application process<sup>20</sup> and SONI application process<sup>21</sup>

Potential generator developers should not be discouraged by choosing a site in which there appears to be a lack of transmission network capacity. Early consultation with us is encouraged so that we can work jointly to explore options relating to any potential proposals and enable timely decision making.

---

<sup>20</sup> <http://www.eirgridgroup.com/customer-and-industry/becoming-a-customer/>

<sup>21</sup> <http://www.soni.ltd.uk/Customers/howconnected/>

## 7.5 Looking to the Future

### Ireland

The Commission for Electricity Regulation (CER) policy for connection of generation to the electricity network in Ireland is captured under the Group Processing Approach (GPA) and Non-Group Processing Approach directions. Under the GPA, offers for connection to the electricity network have been issued in batches called ‘gates’.

Eligibility for inclusion in a Gate has been based on criteria set out by the CER in its decisions on each of the three gates to date, Gate 1 in 2004, Gate 2 in 2006 and Gate 3 in 2008 and 2009. The Non-Group Processing Approach applies to small scale generation and specific technologies.

The CER is now reviewing connection and grid access policy to ensure it is fit for purpose for future grid access requirements. The CER published Consultation CER/15/284 on the 11th December titled “Review of Connection and Grid Access Policy: Initial Thinking & Proposed Transitional Arrangements”.

This paper represents an initial step in the development and implementation of an integrated and enduring connection policy for the electricity system in Ireland. Potential generator project promoters should be aware of these developments.

EirGrid will incorporate relevant policy directions. We will also provide assistance and guidance regarding the connection processes, requirements and arrangements for potential new transmission system users.

### Northern Ireland

In the past, the connection process in Northern Ireland operated on the basis that statutory planning permission was required before a grid connection application could be processed by SONI and NIE Networks.

However, a recent Utility Regulator determination led to the removal of the planning permission requirement for distribution connection applications to NIE Networks. The planning permission requirement currently remains in place for transmission connection applications to SONI.



Towards the end of 2015, NIE Networks received a large number of applications for generation connections to the NI distribution system (approximately 900MW). This comes on top of approximately 1300MW of generation capacity connected and committed to connect to the NI grid.

This presents significant challenges for both the transmission and distribution systems. The current process for assessing connections, which adopts an incremental approach for assessing the impact on the grid, is not appropriate.

An alternative process must be implemented which addresses the challenges involved in processing this volume of applications. SONI and NIE Networks are due to issue a consultation on this matter shortly.

SONI will continue to provide guidance regarding the connection offer processes and provide updates regarding any changes to connection policy. SONI would welcome any feedback in relation to this consultation.



## 8 TRANSMISSION CAPABILITY FOR NEW DEMAND

- 8.1 Transmission System Demand Capability Obligations
- 8.2 All-Island Transmission System Capability for New Demand
- 8.3 New demand Opportunities in the Dublin Area
- 8.4 Transmission System Capability for New Demand in Ireland
- 8.5 Controllable Demand
- 8.6 Transmission System Capability for New Demand in Northern Ireland
- 8.7 How to Use the Information for Demand



The current. The future.

## 8 Transmission System Capability for New Demand

This chapter presents demand opportunity analysis which assesses the capability of the existing and planned transmission system to accommodate increased demand. Opportunities for further demand connections in Ireland and Northern Ireland are discussed.

Demand opportunity analysis is studied in 2020 which includes the planned second North-South 400kV tie-line. Analysis of the 2020 transmission system indicates that all regions studied across the island have opportunities to connect demand at 275, 220 and 110kV stations.

There has recently been a significant volume of enquiries and applications for the connection of data centres in the Dublin region (see Chapter 3). Due to this, we have added section 8.2.1 which presents a qualitative approach describing demand opportunities in the Dublin area. The qualitative analysis of Dublin indicates that there is network capacity available for the connection of data centres.

### 8.1 Transmission System Demand Capability Obligations

This chapter of the TYTFS is published in order to meet the requirements of EirGrid's Section 38 of the 1999 Electricity Act and Condition 33 of SONI's licence.

The analysis illustrated in Chapter 8 is presented to provide a high-level indication of transmission network capacity for developers. Results from demand capability studies are based on a specific set of assumptions (see Chapter 6) which may be subject to change. Developers wishing to connect to the transmission system will therefore require further detailed studies.

It is not intended to have any legal effect on the negotiation of contractual terms for transmission system connections. Before making any commercial decisions developers should contact us for discussions on their proposed developments.

## 8.2 All-Island Transmission System Capability for New Demand

As detailed in Chapter 6, the transmission system's capability to accommodate new demand is assessed using demand opportunity analysis. The study was performed for 2020 winter and summer peak.

Data used for the demand opportunity analysis is based on the best available information at the July 2015 data freeze date. The results of the demand opportunity analysis presented in this chapter are based on the following assumptions:

- Demand forecast was based on 2020 figures (see Appendix C)
- Only transmission reinforcements with capital approval (Ireland) which are planned to be completed by 2020 were included in analysis (see Chapter 2)
- Planned generation up until 2020 was included in the analysis (see Appendix D)
- As wind energy is variable, it cannot be relied upon to serve demand. As such, wind generation local to the test station was switched out.
- The 2020 transmission system was assessed for the loss of a single transmission asset (N-1), maintenance-trip (N-1-1) and loss of a double transmission circuit (N-DC, Northern Ireland) contingences.

Twenty-eight 110kV stations, which feed principal towns and main load centres throughout Ireland were chosen for this analysis. The stations examined and their accompanying results are shown in Figure 8-1. In response to stakeholder feedback, this TYTFS also includes analysis at ten 275kV stations and four 220kV stations. These stations were included to help identify potentially suitable locations for major industrial load centres with large power requirements.

It should be noted that demand opportunity is tested at each station on an individual basis. As such, the opportunities presented are not cumulative. If new demand connects in an area that is currently shown to have capacity, this will then use up some or all of the available capacity in that area.

As a general rule, demand opportunity at a particular station would tend to reduce over time. This is due to normal demand growth using up available capacity. Yet, in many cases demand opportunities can improve as a result of planned transmission system or generation developments.

The results of the analysis are presented on a regional basis through Figure 8-5 to Figure 8-11. Each Figure is accompanied by a description of factors restricting demand opportunity and future network reinforcements which may release demand capacity in the area. The results indicate that in 2020 there will be opportunities at each of the forty-two stations examined.




Figure 8-1 Capability for Additional Demand at 275kV, 220kV and 110kV Stations (given to the nearest 10MW)

### 8.3 New Demand Opportunities for the Dublin Area

#### Context

Dublin is the largest load centre on the island of Ireland. We have expanded this section this year due to the considerable interest and number of enquiries for connection to the grid around Dublin (see chapter 3 Demand). The volume of enquiries and the uncertainty of their final outcome and interaction require us to make a qualitative assessment of demand opportunities for the future.

The scale of individual demand connection enquiries to the transmission system vary from 20MW to some possibly extending to 250MW in the final stages of development. The connections are mainly comprised of data centres that support the information, communications and technology (ICT) infrastructure of large multinational companies.

There is currently around 550MW of demand capacity either contracted or in the EirGrid connection offer process. In addition to this, there is approximately 1000MW of enquiries regarding further demand connections from 2019 onwards.

To put this figure in perspective, the current winter peak demand in Dublin and on the all-island system is approximately 2100MW and 6500MW respectively. If all of these enquiries were to materialise and connect, they would sum to around 20% of the all island system peak demand and 70% of Dublin peak demand.

Connections on this scale cannot be managed solely at distribution level. Rather they will require connections to the 220kV and 110kV transmission network. EirGrid is working with customers and the distribution system operator ESB Networks to meet their individual needs and to ensure optimal network development and solutions.

### The Dublin Network:

The diagram in Figure 8-2 represents the 220kV backbone transmission system in the greater Dublin area in 2020. There also exists a 110kV network in the Dublin area however, for clarity we have not shown it in Figure 8-2.



Figure 8-2: Dublin area 220kV transmission system

Electricity is supplied within Dublin via a 220kV network arranged in a figure of eight. A combination of operational arrangements and network devices (normally open points at Shellybanks 220kV station and a reactor at Poolbeg 220kV station) effectively divides the Dublin 220kV network into North and South rings.

This network configuration is primarily used to maintain fault currents at safe levels should a network fault occur. It also prevents excessive power flows through the Dublin region. Dublin is then fed via the underlying 110kV distribution infrastructure which is mainly arranged radially from transmission bulk supply point (BSP) interface stations (220/110kV).

The larger Dublin power stations are located at Huntstown in North Dublin and at Irishtown and Shellybanks in Dublin Bay. The combined capacity of these stations is approximately 1600MW. The 500MW East West Interconnector also feeds into Woodland 400kV station on the periphery of North Dublin.

Analysis is carried out to ensure compliance with the Transmission Planning Criteria (TPC) for all new connections to the transmission system.

This ensures the co-ordinated development of a reliable, efficient, and economical system for transmission system users. EirGrid must ensure the performance requirements of the TPC are met, for example the thermal capacity limits of equipment must be maintained for all operating conditions.

There are three primarily limitations that can restrict the availability of transmission capacity in Dublin;

- (1) Limitations at the 220/110kV interface stations, these can include restrictions due to the 220/110kV transformers or spatial constraints,
- (2) Power flow limitations on local transmission circuits within Dublin,
- (3) Limited capacity on circuits outside Dublin in terms of facilitating large power flows across the transmission network.

Generation dispatch is critical in assessing the capability of the network and can have a significant impact on (2) and (3) above, especially in the case of Dublin.

The power delivered to Dublin demand centres can originate from power stations located within or outside Dublin or a combination of both. This is dependent on wholesale electricity market generation costs in the Single Electricity Market (SEM) as well as network/system issues.

Recently there has been a tendency for increased high power flows into Dublin from generation located outside the area. This is a result of the increased penetration of wind generation and the commissioning of other high merit order generators outside of Dublin.

In some instances these high power flows from outside the Dublin area can be reduced when power is generated inside Dublin. This could release network capacity for transmission users.



## Dublin Transmission Development Plans

Figure 8-3 below describes the areas of focus for demand connections in Dublin and the scale of interest in each zone. The connections fall into three zones North, West and South Dublin.




Figure 8-3: Dublin potential demand connections

Each zone is described below with consideration given to potential levels of connection demand, existing transmission infrastructure, transmission network projects and lead times.

Should the reader require more detailed transmission network project information please reference the EirGrid draft grid development strategy document published in 2015<sup>1</sup>, the current Transmission Development Plan<sup>2</sup> and the latest associated transmission reinforcement (ATR) update<sup>3</sup>.

The project table provides a brief description of the project, the estimated lead-time and the projects status. Project status is categorised into three areas; pre-planning, planning, approved. In construction and complete are subsets of approved. A description of each project status category is given in Appendix F, section F.1.

<sup>1</sup> <http://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid-Draft-Grid-Development-Strategy.pdf>

<sup>2</sup> The latest TDP can be found on the EirGrid website <http://www.eirgridgroup.com/>

<sup>3</sup> <http://www.eirgridgroup.com/site-files/library/EirGrid/Q4-2015-ATR-Status-Update-as-at-31-Dec-15-published-01-Feb-16.pdf>

### North Dublin

*North Dublin* includes two 220/110kV interface stations at Corduff and Finglas with another planned at Belcamp. The level of interest for connection in North Dublin is the highest of all Dublin areas.

A number of transmission projects are in place to increase the network capacity and security of supply in this area, they are summarised in Table 8-1 below.

Table 8-1: North Dublin projects

| <i>North Dublin</i> |                                 |                 |                     |
|---------------------|---------------------------------|-----------------|---------------------|
| Project Name        | Project Description             | Status          | Estimated lead-time |
| Cloghran            | Uprate/Modify 110kV station     | In construction | 2016                |
| Maynooth - Woodland | 220kV line refurbishment        | Planned         | 2016                |
| Cloghran-Corduff    | New 110kV cable                 | Approved        | 2016                |
| Belcamp             | New 220/110kV station           | Approved        | 2018                |
| Finglas             | Uprate/Modify 220/110kV station | Approved        | 2018                |
| Macetown            | 110kV busbar uprate             | Pre-planning    | 2018                |

The transmission projects described above are sufficient to meet the current level of demand connections either contracted or in the EirGrid connection offer process. However, this area of Dublin has limited additional network capacity available to meet demand connections based on the present level of interest.

It is envisaged that facilitating further high levels of demand connections will require additional network capacity in the area. This could be in the form of increased network connectivity with Woodland 400kV station for example. Typically, such major projects delivering additional network capacity have significant lead times (five to eight years) which are dependent on the chosen technology.

### West Dublin

*West Dublin* includes two main 220/110kV interface stations at Inchicore and Poolbeg with another planned at West Dublin station. These stations are supported by the Maynooth 220kV station on the outer rim of the Dublin region. The level of interest for connection in the West Dublin area is very high, second only to North Dublin.

A number of transmission projects are in place to increase the network capacity and security of supply in this area, they are summarised in Table 8-2 below.

Table 8-2: West Dublin projects

| <i>West Dublin</i>              |   |              |                     |
|---------------------------------|---|--------------|---------------------|
| Project Name                    | Project Description   | Status       | Estimated lead-time |
| Inchicore-Maynooth <sup>4</sup> | Uprate No.1 & No.2 line uprates   | Complete     | 2015                |
| Maynooth-Ryebrook <sup>2</sup>  | Uprate 110kV line   | Complete     | 2015                |
| Poolbeg                         | Installation of 100 Mvar reactive support   | Approved     | 2016                |
| Ryebrook-Corduff                | Uprate 110kV line   | Approved     | 2016                |
| Ryebrook                        | Refurbish 110kV station   | Approved     | 2017                |
| North Wall - Poolbeg            | Replacement of cable due to a requirement to divert the circuit to make way for development at Dublin Port. | Pre-planning | 2018                |
| West Dublin                     | New 220/110kV station   | Planning     | 2019                |
| Inchicore                       | Uprate/Modify 220/110kV station   | Pre-planning | 2022                |
| Maynooth                        | Uprate/Modify 220/110kV station   | Pre-planning | 2023                |

It is anticipated that this area of Dublin will have a reasonable level of network capacity upon completion of the new West Dublin 220kV station.

It will facilitate connections either contracted or in the EirGrid/ESB Networks connection offer process. There will also be some further network capacity available to transmission network users beyond what is currently contracted or in the EirGrid/ESB Networks connection offer process.

After the construction of the new West Dublin 220kV station, it is expected that additional transmission network capacity at Inchicore 220kV station may be available. This is due to the transferring of some existing demand at Inchicore to the new West Dublin 220kV station.

### South Dublin

*South Dublin* includes one main 220/110kV interface station at Carrickmines connected at 220kV to Dunstown 400kV station and Arklow 220kV station. The level of interest for connections in South Dublin area is lower in comparison to the interest in North and West Dublin.

<sup>4</sup> This project has been completed since the data freeze date of July 2015

A number of transmission projects are in place to increase the network capacity and security of supply in this area, they are summarised in Table 8-3 below.

Table 8-3: South Dublin projects

| <i>South Dublin</i>   |   |           |                     |
|-----------------------|---|-----------|---------------------|
| Project Name          | Project Description                                 | Status    | Estimated lead-time |
| Dunstown <sup>5</sup> | New 400/220kV 500 MVA transformer                   | Completed | 2015                |
| Carrickmines          | New 220/110kV 250 MVA transformer & GIS development | Approved  | 2017                |

Considering the South Dublin transmission projects and the level of connection enquiries, this area of Dublin has a reasonable level of network capacity available to facilitate connections either contracted or in the EirGrid/ESB Networks connection offer process. Indeed there is further network capacity available to transmission network users beyond these connections.

#### **Impact of Generation on North, West and South Dublin**

As described in Chapter 7 there is currently a small generation deficit in the Dublin region which has the potential to increase. If additional generation was to locate in the Dublin area this would generally have a positive impact by releasing network capacity available for transmission system users in North, West and South Dublin zones.

However, the specific location of any proposed additional generation would have to be assessed to fully understand its full impact on the network.

<sup>5</sup> This project has been completed since the data freeze date of July 2015

## Looking Forward

In 2015 EirGrid released a discussion paper on Ireland’s draft grid development strategy. In this paper, we explained the role of electricity transmission infrastructure in supporting new investments and jobs as well as ensuring competitiveness by offering cost-effective power capacity.

This strategy put forward a number of major projects to upgrade the transmission network. The Regional Solution (see Chapter 2) and Dunstown – Woodland corridor reinforcement<sup>6</sup> projects have many system benefits, which include providing additional network capacity and improving security of supply for the eastern side of Ireland.

The Regional Solution project involves a new circuit across the Shannon Estuary and the installation of “series compensation” equipment on the 400kV circuits that extend from Moneypoint 400kV power station in the West of Ireland towards Woodland and Dunstown 400kV stations located on the western outskirts of Dublin.

This project will greatly enhance the capability of the existing 400kV circuits to transfer bulk power generated in remote locations in the South-West, West and North-West to Dublin and other demand centres in the East as illustrated by the green arrows in Figure 8-4.

The Dunstown – Woodland corridor reinforcement is at an early point in the project life-cycle. The project will increase the strength of the link between two 400kV stations at Dunstown and Woodland. This will provide benefit by reducing power flows that pass through the Dublin transmission 220kV network, thus releasing network capacity on several key constrained circuits.

To maintain system stability and facilitate significant inter regional power flows we are also developing a number of voltage support solutions across Ireland.

---

<sup>6</sup> This project is at an early stage of development and has therefore has not formed part of the 2015 TYTFS studies.




Figure 8-4: Transfer of power generated in the North-West, West and South-West regions to the East

### Summary

Depending on the location, number and scale of projects that materialise and the capacity limitations of the existing network in Dublin, new transmission solutions will be required to strengthen the grid. These solutions are now under initial investigation and could vary from short to longer lead time developments.

EirGrid continues to apply a strategic approach to network development and is now considering the approach to the level of demand enquires. Our strategic approach will take account of the following:

- Companies developing data centres operate in a rapid and dynamic environment. Their business requires connection timescales that are short relative to time taken for transmission reinforcement. Most are considering being operational within two to three years and growing their power usage rapidly thereafter.
- We are working to understand the needs of these developers and their impact in terms of our grid development strategy. We are publishing information on the system adequacy, grid needs and opportunities to ensure transparency so that the impacts of this sector and its developments are known.
- To date, we have been able to facilitate connections for developers who have applied. We will continue to examine innovative solutions and technologies in response to future requests. However, with each application, the opportunity to utilise the existing transmission network becomes more challenging.

It is advised that any potential new demand consumers with EirGrid early so that we can work jointly to achieve a connection solution. This facilitates the optimisation of transmission reinforcements so that the requested capacity can be delivered.

It is also recommended to locate any new data centres in close proximity to existing 220kV stations or circuits as this may help expedite the provision of a suitable connection.

As a prudent system operator, EirGrid ensures that adequate spare capacity for regional and national demand growth is available, while avoiding unnecessary overinvestment in grid capability. Therefore a balance is maintained between the reasonable expectations placed on the network and the cost of grid development and maintenance. Delivering an efficient transmission grid requires that this balance of investment is maintained.

## 8.4 Transmission System Capability for New Demand in Ireland

Demand opportunities available on an Ireland regional basis are discussed in sections 8.4.1 to 8.4.5. Results presented in Section 8.4 are based on the assumptions detailed in Chapter 6.

### 8.4.1 Incremental Transfer Capability Results for New Demand in the Midlands and Mid-West

The demand opportunities available for the Midlands region are shown in Figure 8-5. It is shown that there are potential demand opportunities available for industrial customers at all stations examined in the region. In particular, Cashla and Shannonbridge 220kV stations would be suitable connection points for major industrial load centres. Both of these stations are capable of accommodating in the order of 200MW without additional network reinforcements.




Figure 8-5 Capability for Additional Demand in Midlands and Mid-West Regions

### 8.4.2 Incremental Transfer Capability Results for New Demand in the North-East

The demand opportunities available for the North-East region are shown in Figure 8-6. It is shown that there are potential demand opportunities available for industrial customers at all stations examined in the region. The delivery of the North-South interconnector aids demand opportunity in the North-East. The North-South interconnector provides a route for large power transfers to flow between Northern Ireland and the Republic of Ireland via the North-East region of Ireland. The North-South interconnector will benefit potential demand customers connecting in this region by releasing more capacity on the underlying 110kV network.



Potential overloading of the Louth – Mullagharlin 110kV line is responsible for limiting the opportunity at Mullagharlin (40MW). The overload occurs during winter and summer peaks for single circuit outage conditions. This is a local issue as only two circuits supply the load at Mullagharlin. Drybridge (100MW), however, is more interconnected with four circuits supplying the station from disparate locations.




Figure 8-6 Capability for Additional Demand in North-East Region

#### 8.4.3 Incremental Transfer Capability Results for New Demand in the North-West<sup>7</sup>

The demand opportunities available for the North-West region are shown in Figure 8-7. It is shown that there are potential demand opportunities available for industrial customers at all stations examined in the region. The potential demand opportunity at Castlebar (10MW) could be viewed as limited when compared with other stations in the North West. Analysis has shown that the Castlebar – Cloon 110kV line<sup>8</sup> could overload as power tries to flow to Castlebar under certain maintenance-trip scenarios (see Chapter 6). The uprate of Castlebar – Cloon 110kV line would allow for more demand opportunity at Castlebar.

<sup>7</sup> Results shown for the North-West region are based on the assumption of the HVDC option being the chosen solution for the Grid West project (see Chapter 2). This assumption was based on the HVDC option providing the least transmission network capacity. It should be noted therefore, that as the project matures and further detailed analysis is carried out, the capability in the area potentially could increase dependent on the final solution chosen.

<sup>8</sup> As of the July 2015 data freeze date this project was still in pre-planning and is therefore not included in demand opportunity studies




Figure 8-7 Capability for Additional Demand in North-West Region

#### 8.4.4 Incremental Transfer Capability Results for New Demand in the South-East

The demand opportunities available for the South-East region are shown in Figure 8-8. It is shown that there are potential opportunities available for industrial customers at all stations examined in the region. The demand opportunity at Kellis 220kV station is limited to 70MW due to the maintenance-trip scenario (see Chapter 6) where both 220kV lines supplying Kellis are assumed to be out of service.

This scenario means that demand at Kellis 220kV station must be supplied by the underlying 110kV network, which does not have the capacity to carry as much power as the 220kV network. However, should a demand facility wishing to connect at Kellis 220kV station implement a 'Controllable Demand' strategy there would be potential for much greater capacity of demand to connect to Kellis 220kV. This is explained further in section 8.5 on 'Controllable Demand'.




Figure 8-8 Capability for Additional Demand in the South-East Region

#### 8.4.5 Incremental Transfer Capability Results for New Demand in the South-West

The demand opportunities available for the South-West region are shown in Figure 8-9. It can be seen that there are potential opportunities available for industrial customers at all stations examined in the region. In particular the Killonan 220kV station would be a suitable connection point for a major industrial load centre, with the capability of accommodating in excess of 200MW without additional network reinforcements.




Figure 8-9 Capability for Additional Demand in South-West Region

### 8.5 Controllable Demand

Section 8.1.5 used Kellis 220kV station as an example to demonstrate the potential to increase the assessed capacity of a station through the concept of ‘controllable demand’. In the case of Kellis 220kV station, demand opportunity is limited to 70MW due to a maintenance-trip scenario where both 220kV lines supplying Kellis 220kV station are assumed to be out of service. The next limiting scenario after the outage of both 220kV lines supplying Kellis would allow for much greater demand opportunity at Kellis 220kV station.

Maintenance-trip contingency planning forms part of a suite of contingencies considered by EirGrid for prudent planning of the transmission system. However, it is also recognised in the Transmission Planning Criteria that

exposure to maintenance-trip events is much less than the other contingency events considered.

This means that under certain circumstances, potential demand customers may enter an agreement with EirGrid to connect a higher level of demand at a particular station, on the condition that the customer would reduce load if certain contingencies came to fruition.

Using Kellis 220kV station as an example, a potential demand customer may enter an agreement with EirGrid to connect 200MW of load at Kellis, but drop to 70MW if either of the 220kV lines supplying Kellis are out of service.

It should be noted that Kellis has been used as an example however, depending on reliability requirements, this type of agreement may not be suitable for all types of demand facilities or locations. We encourage any potential customers to discuss the possibility of controllable demand with us at an early stage of project planning and development.

## 8.6 Transmission System Capability for New Demand in Northern Ireland

Demand opportunities available for the Eastern region of Northern Ireland are discussed in section 8.6.1, while section 8.6.2 presents the Western region. Results presented in Section 8.6 are based on the assumptions detailed in Chapter 6.

Readers should be aware that the analysis is based on the year 2020 and includes an assumption that North – South 400 kV tie line is in place. The completion of this new line improves the generation adequacy situation in Northern Ireland and is an important factor when considering the capacity of the system to connect significant amounts of additional demand in Northern Ireland. The All Island Generation Adequacy Statement 2016-2025, published on the EirGrid and SONI websites, describes the overall generation adequacy situation in detail.

### 8.6.1 Incremental Transfer Capability Results for New Demand in East of Northern Ireland

The demand opportunities available for the East of Northern Ireland are shown in Figure 8-10. It can be seen that there are potential opportunities available for industrial customers at all stations examined in the region.

The majority of 275kV stations in the East of Northern Ireland can accommodate approximately 300MW of additional demand.

Castlereagh and Hannahstown are slightly more limited by thermal overloading on the 110kV network in the central Belfast area. This occurs during the loss of a 275kV circuit supplying either station.




Figure 8-10 Capability for Additional Demand in the East of Northern Ireland

### 8.6.2 Incremental Transfer Capability Results for New Demand in West of Northern Ireland

The demand opportunities available for the West of Northern Ireland are shown in Figure 8-11. It can be seen that there are potential opportunities available for industrial customers at all stations examined in the region.

It should be noted that the North-West of Northern Ireland requires specific assessment in line with the TSSPS (see Chapter 6). As the North-West is connected by a single double circuit 275kV spur, an N-1-1 contingency is performed as a credible contingency.

Under N-1-1 the demand capability of Coolkeeragh is limited to 120MW following the loss of the Coolkeeragh-Magherafelt 275kV double circuit while the Coolkeeragh steam and gas units are out on maintenance and Coolkeeragh G8 is dispatched.

Enniskillen 110kV station which represents the lowest capability is connected to Omagh South station via two 110kV circuits. The loss of one of these circuits creates a thermal overload on the other which limits demand connection capability.




Figure 8-11 Capability for Additional Demand in the West of Northern Ireland

## 8.7 How to Use the Information for Demand

Although not every station was considered, the results presented can be regarded as a guide to opportunities at other stations in the same area.

Customers wishing to use the demand opportunity results described in this chapter when considering where to connect should follow these steps:

1. Consult the maps in Appendix A to find the nearest transmission station to the proposed development. Also, the nearest station for which opportunity has been assessed (section 8.4 and 8.6) should be identified, where it differs from the nearest transmission station.
2. The anticipated demand growth at the relevant station can be obtained from the demand forecasts presented in Appendix C. The transmission system is being planned to meet this level of demand increase.
3. Review assumptions in Chapters 2 to 4 and consider the impact of changes to the transmission system since the analysis was carried out.
4. Consult with EirGrid and SONI on the proposed location as early as possible as well as consulting the EirGrid application process<sup>9</sup> and SONI application process<sup>10</sup>

Potential demand customers should not be discouraged by choosing a site in which there appears to be a lack of transmission system capacity. Early consultation with us is encouraged so that we can work jointly to explore options relating to any potential proposals and enable timely decision making.

---

<sup>9</sup> <http://www.eirgridgroup.com/customer-and-industry/becoming-a-customer/>


<sup>10</sup> <http://www.soni.ltd.uk/Customers/howconnected/>





## APPENDIX A: MAPS AND SCHEMATIC DIAGRAMS

- A.1 Network Maps
- A.2 Short Bus Codes
- A.3 Schematic Diagrams of the All Island Transmission System



The current. The future.

## Appendix A Maps and Schematic Diagrams

Appendix A contains geographical maps of the All-Island Transmission System and short bus codes for every transmission voltage node on the island. Geographical maps are presented illustrating the All-Island Transmission System as it exists at the beginning October of 2014 and as planned for 2024.

### A.1 Network Maps















This section includes two network maps:




- Figure A-1 is a map of the existing All-Island Transmission System as at October 2014;
- Figure A-2 is a map of the existing Transmission System including planned Transmission System developments as at December 31<sup>st</sup> 2024.

Note: Grid Link, Grid West, The North West Project and The North Connaught Reinforcement are all new developments. The solution that will be used for these projects have not yet been finalised. They are shown on the Transmission System Map as a transparent bubble.

**Figure A - 1**  
**Transmission System**  
**400 kV, 275 kV, 220 kV and 110 kV**  
**As at July 2015**

**LEGEND**

|   |                            |   |                |
|---|----------------------------|---|----------------|
|  | 400 kV Lines               |  | Hydro          |
|  | 275 kV Lines               |  | Thermal        |
|  | 220 kV Lines               |  | Pumped Storage |
|  | HVDC Cables                |  | Wind           |
|  | 220 kV Cables              |   |                |
|  | 400 kV Stations            |   |                |
|  | 275 kV Stations            |   |                |
|  | 220 kV Stations            |   |                |
|  | 110 kV Stations            |   |                |
|  | Phase Shifting Transformer |   |                |



# Figure A - 2

## Planned Transmission System

### 400 kV, 275 kV, 220 kV and 110 kV

#### As at Year End 2024

**LEGEND**

**Transmission**

- 400 kV Lines
- 275 kV Lines
- 220 kV Lines
- 110 kV Lines
- HVDC Cables
- 220 kV Cables
- 110 kV Cables

**Generation**


- Hydro
- Thermal
- Pumped Storage
- Wind
- Tidal
- Compressed Air Energy Storage

**Stations**

- 400 kV Stations
- 275 kV Stations
- 220 kV Stations
- 110 kV Stations

**Other**

- Phase Shifting Transformer



## A.2 Short Bus Codes

The following table associates full station names with the two or three letter codes used in the schematic diagrams in Section A.3, in the tables in Appendices B and C, and the power flow diagrams in Appendix I. Stations in Northern Ireland and Ireland with the same three letter bus code are distinguished with (N) for Northern Ireland and (I) for Ireland.

Table A-1 Short Bus Codes

| Short Bus Code | Full Name                   | Short Bus Code | Full Name                    | Short Bus Code | Full Name                      |
|----------------|-----------------------------|----------------|------------------------------|----------------|--------------------------------|
| AA             | Ardnacrusha                 | BGT            | Ballyragget                  | CAM            | Cam Cluster                    |
| AD             | Aghada                      | BIN            | Binbane                      | CAR            | Belfast - Carnmoney Main       |
| ADM            | Adamstown                   | BK             | Bellacorick                  | CAS            | Castlereagh Main               |
| AGH            | Aghyoule Main               | BKM            | Bunkimalta                   | CBG            | Carrowbeg                      |
| AGL            | Agannygal                   | BKY            | Barnakyle                    | CBL            | Cloghboola                     |
| AGY            | Ardnagappary                | BLC            | Belcamp                      | CBR            | Castlebar                      |
| AHA            | Ahane                       | BLA            | Blackrock                    | CD             | Carrigadrohid                  |
| AIR            | Belfast - Airport Road Main | BLI            | Ballylickey                  | CDK            | Castledockrill                 |
| ANR            | Anner                       | BLK            | Blake                        | CDL            | Cordal                         |
| ANT            | Antrim Main                 | BLP            | Blackpool                    | CDU            | Corduff                        |
| ARI            | Arigna                      | BMA            | Ballymena Mesh (Rural)       | CDY            | Corderry                       |
| ARK            | Arklow                      | BMA            | Ballymena SWBD (Town)        | CEN            | Belfast - Belfast Central Main |
| ARM            | Armagh Main                 | BNH            | Ballynahinch Main            | CF             | Cathaleen's Fall               |
| ART            | Artane                      | BNM            | Belfast - Belfast North Main | CFM            | Castlefarm                     |
| ARV            | Arva                        | BOG            | Banoge                       | CGL            | Coomagearlahy                  |
| ATE            | Athea                       | BOL            | Booltiagh                    | CHA            | Charleville                    |
| ATH            | Athlone                     | BPS            | Ballylumford Power Station   | CHE            | Cherrywood                     |
| ATY            | Athy                        | BRA            | Bracklone                    | CHR            | Cahernagh                      |
| AUG            | Aughinish                   | BRI            | Brinny                       | CKG            | Corkagh                        |
| BAL            | Baltrasna                   | BRO            | Brockaghboy Main             | CKM            | Carrickmines                   |
| BAN (I)        | Bandon                      | BRY            | Barnahely                    | CKN            | Clonkeen                       |
| BAN (N)        | Banbridge Main              | BUT            | Butlerstown                  | CL             | Cliff                          |
| BAR            | Barrymore                   | BVG            | Ballyvallah                  | CLA            | Clashavoon                     |
| BCM            | Ballycummin                 | BVK            | Ballyvouskill                | CLG            | Cloghran                       |
| BCT            | Bancroft                    | BWR            | Ballywater                   | CLH            | Clahane                        |
| BDA            | Baroda                      | BY             | BallaKelly                   | CLN            | Cloon                          |
| BDN            | Ballydine                   | BYC            | Ballycronan More (Moyle)     | CLO            | Clogher                        |
| BDV            | Barnadivane                 | BYH            | Ballynahulla                 | CLW            | Carlow                         |
| BEG            | Ballybeg                    | CAB            | Cabra                        | CMK            | Curraghmulkin Cluster          |
| BGH            | Boggeragh                   | CAH            | Cahir                        | COL (I)        | College Park                   |

Table A-1 Short Bus Codes (continued)

| Short Bus Code | Full Name                 | Short Bus Code | Full Name                  | Short Bus Code | Full Name             |
|----------------|---------------------------|----------------|----------------------------|----------------|-----------------------|
| COL (N)        | Coleraine Main            | DRY            | Drybridge                  | HTS            | Hartnett's Cross      |
| COO            | Cookstown                 | DSN            | Dunstown                   | IA             | Inniscarra            |
| COR            | Corraclassy               | DTN            | Dardistown                 | IKE            | Ikerrin               |
| COS            | Carrick-on-Shannon        | DUN            | Dungannon Main             | INC            | Inchicore             |
| COW            | Cow Cross                 | DYN            | Derrybrien                 | ISH            | Irishtown             |
| CPK            | Central Park              | EDE            | Eden Main                  | KBY            | Kilbarry              |
| CPS            | Coolkeeragh Power Station | ENN (I)        | Ennis                      | KCR            | Knockacummer          |
| CRA            | Crane                     | ENN (N)        | Enniskillen Main           | KDN            | Kildonan              |
| CRE            | Belfast - Cregagh Main    | FAS            | Fassaroe                   | KEL            | Kells Main            |
| CRF            | Cronacarkfree             | FAS E          | Fassaroe East              | KER            | Knockearagh           |
| CRG            | Creagh Main               | FIN (I)        | Finglas                    | KHL            | Kill Hill             |
| CRM            | Cromcastle                | FIN (N)        | Belfast - Finaghy Main     | KIN            | Kinnegad              |
| CRO            | Coolroe                   | FLA            | Flagford                   | KKY            | Kilkenny              |
| CRY            | Croy                      | FNT            | Finnstown                  | KLM            | Kilmore               |
| CSH            | Cashla                    | FRN            | Francis Street             | KLN            | Killonan              |
| CTG            | Coomataggart              | GAE            | Glanlee                    | KLS            | Kellis                |
| CTN            | Cauteen                   | GAL            | Galway                     | KLW            | Kells Wind Cluster    |
| CTO            | Castletownmoor            | GAR (I)        | Garvagh                    | KMT            | Killymallaght         |
| CTY            | City West                 | GAR (N)        | Garvagh Cluster            | KNO            | Belfast - Knock Main  |
| CUI            | Cuilleen                  | GCA            | Grange Castle              | KNR            | Knockanure            |
| CUL            | Cullenagh                 | GGO            | Glanagow                   | KNV            | Knockavanna           |
| CUN            | Cunghill                  | GI             | Great Island               | KNY            | Knockranny            |
| CUR            | Cureeny                   | GIL            | Gilra                      | KPG            | Kilpaddoge            |
| CUS            | Cushaling                 | GLA            | Glasmore                   | KPN            | Killinaparson         |
| CVW            | Castleview                | GLE (I)        | Glenlara                   | KPS            | Kilroot Power Station |
| DAL            | Dallow                    | GLE (N)        | Belfast - Glengormley Main | KRA            | Knockraha             |
| DDK            | Dundalk                   | GLR            | Glenree                    | KTL            | Kilteel               |
| DER            | Derryiron                 | GLT            | Glentane Macelligot        | KTN            | Killoteran            |
| DFR            | Dunfirth                  | GOL            | Golagh                     | KUD            | Kilmahud              |
| DGN            | Dungarvan                 | GOR (I)        | Gorman                     | KUR            | Knockumber            |
| DLN            | Derrylyn                  | GOR (N)        | Gort Cluster               | LA             | Lanesboro             |
| DLT            | Dalton                    | GRA            | Grange                     | LAR            | Larne Main            |
| DMY            | Dunmanway                 | GRI            | Griffinrath                | LET            | Letterkenny           |
| DON            | Belfast - Donegall Main   | GRO            | Garrow                     | LIB            | Liberty Street        |
| DOO            | Doon                      | GWE            | Gortawee                   | LIM (I)        | Limerick              |
| DRM            | Drumkeen                  | HAN            | Hannastown                 | LIM (N)        | Limavady Main         |
| DRO            | Dromada                   | HAR            | Harolds Cross              | LIS (I)        | Lisdrum               |
| DRU (I)        | Drumline                  | HEU            | Heuston Square             | LIS (N)        | Lisburn Main          |
| DRU(N)         | Drumnakelly Main          | HN             | Huntstown                  | LMR            | Lisaghmore Main       |

Table A-1 Short Bus Codes (continued)

| Short Bus Code | Full Name              | Short Bus Code | Full Name               | Short Bus Code | Full Name        |
|----------------|------------------------|----------------|-------------------------|----------------|------------------|
| LOG            | Loguestown Main        | OLD            | Oldcourt                | SOM            | Somerset         |
| LOU            | Louth                  | OMA            | Omagh Main              | SOR            | Sorne Hill       |
| LPT            | Longpoint              | OMS            | Omagh South Main        | SPR            | Springtown Main  |
| LSE            | Laois                  | ORL            | Oriel                   | SRA            | Srananagh        |
| LSN            | Lisheen                | OST            | Oldstreet               | STR (I)        | Stratford        |
| LWD            | Lodgewood              | OUG            | Oughtragh               | STR (N)        | Strabane Main    |
| MAC            | Macroom                | OWN            | Oweninney               | SUR            | Suir             |
| MAG            | Magherafelt            | PA             | Pollaphuca              | SVN            | Stevenstown      |
| MAL            | Mallow                 | PB             | Poolbeg                 | TAN            | Tandragee        |
| MAY            | Maynooth               | PLA            | Platin                  | TAW            | Tawnaghmore      |
| MCD            | McDermott              | PLS            | Portlaoise              | TB             | Tarbert          |
| MCE            | Macetown               | POP            | Poppintree              | TBG            | Trabeg           |
| MEE            | Meentycat              | PRT            | Portan                  | TBK            | Tullabrack       |
| MID            | Midleton               | POT            | Pottery Road            | TH             | Turlough Hill    |
| MHL            | Misery Hill            | PRO            | Prospect                | THU            | Thurles          |
| MIL            | Milltown               | PTN            | Pelletstown             | TID            | Tidal            |
| MKL            | Magherakeel Cluster    | RAF            | Raffeen                 | TIP            | Tipperary        |
| MLC            | Mountlucas             | RAT (I)        | Rathkeale               | TIV            | Tievebrack       |
| MLN            | Mullagharlin           | RAT (N)        | Rathgael Main           | TLK            | Trillick         |
| MON            | Monread                | RE             | Ringsend                | TLY            | Tanley           |
| MOY            | Moy                    | REM            | Reamore                 | TMN            | Tamnamore        |
| MP             | Moneypoint             | RIC            | Richmond                | TON            | Tonroe           |
| MR             | Marina                 | RNW            | Rinawade                | TRE            | Tremoge Cluster  |
| MRY            | Mulreavy               | ROS            | Belfast - Rosebank Main | TRI            | Trien            |
| MTH            | Meath Hill             | RRU            | Ratrussan               | TRL            | Tralee           |
| MTN            | Moneteen               | RSK            | Rasharkin Cluster       | TRN            | Trinity          |
| MUL            | Mullingar              | RSY            | Ringaskiddy             | TSB            | Thornsberry      |
| MUN            | Mungret                | RYB            | Ryebrook                | TUR            | Turleenan        |
| NAN (I)        | Nangor                 | SAL            | Salthill                | TYN            | Tynagh           |
| NAR            | Newtownards Main       | SBN            | Strabane                | UGL            | Uggool           |
| NAV            | Navan                  | SCR            | Screeb                  | WAR            | Waringstown Main |
| NBY            | Newbury                | SH             | Shannonbridge           | WAT            | Waterford        |
| NEN            | Nenagh                 | SHE            | Shelton Abbey           | WDU            | West Dublin      |
| NEW (I)        | Newbridge              | SHL            | Shellybanks             | WEX            | Wexford          |
| NEW (N)        | Newry Main             | SK             | Sealrock                | WH             | Woodhouse        |
| NMO            | North Mayo             | SKL            | Shankill                | WHI            | Whitegate        |
| NO             | Nore                   | SLI            | Sligo                   | WOL            | Wolfe Tone       |
| NQS            | North Quays            | SLB            | Sliabh Bawn             | WOO            | Woodland         |
| NST            | Newtownstewart Cluster | SLK            | Slieve Kirk             |                |                  |
| NW             | North Wall             | SNG            | Singland                |                |                  |

### A.3 Schematic Diagrams of the All Island Transmission System

Appendix A Schematic diagrams of the Transmission System of Ireland are included to assist users in understanding the Transmission System and in the identification of the changes outlined in Appendix B. Lines, cables, transformers, station busbars and reactive compensation devices are illustrated in the diagrams. The type of generation (thermal, wind, hydro or solar) at a station is also displayed. Table A-2 indicates the diagram conventions.

Appendix B The schematic diagram for 2015 highlights the developments due to be completed by July 2015. The schematic diagram for 2024 highlights the developments due to be completed by the end of 2024.

Appendix C In the 2024 diagram **blue shading** represents a new development since summer 2015.

Appendix D In all diagrams **orange shading** denotes a circuit upgrading. In the 2015 diagram this is any uprate that has occurred since winter 2014. In the 2024 diagrams this is any uprate between summer 2015 and the end of 2024.



Table A-2 Schematic Legend




























| Appendix E Symbol   | Appendix F Network Element Represented   |
|---|--|
|    | 110 kV circuit                           |
|    | 220 kV circuit                           |
|    | 275 kV circuit                           |
|    | 400 kV circuit                           |
|    | System Link                              |
|    | 110 kV Busbar                            |
|    | 220 kV Busbar                            |
|    | 275 kV Busbar                            |
|    | 400 kV Busbar                            |
|    | Busbar with Thermal Generation           |
|    | Busbar with Wind Generation (>5MW)       |
|    | Busbar with Hydro Generation             |
|   | Busbar with Solar Generation             |
|  | Compressed Air and Energy Storage (CAES) |
|  | Busbar with Wind and Thermal Generation  |
|  | Busbar with Wind and Hydro Generation    |
|  | Busbar with Wind and Solar Generation    |
|  | Busbar with Tidal Generation             |
|  | Capacitor                                |
|  | Static Var Compensator (SVC)             |
|  | Reactor                                  |
|  | Phase Shifting Transformer               |
|  | Double-Wound Transformer                 |
|  | Auto-Transformer                         |
|  | Split Busbar                             |
|  | Busbar Operated as Split                 |
|  | Normally Open Point                      |

Figure A-3 Schematic Diagram of the All-Island Transmission System as of July 2015






Figure A-4 Schematic Diagram of the All-Island Transmission System as at Year End 2024





## APPENDIX B: TRANSMISSION SYSTEM CHARACTERISTICS

- B.1 Characteristics of the Existing Transmission System
- B.2 Changes in Transmission System Characteristics



The current. The future.

## Appendix B Transmission System Characteristics

This appendix presents details of the physical and electrical characteristics of the all-island transmission system in tabular form. Data for the existing transmission system is presented first, followed by the data for planned transmission system developments.

The planned developments include transmission system reinforcement projects that have been selected by the TSOs. It also includes developments necessary to connect new generation and demands to the transmission system as at the beginning of October and December 2014.

Readers should refer to Section 1.4 in Chapter 1 of the main text to obtain information on projects approved since the respective data freeze dates.

The following is a list of tables in Section B.1:

- Table B-1 Nominal and Reference Voltage Levels
- Table B-2 Characteristics of Existing 400 kV Lines
- Table B-3 Characteristics of Existing 275 kV Lines and Cables
- Table B-4 Characteristics of Existing 220 kV Lines and Cables
- Table B-5 Characteristics of Existing 110 kV Lines and Cables
- Table B-6 Characteristics of Existing 400/220 kV Transformers
- Table B-7 Characteristics of Existing 275/220 kV Transformers
- Table B-8 Characteristics of Existing 275/110 kV Interbus Transformers
- Table B-9 Characteristics of Existing 275/11.5 kV Generator Transformers
- Table B-10 Characteristics of Existing 220/110 kV Transformers
- Table B-11 Characteristics of Existing Power Flow Controllers
- Table B-12 Characteristics of Existing Reactive Compensation

The following is a list of tables in Section B.2:

- Table B-13 Changes in Circuit Characteristics Expected in 2015
- Table B-14 Changes in Circuit Characteristics Expected in 2016
- Table B-15 Changes in Circuit Characteristics Expected in 2017
- Table B-16 Changes in Circuit Characteristics Expected in 2018
- Table B-17 Changes in Circuit Characteristics Expected after 2018
- Table B-18 Characteristics of 220/110 kV Transformer Changes in Winter 2015
- Table B-19 Characteristics of 400/220 kV Transformer Changes in 2016

Table B-20 Characteristics of 275/110 kV Transformer Changes in 2016

Table B-21 Characteristics of 220/110 kV Transformer Changes in 2016

Table B-22 Characteristics of 220/110 kV Transformer Changes in 2017

Table B-23 Characteristics of 275/110 kV Transformer Changes in 2018

Table B-24 Characteristics of 220/110 kV Transformer Changes in 2018

Table B-25 Characteristics of 400/275 kV Transformer Changes after 2018

Table B-26 Characteristics of 400/220 kV Transformer Changes after 2018

Table B-27 Characteristics of 400/110 kV Transformer Changes after 2018

Table B-28 Characteristics of 275/110 kV Transformer Changes after 2018

Table B-29 Characteristics of 220/110 kV Transformer Changes after 2018

Table B-30 Changes in the Characteristics of Reactive Compensation Expected in 2016

Table B-31 Changes in the Characteristics of Reactive Compensation Expected in 2017

Table B-32 Changes in the Characteristics of Reactive Compensation Expected after 2018

Tables B-2 to B-5 and Tables B-12 to B-17 include the ratings for lines and cables in MVA for winter and summer reference temperature conditions at 1 per unit (p.u.) voltage. The higher ambient temperature in summer dictates a reduced thermal rating for overhead lines. The rating is the maximum permissible power that the circuit can transport on a continuous basis. Reference ambient temperatures are:

winter - 5°C;

summer - 25°C.

Appendix G The electrical characteristics of the all-island transmission system at the four nominal voltage levels are quoted. They are in per unit to an MVA base of 100, and the applicable reference voltage as reflected in Table 8-1.

Table B-1 Nominal and Reference Voltage Levels

| Nominal Voltage Level | Reference Voltage |
|-----------------------|-------------------|
| 400 kV                | 380 kV            |
| 275 kV                | 275 kV            |
| 220 kV                | 220 kV            |
| 110 kV                | 110 kV            |

In some cases, other equipment associated with a line or cable, such as current transformers, may have lower ratings. However, as these are easier to uprate or change out than the line or cable, they are not expected to restrict access to the transmission system.

Historically, a small number of 110 kV stations were connected to the transmission system via a tee. A tee is an un-switched connection into an existing line between two other stations. For the purposes of describing the various sections of lines in the following tables, the tee point is identified by the name of the teed 110 kV station with a suffix "T" added.

## B.1 Characteristics of the Existing Transmission System

Table B-2 Characteristics of Existing 400 kV Lines

| 400 kV Circuits |     |     | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |
|-----------------|-----|-----|-------------|--------------------------------|-------|-------|--------------|--------|
| From            | To  | No. |             | R                              | X     | B     | Summer       | Winter |
| DSN             | MP  | 1   | 208.5       | 0.004                          | 0.047 | 1.049 | 1577         | 1944   |
| MP              | OST | 1   | 105.0       | 0.002                          | 0.023 | 0.530 | 1577         | 1944   |
| OST             | WOO | 1   | 125.0       | 0.0024                         | 0.028 | 0.631 | 1577         | 1944   |
| WOO             | PRN | 1   | 0.5         | 0                              | 0     | 0.043 | 685          | 685    |

Table B-3 Characteristics of Existing 275 kV Lines and Cables

| 275 kV Circuits |     |     | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |        |
|-----------------|-----|-----|-------------|--------------------------------|-------|-------|--------------|--------|--------|
| From            | To  | No. |             | R                              | X     | B     | Summer       | Autumn | Winter |
| LOU             | TAN | 1   | 49.8        | 0.003                          | 0.021 | 0.127 | 710          | 820    | 881    |
| LOU             | TAN | 2   | 49.8        | 0.003                          | 0.021 | 0.127 | 710          | 820    | 881    |
| BPS             | HAN | 2   | 45.5        | 0.002                          | 0.019 | 0.114 | 710          | 820    | 881    |
| BPS             | KEL | 1   | 34.5        | 0.002                          | 0.014 | 0.089 | 710          | 820    | 881    |
| BPS             | MAG | 1   | 65.5        | 0.003                          | 0.027 | 0.169 | 710          | 820    | 881    |
| BPS             | BYC | 1   | 0.8         | 0.000                          | 0.000 | 0.002 | 710          | 820    | 881    |
| CACO2A          | CPS | 1   | 0.2         | 0.000                          | 0.000 | 0.040 | 761          | 761    | 837    |
| CACO2A          | MAG | 1   | 56.0        | 0.006                          | 0.025 | 0.151 | 412          | 477    | 513    |
| CACO2B          | CPS | 1   | 0.2         | 0.000                          | 0.000 | 0.034 | 761          | 761    | 837    |
| CACO2B          | MAG | 1   | 56.0        | 0.006                          | 0.025 | 0.151 | 412          | 477    | 513    |
| CAS             | HAN | 1   | 18.4        | 0.001                          | 0.008 | 0.046 | 710          | 820    | 881    |
| CAS             | HAN | 2   | 18.4        | 0.001                          | 0.008 | 0.046 | 710          | 820    | 881    |
| CAS             | KPS | 1   | 66.8        | 0.003                          | 0.028 | 0.171 | 710          | 820    | 881    |
| CAS             | TAN | 1   | 45.6        | 0.002                          | 0.019 | 0.114 | 710          | 820    | 881    |
| HAN             | BYC | 1   | 44.7        | 0.002                          | 0.019 | 0.112 | 710          | 820    | 881    |
| KEL             | KPS | 1   | 29.0        | 0.001                          | 0.012 | 0.075 | 710          | 820    | 881    |
| KEL             | KPS | 2   | 29.0        | 0.001                          | 0.012 | 0.075 | 710          | 820    | 881    |
| KEL             | MAG | 1   | 31.1        | 0.001                          | 0.013 | 0.080 | 710          | 820    | 881    |
| KPS             | TAN | 1   | 80.8        | 0.004                          | 0.034 | 0.206 | 710          | 820    | 881    |
| MAG             | TAN | 1   | 51.6        | 0.002                          | 0.022 | 0.129 | 710          | 820    | 881    |
| MAG             | TMN | 1   | 25.8        | 0.001                          | 0.011 | 0.065 | 710          | 820    | 881    |
| TAN             | TMN | 1   | 25.8        | 0.001                          | 0.011 | 0.065 | 710          | 820    | 881    |



TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-4 Characteristics of Existing 220 kV Lines and Cables

| 220 kV Circuits |        |     | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |
|-----------------|--------|-----|-------------|--------------------------------|-------|-------|--------------|--------|
| From            | To     | No. |             | R                              | X     | B     | Summer       | Winter |
| AD              | AD     | 1   | 1.4         | 0.000                          | 0.001 | 0.038 | 593          | 593    |
| AD              | KRA    | 1   | 25.6        | 0.003                          | 0.022 | 0.034 | 434          | 534    |
| AD              | RAF    | 1   | 15.2        | 0.001                          | 0.009 | 0.245 | 434          | 534    |
| AD              | LPT    | 1   | 1.0         | 0.000                          | 0.000 | 0.027 | 593          | 593    |
| AD              | GGO    | 1   | 3.8         | 0.000                          | 0.002 | 0.104 | 593          | 593    |
| AD              | KRA    | 2   | 25.6        | 0.003                          | 0.022 | 0.034 | 434          | 534    |
| ARK             | CKM    | 1   | 53.3        | 0.006                          | 0.046 | 0.070 | 434          | 534    |
| ARK             | LWD    | 1   | 39.0        | 0.005                          | 0.034 | 0.051 | 434          | 534    |
| CLA             | KRA    | 1   | 45.0        | 0.006                          | 0.039 | 0.061 | 644          | 788    |
| CLA             | TB     | 1   | 97.3        | 0.011                          | 0.084 | 0.127 | 476          | 476    |
| CSH             | FLA    | 1   | 88.1        | 0.010                          | 0.076 | 0.115 | 405          | 405    |
| CSH             | PRO    | 1   | 88.5        | 0.010                          | 0.077 | 0.116 | 392          | 482    |
| CSH             | TYN    | 1   | 33.8        | 0.005                          | 0.029 | 0.046 | 761          | 804    |
| CKM             | DSN    | 1   | 41.6        | 0.005                          | 0.036 | 0.054 | 434          | 534    |
| CKM             | ISH    | 1   | 11.5        | 0.000                          | 0.005 | 0.315 | 593          | 593    |
| CUL             | GI     | 1   | 23.3        | 0.003                          | 0.020 | 0.045 | 761          | 804    |
| CUL             | KRA    | 1   | 86.0        | 0.012                          | 0.074 | 0.117 | 761          | 804    |
| CDU             | FIN(I) | 1   | 3.7         | 0.001                          | 0.003 | 0.005 | 434          | 534    |
| CDU             | HN     | 1   | 4.5         | 0.000                          | 0.002 | 0.123 | 593          | 593    |
| CDU             | WOO    | 1   | 18.4        | 0.002                          | 0.016 | 0.024 | 434          | 534    |
| CDU             | FIN(I) | 2   | 3.7         | 0.001                          | 0.003 | 0.005 | 434          | 534    |
| CDU             | WOO    | 2   | 17.8        | 0.002                          | 0.016 | 0.023 | 434          | 534    |
| DSN             | KLS    | 1   | 59.3        | 0.007                          | 0.051 | 0.077 | 434          | 534    |
| DSN             | MAY    | 1   | 36.3        | 0.004                          | 0.032 | 0.048 | 434          | 534    |
| DSN             | MAY    | 2   | 30.6        | 0.004                          | 0.027 | 0.040 | 434          | 534    |
| DSN             | TH     | 1   | 26.6        | 0.003                          | 0.022 | 0.144 | 351          | 351    |
| FLA             | LOU    | 1   | 110.1       | 0.013                          | 0.095 | 0.144 | 434          | 534    |
| FLA             | SRA    | 1   | 55.0        | 0.006                          | 0.048 | 0.072 | 434          | 534    |
| FIN(I)          | HN     | 1   | 1.4         | 0.000                          | 0.001 | 0.038 | 593          | 593    |
| FIN(I)          | SHL    | 1   | 13.4        | 0.001                          | 0.005 | 0.367 | 593          | 593    |
| FIN(I)          | NW     | 1   | 11.9        | 0.001                          | 0.004 | 0.680 | 332          | 332    |
| GI              | KLS    | 1   | 69.3        | 0.008                          | 0.060 | 0.091 | 434          | 534    |
| GOR (I)         | LOU    | 1   | 32.4        | 0.004                          | 0.028 | 0.042 | 434          | 534    |
| GOR (I)         | MAY    | 1   | 42.2        | 0.005                          | 0.037 | 0.055 | 434          | 534    |
| GGO             | RAF    | 1   | 9.5         | 0.000                          | 0.005 | 0.414 | 593          | 593    |
| INC             | ISH    | 1   | 12.1        | 0.000                          | 0.005 | 0.330 | 593          | 593    |
| INC             | MAY    | 2   | 19.2        | 0.003                          | 0.017 | 0.025 | 548          | 548    |
| ISH             | SHL    | 1   | 1.3         | 0.000                          | 0.001 | 0.036 | 593          | 593    |
| KRA             | KLN    | 1   | 82.4        | 0.015                          | 0.073 | 0.107 | 512          | 565    |

Table B-4 Characteristics of Existing 220 kV Lines and Cables (continued)

| 220 kV Circuits |     |     | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |
|-----------------|-----|-----|-------------|--------------------------------|-------|-------|--------------|--------|
| From            | To  | No. |             | R                              | X     | B     | Summer       | Winter |
| KRA             | RAF | 1   | 23.4        | 0.003                          | 0.020 | 0.031 | 353          | 454    |
| KLN             | SH  | 1   | 89.7        | 0.014                          | 0.080 | 0.115 | 269          | 377    |
| KLN             | TB  | 1   | 70.6        | 0.008                          | 0.061 | 0.092 | 434          | 534    |
| LOU             | WOO | 1   | 61.2        | 0.007                          | 0.053 | 0.080 | 405          | 454    |
| MAY             | TH  | 1   | 53.1        | 0.006                          | 0.044 | 0.184 | 351          | 351    |
| MAY             | INC | 1   | 19.1        | 0.003                          | 0.016 | 0.026 | 793          | 833    |
| MAY             | SH  | 1   | 105.6       | 0.017                          | 0.094 | 0.135 | 269          | 377    |
| MAY             | WOO | 1   | 22.3        | 0.003                          | 0.020 | 0.030 | 434          | 534    |
| MP              | PRO | 1   | 12.7        | 0.001                          | 0.009 | 0.021 | 868          | 1070   |
| NW              | PB  | 1   | 4.5         | 0.000                          | 0.001 | 0.261 | 332          | 332    |
| OST             | TYN | 1   | 14.5        | 0.002                          | 0.013 | 0.019 | 434          | 534    |
| PB              | SHL | 1   | 0.1         | 0.000                          | 0.000 | 0.003 | 593          | 593    |
| PB              | INC | 1   | 12.5        | 0.001                          | 0.004 | 0.504 | 267          | 267    |
| PB              | INC | 2   | 11.3        | 0.001                          | 0.003 | 0.722 | 267          | 351    |
| PRO             | TB  | 1   | 10.3        | 0.001                          | 0.007 | 0.173 | 467          | 467    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-5 Characteristics of Existing 110 kV Lines and Cables

| 110 kV Circuits |         |     | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |        |
|-----------------|---------|-----|-------------|--------------------------------|-------|-------|--------------|--------|--------|
| From            | To      | No. |             | R                              | X     | B     | Summer       | Autumn | Winter |
| AA              | DRU (I) | 1   | 18.4        | 0.029                          | 0.067 | 0.006 | 99           |        | 125    |
| AA              | ENN (I) | 1   | 32.9        | 0.051                          | 0.114 | 0.012 | 99           |        | 124    |
| AA              | LIM (I) | 1   | 11.7        | 0.007                          | 0.037 | 0.012 | 99           |        | 125    |
| AD              | WHI     | 1   | 3.1         | 0.005                          | 0.011 | 0.001 | 99           |        | 125    |
| AGH             | ENN(N)  | 1   | 31.1        | 0.039                          | 0.095 | 0.019 | 109          | 119    | 124    |
| AGL             | DYN     | 1   | 8.0         | 0.013                          | 0.028 | 0.003 | 105          |        | 128    |
| AGL             | KEE     | 1   | 38.2        | 0.059                          | 0.131 | 0.012 | 99           |        | 128    |
| AGL             | SH      | 1   | 46.2        | 0.072                          | 0.159 | 0.015 | 105          |        | 128    |
| AHA             | KLN     | 1   | 3.8         | 0.004                          | 0.012 | 0.004 | 112          |        | 112    |
| ANR             | DOO     | 1   | 2.0         | 0.003                          | 0.007 | 0.001 | 105          |        | 128    |
| ANT             | KEL     | 1   | 8.9         | 0.012                          | 0.030 | 0.003 | 82           | 95     | 103    |
| ANT             | KEL     | 2   | 8.9         | 0.012                          | 0.030 | 0.003 | 82           | 95     | 103    |
| ARI             | ARI T   | 1   | 0.2         | 0.000                          | 0.001 | 0.000 | 105          |        | 128    |
| ARK             | BEG     | 1   | 21.9        | 0.010                          | 0.079 | 0.007 | 136          |        | 166    |
| ARK             | BOG     | 1   | 29.0        | 0.021                          | 0.095 | 0.010 | 178          |        | 219    |
| ARK             | SHE     | 2   | 2.2         | 0.004                          | 0.008 | 0.001 | 34           |        | 57     |
| ART             | FIN (I) | 1   | 9.0         | 0.005                          | 0.010 | 0.055 | 120          |        | 131    |
| ART             | MCD     | 1   | 4.9         | 0.003                          | 0.006 | 0.030 | 120          |        | 131    |
| ARV             | COS     | 1   | 43          | 0.067                          | 0.148 | 0.014 | 99           |        | 125    |
| ARV             | GWE     | 1   | 30.6        | 0.019                          | 0.099 | 0.011 | 178          |        | 219    |
| ARV             | NAV     | 1   | 65.5        | 0.041                          | 0.213 | 0.023 | 178          |        | 219    |
| ARV             | SKL     | 1   | 18.6        | 0.029                          | 0.065 | 0.006 | 80           |        | 110    |
| ARV             | SKL     | 2   | 23.6        | 0.015                          | 0.076 | 0.010 | 80           |        | 219    |
| ATE             | DRO     | 1   | 5.5         | 0.003                          | 0.003 | 0.064 | 140          |        | 140    |
| ATH             | CUI     | 1   | 2.3         | 0.002                          | 0.003 | 0.023 | 140          |        | 140    |
| ATH             | LA      | 1   | 35.8        | 0.054                          | 0.123 | 0.012 | 105          |        | 128    |
| ATH             | SH      | 1   | 21.6        | 0.014                          | 0.070 | 0.011 | 178          |        | 219    |
| ATY             | CLW     | 1   | 25          | 0.039                          | 0.086 | 0.008 | 99           |        | 125    |
| ATY             | PLS     | 1   | 26.6        | 0.041                          | 0.092 | 0.009 | 99           |        | 125    |
| AUG             | CFM     | 1   | 0.7         | 0.001                          | 0.002 | 0.001 | 96           |        | 96     |
| AUG             | CFM     | 2   | 0.7         | 0.001                          | 0.002 | 0.001 | 96           |        | 96     |
| AUG             | MTN     | 1   | 27.5        | 0.017                          | 0.089 | 0.010 | 178          |        | 219    |
| AUG             | SK      | 3   | 1           | 0.001                          | 0.001 | 0.006 | 120          |        | 131    |
| AUG             | SK      | 4   | 1           | 0.001                          | 0.001 | 0.006 | 120          |        | 131    |
| AUG             | TB      | 1   | 34          | 0.021                          | 0.111 | 0.012 | 152          |        | 152    |
| BAL             | CDU     | 1   | 16.8        | 0.011                          | 0.055 | 0.006 | 178          |        | 219    |
| BAL             | DRY     | 1   | 20          | 0.013                          | 0.065 | 0.007 | 178          |        | 219    |
| BAN (I)         | BRI     | 1   | 2.6         | 0.004                          | 0.009 | 0.001 | 105          |        | 128    |
| BAN (I)         | BRI     | 2   | 2.5         | 0.004                          | 0.009 | 0.001 | 105          |        | 128    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-5 Characteristics of Existing 110 kV Lines and Cables (continued)

| 110 kV Circuits |         |     | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |        |
|-----------------|---------|-----|-------------|--------------------------------|-------|-------|--------------|--------|--------|
| From            | To      | No. |             | R                              | X     | B     | Summer       | Autumn | Winter |
| BAN (I)         | DMY     | 1   | 25.9        | 0.040                          | 0.089 | 0.008 | 99           |        | 125    |
| BAN (I)         | RAF     | 1   | 26.9        | 0.041                          | 0.091 | 0.012 | 105          |        | 128    |
| BAN (N)         | TAN     | 1   | 18.4        | 0.024                          | 0.062 | 0.006 | 82           | 95     | 103    |
| BAN (N)         | TAN     | 2   | 14.2        | 0.019                          | 0.049 | 0.005 | 82           | 95     | 103    |
| BAR             | BAR T   | 1   | 0.3         | 0.000                          | 0.001 | 0.000 | 136          |        | 166    |
| BCT             | CKM     | 1   | 3.1         | 0.002                          | 0.005 | 0.031 | 140          |        | 140    |
| BDA             | MON     | 1   | 12.5        | 0.012                          | 0.037 | 0.031 | 99           |        | 124    |
| BDA             | NEW (I) | 1   | 7.9         | 0.007                          | 0.021 | 0.030 | 120          |        | 124    |
| BDN             | CUL     | 1   | 21.8        | 0.031                          | 0.075 | 0.007 | 196          |        | 222    |
| BDN             | DOO     | 1   | 11.3        | 0.00                           | 0.037 | 0.004 | 178          |        | 219    |
| BEG             | CKM     | 1   | 32.3        | 0.015                          | 0.116 | 0.010 | 136          |        | 166    |
| BGH             | CLA     | 1   | 13.5        | 0.008                          | 0.040 | 0.039 | 178          |        | 219    |
| BIN             | CF      | 1   | 34.3        | 0.053                          | 0.118 | 0.011 | 105          |        | 128    |
| BK              | CBR     | 1   | 37.4        | 0.058                          | 0.128 | 0.013 | 99           |        | 125    |
| BK              | MOY     | 1   | 27          | 0.042                          | 0.093 | 0.009 | 99           |        | 114    |
| BLA             | POT     | 1   | 5.2         | 0.002                          | 0.004 | 0.092 | 119          |        | 119    |
| BLA             | RE      | 1   | 7.7         | 0.003                          | 0.006 | 0.136 | 119          |        | 119    |
| BLI             | DMY     | 1   | 27.6        | 0.043                          | 0.094 | 0.010 | 105          |        | 128    |
| BLK             | BLK T   | 1   | 0.5         | 0.001                          | 0.002 | 0.000 | 136          |        | 166    |
| BMA             | KEL     | 1   | 10          | 0.013                          | 0.035 | 0.003 | 109          | 119    | 124    |
| BMA             | KEL     | 2   | 11.5        | 0.015                          | 0.040 | 0.004 | 109          | 119    | 124    |
| BNH             | CAS     | 1   | 21.2        | 0.028                          | 0.071 | 0.007 | 82           | 95     | 103    |
| BNH             | CAS     | 2   | 21.2        | 0.028                          | 0.071 | 0.007 | 82           | 95     | 103    |
| BOG             | CRA     | 1   | 24.7        | 0.018                          | 0.081 | 0.009 | 178          |        | 219    |
| BOL             | ENN (I) | 1   | 24          | 0.037                          | 0.083 | 0.008 | 105          |        | 128    |
| BOL             | TBK T   | 1   | 19.6        | 0.031                          | 0.067 | 0.006 | 105          |        | 128    |
| BPS             | BVG     | 1   | 17.3        | 0.023                          | 0.058 | 0.006 | 82           | 95     | 103    |
| BPS             | BVG     | 2   | 17.3        | 0.023                          | 0.058 | 0.006 | 82           | 95     | 103    |
| BPS             | EDE     | 1   | 15.1        | 0.023                          | 0.054 | 0.005 | 69           | 80     | 86     |
| BPS             | EDE     | 2   | 15.1        | 0.023                          | 0.053 | 0.005 | 70           | 81     | 87     |
| BRY             | RAF     | 1   | 1.7         | 0.003                          | 0.006 | 0.001 | 63           |        | 99     |
| BRY             | RAF     | 2   | 1.8         | 0.002                          | 0.006 | 0.001 | 105          |        | 128    |
| BUT             | CUL     | 1   | 12.3        | 0.08                           | 0.04  | 0.013 | 178          |        | 219    |
| BUT             | KTN     | 1   | 2.7         | 0.004                          | 0.010 | 0.001 | 200          |        | 221    |
| BVG             | KEL     | 1   | 21.2        | 0.028                          | 0.073 | 0.007 | 109          | 119    | 124    |
| BVG             | KEL     | 2   | 20.3        | 0.027                          | 0.070 | 0.007 | 109          | 119    | 124    |
| BVG             | LAR     | 1   | 7.1         | 0.007                          | 0.023 | 0.002 | 79           | 96     | 113    |
| BVG             | LAR     | 2   | 7.1         | 0.007                          | 0.023 | 0.002 | 79           | 96     | 113    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-5 Characteristics of Existing 110 kV Lines and Cables (continued)

| 110 kV Circuits |         |     | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |        |
|-----------------|---------|-----|-------------|--------------------------------|-------|-------|--------------|--------|--------|
| From            | To      | No. |             | R                              | X     | B     | Summer       | Autumn | Winter |
| BWR             | CRA     | 1   | 21.9        | 0.011                          | 0.030 | 0.137 | 116          |        | 116    |
| CAB             | PTN     | 1   | 2.7         | 0.002                          | 0.007 | 0.005 | 80           |        | 129    |
| CAB             | WOL     | 1   | 4.7         | 0.003                          | 0.005 | 0.029 | 120          |        | 131    |
| CAH             | BAR T   | 1   | 43.7        | 0.065                          | 0.150 | 0.014 | 105          |        | 128    |
| CAH             | DOO     | 1   | 15.7        | 0.010                          | 0.051 | 0.006 | 178          |        | 219    |
| CAH             | KHL     | 1   | 21.8        | 0.013                          | 0.066 | 0.033 | 178          |        | 219    |
| CAH             | TIP     | 1   | 18.1        | 0.011                          | 0.059 | 0.006 | 105          |        | 219    |
| CAR             | CAS     | 1   | 24.7        | 0.037                          | 0.088 | 0.008 | 69           | 80     | 86     |
| CAR             | CAS     | 2   | 24.7        | 0.037                          | 0.086 | 0.008 | 70           | 81     | 87     |
| CAR             | EDE     | 1   | 12.4        | 0.019                          | 0.043 | 0.004 | 70           | 81     | 87     |
| CAR             | EDE     | 2   | 12.4        | 0.019                          | 0.044 | 0.004 | 69           | 80     | 86     |
| CAS             | CRE     | 1   | 3           | 0.001                          | 0.004 | 0.061 | 132          | 132    | 145    |
| CAS             | CRE     | 2   | 3           | 0.001                          | 0.004 | 0.061 | 132          | 132    | 145    |
| CAS             | KNO     | 2   | 4.5         | 0.005                          | 0.004 | 0.044 | 66           | 66     | 73     |
| CAS             | NAR     | 1   | 18          | 0.015                          | 0.040 | 0.071 | 109          | 119    | 124    |
| CAS             | NAR     | 2   | 19.8        | 0.018                          | 0.046 | 0.070 | 109          | 119    | 124    |
| CAS             | RAT (N) | 1   | 18.9        | 0.025                          | 0.064 | 0.006 | 82           | 95     | 103    |
| CAS             | RAT (N) | 2   | 18.9        | 0.025                          | 0.064 | 0.006 | 82           | 95     | 103    |
| CAS             | ROS     | 1   | 1.9         | 0.001                          | 0.002 | 0.026 | 117          | 117    | 128    |
| CAS             | ROS     | 2   | 1.9         | 0.001                          | 0.002 | 0.026 | 117          | 117    | 128    |
| CBL             | TRI     | 1   | 13.8        | 0.009                          | 0.029 | 0.090 | 124          |        | 124    |
| CBR             | CBG     | 1   | 26.5        | 0.038                          | 0.083 | 0.052 | 99           |        | 124    |
| CBR             | CLN     | 1   | 57.5        | 0.089                          | 0.198 | 0.020 | 99           |        | 125    |
| CBR             | DLT     | 1   | 27.8        | 0.043                          | 0.096 | 0.009 | 90           |        | 95     |
| CD              | KBY     | 1   | 32.1        | 0.020                          | 0.104 | 0.011 | 178          |        | 219    |
| CD              | MAC     | 1   | 2.4         | 0.004                          | 0.008 | 0.001 | 99           |        | 219    |
| CDK             | LWD     | 1   | 6.6         | 0.003                          | 0.009 | 0.041 | 116          |        | 116    |
| CDU             | MUL     | 1   | 73.3        | 0.088                          | 0.237 | 0.041 | 105          |        | 128    |
| CDU             | PLA     | 1   | 37          | 0.023                          | 0.120 | 0.013 | 178          |        | 219    |
| CDU             | RYB     | 1   | 13          | 0.014                          | 0.043 | 0.005 | 178          |        | 219    |
| CDY             | ARI T   | 1   | 13.7        | 0.014                          | 0.046 | 0.005 | 136          |        | 166    |
| CDY             | GRV     | 1   | 7.3         | 0.005                          | 0.024 | 0.003 | 178          |        | 219    |
| CDY             | SRA     | 1   | 12.7        | 0.020                          | 0.044 | 0.004 | 99           |        | 125    |
| CEN             | CRE     | 1   | 4.2         | 0.001                          | 0.004 | 0.030 | 144          | 144    | 144    |
| CEN             | CRE     | 2   | 4.2         | 0.001                          | 0.004 | 0.030 | 144          | 144    | 144    |
| CF              | CL      | 1   | 5.5         | 0.006                          | 0.018 | 0.002 | 178          |        | 219    |
| CF              | COR     | 1   | 61.3        | 0.039                          | 0.199 | 0.022 | 178          |        | 219    |
| CF              | DRM     | 1   | 51.3        | 0.077                          | 0.176 | 0.017 | 99           |        | 125    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-5 Characteristics of Existing 110 kV Lines and Cables (continued)

| 110 kV Circuits |         |     | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |        |
|-----------------|---------|-----|-------------|--------------------------------|-------|-------|--------------|--------|--------|
| From            | To      | No. |             | R                              | X     | B     | Summer       | Autumn | Winter |
| CF              | GOL T   | 1   | 25.5        | 0.036                          | 0.093 | 0.009 | 196          |        | 222    |
| CF              | SRA     | 1   | 53          | 0.065                          | 0.179 | 0.021 | 187          |        | 190    |
| CGL             | BVK     | 1   | 30          | 0.019                          | 0.098 | 0.011 | 178          |        | 219    |
| CGL             | CKN     | 1   | 6.3         | 0.004                          | 0.021 | 0.002 | 178          |        | 219    |
| CGL             | GAE     | 1   | 2           | 0.001                          | 0.003 | 0.015 | 130          |        | 130    |
| CHA             | GLE (I) | 1   | 30          | 0.047                          | 0.103 | 0.010 | 105          |        | 128    |
| CKM             | CPK     | 1   | 0.1         | 0.000                          | 0.000 | 0.000 | 136          |        | 166    |
| CKM             | POT     | 1   | 3.2         | 0.001                          | 0.003 | 0.057 | 119          |        | 119    |
| CKN             | KER     | 1   | 20.3        | 0.013                          | 0.066 | 0.007 | 178          |        | 219    |
| CLA             | CKN     | 1   | 29.8        | 0.019                          | 0.097 | 0.011 | 178          |        | 219    |
| CLA             | MAC     | 1   | 5.7         | 0.004                          | 0.018 | 0.002 | 160          |        | 196    |
| CLG             | KDN     | 1   | 3.6         | 0.004                          | 0.011 | 0.007 | 124          |        | 124    |
| CLG             | MCE     | 1   | 4.7         | 0.005                          | 0.015 | 0.005 | 99           |        | 125    |
| CLH             | TRI     | 1   | 9           | 0.014                          | 0.031 | 0.003 | 99           |        | 125    |
| CLH             | TRL     | 1   | 13.5        | 0.020                          | 0.045 | 0.025 | 105          |        | 128    |
| CLN             | LA      | 1   | 64.8        | 0.095                          | 0.222 | 0.021 | 99           |        | 125    |
| CLW             | KLS     | 1   | 5.4         | 0.008                          | 0.019 | 0.002 | 99           |        | 125    |
| CLW             | KLS     | 2   | 5.3         | 0.008                          | 0.019 | 0.002 | 99           |        | 125    |
| CLW             | STR (I) | 1   | 17.6        | 0.027                          | 0.061 | 0.006 | 105          |        | 128    |
| COL (I)         | CDU     | 1   | 2.7         | 0.001                          | 0.004 | 0.020 | 130          |        | 130    |
| COL (I)         | KDN     | 1   | 5           | 0.003                          | 0.013 | 0.037 | 104          |        | 124    |
| COL (N)         | CPS     | 1   | 46.7        | 0.061                          | 0.161 | 0.015 | 82           | 95     | 103    |
| COL (N)         | KEL     | 1   | 58.9        | 0.067                          | 0.201 | 0.020 | 109          | 119    | 124    |
| COL (N)         | LIM (N) | 1   | 18.6        | 0.024                          | 0.064 | 0.006 | 82           | 95     | 103    |
| COL (N)         | LOG     | 1   | 8.1         | 0.011                          | 0.027 | 0.003 | 82           | 95     | 103    |
| COL (N)         | LOG     | 2   | 8.1         | 0.011                          | 0.027 | 0.003 | 82           | 95     | 103    |
| COO             | BCT     | 1   | 15.1        | 0.014                          | 0.045 | 0.027 | 130          |        | 130    |
| COO             | CKM     | 2   | 16          | 0.013                          | 0.042 | 0.060 | 130          |        | 130    |
| COR             | ENN(I)  | 1   | 27.5        | 0.043                          | 0.095 | 0.009 | 105          |        | 128    |
| COR             | GWE     | 1   | 10.9        | 0.007                          | 0.036 | 0.004 | 161          |        | 196    |
| COS             | ARI T   | 1   | 20.7        | 0.022                          | 0.069 | 0.007 | 120          |        | 128    |
| COS             | FLA     | 1   | 3.4         | 0.005                          | 0.012 | 0.001 | 99           |        | 125    |
| COS             | FLA     | 2   | 3.4         | 0.005                          | 0.011 | 0.001 | 99           |        | 125    |
| COW             | CVW     | 1   | 17.2        | 0.025                          | 0.054 | 0.018 | 99           |        | 125    |
| COW             | OLD     | 1   | 2.3         | 0.004                          | 0.008 | 0.001 | 105          |        | 128    |
| COW             | OLD     | 2   | 2.2         | 0.003                          | 0.008 | 0.001 | 105          |        | 128    |
| COW             | RAF     | 1   | 6.9         | 0.010                          | 0.024 | 0.003 | 99           |        | 125    |
| COW             | WHI     | 1   | 17.8        | 0.027                          | 0.062 | 0.006 | 105          |        | 128    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-5 Characteristics of Existing 110 kV Lines and Cables (continued)

| 110 kV Circuits |         |     | Length (km) | Impedance p.u. on 100 MVA base |        |       | Rating (MVA) |        |        |
|-----------------|---------|-----|-------------|--------------------------------|--------|-------|--------------|--------|--------|
| From            | To      | No. |             | R                              | X      | B     | Summer       | Autumn | Winter |
| CPK             | TLY     | 1   | 5.6         | 0.003                          | 0.006  | 0.073 | 100          |        | 100    |
| CPK             | CPK T   | 1   | 3.4         | 0.002                          | 0.004  | 0.025 | 100          |        | 100    |
| CPS             | KMT     | 1   | 14.5        | 0.011                          | 0.048  | 0.005 | 143          | 158    | 166    |
| CPS             | LIM (N) | 1   | 29.5        | 0.039                          | 0.101  | 0.010 | 82           | 95     | 103    |
| CPS             | LMR     | 1   | 9           | 0.012                          | 0.030  | 0.003 | 82           | 95     | 103    |
| CPS             | LMR     | 1   | 9           | 0.012                          | 0.030  | 0.003 | 82           | 95     | 103    |
| CPS             | SPR     | 1   | 9.2         | 0.011                          | 0.029  | 0.012 | 82           | 95     | 103    |
| CPS             | SPR     | 2   | 9.4         | 0.011                          | 0.029  | 0.013 | 82           | 95     | 103    |
| CPS             | STR (N) | 1   | 27          | 0.018                          | 0.053  | 0.017 | 143          | 158    | 166    |
| CRA             | LWD     | 1   | 8           | 0.005                          | 0.026  | 0.003 | 178          |        | 219    |
| CRA             | WEX     | 1   | 21.3        | 0.022                          | 0.071  | 0.007 | 136          |        | 166    |
| CRG             | DUN     | 1   | 37.4        | 0.047                          | 0.125  | 0.017 | 82           | 95     | 103    |
| CRG             | KEL     | 1   | 23.1        | 0.029                          | 0.077  | 0.013 | 82           | 95     | 103    |
| CRM             | KLM     | 1   | 1.4         | 0.001                          | 0.002  | 0.014 | 140          |        | 140    |
| CRM             | KLM     | 2   | 1.4         | 0.001                          | 0.002  | 0.014 | 140          |        | 140    |
| CRO             | IA      | 1   | 2.7         | 0.004                          | 0.0010 | 0.001 | 196          |        | 222    |
| CRO             | KBY     | 1   | 14.4        | 0.009                          | 0.047  | 0.005 | 178          |        | 219    |
| CSH             | CLN     | 1   | 22.8        | 0.014                          | 0.074  | 0.008 | 178          |        | 219    |
| CSH             | DLT     | 1   | 60.8        | 0.075                          | 0.205  | 0.020 | 99           |        | 125    |
| CSH             | ENN (I) | 1   | 53.5        | 0.034                          | 0.174  | 0.019 | 178          |        | 219    |
| CSH             | GAL     | 1   | 13.8        | 0.022                          | 0.048  | 0.005 | 99           |        | 125    |
| CSH             | GAL     | 2   | 11.3        | 0.018                          | 0.039  | 0.004 | 99           |        | 125    |
| CSH             | GAL     | 3   | 11.3        | 0.018                          | 0.039  | 0.004 | 99           |        | 125    |
| CSH             | SAL     | 1   | 24.9        | 0.025                          | 0.072  | 0.068 | 99           |        | 105    |
| CSH             | SOM T   | 1   | 50          | 0.078                          | 0.172  | 0.016 | 99           |        | 125    |
| CTN             | KLN     | 1   | 28.1        | 0.044                          | 0.098  | 0.009 | 105          |        | 128    |
| CTN             | TIP     | 1   | 13.2        | 0.008                          | 0.043  | 0.005 | 105          |        | 129    |
| CTY             | COO     | 1   | 2.9         | 0.004                          | 0.010  | 0.001 | 103          |        | 128    |
| CTY             | INC     | 1   | 8.9         | 0.011                          | 0.030  | 0.003 | 103          |        | 128    |
| CUL             | DGN     | 1   | 34.2        | 0.022                          | 0.109  | 0.020 | 178          |        | 219    |
| CUL             | WAT     | 1   | 13.1        | 0.006                          | 0.033  | 0.055 | 178          |        | 219    |
| CUN             | GLR     | 1   | 25.9        | 0.037                          | 0.095  | 0.009 | 178          |        | 219    |
| CUN             | SLI     | 1   | 21.3        | 0.033                          | 0.073  | 0.007 | 99           |        | 126    |
| CUS             | MLC     | 1   | 13.7        | 0.015                          | 0.048  | 0.005 | 136          |        | 166    |
| CUS             | NEW (I) | 1   | 24.6        | 0.026                          | 0.082  | 0.008 | 136          |        | 166    |
| CUS             | PLS     | 1   | 42.1        | 0.044                          | 0.140  | 0.014 | 136          |        | 166    |
| CVW             | DKL     | 1   | 0.4         | 0.001                          | 0.001  | 0.000 | 105          |        | 128    |
| CVW             | KRA     | 1   | 7.6         | 0.012                          | 0.026  | 0.004 | 99           |        | 125    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-5 Characteristics of Existing 110 kV Lines and Cables (continued)

| 110 kV Circuits |         |     | Length (Km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |        |
|-----------------|---------|-----|-------------|--------------------------------|-------|-------|--------------|--------|--------|
| From            | To      | No. |             | R                              | X     | B     | Summer       | Autumn | Winter |
| DAL             | DAL T   | 1   | 12.2        | 0.019                          | 0.042 | 0.004 | 105          |        | 128    |
| DAL T           | KPN     | 1   | 25.5        | 0.016                          | 0.083 | 0.009 | 178          |        | 219    |
| DDK             | LOU     | 1   | 16.8        | 0.026                          | 0.058 | 0.005 | 105          |        | 128    |
| DDK             | MLN     | 1   | 7.5         | 0.012                          | 0.026 | 0.003 | 105          |        | 128    |
| DER             | KIN     | 1   | 15.1        | 0.012                          | 0.050 | 0.005 | 99           |        | 125    |
| DER             | MAY     | 1   | 43          | 0.027                          | 0.139 | 0.018 | 74           |        | 93     |
| DER             | TSB     | 1   | 19.7        | 0.031                          | 0.068 | 0.006 | 105          |        | 128    |
| DFR             | DFR T   | 1   | 0.1         | 0.000                          | 0.000 | 0.000 | 105          |        | 128    |
| DGN             | WH      | 1   | 8.7         | 0.006                          | 0.028 | 0.003 | 178          |        | 219    |
| DMY             | MAC     | 1   | 26.2        | 0.037                          | 0.096 | 0.009 | 120          |        | 222    |
| DON             | FIN (N) | 1   | 3.7         | 0.004                          | 0.011 | 0.008 | 69           | 80     | 86     |
| DON             | FIN (N) | 2   | 3.7         | 0.004                          | 0.011 | 0.007 | 69           | 80     | 86     |
| DON             | HAN     | 1   | 5.8         | 0.002                          | 0.005 | 0.140 | 144          | 144    | 158    |
| DON             | HAN     | 2   | 5.8         | 0.002                          | 0.005 | 0.140 | 144          | 144    | 158    |
| DON             | BNM     | 1   | 6.3         | 0.006                          | 0.006 | 0.066 | 75           | 75     | 82     |
| DON             | BNM     | 2   | 6.3         | 0.006                          | 0.006 | 0.066 | 75           | 75     | 82     |
| DRM             | LET     | 1   | 8.3         | 0.013                          | 0.028 | 0.003 | 105          |        | 128    |
| DRM             | MEE     | 1   | 5           | 0.008                          | 0.017 | 0.002 | 105          |        | 128    |
| DRU (I)         | ENN (I) | 1   | 17.4        | 0.027                          | 0.060 | 0.006 | 99           |        | 125    |
| DRU (N)         | DUN     | 1   | 25.5        | 0.033                          | 0.087 | 0.009 | 82           | 95     | 103    |
| DRU (N)         | DUN     | 2   | 28.7        | 0.037                          | 0.095 | 0.010 | 82           | 95     | 103    |
| DRU (N)         | TAN     | 1   | 4.4         | 0.004                          | 0.014 | 0.002 | 79           | 96     | 113    |
| DRU (N)         | TAN     | 2   | 4.4         | 0.004                          | 0.014 | 0.002 | 79           | 96     | 113    |
| DRU (N)         | TAN     | 3   | 4.1         | 0.005                          | 0.014 | 0.001 | 79           | 96     | 113    |
| DRY             | GOR (I) | 1   | 19.4        | 0.029                          | 0.067 | 0.006 | 99           |        | 125    |
| DRY             | LOU     | 1   | 31.9        | 0.020                          | 0.104 | 0.011 | 178          |        | 219    |
| DRY             | PLA     | 1   | 5.3         | 0.008                          | 0.018 | 0.002 | 105          |        | 128    |
| DTN             | FIN (I) | 1   | 9.2         | 0.002                          | 0.014 | 0.111 | 140          |        | 140    |
| DTN             | KLM     | 1   | 3.2         | 0.002                          | 0.005 | 0.032 | 140          |        | 140    |
| DUN             | OMA     | 1   | 36.1        | 0.042                          | 0.124 | 0.012 | 150          | 150    | 150    |
| DUN             | OMA     | 2   | 39.5        | 0.047                          | 0.135 | 0.013 | 150          | 150    | 150    |
| DUN             | TMN     | 1   | 5.9         | 0.004                          | 0.017 | 0.005 | 132          |        | 152    |
| ENN (N)         | OMA     | 1   | 33.8        | 0.044                          | 0.113 | 0.011 | 82           | 95     | 103    |
| ENN (N)         | OMA     | 2   | 33.7        | 0.044                          | 0.113 | 0.011 | 82           | 95     | 103    |
| FAS             | CKM     | 1   | 7.5         | 0.012                          | 0.026 | 0.002 | 105          |        | 128    |
| FIN (I)         | GLA     | 1   | 14          | 0.022                          | 0.048 | 0.005 | 105          |        | 128    |
| FIN (I)         | GRA     | 1   | 13.2        | 0.005                          | 0.012 | 0.236 | 119          |        | 119    |
| FIN (I)         | MCD     | 1   | 7.9         | 0.003                          | 0.007 | 0.141 | 119          |        | 119    |



Table B-5 Characteristics of Existing 110 kV Lines and Cables (continued)

| 110 kV Circuits      |       |     | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |        |
|----------------------|-------|-----|-------------|--------------------------------|-------|-------|--------------|--------|--------|
| From                 | To    | No. |             | R                              | X     | B     | Summer       | Autumn | Winter |
| FIN (I)              | POP   | 1   | 4.3         | 0.002                          | 0.005 | 0.026 | 120          |        | 131    |
| FIN (I)              | PTN   | 1   | 3.5         | 0.003                          | 0.010 | 0.006 | 80           |        | 129    |
| FIN (I)              | SVN   | 1   | 32.2        | 0.039                          | 0.104 | 0.056 | 105          |        | 115    |
| FIN (N)              | HAN   | 1   | 3.1         | 0.001                          | 0.003 | 0.022 | 144          | 144    | 144    |
| FIN (N)              | HAN   | 2   | 3.1         | 0.001                          | 0.003 | 0.022 | 144          | 144    | 144    |
| FLA                  | GIL   | 1   | 10.6        | 0.017                          | 0.037 | 0.003 | 105          |        | 128    |
| FLA                  | LA    | 1   | 30.6        | 0.048                          | 0.105 | 0.010 | 99           |        | 125    |
| FLA                  | SLI   | 1   | 50.5        | 0.079                          | 0.174 | 0.016 | 105          |        | 128    |
| FLA                  | TON   | 1   | 32.3        | 0.050                          | 0.111 | 0.010 | 99           |        | 126    |
| FRN                  | HAR   | 1   | 2.3         | 0.002                          | 0.004 | 0.030 | 107          |        | 107    |
| FRN                  | HEU   | 1   | 2.4         | 0.002                          | 0.004 | 0.024 | 140          |        | 140    |
| FRN                  | INC   | 1   | 5.6         | 0.004                          | 0.010 | 0.073 | 107          |        | 107    |
| FRN                  | MHL   | 1   | 4.2         | 0.003                          | 0.006 | 0.042 | 140          |        | 140    |
| GAL                  | SAL   | 1   | 6.1         | 0.004                          | 0.009 | 0.061 | 105          |        | 105    |
| GCA                  | GRI   | 1   | 8.9         | 0.009                          | 0.029 | 0.006 | 103          |        | 131    |
| GCA                  | INC   | 1   | 8.1         | 0.008                          | 0.025 | 0.009 | 103          |        | 143    |
| GCA                  | INC   | 2   | 8.1         | 0.008                          | 0.025 | 0.009 | 103          |        | 143    |
| GCA                  | INC   | 3   | 7.7         | 0.005                          | 0.004 | 0.004 | 103          |        | 124    |
| GCA                  | KUD   | 1   | 2.1         | 0.002                          | 0.003 | 0.021 | 140          |        | 140    |
| GCA                  | KUD   | 2   | 2.1         | 0.002                          | 0.003 | 0.021 | 140          |        | 140    |
| GCA                  | NAN   | 1   | 1.8         | 0.001                          | 0.002 | 0.011 | 120          |        | 131    |
| GCA                  | NAN   | 2   | 1.7         | 0.001                          | 0.002 | 0.011 | 120          |        | 131    |
| GCA                  | GRI T | 1   | 8.9         | 0.009                          | 0.029 | 0.006 | 103          |        | 131    |
| GI                   | KKY   | 1   | 49.2        | 0.077                          | 0.169 | 0.016 | 99           |        | 125    |
| GI                   | WAT   | 1   | 11.7        | 0.007                          | 0.038 | 0.004 | 178          |        | 219    |
| GI                   | WAT   | 2   | 12.9        | 0.008                          | 0.042 | 0.005 | 178          |        | 219    |
| GI                   | WEX   | 1   | 34.5        | 0.054                          | 0.119 | 0.011 | 99           |        | 125    |
| GLE (N) <sup>1</sup> | KEL   | 1   | 21.4        | 0.027                          | 0.068 | 0.027 | 82           | 82     | 90     |
| GLE (N) <sup>2</sup> | KEL   | 1   | 21.4        | 0.027                          | 0.068 | 0.027 | 82           | 82     | 90     |
| GOL                  | GOL T | 1   | 3.9         | 0.006                          | 0.014 | 0.001 | 105          |        | 128    |
| GOR (I)              | MTH   | 1   | 27.3        | 0.028                          | 0.090 | 0.013 | 99           |        | 125    |
| GOR (I)              | NAV   | 1   | 5.3         | 0.008                          | 0.019 | 0.002 | 99           |        | 125    |
| GOR (I)              | NAV   | 2   | 6.3         | 0.009                          | 0.022 | 0.002 | 99           |        | 125    |
| GOR (I)              | NAV   | 3   | 6.5         | 0.007                          | 0.022 | 0.002 | 99           |        | 125    |
| GOR (I)              | PLA   | 1   | 19.7        | 0.030                          | 0.068 | 0.006 | 103          |        | 143    |

<sup>1</sup> Glengormely A section<sup>2</sup> Glengormely B section

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-5 Characteristics of Existing 110 kV Lines and Cables (continued)

| 110 kV Circuits |         |     | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |        |
|-----------------|---------|-----|-------------|--------------------------------|-------|-------|--------------|--------|--------|
| From            | To      | No. |             | R                              | X     | B     | Summer       | Autumn | Winter |
| GRA             | NBY     | 1   | 5.1         | 0.002                          | 0.005 | 0.089 | 119          |        | 119    |
| GRI             | GRI T   | 1   | 1           | 0.002                          | 0.004 | 0.000 | 105          |        | 128    |
| GRO             | CKN     | 1   | 15.2        | 0.008                          | 0.014 | 0.150 | 120          |        | 120    |
| HAN             | LIS (N) | 1   | 9.2         | 0.010                          | 0.026 | 0.018 | 82           | 95     | 103    |
| HAR             | RE      | 1   | 5.6         | 0.005                          | 0.010 | 0.073 | 107          |        | 107    |
| HEU             | INC     | 1   | 3.6         | 0.003                          | 0.005 | 0.036 | 140          |        | 140    |
| IA              | MAC     | 1   | 18.6        | 0.027                          | 0.068 | 0.006 | 211          |        | 222    |
| IKE             | IKE T   | 1   | 0.2         | 0.000                          | 0.001 | 0.000 | 80           |        | 129    |
| INC             | COO     | 1   | 6.2         | 0.006                          | 0.016 | 0.029 | 136          |        | 140    |
| INC             | MIL     | 1   | 8.4         | 0.004                          | 0.009 | 0.051 | 120          |        | 131    |
| KCR             | GLE (I) | 1   | 11.2        | 0.008                          | 0.017 | 0.115 | 140          |        | 140    |
| KRA             | WH      | 1   | 45.4        | 0.029                          | 0.147 | 0.016 | 178          |        | 219    |
| KER             | OUG T   | 1   | 22.6        | 0.014                          | 0.074 | 0.008 | 178          |        | 219    |
| KHL             | THU     | 1   | 21.8        | 0.013                          | 0.066 | 0.033 | 178          |        | 219    |
| KIN             | DFR T   | 1   | 29.3        | 0.021                          | 0.096 | 0.010 | 99           |        | 125    |
| KKY             | KLS     | 1   | 34.3        | 0.053                          | 0.118 | 0.011 | 99           |        | 125    |
| KLM             | NBY     | 1   | 1.2         | 0.001                          | 0.001 | 0.020 | 119          |        | 119    |
| KLM             | POP     | 1   | 6           | 0.003                          | 0.007 | 0.037 | 120          |        | 131    |
| KLN             | LIM (I) | 1   | 9           | 0.014                          | 0.031 | 0.003 | 99           |        | 125    |
| KLN             | SNG     | 1   | 4.1         | 0.003                          | 0.013 | 0.003 | 178          |        | 219    |
| KMT             | SLK     | 1   | 6.2         | 0.007                          | 0.018 | 0.006 | 98           | 105    | 110    |
| KMT             | STR (N) | 1   | 11.2        | 0.008                          | 0.037 | 0.004 | 143          | 158    | 166    |
| KRA             | BAR     | 1   | 19.5        | 0.020                          | 0.065 | 0.007 | 136          |        | 166    |
| KRA             | KBY     | 1   | 11.9        | 0.008                          | 0.039 | 0.004 | 178          |        | 219    |
| KRA             | KBY     | 2   | 12.5        | 0.018                          | 0.043 | 0.004 | 99           |        | 125    |
| KRA             | MID     | 1   | 10.7        | 0.017                          | 0.037 | 0.004 | 99           |        | 125    |
| KTL             | MAY     | 1   | 21.4        | 0.022                          | 0.072 | 0.007 | 99           |        | 125    |
| KTL             | MON     | 1   | 8.9         | 0.009                          | 0.030 | 0.003 | 136          |        | 166    |
| KTN             | WAT     | 1   | 5           | 0.004                          | 0.008 | 0.050 | 99           |        | 125    |
| KUR             | NAV     | 1   | 6.1         | 0.010                          | 0.021 | 0.002 | 105          |        | 128    |
| LA              | MUL     | 1   | 46.3        | 0.072                          | 0.160 | 0.015 | 105          |        | 128    |
| LA              | RIC     | 1   | 15.7        | 0.024                          | 0.054 | 0.007 | 105          |        | 128    |
| LET             | GOL T   | 1   | 38.4        | 0.058                          | 0.132 | 0.012 | 103          |        | 128    |
| LET             | STR (N) | 1   | 22.3        | 0.035                          | 0.077 | 0.007 | 105          |        | 128    |
| LET             | TLK     | 1   | 34.9        | 0.054                          | 0.120 | 0.013 | 105          |        | 128    |
| LIB             | MR      | 1   | 2.7         | 0.001                          | 0.003 | 0.017 | 100          |        | 100    |
| LIM (I)         | KLN     | 1   | 11.7        | 0.018                          | 0.040 | 0.009 | 80           |        | 110    |
| LIM (I)         | MTN     | 1   | 6.5         | 0.005                          | 0.025 | 0.003 | 178          |        | 219    |

## TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-5 Characteristics of Existing 110 kV Lines and Cables (continued)

| 110 kV Circuits |         |     | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |        |
|-----------------|---------|-----|-------------|--------------------------------|-------|-------|--------------|--------|--------|
| From            | To      | No. |             | R                              | X     | B     | Summer       | Autumn | Winter |
| LIM (I)         | RAT (I) | 1   | 29.1        | 0.044                          | 0.101 | 0.012 | 99           |        | 125    |
| LIS (I)         | LOU     | 1   | 40.4        | 0.063                          | 0.139 | 0.013 | 105          |        | 128    |
| LIS (I)         | SKL     | 1   | 39.3        | 0.061                          | 0.135 | 0.013 | 105          |        | 128    |
| LIS (N)         | TAN     | 1   | 31          | 0.040                          | 0.106 | 0.010 | 82           | 95     | 103    |
| LIS (N)         | TAN     | 2   | 29.2        | 0.034                          | 0.100 | 0.009 | 80           | 93     | 100    |
| LOU             | MLN     | 1   | 13          | 0.020                          | 0.045 | 0.004 | 105          |        | 128    |
| LOU             | RRU     | 1   | 37.5        | 0.058                          | 0.129 | 0.012 | 105          |        | 128    |
| LSN             | THU     | 1   | 10.4        | 0.016                          | 0.036 | 0.003 | 99           |        | 125    |
| MAL             | KBY     | 1   | 29.2        | 0.018                          | 0.095 | 0.01  | 178          |        | 219    |
| MAY             | BLK T   | 1   | 30.9        | 0.032                          | 0.103 | 0.011 | 136          |        | 166    |
| MAY             | GRI     | 1   | 2.2         | 0.003                          | 0.009 | 0.001 | 105          |        | 128    |
| MAY             | GRI T   | 1   | 2.2         | 0.002                          | 0.007 | 0.002 | 103          |        | 120    |
| MAY             | RNW     | 1   | 7.1         | 0.008                          | 0.024 | 0.002 | 103          |        | 128    |
| MAY             | RYB     | 1   | 9           | 0.009                          | 0.030 | 0.005 | 178          |        | 219    |
| MCD             | NQS     | 1   | 2           | 0.001                          | 0.002 | 0.036 | 119          |        | 119    |
| MCD             | WOL     | 1   | 1.4         | 0.001                          | 0.002 | 0.009 | 120          |        | 131    |
| MCE             | CDU     | 1   | 4.1         | 0.003                          | 0.010 | 0.016 | 99           |        | 125    |
| MHL             | RE      | 1   | 3           | 0.002                          | 0.005 | 0.030 | 140          |        | 140    |
| MID             | WHI     | 1   | 20          | 0.030                          | 0.069 | 0.007 | 99           |        | 125    |
| MIL             | RE      | 1   | 4.9         | 0.003                          | 0.005 | 0.075 | 100          |        | 100    |
| MIL             | RE      | 2   | 5.6         | 0.003                          | 0.006 | 0.034 | 100          |        | 131    |
| MIL             | TLY     | 1   | 5.5         | 0.003                          | 0.006 | 0.070 | 100          |        | 100    |
| MKL             | OMA     | 1   | 37.5        | 0.028                          | 0.113 | 0.015 | 139          | 150    | 157    |
| MOY             | GLR     | 1   | 14          | 0.022                          | 0.048 | 0.005 | 99           |        | 125    |
| MOY             | TAW     | 1   | 8.4         | 0.013                          | 0.029 | 0.003 | 105          |        | 125    |
| MOY             | TAW     | 2   | 8.3         | 0.013                          | 0.029 | 0.003 | 105          |        | 128    |
| MP              | TBK T   | 1   | 6.6         | 0.010                          | 0.023 | 0.002 | 105          |        | 128    |
| MR              | KBY     | 1   | 4.0         | 0.004                          | 0.013 | 0.003 | 99           |        | 115    |
| MR              | KBY     | 2   | 4.0         | 0.004                          | 0.013 | 0.003 | 99           |        | 115    |
| MR              | TBG     | 1   | 3.3         | 0.001                          | 0.004 | 0.036 | 178          |        | 219    |
| MR              | TBG     | 2   | 3.3         | 0.001                          | 0.004 | 0.036 | 178          |        | 219    |
| MTH             | LOU     | 1   | 15.1        | 0.024                          | 0.052 | 0.005 | 99           |        | 125    |
| MTN             | MUN     | 1   | 0.7         | 0.001                          | 0.003 | 0.000 | 105          |        | 128    |
| MTN             | MUN     | 2   | 0.7         | 0.001                          | 0.002 | 0.000 | 105          |        | 128    |
| NEW (I)         | BLK T   | 1   | 12.2        | 0.013                          | 0.041 | 0.004 | 136          |        | 166    |
| NEW (I)         | PLS     | 1   | 43          | 0.055                          | 0.146 | 0.014 | 105          |        | 128    |
| NEW (N)         | TAN     | 1   | 24.1        | 0.031                          | 0.080 | 0.008 | 82           | 95     | 103    |
| NEW (N)         | TAN     | 2   | 24          | 0.031                          | 0.080 | 0.008 | 82           | 95     | 103    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-5 Characteristics of Existing 110 kV Lines and Cables (continued)

| 110 kV Circuits |         |     | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |        |
|-----------------|---------|-----|-------------|--------------------------------|-------|-------|--------------|--------|--------|
| From            | To      | No. |             | R                              | X     | B     | Summer       | Autumn | Winter |
| NQS             | RE      | 1   | 2.1         | 0.001                          | 0.002 | 0.038 | 119          |        | 119    |
| OMA             | STR (N) | 1   | 35.5        | 0.046                          | 0.123 | 0.012 | 109          | 119    | 124    |
| OMA             | STR (N) | 2   | 36.1        | 0.047                          | 0.125 | 0.012 | 109          |        | 103    |
| OUG             | OUG T   | 1   | 11.0        | 0.017                          | 0.038 | 0.004 | 105          |        | 128    |
| PA              | STR (I) | 1   | 22.4        | 0.035                          | 0.077 | 0.007 | 105          |        | 128    |
| PB              | RE      | 3   | 1.4         | 0.000                          | 0.002 | 0.046 | 269          |        | 269    |
| PB              | RE      | 4   | 1.4         | 0.000                          | 0.002 | 0.046 | 269          |        | 269    |
| PLS             | KPN     | 1   | 32          | 0.020                          | 0.104 | 0.011 | 178          |        | 219    |
| RAF             | RSY     | 1   | 2.1         | 0.003                          | 0.007 | 0.001 | 63           |        | 99     |
| RAF             | TBG     | 1   | 10.6        | 0.016                          | 0.036 | 0.005 | 105          |        | 128    |
| RAF             | TBG     | 2   | 9.5         | 0.006                          | 0.031 | 0.005 | 178          |        | 219    |
| RAT (I)         | TB      | 1   | 33.6        | 0.035                          | 0.112 | 0.012 | 136          |        | 166    |
| RE              | PB      | 1   | 1.2         | 0.001                          | 0.001 | 0.016 | 112          |        | 112    |
| REM             | TRL     | 1   | 12          | 0.006                          | 0.018 | 0.120 | 106          |        | 106    |
| RNW             | DFR T   | 1   | 25.9        | 0.020                          | 0.085 | 0.009 | 99           |        | 125    |
| RRU             | SKL     | 1   | 14.5        | 0.023                          | 0.050 | 0.005 | 99           |        | 125    |
| SCR             | SAL     | 1   | 51.8        | 0.053                          | 0.166 | 0.056 | 136          |        | 140    |
| SH              | DAL T   | 1   | 12          | 0.008                          | 0.039 | 0.007 | 178          |        | 219    |
| SH              | IKE T   | 1   | 53.7        | 0.034                          | 0.175 | 0.019 | 178          |        | 219    |
| SH              | SOM T   | 1   | 13.8        | 0.021                          | 0.047 | 0.006 | 105          |        | 128    |
| SLI             | SRA     | 1   | 11.1        | 0.017                          | 0.038 | 0.004 | 99           |        | 125    |
| SLI             | SRA     | 2   | 12          | 0.019                          | 0.041 | 0.004 | 99           |        | 125    |
| SNG             | AA      | 1   | 5.6         | 0.004                          | 0.018 | 0.004 | 178          |        | 219    |
| SOR             | TLK     | 1   | 4.4         | 0.007                          | 0.015 | 0.002 | 105          |        | 128    |
| SRA             | CF      | 2   | 49.2        | 0.031                          | 0.160 | 0.017 | 178          |        | 219    |
| STR (I)         | STR T   | 1   | 2.0         | 0.003                          | 0.007 | 0.001 | 105          |        | 128    |
| TAN             | WAR     | 1   | 12.9        | 0.013                          | 0.042 | 0.005 | 79           | 96     | 113    |
| TAN             | WAR     | 2   | 12.9        | 0.013                          | 0.042 | 0.005 | 79           | 96     | 113    |
| TB              | TRL     | 1   | 42          | 0.063                          | 0.147 | 0.014 | 99           |        | 125    |
| TBK             | TBK T   | 1   | 2.9         | 0.005                          | 0.010 | 0.001 | 105          |        | 128    |
| THU             | IKE T   | 1   | 25.9        | 0.016                          | 0.084 | 0.009 | 178          |        | 219    |
| TRL             | OUG T   | 1   | 11.3        | 0.007                          | 0.037 | 0.004 | 178          |        | 219    |
| TRL             | TB      | 2   | 45.7        | 0.028                          | 0.148 | 0.024 | 178          |        | 219    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-6 Characteristics of Existing 400/220 kV Transformers

| Transformer      | Rating (MVA) | Impedance p.u. on 100 MVA base |        | Voltage Ratio Tapping Range |     |
|------------------|--------------|--------------------------------|--------|-----------------------------|-----|
|                  |              | R                              | X      | +                           | -   |
| Dunstown T4201   | 500          | 0.000                          | 0.032  | 1%                          | 15% |
| Moneypoint T4201 | 500          | 0.000                          | 0.033  | 1%                          | 15% |
| Oldstreet T4202  | 500          | 0.000                          | 0.027  | 10%                         | 7%  |
| Woodland T4201   | 500          | 0.000                          | 0.032  | 1%                          | 15% |
| Woodland T4202   | 550          | 0.000                          | 0.027  | N/A                         |     |
| Woodland T4204   | 500          | 0.000                          | 0.0316 | 1%                          | 15% |
| Total            | 3,050        |                                |        |                             |     |

Table B-7 Characteristics of Existing 275/220 kV Transformers

| Transformer | Rating (MVA) | Impedance p.u. on 100 MVA base |       | Voltage Ratio Tapping Range |     |
|-------------|--------------|--------------------------------|-------|-----------------------------|-----|
|             |              | R                              | X     | +                           | -   |
| Louth AT1   | 300          | 0.001                          | 0.030 | 15%                         | 15% |
| Louth AT2   | 600          | 0.001                          | 0.015 | 15%                         | 15% |
| Louth AT3   | 300          | 0.001                          | 0.030 | 15%                         | 15% |
| Total       | 1,200        |                                |       |                             |     |

Table B-8 Characteristics of Existing 275/110 kV Interbus Transformers

| Substation/<br>Transformer | Impedance p.u. on 100 MVA base |        |        |        |      |        | Rating (MVA) |     |    | Off Nominal Ratio (PU) |       | No. of Taps |
|----------------------------|--------------------------------|--------|--------|--------|------|--------|--------------|-----|----|------------------------|-------|-------------|
|                            | W1-2                           |        | W2-3   |        | W3-1 |        |              |     |    |                        |       |             |
|                            | R                              | X      | R      | X      | R    | X      | W1           | W2  | W3 | Upper                  | Lower |             |
| Ballylumford IBTx 1        | 0.0018                         | 0.0641 | 0.0018 | 0.2092 | 0    | 0.1325 | 240          | 240 | 30 | 1.15                   | 0.85  | 19          |
| Ballylumford IBTx 2        | 0.0018                         | 0.0641 | 0.0018 | 0.2059 | 0    | 0.128  | 240          | 240 | 30 | 1.15                   | 0.85  | 19          |
| Castlereagh IBTx 1         | 0.0018                         | 0.0641 | 0.0018 | 0.2092 | 0    | 0.1325 | 240          | 240 | 60 | 1.15                   | 0.85  | 19          |
| Castlereagh IBTx 2         | 0.0014                         | 0.0639 | 0.0014 | 0.2236 | 0    | 0.1449 | 240          | 240 | 30 | 1.15                   | 0.85  | 19          |
| Castlereagh IBTx 3         | 0.0018                         | 0.0656 | 0.0018 | 0.2375 | 0    | 0.1593 | 240          | 240 | 30 | 1.15                   | 0.85  | 19          |
| Coolkeeragh IBTx 1         | 0.0018                         | 0.0609 | 0.0018 | 0.1273 | 0    | 0.057  | 240          | 240 | 60 | 1.15                   | 0.85  | 19          |
| Coolkeeragh IBTx 2         | 0.0014                         | 0.0639 | 0.0014 | 0.2236 | 0    | 0.1449 | 240          | 240 | 30 | 1.15                   | 0.85  | 19          |
| Hannahstown IBTx 1         | 0.0018                         | 0.0591 | 0.0018 | 0.1261 | 0    | 0.056  | 240          | 240 | 45 | 1.15                   | 0.85  | 19          |
| Hannahstown IBTx 2         | 0.0018                         | 0.0591 | 0.0018 | 0.1261 | 0    | 0.056  | 240          | 240 | 45 | 1.15                   | 0.85  | 19          |
| Hannahstown IBTx 3         | 0.0014                         | 0.0639 | 0.0014 | 0.2236 | 0    | 0.1449 | 240          | 240 | 60 | 1.15                   | 0.85  | 19          |
| Kells IBTx 1               | 0.0018                         | 0.0609 | 0.0018 | 0.1273 | 0    | 0.057  | 240          | 240 | 45 | 1.15                   | 0.85  | 19          |
| Kells IBTx 2               | 0.0018                         | 0.0607 | 0.0018 | 0.1317 | 0    | 0.057  | 240          | 240 | 45 | 1.15                   | 0.85  | 19          |
| Tandragee IBTx 1           | 0.0018                         | 0.0641 | 0.0018 | 0.2092 | 0    | 0.1325 | 240          | 240 | 30 | 1.15                   | 0.85  | 19          |

Table B-8 Characteristics of Existing 275/110 kV Interbus Transformers  
(Continued)

| Substation/<br>Transformer | Impedance p.u. on 100 MVA base |        |        |        |      |        | Rating (MVA) |     |    | Off Nominal<br>Ratio (PU) |       | No.<br>of<br>Taps |
|----------------------------|--------------------------------|--------|--------|--------|------|--------|--------------|-----|----|---------------------------|-------|-------------------|
|                            | W1-2                           |        | W2-3   |        | W3-1 |        |              |     |    |                           |       |                   |
|                            | R                              | X      | R      | X      | R    | X      | W1           | W2  | W3 | Upper                     | Lower |                   |
| Tandragee<br>IBTx 2        | 0.0018                         | 0.0641 | 0.0018 | 0.2092 | 0    | 0.1325 | 240          | 240 | 30 | 1.15                      | 0.85  | 19                |
| Tandragee<br>IBTx 3        | 0.0014                         | 0.0639 | 0.0018 | 0.2375 | 0    | 0.1575 | 240          | 240 | 60 | 1.15                      | 0.85  | 19                |
| Tamnamore<br>IBTx 1        | 0.0014                         | 0.0656 | 0.0018 | 0.2375 | 0    | 0.1449 | 240          | 240 | 60 | 1.15                      | 0.85  | 19                |

Table B-9 Characteristics of Existing 275/11.5 kV Generator Transformers

| Substation/<br>Transformer | Impedance p.u. on 100 MVA base |        |      |        |      |        | Rating (MVA) |    |    | Off Nominal<br>Ratio (PU) |       | No.<br>of<br>Taps |
|----------------------------|--------------------------------|--------|------|--------|------|--------|--------------|----|----|---------------------------|-------|-------------------|
|                            | W1-2                           |        | W2-3 |        | W3-1 |        |              |    |    |                           |       |                   |
|                            | R                              | X      | R    | X      | R    | X      | W1           | W2 | W3 | Upper                     | Lower |                   |
| Kilroot IBTx1              | 0                              | 0.1635 | 0    | 0.3040 | 0    | 0.1635 | 110          | 55 | 55 | 1.15                      | 0.938 | 33                |

Table B-10 Characteristics of Existing 220/110 kV Transformers

| Transformer               | Rating<br>(MVA) | Impedance p.u. on 100 MVA<br>base |       | Voltage Ratio Tapping<br>Range |     |
|---------------------------|-----------------|-----------------------------------|-------|--------------------------------|-----|
|                           |                 | R                                 | X     | +                              | -   |
| Aghada T2102              | 125             | 0.001                             | 0.124 | 10%                            | 18% |
| Arklow T2101              | 63              | 0.007                             | 0.180 | 23%                            | 19% |
| Arklow T2102              | 125             | 0.002                             | 0.124 | 9%                             | 18% |
| Ballyvouskill T2101       | 255             | 0.001                             | 0.064 | 10%                            | 18% |
| Carrickmines T2101        | 250             | 0.001                             | 0.065 | 9%                             | 17% |
| Carrickmines T2102        | 250             | 0.001                             | 0.065 | 9%                             | 17% |
| Carrickmines T2103        | 250             | 0.001                             | 0.065 | 9%                             | 17% |
| Cashla T2101 <sup>3</sup> | 238             | 0.000                             | 0.063 | 9%                             | 18% |
| Cashla T2102              | 250             | 0.000                             | 0.063 | 9%                             | 18% |
| Cashla T2104              | 175             | 0.002                             | 0.133 | 22%                            | 18% |
| Clashavoon T2101          | 125             | 0.001                             | 0.124 | 9%                             | 17% |
| Clashavoon T2102          | 250             | 0.001                             | 0.065 | 9%                             | 17% |
| Corduff T2101             | 250             | 0.001                             | 0.062 | 9%                             | 17% |
| Corduff T2102             | 250             | 0.001                             | 0.061 | 9%                             | 17% |
| Cullenagh T2101           | 250             | 0.001                             | 0.064 | 9%                             | 18% |
| Finglas T2101             | 250             | 0.001                             | 0.065 | 9%                             | 18% |
| Finglas T2102             | 250             | 0.001                             | 0.065 | 9%                             | 18% |
| Finglas T2103             | 250             | 0.001                             | 0.064 | 9%                             | 17% |
| Finglas T2104             | 250             | 0.001                             | 0.064 | 9%                             | 17% |
| Finglas T2105             | 250             | 0.001                             | 0.064 | 9%                             | 17% |

<sup>3</sup> Transformer limited to 238 MVA at 110 kV by the 110 kV switchgear

Table B-10 Characteristics of Existing 220/110 kV Transformers (continued)

| Transformer                 | Rating (MVA) | Impedance p.u. on 100 MVA base |       | Voltage Ratio Tapping Range |     |
|-----------------------------|--------------|--------------------------------|-------|-----------------------------|-----|
|                             |              | R                              | X     | +                           | -   |
| Flagford T2101              | 125          | 0.003                          | 0.128 | 9%                          | 18% |
| Flagford T2102              | 125          | 0.001                          | 0.133 | 9%                          | 18% |
| Gorman T2101                | 250          | 0.001                          | 0.064 | 9%                          | 18% |
| GreatIsland T2101           | 125          | 0.003                          | 0.133 | 9%                          | 18% |
| GreatIsland T2102           | 125          | 0.002                          | 0.124 | 22%                         | 18% |
| Inchicore T2101             | 250          | 0.001                          | 0.056 | 9%                          | 17% |
| Inchicore T2103             | 250          | 0.000                          | 0.060 | 9%                          | 18% |
| Kellis T2101                | 125          | 0.001                          | 0.124 | 9%                          | 18% |
| Kellis T2102                | 125          | 0.001                          | 0.124 | 9%                          | 18% |
| Killonan T2101              | 63           | 0.007                          | 0.245 | 22%                         | 18% |
| Killonan T2102              | 63           | 0.010                          | 0.247 | 22%                         | 18% |
| Killonan T2103              | 250          | 0.000                          | 0.063 | 9%                          | 18% |
| Killonan T2104              | 120          | 0.001                          | 0.123 | 9%                          | 18% |
| Knockraha T2101             | 250          | 0.001                          | 0.065 | 9%                          | 17% |
| Knockraha T2102             | 250          | 0.001                          | 0.065 | 9%                          | 17% |
| Knockraha T2103             | 250          | 0.001                          | 0.065 | 9%                          | 18% |
| Lodgewood T2102             | 250          | 0.001                          | 0.064 | 9%                          | 18% |
| Louth T2101                 | 125          | 0.002                          | 0.133 | 22%                         | 18% |
| Louth T2102                 | 125          | 0.002                          | 0.132 | 23%                         | 18% |
| Louth T2103                 | 125          | 0.002                          | 0.132 | 22%                         | 18% |
| Louth T2104                 | 250          | 0.001                          | 0.064 | 9%                          | 17% |
| Maynooth T2101              | 125          | 0.002                          | 0.134 | 22%                         | 18% |
| Maynooth T2102 <sup>4</sup> | 238          | 0.001                          | 0.064 | 9%                          | 17% |
| Maynooth T2103              | 125          | 0.002                          | 0.132 | 22%                         | 18% |
| Maynooth T2104              | 250          | 0.001                          | 0.064 | 9%                          | 17% |
| Knockanure T2101            | 250          | 0.001                          | 0.064 | 10%                         | 18% |
| Knockanure T2102            | 250          | 0.0001                         | 0.064 | 10%                         | 18% |
| Poolbeg TF3                 | 250          | 0.001                          | 0.059 | 8%                          | 17% |
| Poolbeg TF4                 | 250          | 0.001                          | 0.061 | 8%                          | 17% |
| Raffeen T2101 <sup>4</sup>  | 238          | 0.001                          | 0.064 | 9%                          | 17% |
| Raffeen T2102               | 250          | 0.000                          | 0.056 | 9%                          | 17% |
| Shannonbridge T2101         | 125          | 0.006                          | 0.124 | 9%                          | 18% |
| Shannonbridge T2102         | 125          | 0.001                          | 0.124 | 9%                          | 18% |
| Srananagh T2101             | 250          | 0.001                          | 0.064 | 9%                          | 18% |
| Tarbert T2101 <sup>4</sup>  | 238          | 0.001                          | 0.055 | 9%                          | 17% |
| Tarbert T2102 <sup>4</sup>  | 238          | 0.001                          | 0.055 | 9%                          | 17% |
| Total                       | 11.679       |                                |       |                             |     |

<sup>4</sup> Transformer limited to 238 MVA at 110 kV by the 110 kV switchgear

Table B-11 Characteristics of Existing Power Flow Controllers

| Station      | Rating (MVA) | Circuit           | Impedance p.u. on 100 MVA base |        | Phase Angle Range (electrical degrees) |      |
|--------------|--------------|-------------------|--------------------------------|--------|--|------|
|              |              |                   | R                              | X      | +                                      | -    |
| Carrickmines | 350          | CKM – PB 220 kV   | 0.000                          | 0.029  | 15.3                                   | 15.3 |
| Enniskillen  | 125          | ENNK – COR 110 kV | 0.000                          | 0.0213 | 1.2                                    | 0.8  |
| Strabane     | 125          | STRA – LET 110 kV | 0.000                          | 0.0213 | 1.2                                    | 0.8  |

Table B-12 Characteristics of Existing Reactive Compensation

| Station          | Bus     | Plant                     | Mvar Capability |        |
|------------------|---------|---------------------------|-----------------|--------|
|                  |         |                           | Generate        | Absorb |
| Ardnacrusha      | ARD 110 | 1 Capacitor               | 30              |        |
| Athlone          | ATH 110 | 2 Capacitors (1 Mobile)   | 60              |        |
| Bandon           | BAN 110 | 1 Capacitor               | 15              |        |
| Cahir            | CAH 110 | 4 Capacitors (4 x 15)     | 60              |        |
| Carrickmines     | CKM 220 | 1 Shunt Reactor           |                 | 100    |
| Cashla           | CSH 110 | 2 Capacitors (2 x 40)     | 80              |        |
| Castlebar        | CBR 110 | 1 Capacitor               | 30              |        |
| Castlebar        | CBR 110 | 1 Static Var Compensator  | 60              | 10     |
| Castlereaugh     | CAS 22  | 3 Capacitors (3 x 25)     | 75              |        |
| Castlereaugh     | CAS 22  | 1 Shunt Reactor           |                 | 30     |
| Cathaleen's Fall | CF 110  | 1 Capacitor               | 15              |        |
| Coleraine        | COL 110 | 1 Capacitor               | 36              |        |
| Coolkeeragh      | CPS 110 | 1 Capacitor               | 40              |        |
| Dalton           | DLT 110 | 1 Capacitor               | 15              |        |
| Derrylin         | DLN 33  | 1 Capacitor               | 5               |        |
| Doon             | DOO 110 | 1 Capacitor               | 15              |        |
| Drumline         | DRU 110 | 1 Capacitor               | 15              |        |
| Dunmanway        | DMY 110 | 1 Capacitor               | 15              |        |
| Dunstown         | DSN 400 | 1 Shunt Reactor           |                 | 80     |
| Enniskillen      | ENN 33  | 4 Capacitors (4 x 6)      | 24              |        |
| Gortawee         | GWE 110 | 1 Capacitor               | 15              |        |
| Hannahstown      | HAN 22  | 2 Shunt Reactors (2 x 30) |                 | 60     |
| Kells            | KEL 22  | 2 Shunt Reactors (2 x 30) |                 | 60     |
| Kilkenny         | KKY 110 | 2 Capacitor (2 x 15)      | 30              |        |
| Kilteel          | KTL 110 | 1 Capacitor               | 30              |        |
| Letterkenny      | LET 110 | 1 Capacitor               | 15              |        |
| Letterkenny      | LET 110 | 1 Static Var Compensators | 30              |        |
| Lisdrum          | LIS 110 | 2 Capacitors (2 x 15)     | 30              |        |
| Louth            | LOU 110 | 1 Capacitor               | 30              |        |
| Moy              | MOY 110 | 2 Capacitors (2 x 15)     | 30              |        |
| Moyle            | BYC 275 | 4 Capacitors (4 x 59)     | 236             |        |
| Mullingar        | MUL 110 | 2 Capacitors (2 x 15)     | 30              |        |
| Navan            | NAV 110 | 1 Capacitor (1 Mobile)    | 30              |        |
| Portlaoise       | PLS 110 | 1 Capacitor (1 Mobile)    | 30              |        |
| Portan           | POR 400 | EWIC HVDC                 | 175             | 175    |
| Raffeen          | RAF 110 | 1 Capacitor               | 60              |        |



Table B-12 Characteristics of Existing Reactive Compensation (Continued)

| Station     | Bus     | Plant                     | Mvar Capability |        |
|-------------|---------|---------------------------|-----------------|--------|
|             |         |                           | Generate        | Absorb |
| Shankill    | SKL 110 | 1 Capacitor (1 Mobile)    | 30              |        |
| Sligo       | SLI 110 | 1 Capacitor               | 15              |        |
| Tandragee   | TAN 22  | 2 Capacitors (2 x 25)     | 50              |        |
| Tandragee   | TAN 22  | 2 Shunt Reactors (2 x 30) |                 | 60     |
| Thurles     | THU 110 | 2 Capacitor (2 x 15)      | 30              |        |
| Tralee      | TRL 110 | 1 Capacitor               | 30              |        |
| Trien       | TRI 110 | 1 Capacitor               | 30              |        |
| Wexford     | WEX 110 | 2 Capacitors (2 x 15)     | 30              |        |
| Woodland    | WOO 400 | 1 Shunt Reactor           |                 | 80     |
| Slieve Kirk | SKIR 20 | 1 Capacitor               | 13              |        |
| Total       |         |                           | 1,589           | 655    |

## B.2 Changes in Transmission System Characteristics

Future developments of the transmission system are listed in this section according to the year in which they are expected to be completed. The network changes related to each development project are grouped together and collectively headed by a Capital Project (CP) number and title. The physical and electrical characteristics of future transmission plant or changes to the characteristics brought about by planned developments are listed in the tables. These characteristics are indicative at this stage and will be reviewed when the item of plant is commissioned.

Table B-13 Changes in Circuit Characteristics Expected in Winter 2015

| Change | Voltage (kV) | From | To    | No. | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |
|--------|--------------|------|-------|-----|-------------|--------------------------------|-------|-------|--------------|--------|
|        |              |      |       |     |             | R                              | X     | B     | Summer       | Winter |
| Add    | 110          | ADM  | GCA   | 1   | 2.5         | 0.002                          | 0.004 | 0.025 | 140          | 140    |
| Add    | 110          | ADM  | INC   | 1   | 10.5        | 0.009                          | 0.027 | 0.024 | 103          | 143    |
| Add    | 110          | ATE  | KNR   | 1   | 9.0         | 0.006                          | 0.029 | 0.003 | 178          | 219    |
| Add    | 220          | BVK  | CLA   | 1   | 18.4        | 0.002                          | 0.016 | 0.024 | 761          | 534    |
| Add    | 110          | BVK  | GRO   | 1   | 7.0         | 0.004                          | 0.023 | 0.003 | 178          | 219    |
| Add    | 220          | BVK  | KNR   | 1   | 61.5        | 0.008                          | 0.053 | 0.082 | ...          | 804    |
| Amend  | 110          | CAH  | TIP   | 1   | 18.1        | 0.011                          | 0.059 | 0.006 | 178          | 219    |
| Amend  | 110          | CD   | MAC   | 1   | 2.4         | 0.002                          | 0.008 | 0.001 | 178          | 219    |
| Amend  | 110          | CDU  | RYB   | 1   | 13.0        | 0.014                          | 0.043 | 0.005 | 218          | 236    |
| Add    | 110          | CF   | CLO   | 1   | 25.9        | 0.037                          | 0.094 | 0.009 | 187          | 222    |
| Add    | 110          | CLO  | GOL T | 1   | 0.3         | 0.000                          | 0.001 | 0.001 | 187          | 222    |
| Add    | 110          | CLG  | CDU   | 1   | 2.5         | 0.001                          | 0.003 | 0.028 | 187          | 219    |
| Add    | 110          | CTG  | BVK   | 1   | 30.0        | 0.019                          | 0.098 | 0.011 | 178          | 219    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-13 Changes in Circuit Characteristics Expected in Winter 2015  
(continued)

| Change | Voltage (kV) | From | To    | No. | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |
|--------|--------------|------|-------|-----|-------------|--------------------------------|-------|-------|--------------|--------|
|        |              |      |       |     |             | R                              | X     | B     | Summer       | Winter |
| Amend  | 110          | CTN  | TIP   | 1   | 13.2        | 0.008                          | 0.043 | 0.005 | 178          | 219    |
| Add    | 110          | CKG  | BKY   | 1   | 3.0         | 0.001                          | 0.003 | 0.033 | 187          | 223    |
| Add    | 110          | CKG  | KUD   | 1   | 0.8         | 0.000                          | 0.001 | 0.008 | 187          | 223    |
| Add    | 110          | DRM  | CLO   | 1   | 27.0        | 0.039                          | 0.091 | 0.015 | 103          | 128    |
| Add    | 110          | INC  | BKY   | 1   | 10.0        | 0.002                          | 0.011 | 0.110 | 187          | 223    |
| Add    | 110          | KLM  | NBY   | 1   | 1.2         | 0.001                          | 0.001 | 0.020 | 119          | 119    |
| Add    | 110          | KNR  | TRI   | 1   | 4.4         | 0.005                          | 0.017 | 0.002 | 120          | 128    |
| Add    | 110          | KNR  | TRI   | 2   | 5.7         | 0.004                          | 0.019 | 0.002 | 178          | 219    |
| Amend  | 110          | KRA  | KBY   | 1   | 11.9        | 0.008                          | 0.039 | 0.004 | 178          | 219    |
| Amend  | 110          | MAY  | RYB   | 1   | 9.0         | 0.009                          | 0.030 | 0.005 | 178          | 219    |
| Remove | 110          | SH   | IKE T | 1   | 53.7        | 0.034                          | 0.175 | 0.019 | 178          | 219    |

Table B-14 Changes in Circuit Characteristics Expected in 2016

| Change | Voltage (kV) | From | To      | No. | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |
|--------|--------------|------|---------|-----|-------------|--------------------------------|-------|-------|--------------|--------|
|        |              |      |         |     |             | R                              | X     | B     | Summer       | Winter |
| Amend  | 110          | ARV  | SKL     | 1   | 18.6        | 0.012                          | 0.061 | 0.007 | 178          | 219    |
| Add    | 110          | AUG  | KPG     | 1   | 32.8        | 0.021                          | 0.107 | 0.017 | 178          | 219    |
| Remove | 110          | AUG  | TB      | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Remove | 110          | BAR  | BAR T   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | BAR  | CAH     | 1   | 44.5        | 0.066                          | 0.153 | 0.014 | 105          | 128    |
| Add    | 110          | BAR  | KRA     | 1   | 19.7        | 0.020                          | 0.066 | 0.007 | 136          | 166    |
| Remove | 110          | BIN  | LET     | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | BIN  | TIV     | 1   | 23.2        | 0.024                          | 0.077 | 0.008 | 136          | 166    |
| Amend  | 110          | BK   | CBR     | 1   | 37.4        | 0.053                          | 0.128 | 0.014 | 178          | 219    |
| Add    | 110          | BYH  | GLE (I) | 1   | 12.5        | 0.005                          | 0.024 | 0.244 | 178          | 219    |
| Add    | 110          | BNM  | DON     | 1   |             | 0.005                          | 0.005 | 0.053 | 75           | 82     |
| Add    | 110          | BNM  | DON     | 2   |             | 0.005                          | 0.005 | 0.053 | 75           | 82     |
| Amend  | 110          | BOL  | ENN (I) | 1   | 24.0        | 0.015                          | 0.078 | 0.009 | 178          | 219    |
| Add    | 220          | BVK  | BYH     | 1   | 14.5        | 0.002                          | 0.012 | 0.054 | 660          | 660    |
| Amend  | 110          | BVK  | CLA     | 1   | 18.4        | 0.002                          | 0.002 | 0.054 | 761          | 804    |
| Remove | 220          | BVK  | KNR     | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Remove | 110          | CAH  | BAR T   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Amend  | 110          | CAS  | ROS     | 1   | 1.9         | 0.001                          | 0.003 | 0.015 | 144          | 152    |
| Amend  | 110          | CAS  | ROS     | 2   | 1.9         | 0.001                          | 0.003 | 0.015 | 144          | 152    |
| Amend  | 110          | CDY  | ARI T   | 1   | 13.7        | 0.009                          | 0.045 | 0.005 | 178          | 219    |
| Add    | 110          | CHE  | FAS     | 1   | 2.2         | 0.004                          | 0.008 | 0.001 | 105          | 128    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-14 Changes in Circuit Characteristics Expected in 2016 (continued)

| Change | Voltage (kV) | From    | To    | No. | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |
|--------|--------------|---------|-------|-----|-------------|--------------------------------|-------|-------|--------------|--------|
|        |              |         |       |     |             | R                              | X     | B     | Summer       | Winter |
| Add    | 110          | CKM     | CHE   | 1   | 4.0         | 0.004                          | 0.008 | 0.030 | 105          | 128    |
| Add    | 110          | CKM     | FAS   | 1   | 2.9         | 0.005                          | 0.010 | 0.001 | 105          | 128    |
| Add    | 110          | CLA     | DMY   | 1   | 35.0        | 0.022                          | 0.114 | 0.012 | 178          | 219    |
| Remove | 220          | CLA     | TB    | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | CLO     | MUL   | 1   | 7.4         | 0.005                          | 0.011 | 0.074 | 124          | 124    |
| Remove | 110          | COL (N) | KEL   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | COL (N) | RSK   | 1   |             | 0.024                          | 0.069 | 0.007 | 185          | 193    |
| Amend  | 110          | COS     | ARI T | 1   | 20.7        | 0.013                          | 0.067 | 0.007 | 178          | 219    |
| Remove | 110          | CRG     | DUN   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | CRG     | TMN   | 1   |             | 0.045                          | 0.119 | 0.022 | 109          | 124    |
| Add    | 110          | CRF     | CLO   | 1   | 18.0        | 0.011                          | 0.059 | 0.006 | 178          | 219    |
| Amend  | 110          | CSH     | SAL   | 1   | 24.9        | 0.024                          | 0.074 | 0.068 | 178          | 219    |
| Amend  | 110          | CTN     | KLN   | 1   | 28.0        | 0.018                          | 0.091 | 0.010 | 178          | 219    |
| Amend  | 110          | CUN     | SLI   | 1   | 21.3        | 0.030                          | 0.073 | 0.007 | 211          | 222    |
| Add    | 110          | DMY     | BDV   | 1   | 15.6        | 0.022                          | 0.057 | 0.005 | 187          | 222    |
| Remove | 110          | DMY     | MAC   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Remove | 110          | DON     | BNM   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Remove | 110          | DON     | BMN   | 2   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Remove | 110          | DRU (N) | DUN   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Remove | 110          | DRU (N) | DUN   | 2   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | DRU (N) | TMN   | 1   |             | 0.028                          | 0.073 | 0.012 | 82           | 103    |
| Add    | 110          | DRU (N) | TMN   | 2   |             | 0.029                          | 0.075 | 0.008 | 82           | 103    |
| Add    | 110          | DUN     | TMN   | 1   |             | 0.004                          | 0.017 | 0.005 | 139          | 152    |
| Add    | 110          | DUN     | TMN   | 2   |             | 0.009                          | 0.023 | 0.002 | 139          | 103    |
| Remove | 110          | DUN     | OMA   | 2   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Remove | 110          | DUN     | TMN   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | DUN     | TMN   | 1   |             | 0.004                          | 0.020 | 0.019 | 185          | 195    |
| Remove | 110          | FAS E   | CKM   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | FAS E   | FAS   | 1   | 5.0         | 0.008                          | 0.017 | 0.002 | 105          | 128    |
| Remove | 110          | FLA     | LA    | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | FLA     | SLB   | 1   | 21.7        | 0.034                          | 0.075 | 0.007 | 105          | 128    |
| Remove | 110          | FRN     | MHL   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | FRN     | TRN   | 1   | 2.8         | 0.002                          | 0.004 | 0.028 | 140          | 140    |
| Add    | 110          | GOR (N) | OMA   | 1   |             | 0.011                          | 0.066 | 0.006 | 188          | 213    |
| Add    | 110          | GOR (N) | TMN   | 1   |             | 0.021                          | 0.131 | 0.013 | 188          | 213    |
| Add    | 110          | KEL     | RSK   | 1   |             | 0.039                          | 0.133 | 0.013 | 188          | 193    |
| Add    | 110          | KIN     | MUL   | 1   | 27.0        | 0.017                          | 0.088 | 0.010 | 178          | 219    |
| Amend  | 110          | KPG     | KNR   | 1   | 15.0        | 0.015                          | 0.050 | 0.005 | 136          | 166    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-14 Changes in Circuit Characteristics Expected in 2016 (continued)

| Change | Voltage (kV) | From    | To      | No | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |
|--------|--------------|---------|---------|----|-------------|--------------------------------|-------|-------|--------------|--------|
|        |              |         |         |    |             | R                              | X     | B     | Summer       | Winter |
| Add    | 220          | KPG     | MP      | 1  | 5.4         | 0.000                          | 0.002 | 0.236 | 660          | 660    |
| Add    | 110          | KPG     | RAT (I) | 1  | 32.2        | 0.033                          | 0.108 | 0.011 | 136          | 166    |
| Add    | 220          | KPG     | TB      | 1  | 2.8         | 0.000                          | 0.002 | 0.026 | 761          | 802    |
| Add    | 110          | KPG     | TB      | 1  | 1.6         | 0.002                          | 0.007 | 0.001 | 120          | 128    |
| Add    | 110          | KPG     | TB      | 2  | 1.6         | 0.002                          | 0.007 | 0.001 | 120          | 128    |
| Add    | 110          | KPG     | TRL     | 1  | 39.4        | 0.060                          | 0.135 | 0.013 | 105          | 128    |
| Add    | 110          | KPG     | TRL     | 2  | 44.4        | 0.028                          | 0.144 | 0.016 | 105          | 219    |
| Add    | 220          | KNR     | BYH     | 1  | 47          | 0.006                          | 0.040 | 0.064 | 660          | 660    |
| Add    | 110          | KNY     | GAL     | 1  | 26.5        | 0.005                          | 0.036 | 0.303 | 228          | 228    |
| Add    | 220          | KNR     | KPG     | 1  | 21.4        | 0.003                          | 0.015 | 0.054 | 660          | 660    |
| Add    | 110          | KNR     | KPG     | 1  | 15.0        | 0.015                          | 0.050 | 0.005 | 136          | 166    |
| Add    | 110          | KNY     | SAL     | 1  | 28.4        | 0.024                          | 0.081 | 0.079 | 187          | 223    |
| Add    | 110          | KNY     | UGL     | 1  | 3.4         | 0.001                          | 0.005 | 0.039 | 228          | 228    |
| Remove | 110          | KRA     | BAR T   | 1  | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | LA      | SLB     | 1  | 9.1         | 0.014                          | 0.031 | 0.003 | 105          | 128    |
| Add    | 110          | LET     | TIV     | 1  | 45.2        | 0.047                          | 0.151 | 0.015 | 136          | 166    |
| Add    | 110          | MAC     | BDV     | 1  | 10.6        | 0.015                          | 0.039 | 0.004 | 187          | 222    |
| Remove | 275          | MAG     | TAN     | 1  | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | MHL     | TRN     | 1  | 1.4         | 0.001                          | 0.002 | 0.014 | 140          | 140    |
| Add    | 110          | MP      | KPG     | 1  | 5.4         | 0.000                          | 0.002 | 0.236 | 660          | 660    |
| Amend  | 110          | MP      | TBK T   | 1  | 6.6         | 0.004                          | 0.022 | 0.002 | 178          | 219    |
| Add    | 110          | OMA     | TRE     | 1  |             | 0.025                          | 0.073 | 0.007 | 186          | 193    |
| Amend  | 110          | RAF     | TBG     | 1  | 10.6        | 0.007                          | 0.035 | 0.004 | 178          | 219    |
| Remove | 110          | RAT (I) | TB      | 1  | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | SCR     | KNY     | 1  | 28.4        | 0.028                          | 0.089 | 0.035 | 136          | 166    |
| Remove | 110          | SCR     | SAL     | 1  | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 220          | TB      | KPG     | 1  | 2.8         | 0.000                          | 0.020 | 0.028 | 660          | 660    |
| Remove | 110          | TB      | TRL     | 1  | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | TRE     | TMN     | 1  |             | 0.025                          | 0.082 | 0.025 | 185          | 193    |
| Remove | 110          | TRL     | TB      | 1  | ...         | ...                            | ...   | ...   | ...          | ...    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-15 Changes in Circuit Characteristics Expected in 2017

| Change | Voltage (kV) | From    | To      | No. | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |
|--------|--------------|---------|---------|-----|-------------|--------------------------------|-------|-------|--------------|--------|
|        |              |         |         |     |             | R                              | X     | B     | Summer       | Winter |
| Remove | 110          | AGL     | DYN     | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | AGL     | KNV     | 1   | 6.0         | 0.009                          | 0.021 | 0.002 | 105          | 128    |
| Add    | 110          | AGY     | TIV     | 1   | 35.0        | 0.054                          | 0.120 | 0.011 | 105          | 128    |
| Amend  | 110          | BK      | MOY     | 1   | 27.0        | 0.017                          | 0.088 | 0.010 | 178          | 219    |
| Add    | 110          | BLC     | GRA     | 1   | 4.3         | 0.003                          | 0.005 | 0.031 | 140          | 140    |
| Add    | 110          | BLC     | KLM     | 1   | 4.0         | 0.002                          | 0.005 | 0.029 | 140          | 140    |
| Add    | 110          | BLC     | FIN (I) | 1   | 10.0        | 0.000                          | 0.002 | 0.332 | 570          | 570    |
| Amend  | 220          | BVK     | BYH     | 1   | 14.5        | 0.002                          | 0.012 | 0.054 | 660          | 660    |
| Add    | 110          | CDL     | BYH     | 1   | 9.0         | 0.002                          | 0.010 | 0.099 | 209          | 223    |
| Add    | 110          | CTO     | GOR (I) | 1   | 14.0        | 0.003                          | 0.015 | 0.154 | 187          | 223    |
| Amend  | 110          | CUS     | MLC     | 1   | 13.7        | 0.015                          | 0.048 | 0.005 | 178          | 219    |
| Add    | 110          | DYN     | KNV     | 1   | 2.0         | 0.003                          | 0.007 | 0.001 | 105          | 128    |
| Remove | 110          | FIN (I) | GRA     | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | FIN (I) | KLM     | 1   | 9.3         | 0.005                          | 0.010 | 0.056 | 140          | 143    |
| Add    | 110          | GAR (N) | BRO     | 1   |             | 0.000                          | 0.000 | 0.000 | 178          | 219    |
| Add    | 110          | GLT     | BYH     | 1   | 9.3         | 0.006                          | 0.030 | 0.003 | 178          | 219    |
| Add    | 110          | HTS     | MAC     | 1   | 4.5         | 0.007                          | 0.016 | 0.002 | 105          | 128    |
| Amend  | 220          | KNR     | BYH     | 1   | 47.0        | 0.006                          | 0.040 | 0.064 | 660          | 660    |
| Remove | 220          | LOU     | WOO     | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | MLC     | TSB     | 1   | 19.2        | 0.012                          | 0.063 | 0.007 | 178          | 219    |
| Remove | 275          | TAN     | TMN     | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Remove | 275          | TAN     | TMN     | 2   | ...         | ...                            | ...   | ...   | ...          | ...    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-16 Changes in Circuit Characteristics Expected in 2018

| Change | Voltage (kV) | From    | To      | No. | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |
|--------|--------------|---------|---------|-----|-------------|--------------------------------|-------|-------|--------------|--------|
|        |              |         |         |     |             | R                              | X     | B     | Summer       | Winter |
| Add    | 110          | BPS     | CAES    | 1   |             | 0.001                          | 0.007 | 0.082 | 200          | 200    |
| Add    | 110          | BPS     | CAES    | 2   |             | 0.001                          | 0.007 | 0.082 | 200          | 200    |
| Add    | 110          | BK      | NMO     | 1   | 3.3         | 0.002                          | 0.011 | 0.001 | 178          | 219    |
| Add    | 110          | BK      | NMO     | 2   | 3.3         | 0.002                          | 0.011 | 0.001 | 178          | 219    |
| Add    | 110          | BLP     | KBY     | 1   | 0.2         | 0.000                          | 0.000 | 0.002 | 124          | 124    |
| Add    | 110          | BRA     | NEW (I) | 1   | 9.3         | 0.010                          | 0.031 | 0.003 | 136          | 166    |
| Add    | 110          | BRA     | PLS     | 1   | 19.3        | 0.030                          | 0.067 | 0.006 | 105          | 128    |
| Add    | 110          | BKM     | CUR     | 1   | 7.3         | 0.004                          | 0.007 | 0.072 | 120          | 120    |
| Add    | 110          | CLO     | CF      | 1   | 26.5        | 0.016                          | 0.085 | 0.016 | 178          | 219    |
| Add    | 110          | CUR     | NEN     | 1   | 18.8        | 0.029                          | 0.065 | 0.006 | 105          | 128    |
| Add    | 110          | CUR     | BKM     | 1   | 17.3        | 0.004                          | 0.019 | 0.192 | 190          | 190    |
| Add    | 110          | OMS     | ENN (N) | 1   |             | 0.026                          | 0.066 | 0.007 | 82           | 103    |
| Add    | 110          | OMS     | ENN (N) | 2   |             | 0.026                          | 0.066 | 0.007 | 82           | 103    |
| Add    | 110          | OMS     | OMA     | 1   |             | 0.018                          | 0.047 | 0.005 | 82           | 103    |
| Add    | 110          | OMS     | OMA     | 1   |             | 0.018                          | 0.047 | 0.005 | 82           | 103    |
| Remove | 110          | ENN (N) | OMA     | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Remove | 110          | ENN (N) | OMA     | 2   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | KEL     | RSK     | 2   |             | 0.022                          | 0.134 | 0.013 | 188          | 213    |
| Add    | 110          | KBY     | KBY     | 1   | 0.2         | 0.000                          | 0.000 | 0.002 | 130          | 130    |
| Add    | 110          | KLN     | CUR     | 1   | 17.8        | 0.011                          | 0.048 | 0.005 | 136          | 166    |
| Remove | 110          | KLN     | NEN     | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | MAC     | CLA     | 1   | 9.0         | 0.002                          | 0.010 | 0.070 | 140          | 140    |
| Remove | 110          | NEW (I) | PLS     | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |

Table B-17 Changes in Circuit Characteristics Expected after 2018

| Change            | Voltage (kV) | From  | To    | No. | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |
|-------------------|--------------|-------|-------|-----|-------------|--------------------------------|-------|-------|--------------|--------|
|                   |              |       |       |     |             | R                              | X     | B     | Summer       | Winter |
| Add               | 110          | AIR   | CAS   | 1   |             | 0.009                          | 0.022 | 0.004 | 82           | 103    |
| Add               | 110          | AIR   | CAS   | 2   |             | 0.009                          | 0.022 | 0.004 | 82           | 103    |
| Add               | 110          | ARM   | TAN   | 1   |             | 0.024                          | 0.057 | 0.007 | 103          | 103    |
| Add               | 110          | ARM   | TAN   | 2   |             | 0.024                          | 0.057 | 0.007 | 103          | 103    |
| Add               | 110          | ATY   | LSE   | 1   | 21.9        | 0.014                          | 0.071 | 0.008 | 178          | 219    |
| Remove            | 110          | ATY   | PLS   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add               | 110          | BGT   | KKY   | 1   | 22.0        | 0.014                          | 0.072 | 0.008 | 178          | 219    |
| Add               | 110          | BGT   | LSE   | 1   | 28.0        | 0.018                          | 0.091 | 0.010 | 178          | 219    |
| Add               | 110          | BK    | NMO   | 3   | 14.1        | 0.009                          | 0.046 | 0.005 | 178          | 219    |
| Add               | 110          | BK    | NMO   | 4   | 38.5        | 0.024                          | 0.125 | 0.014 | 178          | 219    |
| Add               | 110          | BK    | OWN   | 1   | 4.0         | 0.001                          | 0.004 | 0.044 | 187          | 223    |
| Add <sup>5</sup>  | 380          | BK    | FLA   | 1   | 123.0       | 0.002                          | 0.027 | 0.621 | 1577         | 1944   |
| Add <sup>6</sup>  | 220          | SRA   | FLA 1 | 1   | 47.0        | 0.005                          | 0.041 | 0.061 | 434          | 353    |
|                   |              | FLA 1 | FLA   | 1   | 8.0         | 0.000                          | 0.003 | 0.324 | 680          | 680    |
|                   |              | NMO   | NMO 1 | 1   | 2.0         | 0.000                          | 0.001 | 0.081 | 680          | 680    |
|                   |              | NMO 1 | NMO 2 | 1   | 11.0        | 0.001                          | 0.010 | 0.014 | 434          | 535    |
|                   |              | NMO 2 | NMO 3 | 1   | 20.0        | 0.001                          | 0.009 | 0.809 | 680          | 680    |
|                   |              | NMO 3 | FLA   | 1   | 72.0        | 0.008                          | 0.062 | 0.094 | 434          | 535    |
| Add <sup>7</sup>  | 320          | NMO   | FLA   | 1   | 112.5       | ...                            | ...   | ...   | 500          | 500    |
| Add               | 110          | CAH   | SUR   | 1   |             | 0.002                          | 0.005 | 0.035 | 118          | 118    |
| Add <sup>8</sup>  | 110          | CBR   | MOY   | 1   | 37.0        | 0.023                          | 0.120 | 0.013 | 178          | 219    |
| Add <sup>9</sup>  | 110          | CBR   | MOY1  | 1   | 11.0        | 0.001                          | 0.017 | 0.134 | 295          | 295    |
|                   |              | MOY1  | CBR   | 1   | 26.0        | 0.016                          | 0.084 | 0.092 | 178          | 219    |
| Add <sup>10</sup> | 220          | CLO   | SRA   | 1   | 83.0        | 0.010                          | 0.072 | 0.109 | 434          | 534    |
| Add <sup>11</sup> | 220          | CLO   | CLO1  | 1   | 25.0        | 0.001                          | 0.010 | 0.684 | 593          | 593    |
|                   |              | CLO1  | SRA   | 1   | 58.0        | 0.007                          | 0.050 | 0.076 | 434          | 534    |
| Remove            | 110          | CKG   | BKY   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add               | 110          | CKG   | WDU   | 1   | 0.8         | 0.000                          | 0.001 | 0.008 | 187          | 223    |

<sup>5</sup> Grid West 400kV overhead line option (may be subject to change in future TYTFS versions)

<sup>6</sup> Grid West 220kV partial cable option (may be subject to change in future TYTFS versions)

<sup>7</sup> Grid West 320kV HVDC option (generic model provided, this information may be subject to change in future TYTFS versions as the project matures)

<sup>8</sup> North Connaught Reinforcement 110kV overhead line option (may be subject to change in future TYTFS versions)

<sup>9</sup> North Connaught Reinforcement 110kV partial cable option (generic model provided, this information may be subject to change in future TYTFS versions as the project matures)

<sup>10</sup> North-West Project 220kV overhead line option (may be subject to change in future TYTFS versions)

<sup>11</sup> North-West Project 220kV partial cable option (generic model provided, this information may be subject to change in future TYTFS versions as the project matures)

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-17 Changes in Circuit Characteristics Expected after 2018 (continued)

| Change | Voltage (kV) | From    | To    | No. | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |
|--------|--------------|---------|-------|-----|-------------|--------------------------------|-------|-------|--------------|--------|
|        |              |         |       |     |             | R                              | X     | B     | Summer       | Winter |
| Add    | 110          | CKG     | WDU   | 1   | 0.8         | 0.000                          | 0.001 | 0.008 | 187          | 223    |
| Add    | 110          | COL (N) | CAM   | 1   |             | 0.000                          | 0.000 | 0.000 | 105          | 128    |
| Add    | 380          | DSN     | LSE   | 1   | 44.8        | 0.001                          | 0.010 | 0.226 | 1577         | 1944   |
| Remove | 380          | DSN     | MP    | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | GAR (N) | RSK   | 1   |             | 0.004                          | 0.031 | 0.210 | 178          | 219    |
| Remove | 110          | GCA     | KUD   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Remove | 110          | GCA     | KUD   | 2   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Remove | 110          | INC     | BKY   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 220          | INC     | WDU   | 1   | 14.3        | 0.002                          | 0.012 | 0.020 | 761          | 804    |
| Add    | 110          | KEL     | KLW   | 1   |             | 0.000                          | 0.001 | 0.008 | 144          | 144    |
| Add    | 110          | KEL     | TID   | 1   |             | 0.035                          | 0.192 | 0.019 | 309          | 309    |
| Add    | 110          | KKY     | NO    | 1   | 3.6         | 0.003                          | 0.005 | 0.036 | 140          | 140    |
| Remove | 220          | KLN     | TB    | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 220          | KLS     | KPG   | 1   | 70.0        | 0.009                          | 0.060 | 0.119 | 660          | 660    |
| Add    | 110          | KPG     | CHR   | 1   | 22.6        | 0.024                          | 0.075 | 0.008 | 136          | 166    |
| Add    | 220          | KPG     | MP    | 1   | 5.4         | 0.000                          | 0.002 | 0.236 | 660          | 660    |
| Add    | 220          | LOU     | ORL   | 1   | 14.5        | 0.002                          | 0.013 | 0.019 | 434          | 534    |
| Add    | 110          | LSE     | PSE   | 1   | 8.4         | 0.005                          | 0.026 | 0.008 | 178          | 219    |
| Add    | 380          | LSE     | MP    | 1   | 170.0       | 0.003                          | 0.038 | 0.858 | 1577         | 1944   |
| Remove | 110          | OMA     | STR   | 1   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Remove | 110          | OMA     | STR   | 2   | ...         | ...                            | ...   | ...   | ...          | ...    |
| Add    | 110          | OMA     | NST   | 1   |             | 0.023                          | 0.061 | 0.006 | 186          | 193    |
| Add    | 110          | OMA     | NST   | 2   |             | 0.023                          | 0.061 | 0.006 | 186          | 193    |
| Add    | 110          | OMS     | CMK   | 1   |             | 0.007                          | 0.045 | 0.004 | 167          | 188    |
| Add    | 220          | ORL     | ORL L | 1   | 20.1        | 0.001                          | 0.008 | 0.550 | 593          | 593    |
| Add    | 220          | ORL L   | ORL O | 1   | 15.9        | 0.001                          | 0.002 | 0.528 | 570          | 570    |
| Add    | 110          | OWN     | OWN   | 1   | 4.4         | 0.003                          | 0.014 | 0.002 | 178          | 219    |
| Add    | 110          | STR     | NST   | 1   |             | 0.023                          | 0.061 | 0.006 | 186          | 193    |
| Add    | 110          | STR     | NST   | 2   |             | 0.023                          | 0.061 | 0.006 | 186          | 193    |
| Add    | 275          | TMN     | TUR   | 1   |             | 0.000                          | 0.002 | 0.014 | 710          | 881    |
| Add    | 275          | TMN     | TUR   | 2   |             | 0.000                          | 0.002 | 0.014 | 710          | 881    |
| Add    | 275          | TAN     | TUR   | 1   |             | 0.001                          | 0.009 | 0.051 | 710          | 881    |
| Add    | 275          | TAN     | TUR   | 2   |             | 0.001                          | 0.009 | 0.051 | 710          | 881    |
| Add    | 110          | WDU     | BKY   | 1   | 1.0         | 0.000                          | 0.001 | 0.011 | 187          | 223    |
| Add    | 110          | WDU     | BKY   | 2   | 0.6         | 0.000                          | 0.001 | 0.011 | 187          | 223    |
| Add    | 220          | WDU     | MAY   | 1   | 11.7        | 0.002                          | 0.012 | 0.018 | 761          | 804    |
| Add    | 220          | WDU     | MAY   | 2   | 11.7        | 0.002                          | 0.010 | 0.016 | 761          | 804    |



TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-17 Changes in Circuit Characteristics Expected after 2018 (continued)

| Change | Voltage (kV) | From | To  | No. | Length (km) | Impedance p.u. on 100 MVA base |       |       | Rating (MVA) |        |
|--------|--------------|------|-----|-----|-------------|--------------------------------|-------|-------|--------------|--------|
|        |              |      |     |     |             | R                              | X     | B     | Summer       | Winter |
| Add    | 220          | WDU  | INC | 1   | 14.3        | 0.002                          | 0.009 | 0.014 | 761          | 804    |
| Add    | 220          | WOO  | ORL | 1   | 49.2        | 0.043                          | 0.043 | 0.064 | 434          | 534    |
| Add    | 380          | WOO  | TUR | 1   | 140.0       | 0.003                          | 0.031 | 0.707 | 1424         | 1731   |

Table B-18 Characteristics of 220/110 kV Transformer Changes in 2015

| Action | Station/Transformer | Rating (MVA) | HV/LV (kV) | Impedance p.u. on 100 MVA base |        | Voltage Ratio Tapping Range |      |
|--------|---------------------|--------------|------------|--------------------------------|--------|-----------------------------|------|
|        |                     |              |            | R                              | X      | +                           | -    |
| Add    | Ballyvouskill T2101 | 250          | 220 / 110  | 0.0010                         | 0.0640 | 0.09                        | 0.17 |
| Add    | Knockanure T2101    | 250          | 220 / 110  | 0.0010                         | 0.0640 | 0.09                        | 0.17 |
| Add    | Knockanure T2102    | 250          | 220 / 110  | 0.0010                         | 0.0640 | 0.09                        | 0.17 |

Table B-19 Characteristics of 400/220 kV Transformer Changes in 2016

| Action | Station/Transformer | Rating (MVA) | HV/LV (kV) | Impedance p.u. on 100 MVA base |        | Voltage Ratio Tapping Range |      |
|--------|---------------------|--------------|------------|--------------------------------|--------|-----------------------------|------|
|        |                     |              |            | R                              | X      | +                           | -    |
| Add    | Dunstown T4202      | 500          | 400 / 220  | 0.0003                         | 0.0270 | 0.10                        | 0.07 |
| Add    | MoneypointG1 T4202  | 500          | 400 / 220  | 0.0002                         | 0.0329 | 0.01                        | 0.15 |

Table B-20 Characteristics of 275/110 kV Transformer Changes in 2016

| Action | Substation/Transformer | Impedance p.u. on 100 MVA Base |        |        |        |      |        | Rating in MVA |     |    | Off Nominal Ratio (p.u.) |       | No. of Taps |
|--------|------------------------|--------------------------------|--------|--------|--------|------|--------|---------------|-----|----|--------------------------|-------|-------------|
|        |                        | W1-2                           |        | W2-3   |        | W3-1 |        | W1            | W2  | W3 | Upper                    | Lower |             |
|        |                        | R                              | X      | R      | X      | R    | X      |               |     |    |                          |       |             |
| Add    | Tamnamore IBTx2        | 0.0014                         | 0.0644 | 0.0040 | 0.2299 | 0    | 0.1500 | 240           | 240 | 60 | 1.15                     | 0.85  | 19          |

Table B-21 Characteristics of 220/110 kV Transformer Changes in 2016

| Action | Station/Transformer | Rating (MVA) | HV/LV (kV) | Impedance p.u. on 100 MVA base |        | Voltage Ratio Tapping Range |      |
|--------|---------------------|--------------|------------|--------------------------------|--------|-----------------------------|------|
|        |                     |              |            | R                              | X      | +                           | -    |
| Add    | Ballynahinch T2101  | 250          | 220 / 110  | 0.0010                         | 0.0640 | 0.09                        | 0.17 |
| Add    | Ballynahinch T2102  | 250          | 220 / 110  | 0.0010                         | 0.0640 | 0.09                        | 0.17 |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table B-21 Characteristics of 220/110 kV Transformer Changes in 2016 (continued)

| Action | Station/<br>Transformer | Rating<br>(MVA) | HV/LV<br>(kV) | Impedance p.u. on<br>100 MVA base |        | Voltage Ratio<br>Tapping Range |      |
|--------|-------------------------|-----------------|---------------|-----------------------------------|--------|--------------------------------|------|
|        |                         |                 |               | R                                 | X      | +                              | -    |
| Add    | Carrickmines<br>T2104   | 250             | 220 / 110     | 0.0004                            | 0.0631 | 0.09                           | 0.18 |
| Add    | Kilpaddoge<br>T2101     | 250             | 220 / 110     | 0.0004                            | 0.0631 | 0.09                           | 0.18 |
| Add    | Kilpaddoge<br>T2102     | 250             | 220 / 110     | 0.0004                            | 0.0631 | 0.09                           | 0.18 |
| Add    | Moneypoint<br>T2101     | 250             | 220 / 110     | 0.0010                            | 0.0640 | 0.09                           | 0.17 |

Table B-22 Characteristics of 220/110 kV Transformer Changes in 2017

| Action | Station/<br>Transformer | Rating<br>(MVA) | HV/LV<br>(kV) | Impedance p.u. on<br>100 MVA base |        | Voltage Ratio<br>Tapping Range |      |
|--------|-------------------------|-----------------|---------------|-----------------------------------|--------|--------------------------------|------|
|        |                         |                 |               | R                                 | X      | +                              | -    |
| Add    | Belcamp<br>T2101        | 250             | 220 / 110     | 0.0010                            | 0.0646 | 0.09                           | 0.17 |

Table B-23 Characteristics of 275/110 kV Transformer Changes in 2018

| Action | Substation/<br>Transformer | Impedance p.u. on 100 MVA Base |        |        |        |      |        | Rating in<br>MVA |     |    | Off Nominal<br>Ratio (p.u.) |       | No.<br>of<br>Taps |
|--------|----------------------------|--------------------------------|--------|--------|--------|------|--------|------------------|-----|----|-----------------------------|-------|-------------------|
|        |                            | W1-2                           |        | W2-3   |        | W3-1 |        | W1               | W2  | W3 | Upper                       | Lower |                   |
|        |                            | R                              | X      | R      | X      | R    | X      |                  |     |    |                             |       |                   |
| Add    | Ballylumford<br>IBTx3      | 0.0014                         | 0.0639 | 0.0014 | 0.2236 | 0    | 0.1449 | 240              | 240 | 60 | 1.15                        | 0.85  | 19                |
| Add    | Ballylumford<br>IBTx4      | 0.0014                         | 0.0639 | 0.0014 | 0.2236 | 0    | 0.1449 | 240              | 240 | 60 | 1.15                        | 0.85  | 19                |

Table B-24 Characteristics of 220/110 kV Transformer Changes in 2018

| Action | Station/<br>Transformer | Rating<br>(MVA) | HV/LV<br>(kV) | Impedance p.u. on<br>100 MVA base |        | Voltage Ratio<br>Tapping Range |      |
|--------|-------------------------|-----------------|---------------|-----------------------------------|--------|--------------------------------|------|
|        |                         |                 |               | R                                 | X      | +                              | -    |
| Amend  | Clashavoon<br>T2102     | 250             | 220 / 110     | 0.0013                            | 0.0647 | 0.09                           | 0.17 |
| Remove | Killonan<br>T2103       | 250             | 220 / 110     | 0.0004                            | 0.0631 | 0.09                           | 0.18 |
| Remove | Killonan<br>T2104       | 250             | 220 / 110     | 0.0004                            | 0.0631 | 0.09                           | 0.18 |
| Remove | Knockraha<br>T2101      | 250             | 220 / 110     | 0.0013                            | 0.0647 | 0.09                           | 0.17 |

Table B-25 Characteristics of 400/275 kV Transformer Changes After 2018

| Action | Substation/<br>Transformer | Impedance p.u. on 100 MVA Base |        |      |        |      |        | Rating in MVA |     |    | Off Nominal<br>Ratio (p.u.) |       | No.<br>of<br>Taps |
|--------|----------------------------|--------------------------------|--------|------|--------|------|--------|---------------|-----|----|-----------------------------|-------|-------------------|
|        |                            | W1-2                           |        | W2-3 |        | W3-1 |        |               |     |    |                             |       |                   |
|        |                            | R                              | X      | R    | X      | R    | X      | W1            | W2  | W3 | Upper                       | Lower |                   |
| Add    | Turleenan<br>IBTx1         | 0.0008                         | 0.0150 | 0    | 0.0001 | 0    | 0.0001 | 600           | 600 | 60 | 1.10                        | 0.90  | 23                |
| Add    | Turleenan<br>IBTx2         | 0.0008                         | 0.0150 | 0    | 0.0001 | 0    | 0.0001 | 600           | 600 | 60 | 1.10                        | 0.90  | 23                |
| Add    | Turleenan<br>IBTx3         | 0.0008                         | 0.0150 | 0    | 0.0001 | 0    | 0.0001 | 600           | 600 | 60 | 1.10                        | 0.90  | 23                |

Table B-26 Characteristics of 400/220 kV Transformer Changes After 2018

| Action | Station/<br>Transformer | Rating<br>(MVA) | HV/LV<br>(kV) | Impedance p.u. on<br>100 MVA base |        | Voltage Ratio<br>Tapping Range |      |
|--------|-------------------------|-----------------|---------------|-----------------------------------|--------|--------------------------------|------|
|        |                         |                 |               | R                                 | X      | +                              | -    |
| Add    | Flagford<br>T4201       | 500             | 380 /<br>220  | 0.0003                            | 0.0270 | 0.10                           | 0.07 |
| Add    | Great Island<br>T4201   | 250             | 380 /<br>220  | 0.0005                            | 0.0720 | 0.15                           | 0.15 |
| Add    | Knockraha<br>T4202      | 500             | 380 /<br>220  | 0.0003                            | 0.0270 | 0.10                           | 0.07 |

Table B-27 Characteristics of 400/110 kV Transformer Changes After 2018

| Action | Station/<br>Transformer | Rating<br>(MVA) | HV/LV<br>(kV) | Impedance p.u. on<br>100 MVA base |        | Voltage Ratio<br>Tapping Range |      |
|--------|-------------------------|-----------------|---------------|-----------------------------------|--------|--------------------------------|------|
|        |                         |                 |               | R                                 | X      | +                              | -    |
| Add    | Laois T4101             | 250             | 380 / 110     | 0.0005                            | 0.0720 | 0.15                           | 0.15 |
| Add    | Laois T4101             | 250             | 380 / 110     | 0.0005                            | 0.0720 | 0.15                           | 0.15 |
| Add    | North Mayo<br>T4101     | 500             | 380 / 110     | 0.0005                            | 0.0360 | 0.15                           | 0.15 |

Table B-28 Characteristics of 275/110 kV Transformer Changes After 2018

| Action | Substation/<br>Transformer | Impedance p.u. on 100 MVA Base |        |        |        |      |        | Rating in<br>MVA |     |    | Off Nominal<br>Ratio (p.u.) |       | No.<br>of<br>Taps |
|--------|----------------------------|--------------------------------|--------|--------|--------|------|--------|------------------|-----|----|-----------------------------|-------|-------------------|
|        |                            | W1-2                           |        | W2-3   |        | W3-1 |        |                  |     |    |                             |       |                   |
|        |                            | R                              | X      | R      | X      | R    | X      | W1               | W2  | W3 | Upper                       | Lower |                   |
| Add    | Omagh<br>South IBTx1       | 0.0014                         | 0.0639 | 0.0014 | 0.2236 | 0    | 0.1449 | 240              | 240 | 30 | 1.10                        | 0.80  | 19                |

Table B-29 Characteristics of 220/110 kV Transformer Changes After 2018

| Change | Station/<br>Transformer | Rating<br>(MVA) | HV/LV<br>(kV) | Impedance p.u. on<br>100 MVA base |        | Voltage Ratio<br>Tapping Range |      |
|--------|-------------------------|-----------------|---------------|-----------------------------------|--------|--------------------------------|------|
|        |                         |                 |               | R                                 | X      | +                              | -    |
| Add    | Clogher<br>T2101        | 250             | 220 / 110     | 0.0004                            | 0.0631 | 0.09                           | 0.18 |
| Add    | Clogher<br>T2102        | 250             | 220 / 110     | 0.0004                            | 0.0631 | 0.09                           | 0.18 |
| Add    | West<br>Dublin<br>T2101 | 250             | 220 / 110     | 0.0010                            | 0.0646 | 0.09                           | 0.17 |
| Add    | West<br>Dublin<br>T2101 | 250             | 220 / 110     | 0.0010                            | 0.0646 | 0.10                           | 0.10 |
| Add    | West<br>Dublin<br>T2101 | 250             | 220 / 110     | 0.0010                            | 0.0646 | 0.10                           | 0.10 |

Table B-30 Changes in the Characteristics of Reactive Compensation Expected in 2016

| Add/Remove | Station    | Bus     | Plant               | Mvar Capability |        |
|------------|------------|---------|---------------------|-----------------|--------|
|            |            |         |                     | Generate        | Absorb |
| Add        | Knockranny | KNY 110 | 1 Capacitor         | 30              | -      |
| Add        | Poolbeg    | PB 220  | 2 Reactors (2 x 50) | -               | 100    |

Table B-31 Changes in the Characteristics of Reactive Compensation Expected in 2017

| Add/Remove | Station    | Bus          | Plant       | Mvar Capability |        |
|------------|------------|--------------|-------------|-----------------|--------|
|            |            |              |             | Generate        | Absorb |
| Add        | Castletown | CASTLETO 110 | 1 Capacitor | 15              | -      |

Table B-32 Changes in the Characteristics of Reactive Compensation Expected after 2018

| Add/Remove | Station     | Bus             | Plant       | Mvar Capability |        |
|------------|-------------|-----------------|-------------|-----------------|--------|
|            |             |                 |             | Generate        | Absorb |
| Add        | Coleraine   | COLE_SVC 110.00 | 1 SVC       | 100             | 100    |
| Add        | Coleraine   | COLE_SVC 110.00 | 1 SVC       | 120             | 120    |
| Remove     | Coleraine   | COLE1_CA 110.00 | 1 Capacitor | 36              | -      |
| Add        | Omagh South | OMAS- 110.00    | 1 SVC       | 100             | 100    |
| Add        | Tamnamore   | TAMN1_SV 110.00 | 1 SVC       | 180             | 180    |



## APPENDIX C: DEMAND FORECASTS AT INDIVIDUAL TRANSMISSION INTERFACE STATIONS



The current. The future.

## Appendix C Demand Forecasts at Individual Transmission Interface Stations

Transmission Interface Stations and Bulk Supply Points are connection points to the transmission system. These connection points include transmission system connections to the distribution system or directly-connected customers.

Table C-1 to Table C-4 list the demand forecasts at each Transmission Interface Station and Bulk Supply Point. The forecasts are noted for each node between 2015 and 2024 at the winter peak, summer peak, and summer valley. The autumn peak forecasts are also given for Northern Ireland.

The station demand values do not include transmission losses. Demand values at stations that interface with the distribution system do include distribution losses.

Transmission Interface Stations are generally 110 kV stations. The exceptions to this are four 220 kV interface stations that supply the Dublin City networks. These four interface stations, namely Carrickmines, Finglas, Inchicore and Poolbeg, are operated by the DSO of Ireland.

Only stations feeding demand (generation stations are not included) are included in the tables below.

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table C-1 Demand Forecasts at Time of Winter Peak

| Bus Code | Bus Name                    | Power Factor | Demand Forecast (MW) |       |       |       |       |       |       |       |       |       |
|----------|-----------------------------|--------------|----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|          |                             |              | 2015                 | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| AA       | ARDNACRUSHA                 | 1.00         | 31.39                | 31.36 | 31.54 | 30.75 | 30.90 | 31.06 | 31.20 | 31.50 | 31.84 | 32.21 |
| AD       | AGHADA                      | 1.00         | 1.60                 | 1.60  | 1.60  | 1.56  | 1.57  | 1.58  | 1.59  | 1.60  | 1.62  | 1.64  |
| AGY      | ARDNAGAPPARY                | 0.95         | 0.00                 | 0.00  | 14.28 | 13.92 | 13.99 | 14.06 | 14.12 | 14.26 | 14.42 | 14.58 |
| AHA      | AHANE                       | 0.98         | 5.74                 | 5.73  | 5.77  | 5.62  | 5.65  | 5.68  | 5.70  | 5.76  | 5.82  | 5.89  |
| AA       | ARDNACRUSHA                 | 1.00         | 31.39                | 31.36 | 31.54 | 30.75 | 30.90 | 31.06 | 31.20 | 31.50 | 31.84 | 32.21 |
| AIR      | BELFAST - AIRPORT ROAD MAIN | 0.98         | -                    | -     | -     | -     | 23.22 | 23.36 | 23.53 | 23.71 | 23.87 | 24.04 |
| ANR      | ANNER                       | 0.92         | 16.04                | 16.04 | 16.04 | 16.04 | 16.04 | 16.04 | 16.04 | 16.04 | 16.04 | 16.04 |
| ANT      | ANTRIM MAIN                 | 0.98         | 43.15                | 43.21 | 43.31 | 43.49 | 43.12 | 43.39 | 43.69 | 44.03 | 44.33 | 44.64 |
| ARI      | ARIGNA                      | 1.00         | 4.34                 | 4.34  | 4.36  | 4.25  | 4.27  | 4.29  | 4.32  | 4.36  | 4.40  | 4.45  |
| ARK      | ARKLOW                      | 0.95         | 22.87                | 22.84 | 22.98 | 22.41 | 22.52 | 22.63 | 22.73 | 22.95 | 23.21 | 23.46 |
| ARM      | ARMAGH                      | 0.98         | -                    | -     | -     | -     | -     | -     | -     | 37.11 | 37.36 | 37.61 |
| ATH      | ATHLONE                     | 0.95         | 64.10                | 59.50 | 59.85 | 58.34 | 58.64 | 58.92 | 59.21 | 59.77 | 60.43 | 61.10 |
| ATY      | ATHY                        | 0.90         | 18.17                | 18.15 | 18.26 | 17.80 | 17.89 | 17.97 | 18.06 | 18.23 | 18.43 | 18.64 |
| BAL      | BALTRASNA                   | 1.00         | 14.77                | 14.76 | 14.84 | 14.47 | 14.55 | 14.62 | 14.69 | 14.83 | 14.99 | 15.16 |
| BAN      | BANBRIDGE MAIN              | 0.98         | 39.81                | 39.86 | 39.95 | 40.12 | 39.77 | 40.02 | 40.30 | 40.61 | 40.90 | 41.17 |
| BAN      | BANDON                      | 0.97         | 29.77                | 39.20 | 39.42 | 38.48 | 38.67 | 38.84 | 39.02 | 39.38 | 39.78 | 40.21 |
| BAR      | BARRYMORE                   | 1.00         | 26.34                | 26.31 | 26.47 | 25.80 | 25.94 | 26.06 | 26.19 | 26.44 | 26.73 | 27.03 |
| BDA      | BARODA                      | 0.97         | 5.26                 | 5.26  | 17.27 | 16.97 | 17.03 | 17.08 | 17.14 | 17.25 | 17.39 | 17.52 |
| BDN      | BALLYDINE                   | 0.96         | 17.20                | 17.18 | 17.25 | 16.97 | 17.02 | 17.08 | 17.13 | 17.24 | 17.36 | 17.49 |
| BEG      | BALLYBEG                    | 0.99         | 13.20                | 13.18 | 13.26 | 12.93 | 12.99 | 13.05 | 13.12 | 13.24 | 13.39 | 13.54 |
| BGT      | BALLYRAG                    | 0.95         | 0.00                 | 0.00  | 0.00  | 0.00  | 22.97 | 23.08 | 23.19 | 23.41 | 23.67 | 23.94 |
| BIN      | BINBANE                     | 0.99         | 26.73                | 26.70 | 17.26 | 16.82 | 16.91 | 16.99 | 17.07 | 17.23 | 17.42 | 17.62 |
| BK       | BELLACORICK                 | 0.97         | 10.45                | 10.44 | 10.51 | 10.24 | 10.29 | 10.34 | 10.38 | 10.49 | 10.60 | 10.72 |

Table C-1 Demand Forecasts at Time of Winter Peak (continued)

| Bus Code | Bus Name                       | Power Factor | Demand Forecast (MW) |        |        |        |        |        |        |        |        |        |
|----------|--------------------------------|--------------|----------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
|          |                                |              | 2015                 | 2016   | 2017   | 2018   | 2019   | 2020   | 2021   | 2022   | 2023   | 2024   |
| BKY      | BARNAKYLE                      | 0.95         | 9.08                 | 9.07   | 9.13   | 8.90   | 8.94   | 8.99   | 9.03   | 9.12   | 9.22   | 9.32   |
| BLI      | BALLYLICKY                     | 1.00         | 10.13                | 10.11  | 10.18  | 9.92   | 9.97   | 10.02  | 10.07  | 10.16  | 10.27  | 10.39  |
| BLK      | BLAKE                          | 0.98         | 24.73                | 24.70  | 24.85  | 12.05  | 12.11  | 12.17  | 12.22  | 12.34  | 12.48  | 12.62  |
| BMA      | BALLYMENA MAIN                 | 0.98         | 74.74                | 74.83  | 75.00  | 75.31  | 74.67  | 75.15  | 75.67  | 76.24  | 76.77  | 77.30  |
| BNH      | BALLYNAHINCH MAIN              | 0.98         | 60.57                | 60.64  | 60.78  | 61.03  | 60.51  | 60.90  | 61.32  | 61.79  | 62.22  | 62.64  |
| BNM      | BELFAST - BELFAST NORTH MAIN   | 0.98         | 50.25                | 50.30  | 50.43  | 50.63  | 50.19  | 50.51  | 50.86  | 51.26  | 51.61  | 51.97  |
| BOG      | BANOGE                         | 0.96         | 19.67                | 19.65  | 19.76  | 19.27  | 19.37  | 19.46  | 19.55  | 19.74  | 19.95  | 20.18  |
| BRA      | BRACKLON                       | 0.95         | 0.00                 | 0.00   | 0.00   | 12.18  | 12.24  | 12.30  | 12.36  | 12.47  | 12.61  | 12.75  |
| BRI      | BRINNY                         | 0.97         | 3.95                 | 3.95   | 3.95   | 3.95   | 3.95   | 3.95   | 3.95   | 3.95   | 3.95   | 3.95   |
| BRY      | BARNAHELY                      | 0.98         | 32.32                | 32.29  | 32.47  | 31.65  | 31.82  | 31.97  | 32.13  | 32.43  | 32.79  | 33.16  |
| BUT      | BUTLERSTOWN                    | 0.99         | 36.88                | 36.84  | 37.06  | 36.13  | 36.31  | 36.49  | 36.66  | 37.01  | 37.42  | 37.84  |
| CAH      | CAHIR                          | 0.98         | 23.43                | 23.40  | 23.54  | 22.95  | 23.06  | 23.18  | 23.29  | 23.51  | 23.77  | 24.03  |
| CAR      | BELFAST - CARNMONEY MAIN       | 0.98         | 29.07                | 29.10  | 29.16  | 29.29  | 29.04  | 29.22  | 29.42  | 29.66  | 29.86  | 30.06  |
| CBG      | CARROWBEG                      | 0.98         | 26.77                | 26.75  | 26.88  | 26.31  | 26.43  | 26.53  | 26.64  | 26.85  | 27.09  | 27.35  |
| CBR      | CASTLEBAR                      | 0.97         | 26.62                | 26.59  | 26.75  | 26.08  | 26.21  | 26.34  | 26.46  | 26.72  | 27.01  | 27.31  |
| CDY      | CORDERRY                       | 0.07         | 0.53                 | 0.53   | 0.53   | 0.52   | 0.52   | 0.52   | 0.52   | 0.53   | 0.53   | 0.54   |
| CEN      | BELFAST - BELFAST CENTRAL MAIN | 0.98         | 55.21                | 55.28  | 55.40  | 55.64  | 55.16  | 55.51  | 55.90  | 56.33  | 56.72  | 57.10  |
| CF       | CATHALEEN'S FALL               | 0.95         | 17.90                | 17.88  | 17.99  | 17.53  | 17.62  | 17.71  | 17.79  | 17.96  | 18.16  | 18.36  |
| CFM      | CASTLEFARM                     | 0.90         | 50.80                | 50.80  | 50.80  | 50.80  | 50.80  | 50.80  | 50.80  | 50.80  | 50.80  | 50.80  |
| CHA      | CHARLEVILLE                    | 0.98         | 18.14                | 18.12  | 18.23  | 17.77  | 17.86  | 17.94  | 18.03  | 18.20  | 18.40  | 18.61  |
| CKG      | CORKAGH                        | 0.95         | 33.25                | 33.25  | 33.25  | 152.00 | 152.00 | 152.00 | 152.00 | 152.00 | 152.00 | 152.00 |
| CKM      | CARRICKMINES                   | 0.98         | 380.69               | 399.35 | 401.20 | 393.31 | 394.89 | 396.35 | 397.82 | 400.81 | 404.20 | 407.77 |



Table C-1 Demand Forecasts at Time of Winter Peak (continued)

| Bus Code | Bus Name               | Power Factor | Demand Forecast (MW) |        |        |        |        |        |        |        |        |        |
|----------|------------------------|--------------|----------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
|          |                        |              | 2015                 | 2016   | 2017   | 2018   | 2019   | 2020   | 2021   | 2022   | 2023   | 2024   |
| CLG      | CLOGHRAN               | 0.95         | 23.75                | 23.75  | 23.75  | 23.75  | 23.75  | 23.75  | 23.75  | 23.75  | 23.75  | 23.75  |
| CLN      | CLOON                  | 0.97         | 24.35                | 28.85  | 29.03  | 28.30  | 28.44  | 28.58  | 28.72  | 28.99  | 29.31  | 29.63  |
| CLW      | CARLOW                 | 0.99         | 51.53                | 51.47  | 51.78  | 50.48  | 50.73  | 50.98  | 51.22  | 51.71  | 52.28  | 52.86  |
| COL      | COLERAINE MAIN         | 0.98         | 41.74                | 41.77  | 41.87  | 42.05  | 41.70  | 41.96  | 42.25  | 42.59  | 42.87  | 43.16  |
| COL      | COLLEGE PARK           | 0.98         | 26.20                | 26.17  | 26.33  | 25.66  | 25.80  | 25.92  | 26.04  | 26.29  | 0.00   | 26.88  |
| COS      | CARICKONSHANNON        | 0.99         | 29.69                | 29.66  | 29.83  | 29.08  | 29.23  | 29.37  | 29.51  | 29.80  | 30.12  | 30.46  |
| COW      | COW CROSS              | 0.99         | 11.12                | 11.11  | 11.17  | 10.89  | 10.95  | 11.00  | 11.05  | 11.16  | 11.29  | 11.41  |
| CPS      | COOLKEERAGH MAIN       | 0.98         | 32.64                | 32.69  | 32.76  | 32.90  | 32.62  | 32.83  | 33.05  | 33.31  | 33.54  | 33.76  |
| CRA      | CRANE                  | 0.99         | 31.03                | 30.99  | 31.18  | 30.39  | 30.55  | 30.70  | 30.84  | 31.13  | 31.48  | 31.83  |
| CRE      | BELFAST - CREGAGH MAIN | 0.98         | 77.63                | 77.73  | 77.92  | 78.23  | 77.56  | 78.07  | 78.61  | 79.21  | 79.75  | 80.30  |
| CRG      | CREAGH MAIN            | 0.98         | 35.84                | 35.89  | 35.97  | 36.13  | 35.81  | 36.04  | 36.29  | 36.57  | 36.83  | 37.08  |
| CRO      | COOLROE                | 1.00         | 14.05                | 14.03  | 14.11  | 13.76  | 13.83  | 13.90  | 13.96  | 14.10  | 14.25  | 14.41  |
| CVW      | CASTLEVIEW             | 0.98         | 20.91                | 20.89  | 21.01  | 20.48  | 20.59  | 20.69  | 20.79  | 20.99  | 21.22  | 21.45  |
| DAL      | DALLOW                 | 1.00         | 16.34                | 16.32  | 16.42  | 16.01  | 16.09  | 16.17  | 16.24  | 16.40  | 16.58  | 16.76  |
| DDK      | DUNDALK                | 0.99         | 63.77                | 63.70  | 41.26  | 40.22  | 40.42  | 40.62  | 40.82  | 41.21  | 41.65  | 42.12  |
| DFR      | DUNFIRTH               | 1.00         | 8.39                 | 8.38   | 8.43   | 8.21   | 8.26   | 8.30   | 8.34   | 8.42   | 8.51   | 8.60   |
| DGN      | DUNGARVAN              | 0.98         | 39.46                | 39.42  | 39.65  | 38.66  | 38.85  | 39.04  | 39.23  | 39.60  | 40.03  | 40.48  |
| DLT      | DALTON                 | 0.98         | 23.49                | 23.47  | 23.61  | 23.01  | 23.13  | 23.24  | 23.35  | 23.58  | 23.83  | 24.10  |
| DMY      | DUNMANWAY              | 0.99         | 39.93                | 35.59  | 35.80  | 34.90  | 35.08  | 35.25  | 35.42  | 35.75  | 36.14  | 36.55  |
| DON      | BELFAST - DONEGAL MAIN | 0.98         | 103.94               | 104.08 | 104.33 | 104.74 | 103.86 | 104.51 | 105.24 | 106.05 | 106.79 | 107.51 |
| DOO      | DOON                   | 0.97         | 29.25                | 29.22  | 29.39  | 28.65  | 28.80  | 28.94  | 29.08  | 29.35  | 29.67  | 30.01  |
| DRU      | DRUMNAKELLY MAIN       | 0.98         | 91.04                | 91.16  | 91.38  | 91.75  | 90.96  | 91.54  | 92.18  | 53.39  | 53.76  | 54.13  |

Table C-1 Demand Forecasts at Time of Winter Peak (continued)

| Bus Code | Bus Name                   | Power Factor | Demand Forecast (MW) |        |        |        |        |        |        |        |        |        |
|----------|----------------------------|--------------|----------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
|          |                            |              | 2015                 | 2016   | 2017   | 2018   | 2019   | 2020   | 2021   | 2022   | 2023   | 2024   |
| DRU      | DRUMLINE                   | 0.98         | 26.02                | 25.99  | 26.14  | 25.49  | 25.62  | 25.74  | 25.86  | 26.11  | 26.40  | 26.69  |
| DRY      | DRYBRIDGE                  | 0.98         | 81.42                | 81.33  | 76.34  | 74.42  | 74.80  | 75.16  | 75.52  | 76.24  | 77.07  | 77.94  |
| DUN      | DUNGANNON MAIN             | 0.98         | 96.19                | 96.30  | 96.53  | 96.93  | 96.10  | 96.73  | 97.39  | 98.14  | 98.81  | 99.48  |
| EDE      | EDEN MAIN                  | 0.98         | 32.05                | 32.09  | 32.16  | 32.30  | 32.02  | 32.22  | 32.45  | 32.70  | 32.92  | 33.15  |
| ENN      | ENNISKILLEN MAIN           | 0.98         | 48.97                | 49.04  | 49.15  | 49.35  | 48.92  | 49.25  | 49.59  | 49.97  | 50.32  | 50.66  |
| ENN      | ENNIS                      | 0.98         | 57.78                | 57.72  | 58.06  | 56.60  | 56.89  | 57.16  | 57.44  | 57.99  | 58.62  | 59.28  |
| FIN      | BELFAST - FINAGHY MAIN     | 0.98         | 33.04                | 33.08  | 33.16  | 33.29  | 33.01  | 33.21  | 33.45  | 33.70  | 33.94  | 34.17  |
| FIN      | FINGLAS                    | 0.98         | 484.96               | 484.48 | 487.05 | 476.12 | 478.27 | 480.30 | 482.38 | 486.49 | 474.84 | 496.15 |
| GAL      | GALWAY                     | 1.00         | 71.32                | 71.25  | 71.67  | 69.87  | 70.22  | 70.56  | 70.90  | 71.57  | 72.35  | 73.17  |
| GI       | GREAT ISLAND               | 0.94         | 17.30                | 17.28  | 17.38  | 16.94  | 17.03  | 17.11  | 17.19  | 17.36  | 17.55  | 17.75  |
| GIL      | GILRA                      | 0.97         | 11.42                | 11.42  | 11.42  | 11.42  | 11.42  | 11.42  | 11.42  | 11.42  | 11.42  | 11.42  |
| GLE      | BELFAST - GLENGORMELY MAIN | 0.98         | 27.71                | 27.74  | 27.81  | 27.92  | 27.67  | 27.87  | 28.06  | 28.27  | 28.47  | 28.65  |
| GLE      | GLENLARA                   | 0.95         | 14.52                | 14.51  | 14.60  | 14.23  | 14.30  | 14.37  | 14.44  | 14.58  | 14.74  | 14.90  |
| GRI      | GRIFFINRATH                | 0.95         | 53.91                | 53.85  | 54.17  | 52.81  | 53.08  | 53.33  | 53.59  | 54.10  | 54.69  | 55.31  |
| GWE      | GORTAWEE                   | 0.96         | 31.35                | 31.34  | 31.40  | 31.14  | 31.19  | 31.24  | 31.29  | 31.39  | 31.50  | 31.62  |
| HTS      | HARNETTS CROSS             | 0.98         | 0.00                 | 0.00   | 8.56   | 8.35   | 8.39   | 8.43   | 8.47   | 8.55   | 8.64   | 8.74   |
| IKE      | IKERRIN                    | 0.99         | 26.52                | 26.49  | 26.64  | 26.00  | 26.13  | 26.25  | 26.37  | 26.61  | 26.89  | 27.18  |
| INC      | INCHICORE                  | 0.98         | 352.87               | 362.07 | 363.66 | 357.03 | 358.32 | 359.56 | 360.83 | 363.31 | 353.96 | 369.16 |
| KBY      | KILBARRY                   | 0.99         | 85.89                | 85.81  | 86.31  | 85.03  | 85.46  | 85.87  | 86.29  | 87.11  | 88.06  | 89.05  |
| KER      | KNOCKERAGH                 | 0.96         | 31.15                | 31.12  | 31.30  | 30.52  | 30.67  | 30.82  | 30.97  | 31.26  | 31.60  | 31.96  |
| KIN      | KINNEGAD                   | 0.97         | 10.19                | 10.19  | 10.19  | 10.19  | 10.19  | 10.19  | 10.19  | 10.19  | 10.19  | 10.19  |
| KKY      | KILKENNY                   | 0.97         | 67.98                | 67.90  | 58.03  | 56.56  | 56.85  | 57.13  | 57.40  | 57.95  | 58.58  | 59.24  |

Table C-1 Demand Forecasts at Time of Winter Peak (continued)

| Bus Code | Bus Name             | Power Factor | Demand Forecast (MW) |       |       |       |       |       |       |       |       |       |
|----------|----------------------|--------------|----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|          |                      |              | 2015                 | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| KNO      | BELFAST - KNOCK MAIN | 0.98         | 51.42                | 51.49 | 51.61 | 51.82 | 51.38 | 51.70 | 52.06 | 52.47 | 52.82 | 53.19 |
| KTL      | KILTEEL              | 0.99         | 38.24                | 38.20 | 38.42 | 37.46 | 37.65 | 37.83 | 38.01 | 38.37 | 38.79 | 39.23 |
| KTN      | KILLOTARAN           | 0.96         | 15.98                | 15.97 | 16.05 | 15.71 | 15.77 | 15.84 | 15.90 | 16.03 | 16.18 | 16.33 |
| KUR      | KNOCKUMBER           | 0.93         | 28.14                | 28.14 | 28.14 | 28.14 | 28.14 | 28.14 | 28.14 | 28.14 | 28.14 | 28.14 |
| LA       | LANESBORO            | 0.93         | 11.77                | 11.76 | 11.83 | 11.53 | 11.59 | 11.64 | 11.70 | 11.81 | 11.94 | 12.08 |
| LAR      | LARNE - MAIN         | 0.98         | 42.76                | 42.80 | 42.91 | 43.08 | 42.72 | 42.99 | 43.30 | 43.62 | 43.92 | 44.22 |
| LET      | LETTERKENNY          | 0.98         | 65.40                | 65.32 | 61.03 | 59.50 | 59.80 | 60.09 | 60.38 | 60.95 | 61.62 | 62.31 |
| LIB      | LIBERTY              | 0.95         | 18.14                | 18.12 | 18.23 | 17.77 | 17.86 | 17.94 | 18.03 | 18.20 | 18.40 | 18.61 |
| LIM      | LIMAVADY MAIN        | 0.98         | 24.20                | 24.23 | 24.29 | 24.39 | 24.18 | 24.34 | 24.51 | 24.70 | 24.86 | 25.03 |
| LIM      | LIMERICK             | 0.99         | 77.37                | 77.29 | 77.74 | 75.81 | 76.19 | 76.55 | 76.92 | 77.64 | 78.48 | 79.35 |
| LIS      | LISBURN MAIN         | 0.98         | 60.94                | 61.02 | 61.16 | 61.42 | 60.89 | 61.29 | 61.71 | 62.18 | 62.61 | 63.04 |
| LIS      | LISDRUM              | 0.97         | 26.82                | 26.79 | 26.95 | 26.27 | 26.41 | 26.53 | 26.66 | 26.92 | 27.21 | 27.52 |
| LMR      | LISAGHMORE MAIN      | 0.98         | 47.64                | 47.69 | 47.81 | 48.00 | 47.59 | 47.90 | 48.23 | 48.60 | 48.94 | 49.27 |
| LOG      | LOUGUESTOWN MAIN     | 0.98         | 39.73                | 39.77 | 39.87 | 40.04 | 39.70 | 39.95 | 40.23 | 40.54 | 40.81 | 41.10 |
| LSN      | LISHEEN              | 0.96         | 19.50                | 19.50 | 19.50 | 19.50 | 19.50 | 19.50 | 19.50 | 19.50 | 19.50 | 19.50 |
| MAC      | MACROOM              | 0.98         | 17.65                | 12.47 | 3.99  | 3.89  | 3.91  | 3.93  | 3.94  | 3.98  | 4.03  | 4.07  |
| MAL      | MALLOW               | 0.99         | 21.66                | 21.63 | 21.76 | 21.22 | 21.32 | 21.43 | 21.53 | 21.73 | 21.97 | 22.22 |
| MCE      | MACETOWN             | 0.98         | 28.57                | 28.54 | 28.69 | 28.08 | 28.20 | 28.31 | 28.43 | 28.66 | 28.92 | 29.19 |
| MID      | MIDDLETON            | 0.98         | 34.64                | 34.60 | 34.79 | 33.96 | 34.12 | 34.28 | 34.44 | 34.75 | 35.11 | 35.49 |
| MLN      | MULLAGHARLIN         | 0.95         | 4.46                 | 4.46  | 32.76 | 32.04 | 32.18 | 32.32 | 32.45 | 32.72 | 33.03 | 33.35 |
| MON      | MONREAD              | 0.99         | 12.70                | 12.68 | 12.76 | 12.44 | 12.50 | 12.56 | 12.62 | 12.74 | 12.88 | 13.03 |
| MOY      | MOY                  | 0.99         | 24.70                | 24.67 | 24.82 | 24.19 | 24.32 | 24.43 | 24.55 | 24.79 | 25.06 | 25.34 |
| MR       | MARINA               | 0.96         | 16.71                | 16.70 | 16.80 | 16.37 | 16.46 | 16.54 | 16.62 | 16.77 | 16.96 | 17.15 |

Table C-1 Demand Forecasts at Time of Winter Peak (continued)

| Bus Code | Bus Name      | Power Factor | Demand Forecast (MW) |        |        |        |        |        |        |        |        |        |
|----------|---------------|--------------|----------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
|          |               |              | 2015                 | 2016   | 2017   | 2018   | 2019   | 2020   | 2021   | 2022   | 2023   | 2024   |
| MTH      | MEATH HILL    | 0.98         | 37.25                | 37.21  | 37.43  | 36.49  | 36.68  | 36.85  | 37.03  | 37.39  | 37.79  | 38.22  |
| MUL      | MULLINGAR     | 0.98         | 48.26                | 48.21  | 48.49  | 47.28  | 47.52  | 47.74  | 47.97  | 48.43  | 48.96  | 49.51  |
| MUN      | MUNGRET       | 0.88         | 19.13                | 19.13  | 19.13  | 19.13  | 19.13  | 19.13  | 19.13  | 19.13  | 19.13  | 19.13  |
| NAR      | NEWTOWNARDS   | 0.98         | 41.41                | 41.46  | 41.56  | 41.73  | 41.37  | 41.64  | 41.93  | 42.25  | 42.54  | 42.83  |
| NAV      | NAVAN         | 0.98         | 60.07                | 60.00  | 60.36  | 58.84  | 59.14  | 59.43  | 59.71  | 60.28  | 60.94  | 61.62  |
| NEN      | NENAGH        | 0.98         | 27.25                | 27.22  | 27.38  | 26.69  | 26.83  | 26.96  | 27.09  | 27.35  | 27.65  | 27.96  |
| NEW      | NEWRY MAIN    | 0.98         | 80.25                | 80.33  | 80.53  | 80.86  | 80.17  | 80.68  | 81.24  | 81.87  | 82.43  | 83.00  |
| NEW      | NEWBRIDGE     | 1.00         | 37.18                | 37.14  | 25.35  | 24.71  | 24.83  | 24.95  | 25.07  | 25.31  | 25.59  | 25.88  |
| OLD      | OLDCOURT      | 0.96         | 0.30                 | 0.30   | 0.30   | 0.30   | 0.30   | 0.30   | 0.30   | 0.30   | 0.30   | 0.30   |
| OMA      | OMAGH MAIN    | 0.98         | 58.99                | 59.04  | 59.18  | 59.43  | 58.91  | 59.30  | 59.72  | 60.18  | 60.59  | 60.99  |
| OUG      | OUGHTRAGH     | 0.98         | 24.07                | 24.04  | 24.18  | 23.58  | 23.70  | 23.81  | 23.92  | 24.15  | 24.42  | 24.69  |
| PB       | POOLBEG       | 0.99         | 187.71               | 187.49 | 188.61 | 183.87 | 184.83 | 185.70 | 186.60 | 188.40 | 202.65 | 192.58 |
| PLA      | PLATIN        | 0.96         | 12.65                | 12.65  | 12.65  | 12.65  | 12.65  | 12.65  | 12.65  | 12.65  | 12.65  | 12.65  |
| PLS      | PORTLAOISE    | 0.98         | 50.81                | 50.76  | 37.90  | 36.94  | 37.13  | 37.31  | 37.49  | 37.85  | 38.26  | 38.69  |
| RAT      | RATHGAEL MAIN | 0.98         | 61.81                | 61.89  | 62.03  | 62.29  | 61.74  | 62.15  | 62.57  | 63.06  | 63.49  | 63.93  |
| RAT      | RATHKEALE     | 0.96         | 25.17                | 25.14  | 25.29  | 24.65  | 24.78  | 24.90  | 25.02  | 25.26  | 25.53  | 25.82  |
| RIC      | RICHMOND      | 0.98         | 31.22                | 31.19  | 31.37  | 30.58  | 30.74  | 30.89  | 31.03  | 31.33  | 31.67  | 32.03  |
| RNW      | RINAWADE      | 0.99         | 9.13                 | 9.13   | 9.13   | 9.13   | 9.13   | 9.13   | 9.13   | 9.13   | 9.13   | 9.13   |
| ROS      | ROSEBANK MAIN | 0.98         | 31.45                | 31.48  | 31.55  | 31.69  | 31.41  | 31.62  | 31.83  | 32.08  | 32.31  | 32.52  |
| RSY      | RINGASKIDDY   | 0.95         | 1.69                 | 1.69   | 1.70   | 1.66   | 1.67   | 1.67   | 1.68   | 1.70   | 1.72   | 1.74   |
| RYB      | RYEBROOK      | 0.96         | 104.52               | 104.52 | 104.52 | 104.52 | 104.52 | 104.52 | 104.52 | 104.52 | 104.52 | 104.52 |
| SAL      | SALTHILL      | 0.98         | 69.81                | 69.73  | 70.15  | 68.38  | 68.74  | 69.07  | 69.39  | 70.06  | 70.82  | 71.61  |
| SCR      | SCREEB        | 0.95         | 13.39                | 13.37  | 13.45  | 13.11  | 13.18  | 13.24  | 13.31  | 13.43  | 13.58  | 13.73  |
| SHE      | SHELTON ABBEY | 0.96         | 2.29                 | 2.29   | 2.29   | 2.29   | 2.29   | 2.29   | 2.29   | 2.29   | 2.29   | 2.29   |

Table C-1 Demand Forecasts at Time of Winter Peak (continued)

| Bus Code | Bus Name         | Power Factor | Demand Forecast (MW) |       |       |       |       |       |       |       |       |       |
|----------|------------------|--------------|----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|          |                  |              | 2015                 | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| SKL      | SHANKILL         | 0.97         | 53.48                | 53.42 | 53.74 | 52.39 | 52.65 | 52.91 | 53.16 | 53.67 | 54.26 | 54.87 |
| SLI      | SLIGO            | 0.98         | 54.99                | 54.93 | 55.26 | 53.87 | 54.14 | 54.40 | 54.66 | 55.19 | 55.79 | 56.42 |
| SNG      | SINGLAND         | 0.99         | 14.63                | 14.61 | 14.70 | 14.33 | 14.40 | 14.47 | 14.54 | 14.68 | 14.84 | 15.01 |
| SOM      | SOMERSET         | 0.98         | 29.37                | 29.34 | 29.52 | 28.77 | 28.92 | 29.06 | 29.20 | 29.48 | 29.80 | 30.14 |
| SPR      | SPRINGTOWN MAIN  | 0.98         | 30.50                | 30.54 | 30.62 | 30.74 | 30.48 | 30.68 | 30.89 | 31.12 | 31.34 | 31.56 |
| STR      | STRABANE MAIN    | 0.98         | 37.59                | 37.62 | 37.70 | 37.85 | 37.53 | 37.76 | 38.03 | 38.34 | 38.58 | 38.85 |
| STR      | STRATFORD        | 0.98         | 19.99                | 19.97 | 20.09 | 19.59 | 19.69 | 19.78 | 19.88 | 20.07 | 20.28 | 20.51 |
| TBG      | TRABEG           | 0.99         | 70.60                | 70.52 | 70.94 | 69.16 | 69.50 | 69.84 | 70.18 | 70.85 | 71.62 | 72.43 |
| TBK      | TULLABRACK       | 1.00         | 11.42                | 11.40 | 11.47 | 11.18 | 11.24 | 11.29 | 11.35 | 11.46 | 11.58 | 11.71 |
| THU      | THURLES          | 0.97         | 28.43                | 28.40 | 28.57 | 27.85 | 27.99 | 28.12 | 28.26 | 28.53 | 28.84 | 29.16 |
| TIP      | TIPPERARY        | 0.98         | 16.56                | 16.54 | 16.64 | 16.22 | 16.31 | 16.38 | 16.46 | 16.62 | 16.80 | 16.99 |
| TLK      | TRILLICK         | 0.95         | 22.17                | 22.15 | 22.28 | 21.72 | 21.83 | 21.94 | 22.04 | 22.25 | 22.50 | 22.75 |
| TON      | TONROE           | 0.98         | 12.79                | 12.78 | 12.86 | 12.53 | 12.60 | 12.66 | 12.72 | 12.84 | 12.98 | 13.13 |
| TRI      | TRIEN            | 0.99         | 23.33                | 23.31 | 23.44 | 22.85 | 22.97 | 23.08 | 23.19 | 23.41 | 23.67 | 23.94 |
| TRL      | TRALEE           | 1.00         | 44.90                | 44.85 | 45.12 | 43.99 | 44.21 | 44.42 | 44.64 | 45.06 | 45.55 | 46.07 |
| TSB      | THORNSBERRY      | 0.98         | 31.94                | 31.90 | 32.09 | 31.28 | 31.44 | 31.60 | 31.75 | 32.05 | 32.40 | 32.76 |
| WAR      | WARINGSTOWN MAIN | 0.98         | 63.97                | 64.05 | 64.20 | 64.47 | 63.92 | 64.32 | 64.77 | 65.27 | 65.72 | 66.16 |
| WAT      | WATERFORD        | 0.99         | 46.73                | 46.68 | 46.04 | 44.88 | 45.11 | 45.33 | 45.55 | 45.98 | 46.49 | 47.01 |
| WEX      | WEXFORD          | 0.98         | 51.25                | 51.19 | 51.50 | 50.21 | 50.46 | 50.70 | 50.94 | 51.43 | 51.99 | 52.58 |
| WHI      | WHITEGATE        | 0.88         | 9.19                 | 9.19  | 9.19  | 9.19  | 9.19  | 9.19  | 9.19  | 9.19  | 9.19  | 9.19  |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table C-2 Demand Forecasts at Time of Summer Peak

| Bus Code | Bus Name                    | Power Factor | Demand Forecast (MW) |       |       |       |       |       |       |       |       |       |
|----------|-----------------------------|--------------|----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|          |                             |              | 2015                 | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| AA       | ARDNACRUSHA                 | 1.00         | 15.65                | 14.84 | 14.93 | 14.99 | 14.50 | 14.57 | 14.65 | 14.80 | 14.96 | 15.15 |
| AD       | AGHADA                      | 0.99         | 1.29                 | 1.22  | 1.23  | 1.23  | 1.19  | 1.20  | 1.21  | 1.22  | 1.23  | 1.25  |
| AGH      | AGHYOULE                    | 0.96         | 13.77                | 13.78 | 13.82 | 13.88 | 13.95 | 13.84 | 13.93 | 14.03 | 14.15 | 14.23 |
| AGY      | ARDNAGAPPARY                | 0.95         | 0.00                 | 0.00  | 12.07 | 12.12 | 11.72 | 11.78 | 11.84 | 11.96 | 12.10 | 12.24 |
| AHA      | AHANE                       | 0.97         | 4.66                 | 4.42  | 4.45  | 4.46  | 4.32  | 4.34  | 4.36  | 4.41  | 4.46  | 4.51  |
| AIR      | BELFAST - AIRPORT ROAD MAIN | 0.96         | -                    | -     | -     | -     | -     | 17.79 | 17.91 | 18.02 | 18.18 | 18.30 |
| ANR      | ANNER                       | 0.92         | 16.04                | 16.04 | 16.04 | 16.04 | 16.04 | 16.04 | 16.04 | 16.04 | 16.04 | 16.04 |
| ANT      | ANTRIM MAIN                 | 0.96         | 32.86                | 32.90 | 32.97 | 33.11 | 33.28 | 33.03 | 33.26 | 33.47 | 33.75 | 33.98 |
| ARI      | ARIGNA                      | 1.00         | 3.32                 | 3.15  | 3.17  | 3.18  | 3.08  | 3.09  | 3.11  | 3.14  | 3.17  | 3.21  |
| ARK      | ARKLOW                      | 1.00         | 12.79                | 12.13 | 12.21 | 12.26 | 11.86 | 11.92 | 11.98 | 12.10 | 12.24 | 12.39 |
| ARM      | ARMAGH                      | 0.96         | -                    | -     | -     | -     | -     | -     | -     | -     | 28.44 | 28.63 |
| ATH      | ATHLONE                     | 0.98         | 68.08                | 64.55 | 61.10 | 61.36 | 59.35 | 59.65 | 59.96 | 60.56 | 61.26 | 61.98 |
| ATY      | ATHY                        | 0.83         | 10.22                | 9.69  | 9.75  | 9.79  | 9.47  | 9.52  | 9.57  | 9.67  | 9.78  | 9.89  |
| BAL      | BALTRASNA                   | 1.00         | 10.56                | 10.02 | 10.08 | 10.12 | 9.79  | 9.84  | 9.89  | 9.99  | 10.10 | 10.22 |
| BAN      | BANBRIDGE MAIN              | 0.96         | 30.31                | 30.35 | 30.41 | 30.54 | 30.70 | 30.47 | 30.69 | 30.88 | 31.14 | 31.35 |
| BAN      | BANDON                      | 0.96         | 34.46                | 34.67 | 42.91 | 43.09 | 41.74 | 41.94 | 42.15 | 42.55 | 43.02 | 43.50 |
| BAR      | BARRYMORE                   | 0.99         | 19.00                | 18.01 | 18.13 | 18.20 | 17.61 | 17.70 | 17.79 | 17.97 | 18.17 | 18.39 |
| BDA      | BARODA                      | 0.99         | 5.26                 | 5.26  | 5.26  | 15.45 | 15.12 | 15.17 | 15.22 | 15.32 | 15.44 | 15.56 |
| BDN      | BALLYDINE                   | 0.94         | 14.46                | 14.02 | 14.07 | 14.10 | 13.84 | 13.88 | 13.92 | 14.00 | 14.09 | 14.19 |
| BEG      | BALLYBEG                    | 0.97         | 8.26                 | 7.83  | 7.88  | 7.91  | 7.65  | 7.69  | 7.73  | 7.81  | 7.90  | 7.99  |
| BGT      | BALLYRAG                    | 0.95         | 0.00                 | 0.00  | 0.00  | 0.00  | 0.00  | 19.34 | 19.44 | 19.64 | 19.86 | 20.10 |
| BIN      | BINBANE                     | 0.99         | 16.38                | 15.53 | 7.52  | 7.55  | 7.30  | 7.34  | 7.38  | 7.45  | 7.54  | 7.63  |
| BK       | BELLACORICK                 | 0.95         | 6.19                 | 5.87  | 5.91  | 5.93  | 5.73  | 5.77  | 5.80  | 5.86  | 5.92  | 5.99  |

Table C-2 Demand Forecasts at Time of Summer Peak (continued)

| Bus Code | Bus Name                       | Power Factor | Demand Forecast (MW) |        |        |        |        |        |        |        |        |        |
|----------|--------------------------------|--------------|----------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
|          |                                |              | 2015                 | 2016   | 2017   | 2018   | 2019   | 2020   | 2021   | 2022   | 2023   | 2024   |
| BKY      | BARNAKYLE                      | 0.95         | 0.00                 | 7.67   | 7.71   | 7.75   | 7.49   | 7.53   | 7.57   | 7.65   | 7.73   | 7.82   |
| BLI      | BALLYLICKEY                    | 1.00         | 7.53                 | 7.14   | 7.19   | 7.22   | 6.98   | 7.02   | 7.05   | 7.12   | 7.20   | 7.29   |
| BLK      | BLAKE                          | 0.98         | 19.10                | 18.10  | 18.22  | 7.69   | 7.44   | 7.48   | 7.52   | 7.60   | 7.68   | 7.77   |
| BMA      | BALLYMENA MAIN                 | 0.96         | 56.91                | 56.96  | 57.10  | 57.34  | 57.64  | 57.20  | 57.61  | 57.96  | 58.45  | 58.86  |
| BNH      | BALLYNAHINCH MAIN              | 0.96         | 46.11                | 46.16  | 46.28  | 46.46  | 46.71  | 46.36  | 46.68  | 46.98  | 47.37  | 47.69  |
| BNM      | BELFAST - BELFAST NORTH MAIN   | 0.96         | 38.25                | 38.29  | 38.38  | 38.55  | 38.75  | 38.45  | 38.73  | 38.97  | 39.29  | 39.56  |
| BOG      | BANOGE                         | 0.95         | 8.74                 | 13.86  | 13.95  | 14.00  | 13.55  | 13.62  | 13.68  | 13.82  | 13.98  | 14.15  |
| BRA      | BRACKLON                       | 0.95         | 0.00                 | 0.00   | 0.00   | 10.60  | 10.25  | 10.31  | 10.36  | 10.46  | 10.58  | 10.71  |
| BRI      | BRINNY                         | 0.97         | 3.95                 | 3.95   | 3.95   | 3.95   | 3.95   | 3.95   | 3.95   | 3.95   | 3.95   | 3.95   |
| BRY      | BARNAHELY                      | 0.97         | 34.79                | 32.98  | 33.18  | 33.33  | 32.24  | 32.40  | 32.57  | 32.90  | 33.27  | 33.66  |
| BUT      | BUTLERSTOWN                    | 0.99         | 26.07                | 24.72  | 24.88  | 24.98  | 24.16  | 24.29  | 24.41  | 24.66  | 24.94  | 25.24  |
| CAH      | CAHIR                          | 0.98         | 22.88                | 21.70  | 21.83  | 21.92  | 21.21  | 21.31  | 21.42  | 21.64  | 21.89  | 22.15  |
| CAR      | BELFAST - CARNMONEY MAIN       | 0.96         | 22.13                | 22.15  | 22.20  | 22.30  | 22.41  | 22.25  | 22.40  | 22.54  | 22.73  | 22.88  |
| CBG      | CARROWBEG                      | 0.98         | 23.40                | 22.42  | 22.54  | 22.61  | 22.02  | 22.11  | 22.20  | 22.38  | 22.58  | 22.80  |
| CBR      | CASTLEBAR                      | 0.98         | 31.41                | 29.78  | 29.97  | 30.10  | 29.11  | 29.26  | 29.41  | 29.71  | 30.05  | 30.40  |
| CDY      | CORDERRY                       | 0.04         | 0.07                 | 0.07   | 0.07   | 0.07   | 0.07   | 0.07   | 0.07   | 0.07   | 0.07   | 0.07   |
| CEN      | BELFAST - BELFAST CENTRAL MAIN | 0.96         | 42.03                | 42.08  | 42.19  | 42.35  | 42.58  | 42.26  | 42.55  | 42.83  | 43.18  | 43.47  |
| CF       | CATHALEEN'S FALL               | 0.95         | 13.89                | 13.17  | 13.26  | 13.31  | 12.88  | 12.94  | 13.01  | 13.14  | 13.29  | 13.45  |
| CFM      | CASTLEFARM                     | 0.90         | 50.80                | 50.80  | 50.80  | 50.80  | 50.80  | 50.80  | 50.80  | 50.80  | 50.80  | 50.80  |
| CHA      | CHARLEVILLE                    | 0.97         | 14.25                | 13.52  | 13.60  | 13.66  | 13.21  | 13.28  | 13.35  | 13.48  | 13.64  | 13.80  |
| CKG      | CORKAGH                        | 0.95         | 0.00                 | 33.25  | 33.25  | 33.25  | 152.00 | 152.00 | 152.00 | 152.00 | 152.00 | 152.00 |
| CKM      | CARRICKMINES                   | 0.97         | 253.09               | 305.22 | 306.57 | 307.50 | 300.33 | 301.40 | 302.49 | 304.65 | 307.13 | 309.73 |

Table C-2 Demand Forecasts at Time of Summer Peak (continued)

| Bus Code | Bus Name               | Power Factor | Demand Forecast (MW) |       |       |       |       |       |       |       |       |       |
|----------|------------------------|--------------|----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|          |                        |              | 2015                 | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| CLG      | CLOGHRAN               | 0.95         | 23.75                | 23.75 | 23.75 | 23.75 | 23.75 | 23.75 | 23.75 | 23.75 | 23.75 | 23.75 |
| CLN      | CLOON                  | 0.96         | 23.49                | 22.27 | 26.27 | 26.38 | 25.52 | 25.64 | 25.78 | 26.03 | 26.33 | 26.65 |
| CLW      | CARLOW                 | 0.98         | 44.96                | 42.62 | 42.89 | 43.07 | 41.66 | 41.88 | 42.09 | 42.51 | 43.00 | 43.51 |
| COL      | COLERAINE MAIN         | 0.96         | 31.78                | 31.81 | 31.89 | 32.01 | 32.18 | 31.94 | 32.17 | 32.38 | 32.63 | 32.86 |
| COL      | COLLEGE PARK           | 0.96         | 25.40                | 24.09 | 24.24 | 24.34 | 23.54 | 23.66 | 23.78 | 24.02 | 24.30 | 24.59 |
| COS      | CARICKONSHANNON        | 0.97         | 27.69                | 26.25 | 26.42 | 26.53 | 25.66 | 25.79 | 25.92 | 26.19 | 26.49 | 26.80 |
| COW      | COW CROSS              | 0.99         | 13.20                | 12.52 | 12.60 | 12.65 | 12.23 | 12.30 | 12.36 | 12.49 | 12.63 | 12.78 |
| CPS      | COOLKEERAGH MAIN       | 0.96         | 24.85                | 24.88 | 24.94 | 25.04 | 25.18 | 24.99 | 25.16 | 25.33 | 25.53 | 25.70 |
| CRA      | CRANE                  | 0.99         | 30.73                | 23.57 | 23.72 | 23.82 | 23.04 | 23.15 | 23.28 | 23.51 | 23.78 | 24.06 |
| CRE      | BELFAST - CREGAGH MAIN | 0.96         | 59.09                | 59.18 | 59.32 | 59.56 | 59.88 | 59.43 | 59.84 | 60.22 | 60.72 | 61.13 |
| CRG      | CREAGH MAIN            | 0.96         | 27.30                | 27.33 | 27.39 | 27.50 | 27.64 | 27.44 | 27.63 | 27.81 | 28.03 | 28.22 |
| CRO      | COOLROE                | 1.00         | 12.01                | 11.39 | 11.46 | 11.51 | 11.13 | 11.19 | 11.24 | 11.36 | 11.49 | 11.62 |
| CVW      | CASTLEVIEW             | 0.97         | 24.83                | 23.54 | 23.69 | 23.79 | 23.01 | 23.13 | 23.25 | 23.48 | 23.75 | 24.03 |
| DAL      | DALLOW                 | 0.98         | 13.19                | 12.51 | 12.59 | 12.64 | 12.23 | 12.29 | 12.35 | 12.47 | 12.62 | 12.77 |
| DDK      | DUNDALK                | 0.97         | 48.93                | 46.40 | 46.69 | 27.52 | 26.62 | 26.75 | 26.89 | 27.16 | 27.47 | 27.80 |
| DFR      | DUNFIRTH               | 0.99         | 6.14                 | 5.82  | 5.86  | 5.88  | 5.69  | 5.72  | 5.75  | 5.80  | 5.87  | 5.94  |
| DGN      | DUNGARVAN              | 0.98         | 32.98                | 31.27 | 31.46 | 31.59 | 30.56 | 30.72 | 30.87 | 31.19 | 31.54 | 31.92 |
| DLT      | DALTON                 | 0.96         | 19.89                | 18.86 | 18.98 | 19.06 | 18.44 | 18.53 | 18.62 | 18.81 | 19.03 | 19.25 |
| DMY      | DUNMANWAY              | 0.99         | 23.14                | 21.94 | 18.42 | 18.50 | 17.89 | 17.99 | 18.08 | 18.26 | 18.47 | 18.69 |
| DON      | BELFAST - DONEGAL MAIN | 0.96         | 79.14                | 79.23 | 79.42 | 79.74 | 80.16 | 79.57 | 80.11 | 80.63 | 81.30 | 81.85 |
| DOO      | DOON                   | 0.96         | 14.61                | 13.85 | 13.94 | 13.99 | 13.54 | 13.61 | 13.67 | 13.81 | 13.97 | 14.14 |
| DRU      | DRUMNAKELLY MAIN       | 0.96         | 69.32                | 69.40 | 69.56 | 69.84 | 70.22 | 69.69 | 70.17 | 70.62 | 40.93 | 41.21 |



Table C-2 Demand Forecasts at Time of Summer Peak (continued)

| Bus Code | Bus Name                   | Power Factor | Demand Forecast (MW) |        |        |        |        |        |        |        |        |        |
|----------|----------------------------|--------------|----------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
|          |                            |              | 2015                 | 2016   | 2017   | 2018   | 2019   | 2020   | 2021   | 2022   | 2023   | 2024   |
| DRU      | DRUMLINE                   | 0.97         | 27.63                | 26.19  | 26.36  | 26.47  | 25.60  | 25.73  | 25.86  | 26.13  | 26.43  | 26.74  |
| DRY      | DRYBRIDGE                  | 0.97         | 65.96                | 62.54  | 62.93  | 58.54  | 56.63  | 56.92  | 57.21  | 57.78  | 58.45  | 59.14  |
| DUN      | DUNGANNON MAIN             | 0.96         | 73.24                | 73.32  | 73.49  | 73.79  | 74.18  | 73.63  | 74.14  | 74.61  | 75.22  | 75.74  |
| EDE      | EDEN MAIN                  | 0.96         | 24.40                | 24.43  | 24.49  | 24.59  | 24.72  | 24.53  | 24.70  | 24.86  | 25.06  | 25.24  |
| ENN      | ENNISKILLEN MAIN           | 0.96         | 37.29                | 37.33  | 37.42  | 37.57  | 37.77  | 37.49  | 37.76  | 37.99  | 38.30  | 38.56  |
| ENN      | ENNIS                      | 0.98         | 38.72                | 36.71  | 36.94  | 37.10  | 35.89  | 36.07  | 36.25  | 36.62  | 37.04  | 37.48  |
| FIN      | BELFAST - FINAGHY MAIN     | 0.96         | 25.15                | 25.18  | 25.24  | 25.35  | 25.48  | 25.28  | 25.47  | 25.63  | 25.84  | 26.01  |
| FIN      | FINGLAS                    | 0.98         | 370.23               | 376.79 | 378.82 | 380.21 | 369.49 | 371.10 | 372.71 | 375.94 | 379.66 | 383.54 |
| GAL      | GALWAY                     | 0.99         | 56.15                | 53.25  | 53.57  | 53.80  | 52.05  | 52.31  | 52.57  | 53.11  | 53.72  | 54.36  |
| GI       | GREAT ISLAND               | 0.95         | 12.77                | 12.10  | 12.18  | 12.23  | 11.83  | 11.89  | 11.95  | 12.07  | 12.21  | 12.36  |
| GIL      | GILRA                      | 0.97         | 11.42                | 11.42  | 11.42  | 11.42  | 11.42  | 11.42  | 11.42  | 11.42  | 11.42  | 11.42  |
| GLE      | BELFAST - GLENGORMELY MAIN | 0.96         | 21.10                | 21.12  | 21.17  | 21.26  | 21.37  | 21.21  | 21.36  | 21.50  | 21.67  | 21.82  |
| GLE      | GLENLARA                   | 0.97         | 12.54                | 11.89  | 11.97  | 12.02  | 11.62  | 11.68  | 11.74  | 11.86  | 12.00  | 12.14  |
| GRI      | GRIFFINRATH                | 0.99         | 53.09                | 41.45  | 41.71  | 41.88  | 40.51  | 40.72  | 40.93  | 41.34  | 41.82  | 42.31  |
| GWE      | GORTAWEЕ                   | 0.95         | 33.78                | 33.12  | 33.20  | 33.25  | 32.85  | 32.91  | 32.97  | 33.09  | 33.23  | 33.37  |
| HTS      | HARNETTS CROSS             | 0.98         | 0.00                 | 0.00   | 0.00   | 7.26   | 7.03   | 7.06   | 7.10   | 7.17   | 7.25   | 7.34   |
| IKE      | IKERRIN                    | 0.96         | 25.38                | 24.12  | 24.26  | 24.36  | 23.60  | 23.71  | 23.83  | 24.06  | 24.32  | 24.60  |
| INC      | INCHICORE                  | 0.96         | 232.41               | 252.90 | 253.89 | 254.52 | 249.49 | 250.24 | 251.01 | 252.53 | 254.28 | 256.08 |
| KBY      | KILBARRY                   | 0.98         | 87.05                | 82.53  | 83.05  | 83.40  | 81.42  | 81.84  | 82.26  | 83.08  | 84.04  | 85.04  |
| KER      | KNOCKERAGH                 | 0.97         | 33.38                | 31.65  | 31.85  | 31.98  | 30.94  | 31.09  | 31.25  | 31.57  | 31.93  | 32.31  |
| KIN      | KINNEGAD                   | 0.97         | 10.19                | 10.19  | 10.19  | 10.19  | 10.19  | 10.19  | 10.19  | 10.19  | 10.19  | 10.19  |
| KKY      | KILKENNY                   | 0.96         | 52.08                | 49.38  | 49.69  | 41.18  | 39.83  | 40.03  | 40.24  | 40.64  | 41.11  | 41.60  |

Table C-2 Demand Forecasts at Time of Summer Peak (continued)

| Bus Code | Bus Name             | Power Factor | Demand Forecast (MW) |       |       |       |       |       |       |       |       |       |
|----------|----------------------|--------------|----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|          |                      |              | 2015                 | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| KNO      | BELFAST - KNOCK MAIN | 0.96         | 39.14                | 39.19 | 39.29 | 39.45 | 39.66 | 39.36 | 39.63 | 39.89 | 40.22 | 40.48 |
| KTL      | KILTEEL              | 0.98         | 38.84                | 36.83 | 37.06 | 37.21 | 36.00 | 36.18 | 36.36 | 36.73 | 37.15 | 37.59 |
| KTN      | KILLOTARAN           | 0.96         | 20.17                | 19.25 | 19.36 | 19.43 | 18.88 | 18.96 | 19.04 | 19.21 | 19.40 | 19.60 |
| KUR      | KNOCKUMBER           | 0.93         | 28.14                | 28.14 | 28.14 | 28.14 | 28.14 | 28.14 | 28.14 | 28.14 | 28.14 | 28.14 |
| LA       | LANESBORO            | 0.98         | 11.10                | 11.00 | 11.10 | 11.30 | 10.70 | 10.90 | 11.10 | 11.20 | 11.40 | 11.40 |
| LAR      | LARNE - MAIN         | 0.96         | 32.55                | 32.59 | 32.66 | 32.80 | 32.98 | 32.73 | 32.96 | 33.17 | 33.44 | 33.66 |
| LET      | LETTERKENNY          | 0.98         | 48.26                | 45.76 | 42.09 | 42.27 | 40.89 | 41.10 | 41.31 | 41.72 | 42.20 | 42.70 |
| LIB      | LIBERTY              | 0.95         | 18.77                | 17.79 | 17.90 | 17.98 | 17.39 | 17.48 | 17.57 | 17.75 | 17.95 | 18.16 |
| LIM      | LIMAVADY MAIN        | 0.96         | 18.42                | 18.45 | 18.49 | 18.57 | 18.66 | 18.52 | 18.66 | 18.78 | 18.93 | 19.07 |
| LIM      | LIMERICK             | 0.98         | 62.89                | 59.68 | 60.05 | 60.30 | 58.36 | 58.65 | 58.94 | 59.53 | 60.20 | 60.90 |
| LIS      | LISBURN MAIN         | 0.96         | 46.40                | 46.46 | 46.56 | 46.76 | 47.00 | 46.65 | 46.98 | 47.27 | 47.66 | 47.99 |
| LIS      | LISDRUM              | 0.96         | 20.39                | 19.34 | 19.46 | 19.54 | 18.90 | 19.00 | 19.09 | 19.28 | 19.51 | 19.74 |
| LMR      | LISAGHMORE MAIN      | 0.96         | 36.27                | 36.31 | 36.40 | 36.54 | 36.74 | 36.46 | 36.71 | 36.95 | 37.25 | 37.50 |
| LOG      | LOUGUESTOWN MAIN     | 0.96         | 30.25                | 30.28 | 30.35 | 30.48 | 30.64 | 30.41 | 30.63 | 30.81 | 31.07 | 31.29 |
| LSN      | LISHEEN              | 0.96         | 19.50                | 19.50 | 19.50 | 19.50 | 19.50 | 19.50 | 19.50 | 19.50 | 19.50 | 19.50 |
| MAC      | MACROOM              | 0.94         | 16.10                | 3.90  | 4.00  | 4.00  | 3.10  | 3.10  | 3.20  | 3.20  | 3.30  | 3.30  |
| MAL      | MALLOW               | 0.97         | 17.53                | 16.62 | 16.73 | 16.80 | 16.25 | 16.33 | 16.41 | 16.58 | 16.77 | 16.97 |
| MCE      | MACETOWN             | 0.98         | 25.30                | 24.23 | 24.35 | 24.43 | 23.79 | 23.88 | 23.98 | 24.18 | 24.40 | 24.64 |
| MID      | MIDDLETON            | 0.98         | 32.08                | 30.50 | 30.68 | 30.80 | 29.84 | 29.99 | 30.13 | 30.43 | 30.76 | 31.10 |
| MLN      | MULLAGHARLIN         | 0.96         | 4.46                 | 4.46  | 4.46  | 28.47 | 27.69 | 27.81 | 27.92 | 28.16 | 28.43 | 28.72 |
| MON      | MONREAD              | 0.97         | 10.49                | 9.95  | 10.01 | 10.05 | 9.72  | 9.77  | 9.82  | 9.92  | 10.03 | 10.15 |
| MOY      | MOY                  | 0.98         | 19.13                | 18.14 | 18.25 | 18.33 | 17.73 | 17.82 | 17.91 | 18.09 | 18.30 | 18.51 |
| MR       | MARINA               | 0.97         | 17.57                | 16.66 | 16.77 | 16.84 | 16.29 | 16.37 | 16.45 | 16.62 | 16.81 | 17.01 |

Table C-2 Demand Forecasts at Time of Summer Peak (continued)

| Bus Code | Bus Name        | Power Factor | Demand Forecast (MW) |        |        |        |        |        |        |        |        |        |
|----------|-----------------|--------------|----------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
|          |                 |              | 2015                 | 2016   | 2017   | 2018   | 2019   | 2020   | 2021   | 2022   | 2023   | 2024   |
| MTH      | MEATH HILL      | 0.94         | 35.13                | 33.31  | 33.51  | 33.65  | 32.55  | 32.72  | 32.89  | 33.22  | 33.60  | 34.00  |
| MUL      | MULLINGAR       | 0.97         | 40.39                | 38.30  | 38.54  | 38.70  | 37.44  | 37.63  | 37.81  | 38.20  | 38.64  | 39.10  |
| MUN      | MUNGRET         | 0.88         | 19.13                | 19.13  | 19.13  | 19.13  | 19.13  | 19.13  | 19.13  | 19.13  | 19.13  | 19.13  |
| NAR      | NEWTOWARDS MAIN | 0.96         | 31.52                | 31.57  | 31.64  | 31.77  | 31.93  | 31.70  | 31.92  | 32.12  | 32.39  | 32.61  |
| NAV      | NAVAN           | 0.97         | 38.50                | 36.50  | 36.73  | 36.88  | 35.68  | 35.86  | 36.04  | 36.41  | 36.83  | 37.26  |
| NEN      | NENAGH          | 0.98         | 24.25                | 23.00  | 23.14  | 23.24  | 22.48  | 22.59  | 22.71  | 22.94  | 23.20  | 23.47  |
| NEW      | NEWRY MAIN      | 0.96         | 61.09                | 61.16  | 61.30  | 61.55  | 61.89  | 61.42  | 61.85  | 62.24  | 62.75  | 63.18  |
| NEW      | NEWBRIDGE       | 0.99         | 18.72                | 17.75  | 17.86  | 7.75   | 7.49   | 7.53   | 7.57   | 7.65   | 7.73   | 7.82   |
| OLD      | OLDCOURT        | 0.96         | 0.30                 | 0.30   | 0.30   | 0.30   | 0.30   | 0.30   | 0.30   | 0.30   | 0.30   | 0.30   |
| OMA      | OMAGH MAIN      | 0.96         | 44.90                | 44.94  | 45.06  | 45.25  | 45.48  | 45.16  | 45.47  | 45.75  | 46.12  | 46.45  |
| OUG      | OUGHTRAGH       | 0.98         | 20.02                | 18.98  | 19.10  | 19.18  | 18.55  | 18.65  | 18.74  | 18.93  | 19.15  | 19.38  |
| PB       | POOLBEG         | 0.98         | 202.89               | 192.35 | 193.57 | 194.37 | 188.02 | 188.98 | 189.94 | 191.87 | 194.06 | 196.36 |
| PLA      | PLATIN          | 0.96         | 12.65                | 12.65  | 12.65  | 12.65  | 12.65  | 12.65  | 12.65  | 12.65  | 12.65  | 12.65  |
| PLS      | PORTLAOISE      | 0.97         | 39.32                | 37.28  | 37.51  | 26.50  | 25.63  | 25.76  | 25.90  | 26.16  | 26.45  | 26.76  |
| RAT      | RATHGAEL MAIN   | 0.96         | 47.05                | 47.12  | 47.23  | 47.41  | 47.67  | 47.31  | 47.64  | 47.94  | 48.34  | 48.67  |
| RAT      | RATHKEALE       | 0.95         | 18.28                | 17.33  | 17.44  | 17.51  | 16.94  | 17.02  | 17.11  | 17.28  | 17.48  | 17.69  |
| RIC      | RICHMOND        | 0.96         | 28.63                | 27.14  | 27.31  | 27.43  | 26.53  | 26.67  | 26.80  | 27.07  | 27.38  | 27.71  |
| RNW      | RINAWADE        | 0.99         | 9.13                 | 9.13   | 9.13   | 9.13   | 9.13   | 9.13   | 9.13   | 9.13   | 9.13   | 9.13   |
| ROS      | ROSEBANK MAIN   | 0.96         | 23.94                | 23.97  | 24.02  | 24.12  | 24.25  | 24.07  | 24.24  | 24.39  | 24.59  | 24.76  |
| RSY      | RINGASKIDDY     | 0.78         | 2.66                 | 2.52   | 2.54   | 2.55   | 2.46   | 2.48   | 2.49   | 2.51   | 2.54   | 2.57   |
| RYB      | RYEBROOK        | 0.96         | 104.52               | 104.52 | 104.52 | 104.52 | 104.52 | 104.52 | 104.52 | 104.52 | 104.52 | 104.52 |
| SAL      | SALTHILL        | 0.98         | 56.00                | 53.09  | 53.43  | 53.65  | 51.90  | 52.16  | 52.43  | 52.95  | 53.57  | 54.20  |
| SCR      | SCREEB          | 0.95         | 11.91                | 11.30  | 11.37  | 11.41  | 11.04  | 11.10  | 11.15  | 11.27  | 11.40  | 11.53  |
| SHE      | SHELTON ABBEY   | 0.96         | 2.29                 | 2.29   | 2.29   | 2.29   | 2.29   | 2.29   | 2.29   | 2.29   | 2.29   | 2.29   |

Table C-2 Demand Forecasts at Time of Summer Peak (continued)

| Bus Code | Bus Name         | Power Factor | Demand Forecast (MW) |       |       |       |       |       |       |       |       |       |
|----------|------------------|--------------|----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|          |                  |              | 2015                 | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| SKL      | SHANKILL         | 0.95         | 52.85                | 50.11 | 50.42 | 50.63 | 48.98 | 49.23 | 49.48 | 49.98 | 50.55 | 51.15 |
| SLI      | SLIGO            | 0.98         | 43.08                | 40.85 | 41.10 | 41.28 | 39.93 | 40.13 | 40.34 | 40.74 | 41.21 | 41.70 |
| SNG      | SINGLAND         | 0.97         | 10.82                | 10.26 | 10.32 | 10.37 | 10.03 | 10.08 | 10.13 | 10.23 | 10.35 | 10.47 |
| SOM      | SOMERSET         | 0.99         | 15.47                | 14.67 | 14.76 | 14.82 | 14.34 | 14.41 | 14.48 | 14.63 | 14.80 | 14.97 |
| SPR      | SPRINGTOWN MAIN  | 0.96         | 23.23                | 23.25 | 23.31 | 23.40 | 23.52 | 23.36 | 23.52 | 23.67 | 23.86 | 24.03 |
| STR      | STRABANE MAIN    | 0.96         | 28.60                | 28.63 | 28.70 | 28.82 | 28.97 | 28.75 | 28.97 | 29.13 | 29.38 | 29.58 |
| STR      | STRATFORD        | 0.99         | 12.65                | 11.99 | 12.07 | 12.12 | 11.72 | 11.78 | 11.84 | 11.96 | 12.10 | 12.24 |
| TBG      | TRABEG           | 0.99         | 37.01                | 35.09 | 35.31 | 35.46 | 34.30 | 34.48 | 34.65 | 35.00 | 35.40 | 35.82 |
| TBK      | TULLABRACK       | 0.98         | 9.06                 | 8.59  | 8.65  | 8.68  | 8.40  | 8.44  | 8.49  | 8.57  | 8.67  | 8.77  |
| THU      | THURLES          | 0.96         | 30.61                | 29.02 | 29.20 | 29.32 | 28.36 | 28.51 | 28.65 | 28.94 | 29.27 | 29.62 |
| TIP      | TIPPERARY        | 0.97         | 14.96                | 14.18 | 14.27 | 14.33 | 13.86 | 13.93 | 14.00 | 14.14 | 14.31 | 14.48 |
| TLK      | TRILLICK         | 0.95         | 21.38                | 20.27 | 20.40 | 20.49 | 19.82 | 19.92 | 20.02 | 20.22 | 20.45 | 20.69 |
| TON      | TONROE           | 0.95         | 13.19                | 12.51 | 12.59 | 12.64 | 12.23 | 12.29 | 12.35 | 12.47 | 12.62 | 12.77 |
| TRI      | TRIEN            | 0.97         | 22.46                | 21.29 | 21.43 | 21.52 | 20.81 | 20.92 | 21.02 | 21.24 | 21.48 | 21.73 |
| TRL      | TRALEE           | 1.00         | 34.47                | 32.68 | 32.88 | 33.02 | 31.94 | 32.11 | 32.27 | 32.59 | 32.97 | 33.36 |
| TSB      | THORNSBERRY      | 0.97         | 27.68                | 26.24 | 26.41 | 26.52 | 25.65 | 25.78 | 25.91 | 26.18 | 26.48 | 26.79 |
| WAR      | WARINGSTOWN MAIN | 0.96         | 48.70                | 48.77 | 48.88 | 49.08 | 49.34 | 48.97 | 49.31 | 49.62 | 50.03 | 50.37 |
| WAT      | WATERFORD        | 0.95         | 38.19                | 36.21 | 36.44 | 35.81 | 34.64 | 34.82 | 35.00 | 35.35 | 35.76 | 36.18 |
| WEX      | WEXFORD          | 0.97         | 46.70                | 44.28 | 44.56 | 44.74 | 43.28 | 43.50 | 43.72 | 44.17 | 44.67 | 45.20 |
| WHI      | WHITEGATE        | 0.88         | 9.19                 | 9.19  | 9.19  | 9.19  | 9.19  | 9.19  | 9.19  | 9.19  | 9.19  | 9.19  |

Table C-3 Demand Forecasts at Time of Summer Valley

| Bus Code | Bus Name                    | Power Factor | Demand Forecast (MW) |       |       |       |       |       |       |       |       |       |
|----------|-----------------------------|--------------|----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|          |                             |              | 2015                 | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| AA       | ARDNACRUSHA                 | 0.99         | 12.25                | 10.53 | 10.60 | 10.67 | 9.60  | 9.67  | 9.73  | 9.86  | 10.01 | 10.17 |
| AD       | AGHADA                      | 0.99         | 0.54                 | 0.47  | 0.47  | 0.47  | 0.43  | 0.43  | 0.43  | 0.44  | 0.44  | 0.45  |
| AGH      | AGHYOULE                    | 0.96         | 5.09                 | 5.09  | 5.11  | 5.13  | 5.16  | 5.12  | 5.15  | 5.18  | 5.23  | 5.26  |
| AGY      | ARDNAGAPPARY                | 0.95         | 0.00                 | 0.00  | 3.66  | 3.68  | 3.32  | 3.34  | 3.36  | 3.41  | 3.46  | 3.51  |
| AHA      | AHANE                       | 1.00         | 0.81                 | 0.70  | 0.70  | 0.71  | 0.64  | 0.64  | 0.64  | 0.65  | 0.66  | 0.67  |
| AIR      | BELFAST - AIRPORT ROAD MAIN | 0.96         | -                    | -     | -     | -     | -     | 6.57  | 6.62  | 6.66  | 6.72  | 6.76  |
| ANR      | ANNER                       | 0.92         | 11.78                | 11.78 | 11.78 | 11.78 | 11.78 | 11.78 | 11.78 | 11.78 | 11.78 | 11.78 |
| ANT      | ANTRIM MAIN                 | 0.96         | 12.14                | 12.16 | 12.18 | 12.23 | 12.30 | 12.21 | 12.29 | 12.37 | 12.47 | 12.55 |
| ARI      | ARIGNA                      | 0.95         | 1.61                 | 1.39  | 1.40  | 1.40  | 1.26  | 1.27  | 1.28  | 1.30  | 1.32  | 1.34  |
| ARK      | ARKLOW                      | 0.95         | 7.28                 | 6.26  | 6.30  | 6.34  | 5.70  | 5.74  | 5.78  | 5.86  | 5.95  | 6.04  |
| ARM      | ARMAGH                      | 0.96         | -                    | -     | -     | -     | -     | -     | -     | -     | 10.51 | 10.58 |
| ATH      | ATHLONE                     | 0.99         | 19.94                | 17.14 | 16.10 | 16.18 | 14.57 | 14.66 | 14.76 | 14.96 | 15.19 | 15.43 |
| ATY      | ATHY                        | 0.88         | 3.61                 | 3.10  | 3.12  | 3.14  | 2.83  | 2.85  | 2.86  | 2.90  | 2.95  | 2.99  |
| BAL      | BALTRASNA                   | 0.93         | 3.62                 | 3.11  | 3.14  | 3.15  | 2.84  | 2.86  | 2.88  | 2.92  | 2.96  | 3.01  |
| BAN      | BANBRIDGE MAIN              | 0.96         | 11.20                | 11.21 | 11.24 | 11.29 | 11.35 | 11.26 | 11.34 | 11.41 | 11.50 | 11.58 |
| BAN      | BANDON                      | 0.98         | 11.50                | 11.87 | 14.40 | 14.46 | 13.22 | 13.29 | 13.36 | 13.52 | 13.69 | 13.88 |
| BAR      | BARRYMORE                   | 1.00         | 8.54                 | 7.33  | 7.39  | 7.43  | 6.69  | 6.73  | 6.78  | 6.87  | 6.97  | 7.08  |
| BDA      | BARODA                      | 1.00         | 3.22                 | 3.22  | 3.22  | 6.32  | 6.01  | 6.03  | 6.05  | 6.08  | 6.13  | 6.17  |
| BDN      | BALLYDINE                   | 0.97         | 5.19                 | 4.73  | 4.75  | 4.76  | 4.48  | 4.50  | 4.52  | 4.55  | 4.59  | 4.63  |
| BEG      | BALLYBEG                    | 0.97         | 2.63                 | 2.26  | 2.28  | 2.29  | 2.06  | 2.08  | 2.09  | 2.12  | 2.15  | 2.18  |
| BGT      | BALLYRAG                    | 0.95         | 0.00                 | 0.00  | 0.00  | 0.00  | 0.00  | 5.48  | 5.52  | 5.59  | 5.68  | 5.77  |
| BIN      | BINBANE                     | 0.99         | 5.42                 | 4.66  | 2.23  | 2.24  | 2.02  | 2.03  | 2.04  | 2.07  | 2.10  | 2.14  |
| BK       | BELLACORICK                 | 0.98         | 2.86                 | 2.46  | 2.48  | 2.50  | 2.25  | 2.26  | 2.27  | 2.30  | 2.34  | 2.38  |

Table C-3 Demand Forecasts at Time of Summer Valley (continued)

| Bus Code | Bus Name                       | Power Factor | Demand Forecast (MW) |       |       |       |        |        |        |        |        |        |
|----------|--------------------------------|--------------|----------------------|-------|-------|-------|--------|--------|--------|--------|--------|--------|
|          |                                |              | 2015                 | 2016  | 2017  | 2018  | 2019   | 2020   | 2021   | 2022   | 2023   | 2024   |
| BKY      | BARNAKYLE                      | 0.95         | 0.00                 | 2.32  | 2.34  | 2.35  | 2.12   | 2.13   | 2.15   | 2.18   | 2.21   | 2.25   |
| BLI      | BALLYLICKEY                    | 0.89         | 4.04                 | 3.47  | 3.50  | 3.52  | 3.16   | 3.19   | 3.21   | 3.25   | 3.30   | 3.35   |
| BLK      | BLAKE                          | 1.00         | 6.86                 | 5.90  | 5.94  | 2.75  | 2.47   | 2.49   | 2.51   | 2.54   | 2.58   | 2.62   |
| BMA      | BALLYMENA MAIN                 | 0.96         | 21.03                | 21.05 | 21.10 | 21.19 | 21.30  | 21.14  | 21.29  | 21.42  | 21.60  | 21.75  |
| BNH      | BALLYNAHINCH MAIN              | 0.96         | 17.04                | 17.06 | 17.10 | 17.17 | 17.26  | 17.13  | 17.25  | 17.36  | 17.50  | 17.62  |
| BNM      | BELFAST - BELFAST NORTH MAIN   | 0.96         | 14.13                | 14.15 | 14.18 | 14.24 | 14.32  | 14.21  | 14.31  | 14.40  | 14.52  | 14.62  |
| BOG      | BANOGE                         | 0.95         | 3.55                 | 4.74  | 4.78  | 4.80  | 4.32   | 4.35   | 4.38   | 4.44   | 4.51   | 4.58   |
| BRA      | BRACKLON                       | 0.95         | 0.00                 | 0.00  | 0.00  | 3.22  | 2.90   | 2.92   | 2.94   | 2.98   | 3.02   | 3.07   |
| BRI      | BRINNY                         | 0.97         | 2.63                 | 2.63  | 2.63  | 2.63  | 2.63   | 2.63   | 2.63   | 2.63   | 2.63   | 2.63   |
| BRY      | BARNAHELY                      | 0.98         | 18.01                | 15.47 | 15.59 | 15.67 | 14.10  | 14.20  | 14.29  | 14.49  | 14.71  | 14.94  |
| BUT      | BUTLERSTOWN                    | 1.00         | 10.13                | 8.71  | 8.77  | 8.82  | 7.94   | 7.99   | 8.05   | 8.15   | 8.28   | 8.41   |
| CAH      | CAHIR                          | 1.00         | 7.47                 | 6.42  | 6.47  | 6.51  | 5.86   | 5.90   | 5.93   | 6.01   | 6.11   | 6.20   |
| CAR      | BELFAST - CARNMONEY MAIN       | 0.96         | 8.18                 | 8.18  | 8.20  | 8.24  | 8.28   | 8.22   | 8.28   | 8.33   | 8.40   | 8.46   |
| CBG      | CARROWBEG                      | 0.98         | 13.55                | 12.28 | 12.34 | 12.38 | 11.59  | 11.64  | 11.69  | 11.79  | 11.90  | 12.01  |
| CBR      | CASTLEBAR                      | 0.99         | 7.98                 | 6.86  | 6.91  | 6.95  | 6.25   | 6.30   | 6.34   | 6.42   | 6.52   | 6.62   |
| CDY      | CORDERRY                       | 0.54         | 1.22                 | 1.05  | 1.05  | 1.06  | 0.95   | 0.96   | 0.97   | 0.98   | 0.99   | 1.01   |
| CEN      | BELFAST - BELFAST CENTRAL MAIN | 0.96         | 15.53                | 15.55 | 15.59 | 15.65 | 15.73  | 15.62  | 15.72  | 15.83  | 15.95  | 16.06  |
| CF       | CATHALEEN'S FALL               | 0.95         | 5.26                 | 4.52  | 4.56  | 4.58  | 4.12   | 4.15   | 4.18   | 4.24   | 4.30   | 4.37   |
| CFM      | CASTLEFARM                     | 0.88         | 45.79                | 45.79 | 45.79 | 45.79 | 45.79  | 45.79  | 45.79  | 45.79  | 45.79  | 45.79  |
| CHA      | CHARLEVILLE                    | 1.00         | 5.45                 | 4.68  | 4.72  | 4.74  | 4.27   | 4.30   | 4.32   | 4.38   | 4.45   | 4.52   |
| CKG      | CORKAGH                        | 0.95         | 0.00                 | 33.25 | 33.25 | 33.25 | 152.00 | 152.00 | 152.00 | 152.00 | 152.00 | 152.00 |

Table C-3 Demand Forecasts at Time of Summer Valley (continued)

| Bus Code | Bus Name               | Power Factor | Demand Forecast (MW) |        |        |        |        |        |        |        |        |        |
|----------|------------------------|--------------|----------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
|          |                        |              | 2015                 | 2016   | 2017   | 2018   | 2019   | 2020   | 2021   | 2022   | 2023   | 2024   |
| CKM      | CARRICKMINES           | 0.96         | 115.06               | 166.25 | 166.86 | 167.27 | 159.34 | 159.81 | 160.30 | 161.30 | 162.38 | 163.56 |
| CLG      | CLOGHRAN               | 0.95         | 23.75                | 23.75  | 23.75  | 23.75  | 23.75  | 23.75  | 23.75  | 23.75  | 23.75  | 23.75  |
| CLN      | CLOON                  | 0.99         | 5.98                 | 5.14   | 6.35   | 6.38   | 5.75   | 5.78   | 5.82   | 5.90   | 5.99   | 6.09   |
| CLW      | CARLOW                 | 0.99         | 13.69                | 11.76  | 11.85  | 11.91  | 10.72  | 10.80  | 10.87  | 11.02  | 11.18  | 11.36  |
| COL      | COLERAINE MAIN         | 0.96         | 11.74                | 11.75  | 11.78  | 11.83  | 11.89  | 11.80  | 11.89  | 11.96  | 12.06  | 12.14  |
| COL      | COLLEGE PARK           | 0.97         | 13.57                | 11.66  | 11.75  | 11.81  | 10.63  | 10.70  | 10.77  | 10.92  | 11.08  | 11.26  |
| COS      | CARICKONSHANNON        | 1.00         | 7.96                 | 6.84   | 6.89   | 6.93   | 6.23   | 6.28   | 6.32   | 6.40   | 6.50   | 6.60   |
| COW      | COW CROSS              | 1.00         | 2.86                 | 2.45   | 2.47   | 2.49   | 2.23   | 2.25   | 2.27   | 2.30   | 2.33   | 2.37   |
| CPS      | COOLKEERAGH MAIN       | 0.96         | 9.18                 | 9.19   | 9.22   | 9.25   | 9.30   | 9.23   | 9.30   | 9.36   | 9.43   | 9.50   |
| CRA      | CRANE                  | 1.00         | 11.64                | 8.31   | 8.37   | 8.42   | 7.57   | 7.63   | 7.68   | 7.78   | 7.90   | 8.03   |
| CRE      | BELFAST - CREGAGH MAIN | 0.96         | 21.83                | 21.87  | 21.92  | 22.01  | 22.12  | 21.96  | 22.11  | 22.25  | 22.43  | 22.59  |
| CRG      | CREAGH MAIN            | 0.96         | 10.09                | 10.10  | 10.12  | 10.16  | 10.21  | 10.14  | 10.21  | 10.28  | 10.36  | 10.43  |
| CRO      | COOLROE                | 0.99         | 6.19                 | 5.32   | 5.36   | 5.39   | 4.85   | 4.88   | 4.91   | 4.98   | 5.06   | 5.14   |
| CVW      | CASTLEVIEW             | 0.98         | 9.47                 | 8.13   | 8.20   | 8.24   | 7.42   | 7.47   | 7.52   | 7.62   | 7.73   | 7.86   |
| DAL      | DALLOW                 | 1.00         | 4.31                 | 3.70   | 3.73   | 3.75   | 3.37   | 3.40   | 3.42   | 3.47   | 3.52   | 3.57   |
| DDK      | DUNDALK                | 1.00         | 16.52                | 14.19  | 14.30  | 8.49   | 7.64   | 7.69   | 7.75   | 7.85   | 7.97   | 8.09   |
| DFR      | DUNFIRTH               | 1.00         | 2.72                 | 2.34   | 2.35   | 2.37   | 2.13   | 2.14   | 2.16   | 2.19   | 2.22   | 2.26   |
| DGN      | DUNGARVAN              | 1.00         | 12.13                | 10.42  | 10.50  | 10.55  | 9.50   | 9.56   | 9.63   | 9.76   | 9.91   | 10.06  |
| DLT      | DALTON                 | 1.00         | 7.28                 | 6.25   | 6.30   | 6.33   | 5.70   | 5.74   | 5.78   | 5.85   | 5.94   | 6.04   |
| DMY      | DUNMANWAY              | 0.98         | 10.36                | 8.90   | 7.86   | 7.90   | 7.11   | 7.16   | 7.21   | 7.30   | 7.41   | 7.53   |
| DON      | BELFAST - DONEGAL MAIN | 0.96         | 29.24                | 29.28  | 29.34  | 29.46  | 29.62  | 29.40  | 29.60  | 29.79  | 30.04  | 30.24  |
| DOO      | DOON                   | 0.99         | 12.26                | 10.53  | 10.61  | 10.67  | 9.60   | 9.67   | 9.73   | 9.86   | 10.01  | 10.17  |

Table C-3 Demand Forecasts at Time of Summer Valley (continued)

| Bus Code | Bus Name               | Power Factor | Demand Forecast (MW) |        |        |        |        |        |        |        |        |        |
|----------|------------------------|--------------|----------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
|          |                        |              | 2015                 | 2016   | 2017   | 2018   | 2019   | 2020   | 2021   | 2022   | 2023   | 2024   |
| DRU      | DRUMNAKELLY MAIN       | 0.96         | 25.61                | 25.64  | 25.70  | 25.81  | 25.95  | 25.75  | 25.93  | 26.09  | 15.12  | 15.23  |
| DRU      | DRUMLINE               | 1.00         | 9.23                 | 7.93   | 7.99   | 8.03   | 7.23   | 7.28   | 7.33   | 7.42   | 7.54   | 7.66   |
| DRY      | DRYBRIDGE              | 0.99         | 23.41                | 20.11  | 20.27  | 18.96  | 17.07  | 17.18  | 17.30  | 17.53  | 17.80  | 18.08  |
| DUN      | DUNGANNON MAIN         | 0.96         | 27.06                | 27.09  | 27.15  | 27.27  | 27.41  | 27.21  | 27.39  | 27.57  | 27.79  | 27.98  |
| EDE      | EDEN MAIN              | 0.96         | 9.01                 | 9.03   | 9.05   | 9.09   | 9.13   | 9.06   | 9.13   | 9.18   | 9.26   | 9.33   |
| ENN      | ENNISKILLEN MAIN       | 0.96         | 13.78                | 13.79  | 13.83  | 13.88  | 13.96  | 13.85  | 13.95  | 14.04  | 14.15  | 14.25  |
| ENN      | ENNIS                  | 0.99         | 16.06                | 13.80  | 13.91  | 13.98  | 12.58  | 12.67  | 12.75  | 12.93  | 13.12  | 13.33  |
| FIN      | BELFAST - FINAGHY MAIN | 0.96         | 9.29                 | 9.30   | 9.32   | 9.37   | 9.41   | 9.34   | 9.41   | 9.47   | 9.55   | 9.61   |
| FIN      | FINGLAS                | 0.98         | 161.97               | 166.89 | 167.83 | 168.44 | 156.50 | 157.22 | 157.94 | 159.41 | 161.09 | 162.87 |
| GAL      | GALWAY                 | 1.00         | 26.66                | 22.90  | 23.08  | 23.20  | 20.87  | 21.02  | 21.16  | 21.46  | 21.77  | 22.12  |
| GI       | GREAT ISLAND           | 0.97         | 5.62                 | 4.83   | 4.86   | 4.89   | 4.40   | 4.43   | 4.46   | 4.52   | 4.59   | 4.66   |
| GIL      | GILRA                  | 0.99         | 1.39                 | 1.39   | 1.39   | 1.39   | 1.39   | 1.39   | 1.39   | 1.39   | 1.39   | 1.39   |
| GLE      | GLENLARA               | 0.95         | 4.80                 | 4.12   | 4.16   | 4.18   | 3.76   | 3.78   | 3.81   | 3.86   | 3.92   | 3.98   |
| GRI      | GRIFFINRATH            | 1.00         | 18.55                | 13.24  | 13.34  | 13.41  | 12.07  | 12.15  | 12.24  | 12.40  | 12.59  | 12.79  |
| GWE      | GORTAWEE               | 0.96         | 22.20                | 21.61  | 21.64  | 21.66  | 21.29  | 21.32  | 21.34  | 21.38  | 21.43  | 21.49  |
| HTS      | HARNETTS CROSS         | 0.98         | 0.00                 | 0.00   | 0.00   | 2.21   | 1.99   | 2.00   | 2.02   | 2.04   | 2.07   | 2.11   |
| IKE      | IKERRIN                | 0.98         | 8.07                 | 7.07   | 7.12   | 7.15   | 6.54   | 6.58   | 6.61   | 6.69   | 6.77   | 6.87   |
| INC      | INCHICORE              | 0.98         | 157.90               | 172.68 | 173.30 | 173.71 | 165.57 | 166.07 | 166.56 | 167.56 | 168.71 | 169.94 |
| KBY      | KILBARRY               | 1.00         | 35.22                | 30.26  | 30.49  | 30.65  | 27.79  | 27.99  | 28.18  | 28.55  | 28.98  | 29.44  |
| KER      | KNOCKERAGH             | 1.00         | 12.55                | 10.78  | 10.87  | 10.92  | 9.83   | 9.90   | 9.96   | 10.10  | 10.25  | 10.41  |
| KIN      | KINNEGAD               | 0.96         | 7.12                 | 7.12   | 7.12   | 7.12   | 7.12   | 7.12   | 7.12   | 7.12   | 7.12   | 7.12   |
| KKY      | KILKENNY               | 0.99         | 17.05                | 14.65  | 14.76  | 12.18  | 10.97  | 11.04  | 11.11  | 11.26  | 11.44  | 11.62  |
| KNO      | BELFAST - KNOCK MAIN   | 0.96         | 14.46                | 14.48  | 14.52  | 14.58  | 14.65  | 14.54  | 14.64  | 14.74  | 14.86  | 14.96  |



Table C-3 Demand Forecasts at Time of Summer Valley (continued)

| Bus Code | Bus Name         | Power Factor | Demand Forecast (MW) |       |       |       |       |       |       |       |       |       |
|----------|------------------|--------------|----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|          |                  |              | 2015                 | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| KTL      | KILTEEL          | 0.99         | 16.84                | 14.47 | 14.58 | 14.66 | 13.19 | 13.28 | 13.37 | 13.55 | 13.76 | 13.97 |
| KTN      | KILLOTARAN       | 0.96         | 9.46                 | 8.48  | 8.52  | 8.55  | 7.95  | 7.99  | 8.02  | 8.10  | 8.18  | 8.27  |
| KUR      | KNOCKUMBER       | 0.95         | 20.14                | 20.14 | 20.14 | 20.14 | 20.14 | 20.14 | 20.14 | 20.14 | 20.14 | 20.14 |
| LA       | LANESBORO        | 1.00         | 3.48                 | 2.99  | 3.01  | 3.03  | 2.72  | 2.74  | 2.76  | 2.80  | 2.84  | 2.89  |
| LAR      | LARNE - MAIN     | 0.96         | 12.03                | 12.04 | 12.07 | 12.12 | 12.18 | 12.09 | 12.18 | 12.26 | 12.35 | 12.44 |
| LET      | LETTERKENNY      | 1.00         | 16.48                | 14.16 | 13.07 | 13.13 | 11.82 | 11.90 | 11.98 | 12.14 | 12.33 | 12.52 |
| LIB      | LIBERTY          | 0.95         | 8.28                 | 7.11  | 7.17  | 7.20  | 6.48  | 6.53  | 6.57  | 6.66  | 6.76  | 6.87  |
| LIM      | LIMAVADY MAIN    | 0.96         | 6.81                 | 6.82  | 6.83  | 6.86  | 6.90  | 6.84  | 6.89  | 6.94  | 6.99  | 7.04  |
| LIM      | LIMERICK         | 1.00         | 26.11                | 22.58 | 22.75 | 22.86 | 20.68 | 20.81 | 20.94 | 21.21 | 21.52 | 21.84 |
| LIS      | LISBURN MAIN     | 0.96         | 17.14                | 17.17 | 17.20 | 17.28 | 17.37 | 17.24 | 17.36 | 17.47 | 17.61 | 17.73 |
| LIS      | LISDRUM          | 0.99         | 8.39                 | 7.21  | 7.26  | 7.30  | 6.57  | 6.62  | 6.66  | 6.75  | 6.85  | 6.96  |
| LMR      | LISAGHMORE MAIN  | 0.96         | 13.40                | 13.42 | 13.45 | 13.50 | 13.57 | 13.47 | 13.57 | 13.65 | 13.76 | 13.86 |
| LOG      | LOUGUESTOWN MAIN | 0.96         | 11.18                | 11.19 | 11.21 | 11.26 | 11.32 | 11.24 | 11.32 | 11.39 | 11.48 | 11.56 |
| LSN      | LISHEEN          | 0.98         | 15.00                | 15.00 | 15.00 | 15.00 | 15.00 | 15.00 | 15.00 | 15.00 | 15.00 | 15.00 |
| MAC      | MACROOM          | 0.95         | 5.05                 | 4.34  | 3.04  | 0.85  | 0.76  | 0.77  | 0.77  | 0.78  | 0.80  | 0.81  |
| MAL      | MALLOW           | 0.99         | 7.18                 | 6.17  | 6.22  | 6.25  | 5.63  | 5.66  | 5.70  | 5.78  | 5.87  | 5.96  |
| MCE      | MACETOWN         | 1.00         | 11.83                | 10.58 | 10.63 | 10.67 | 9.90  | 9.95  | 9.99  | 10.09 | 10.20 | 10.31 |
| MID      | MIDLETON         | 0.98         | 15.58                | 13.60 | 13.70 | 13.76 | 12.53 | 12.61 | 12.68 | 12.83 | 13.01 | 13.19 |
| MLN      | MULLAGHARLIN     | 0.99         | 0.35                 | 0.35  | 0.35  | 7.65  | 6.92  | 6.97  | 7.01  | 7.10  | 7.20  | 7.31  |
| MON      | MONREAD          | 0.98         | 3.73                 | 3.20  | 3.23  | 3.25  | 2.92  | 2.94  | 2.96  | 3.00  | 3.05  | 3.09  |
| MOY      | MOY              | 1.00         | 7.25                 | 6.23  | 6.28  | 6.31  | 5.68  | 5.72  | 5.76  | 5.83  | 5.92  | 6.02  |
| MR       | MARINA           | 0.98         | 5.61                 | 4.82  | 4.86  | 4.88  | 4.40  | 4.42  | 4.45  | 4.51  | 4.58  | 4.66  |
| MTH      | MEATH HILL       | 0.99         | 8.00                 | 6.87  | 6.93  | 6.96  | 6.27  | 6.31  | 6.35  | 6.44  | 6.54  | 6.64  |
| MUL      | MULLINGAR        | 1.00         | 11.88                | 10.21 | 10.28 | 10.33 | 9.30  | 9.37  | 9.43  | 9.56  | 9.71  | 9.86  |

Table C-3 Demand Forecasts at Time of Summer Valley (continued)

| Bus Code | Bus Name        | Power Factor | Demand Forecast (MW) |       |       |       |       |       |       |       |       |       |
|----------|-----------------|--------------|----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|          |                 |              | 2015                 | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| MUN      | MUNGRET         | 0.94         | 4.50                 | 4.50  | 4.50  | 4.50  | 4.50  | 4.50  | 4.50  | 4.50  | 4.50  | 4.50  |
| NAR      | NEWTOWARDS MAIN | 0.96         | 11.65                | 11.66 | 11.69 | 11.74 | 11.80 | 11.71 | 11.79 | 11.87 | 11.97 | 12.05 |
| NAV      | NAVAN           | 1.00         | 9.69                 | 8.33  | 8.39  | 8.44  | 7.59  | 7.64  | 7.70  | 7.80  | 7.92  | 8.04  |
| NEN      | NENAGH          | 0.98         | 8.12                 | 6.97  | 7.03  | 7.06  | 6.36  | 6.40  | 6.45  | 6.53  | 6.63  | 6.74  |
| NEW      | NEWRY MAIN      | 0.96         | 22.57                | 22.60 | 22.65 | 22.74 | 22.87 | 22.70 | 22.85 | 23.00 | 23.19 | 23.35 |
| NEW      | NEWBRIDGE       | 1.00         | 9.93                 | 8.54  | 8.60  | 5.55  | 4.99  | 5.03  | 5.06  | 5.13  | 5.21  | 5.29  |
| OLD      | OLDCOURT        | 0.96         | 0.30                 | 0.30  | 0.30  | 0.30  | 0.30  | 0.30  | 0.30  | 0.30  | 0.30  | 0.30  |
| OMA      | OMAGH MAIN      | 0.96         | 16.59                | 16.61 | 16.65 | 16.72 | 16.81 | 16.69 | 16.80 | 16.90 | 17.04 | 17.16 |
| OUG      | OUGHTRAGH       | 1.00         | 9.33                 | 8.02  | 8.08  | 8.12  | 7.31  | 7.36  | 7.41  | 7.51  | 7.62  | 7.74  |
| PB       | POOLBEG         | 1.00         | 73.34                | 63.00 | 63.50 | 63.82 | 57.45 | 57.85 | 58.24 | 59.02 | 59.90 | 60.87 |
| PLA      | PLATIN          | 0.93         | 8.41                 | 8.41  | 8.41  | 8.41  | 8.41  | 8.41  | 8.41  | 8.41  | 8.41  | 8.41  |
| PLS      | PORTLAOISE      | 1.00         | 13.55                | 11.64 | 11.73 | 8.39  | 7.56  | 7.61  | 7.66  | 7.77  | 7.88  | 8.01  |
| RAT      | RATHGAEL MAIN   | 0.96         | 17.39                | 17.41 | 17.45 | 17.52 | 17.61 | 17.48 | 17.60 | 17.71 | 17.86 | 17.98 |
| RAT      | RATHKEALE       | 0.98         | 7.56                 | 6.50  | 6.55  | 6.58  | 5.92  | 5.96  | 6.00  | 6.08  | 6.18  | 6.27  |
| RIC      | RICHMOND        | 1.00         | 9.29                 | 7.98  | 8.04  | 8.08  | 7.28  | 7.32  | 7.37  | 7.47  | 7.59  | 7.71  |
| RNW      | RINAWADE        | 1.00         | 5.75                 | 5.75  | 5.75  | 5.75  | 5.75  | 5.75  | 5.75  | 5.75  | 5.75  | 5.75  |
| ROS      | ROSEBANK MAIN   | 0.96         | 8.85                 | 8.86  | 8.88  | 8.91  | 8.96  | 8.90  | 8.96  | 9.01  | 9.09  | 9.15  |
| RSY      | RINGASKIDDY     | 0.95         | 2.86                 | 2.45  | 2.47  | 2.49  | 2.24  | 2.25  | 2.27  | 2.30  | 2.33  | 2.37  |
| RYB      | RYEBROOK        | 0.96         | 75.00                | 75.00 | 75.00 | 75.00 | 75.00 | 75.00 | 75.00 | 75.00 | 75.00 | 75.00 |
| SAL      | SALTHILL        | 0.99         | 22.64                | 19.46 | 19.61 | 19.72 | 17.74 | 17.86 | 17.98 | 18.23 | 18.50 | 18.79 |
| SCR      | SCREEB          | 0.95         | 3.99                 | 3.43  | 3.45  | 3.47  | 3.12  | 3.14  | 3.17  | 3.21  | 3.26  | 3.31  |
| SHE      | SHELTON ABBEY   | 0.96         | 2.29                 | 2.29  | 2.29  | 2.29  | 2.29  | 2.29  | 2.29  | 2.29  | 2.29  | 2.29  |
| SKL      | SHANKILL        | 0.98         | 15.72                | 13.50 | 13.61 | 13.68 | 12.31 | 12.40 | 12.48 | 12.65 | 12.84 | 13.04 |
| SLI      | SLIGO           | 1.00         | 15.14                | 13.01 | 13.11 | 13.18 | 11.86 | 11.94 | 12.02 | 12.18 | 12.37 | 12.56 |

Table C-3 Demand Forecasts at Time of Summer Valley (continued)

| Bus Code | Bus Name         | Power Factor | Demand Forecast (MW) |       |       |       |       |       |       |       |       |       |
|----------|------------------|--------------|----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|          |                  |              | 2015                 | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| SNG      | SINGLAND         | 0.98         | 4.36                 | 3.74  | 3.77  | 3.79  | 3.41  | 3.44  | 3.46  | 3.51  | 3.56  | 3.62  |
| SOM      | SOMERSET         | 1.00         | 6.06                 | 5.21  | 5.25  | 5.27  | 4.75  | 4.78  | 4.81  | 4.88  | 4.95  | 5.03  |
| SPR      | SPRINGTOWN MAIN  | 0.96         | 8.58                 | 8.59  | 8.61  | 8.65  | 8.69  | 8.63  | 8.69  | 8.75  | 8.82  | 8.88  |
| STR      | STRABANE MAIN    | 0.96         | 10.57                | 10.58 | 10.61 | 10.65 | 10.71 | 10.62 | 10.70 | 10.76 | 10.86 | 10.93 |
| STR      | STRATFORD        | 0.99         | 4.53                 | 3.89  | 3.92  | 3.94  | 3.55  | 3.57  | 3.60  | 3.65  | 3.70  | 3.76  |
| TBG      | TRABEG           | 1.00         | 15.46                | 13.28 | 13.39 | 13.46 | 12.11 | 12.19 | 12.27 | 12.44 | 12.63 | 12.83 |
| TBK      | TULLABRACK       | 0.99         | 4.06                 | 3.49  | 3.51  | 3.53  | 3.18  | 3.20  | 3.22  | 3.26  | 3.31  | 3.37  |
| THU      | THURLES          | 0.98         | 9.01                 | 7.74  | 7.80  | 7.84  | 7.06  | 7.11  | 7.15  | 7.25  | 7.36  | 7.48  |
| TIP      | TIPPERARY        | 1.00         | 5.98                 | 5.14  | 5.18  | 5.21  | 4.69  | 4.72  | 4.75  | 4.81  | 4.89  | 4.96  |
| TLK      | TRILLICK         | 0.95         | 5.70                 | 4.90  | 4.94  | 4.97  | 4.47  | 4.50  | 4.53  | 4.59  | 4.66  | 4.73  |
| TON      | TONROE           | 0.98         | 4.81                 | 4.13  | 4.16  | 4.18  | 3.77  | 3.79  | 3.82  | 3.87  | 3.93  | 3.99  |
| TRI      | TRIEN            | 0.98         | 11.89                | 10.22 | 10.30 | 10.35 | 9.32  | 9.38  | 9.44  | 9.57  | 9.72  | 9.87  |
| TRL      | TRALEE           | 0.98         | 13.46                | 11.57 | 11.66 | 11.72 | 10.55 | 10.62 | 10.69 | 10.83 | 11.00 | 11.17 |
| TSB      | THORNSBERRY      | 0.99         | 8.79                 | 7.55  | 7.61  | 7.65  | 6.88  | 6.93  | 6.98  | 7.07  | 7.18  | 7.29  |
| WAR      | WARINGSTOWN MAIN | 0.96         | 17.99                | 18.02 | 18.06 | 18.14 | 18.23 | 18.10 | 18.22 | 18.33 | 18.49 | 18.61 |
| WAT      | WATERFORD        | 1.00         | 12.67                | 10.89 | 10.97 | 10.79 | 9.71  | 9.78  | 9.85  | 9.98  | 10.13 | 10.29 |
| WEX      | WEXFORD          | 1.00         | 15.40                | 13.23 | 13.34 | 13.41 | 12.07 | 12.16 | 12.23 | 12.40 | 12.59 | 12.78 |
| WHI      | WHITEGATE        | 0.81         | 2.52                 | 2.52  | 2.52  | 2.52  | 2.52  | 2.52  | 2.52  | 2.52  | 2.52  | 2.52  |

Table C-4 Demand Forecasts at Time of Autumn Peak – Northern Ireland only

| Bus Code | Bus Name                       | Power Factor | Demand Forecast (MW) |       |       |       |       |       |       |       |       |       |
|----------|--------------------------------|--------------|----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|          |                                |              | 2015                 | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| AGH      | AGHYOULE                       | 0.97         | 15.71                | 15.73 | 15.77 | 15.83 | 15.70 | 15.80 | 15.90 | 16.03 | 16.14 | 16.14 |
| AIR      | BELFAST - AIRPORT ROAD MAIN    | 0.97         | -                    | -     | -     | -     | 20.17 | 20.29 | 20.44 | 20.60 | 20.74 | 20.74 |
| ANT      | ANTRIM MAIN                    | 0.97         | 37.49                | 37.53 | 37.63 | 37.78 | 37.45 | 37.69 | 37.96 | 38.25 | 38.51 | 38.51 |
| ARM      | ARMAGH                         | 0.97         | -                    | -     | -     | -     | -     | -     | -     | 32.24 | 32.45 | 32.45 |
| BAN      | BANBRIDGE MAIN                 | 0.97         | 34.58                | 34.63 | 34.71 | 34.85 | 34.55 | 34.77 | 35.01 | 35.28 | 35.53 | 35.53 |
| BMA      | BALLYMENA MAIN                 | 0.97         | 64.93                | 65.01 | 65.15 | 65.42 | 64.87 | 65.28 | 65.73 | 66.23 | 66.69 | 66.69 |
| BNH      | BALLYNAHINCH MAIN              | 0.97         | 52.62                | 52.68 | 52.80 | 53.02 | 52.56 | 52.90 | 53.27 | 53.68 | 54.05 | 54.05 |
| BNM      | BELFAST - BELFAST NORTH MAIN   | 0.97         | 43.65                | 43.70 | 43.81 | 43.98 | 43.60 | 43.88 | 44.18 | 44.53 | 44.84 | 44.84 |
| CAR      | BELFAST - CARNMONEY MAIN       | 0.97         | 25.25                | 25.28 | 25.33 | 25.44 | 25.23 | 25.39 | 25.56 | 25.76 | 25.94 | 25.94 |
| CEN      | BELFAST - BELFAST CENTRAL MAIN | 0.97         | 47.96                | 48.02 | 48.13 | 48.33 | 47.92 | 48.22 | 48.56 | 48.93 | 49.27 | 49.27 |
| COL      | COLERAINE MAIN                 | 0.97         | 36.26                | 36.29 | 36.38 | 36.53 | 36.22 | 36.45 | 36.70 | 37.00 | 37.24 | 37.24 |
| CPS      | COOLKEERAGH MAIN               | 0.97         | 28.36                | 28.40 | 28.46 | 28.58 | 28.34 | 28.52 | 28.71 | 28.94 | 29.13 | 29.13 |
| CRE      | BELFAST - CREGAGH MAIN         | 0.97         | 67.43                | 67.52 | 67.69 | 67.96 | 67.38 | 67.82 | 68.29 | 68.81 | 69.27 | 69.27 |
| CRG      | CREAGH MAIN                    | 0.97         | 31.14                | 31.18 | 31.25 | 31.38 | 31.11 | 31.31 | 31.53 | 31.77 | 31.99 | 31.99 |
| DON      | BELFAST - DONEGAL MAIN         | 0.97         | 90.30                | 90.41 | 90.63 | 90.99 | 90.22 | 90.79 | 91.42 | 92.13 | 92.77 | 92.77 |
| DRU      | DRUMNAKELLY MAIN               | 0.97         | 79.09                | 79.19 | 79.38 | 79.70 | 79.02 | 79.52 | 80.07 | 46.38 | 46.70 | 46.70 |
| DUN      | DUNGANNON MAIN                 | 0.97         | 83.56                | 83.66 | 83.85 | 84.20 | 83.49 | 84.03 | 84.60 | 85.25 | 85.84 | 85.84 |
| EDE      | EDEN MAIN                      | 0.97         | 27.84                | 27.87 | 27.94 | 28.06 | 27.81 | 27.99 | 28.19 | 28.40 | 28.60 | 28.60 |
| ENN      | ENNISKILLEN MAIN               | 0.97         | 42.54                | 42.60 | 42.70 | 42.87 | 42.50 | 42.78 | 43.08 | 43.41 | 43.71 | 43.71 |
| FIN      | BELFAST - FINAGHY MAIN         | 0.97         | 28.70                | 28.74 | 28.80 | 28.92 | 28.67 | 28.85 | 29.06 | 29.28 | 29.48 | 29.48 |
| GLE      | BELFAST - GLENGORMELY MAIN     | 0.97         | 24.07                | 24.10 | 24.16 | 24.25 | 24.04 | 24.21 | 24.37 | 24.55 | 24.73 | 24.73 |
| KNO      | BELFAST - KNOCK MAIN           | 0.97         | 44.67                | 44.73 | 44.83 | 45.02 | 44.63 | 44.91 | 45.22 | 45.58 | 45.89 | 45.89 |
| LAR      | LARNE - MAIN                   | 0.97         | 37.15                | 37.18 | 37.28 | 37.43 | 37.11 | 37.35 | 37.61 | 37.89 | 38.15 | 38.15 |
| LIM      | LIMAVADY MAIN                  | 0.97         | 21.02                | 21.05 | 21.10 | 21.19 | 21.00 | 21.14 | 21.29 | 21.45 | 21.60 | 21.60 |
| LIS      | LISBURN MAIN                   | 0.97         | 52.94                | 53.01 | 53.13 | 53.35 | 52.90 | 53.24 | 53.61 | 54.02 | 54.39 | 54.39 |

Table C-4 Demand Forecasts at Time of Autumn Peak – Northern Ireland only (continued)

| Bus Code | Bus Name         | Power Factor | Demand Forecast (MW) |       |       |       |       |       |       |       |       |       |
|----------|------------------|--------------|----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|          |                  |              | 2015                 | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| LMR      | LISAGHMORE MAIN  | 0.97         | 41.38                | 41.43 | 41.53 | 41.70 | 41.34 | 41.61 | 41.89 | 42.22 | 42.51 | 42.51 |
| LOG      | LOUGUESTOWN MAIN | 0.97         | 34.52                | 34.55 | 34.63 | 34.78 | 34.48 | 34.70 | 34.95 | 35.22 | 35.45 | 35.45 |
| NAR      | NEWTOWNARDS MAIN | 0.97         | 35.97                | 36.01 | 36.10 | 36.25 | 35.94 | 36.17 | 36.42 | 36.70 | 36.95 | 36.95 |
| NEW      | NEWRY MAIN       | 0.97         | 69.71                | 69.79 | 69.96 | 70.24 | 69.64 | 70.09 | 70.58 | 71.12 | 71.61 | 71.61 |
| OMA      | OMAGH MAIN       | 0.97         | 51.25                | 51.29 | 51.41 | 51.63 | 51.18 | 51.51 | 51.88 | 52.28 | 52.64 | 52.64 |
| RAT      | RATHGAEL MAIN    | 0.97         | 53.69                | 53.76 | 53.88 | 54.11 | 53.64 | 53.99 | 54.36 | 54.78 | 55.16 | 55.16 |
| ROS      | ROSEBANK MAIN    | 0.97         | 27.32                | 27.35 | 27.41 | 27.53 | 27.29 | 27.47 | 27.65 | 27.87 | 28.07 | 28.07 |
| SPR      | SPRINGTOWN MAIN  | 0.97         | 26.50                | 26.53 | 26.60 | 26.70 | 26.48 | 26.65 | 26.83 | 27.04 | 27.22 | 27.22 |
| STR      | STRABANE MAIN    | 0.97         | 32.65                | 32.68 | 32.75 | 32.88 | 32.61 | 32.80 | 33.04 | 33.30 | 33.51 | 33.51 |
| WAR      | WARINGSTOWN MAIN | 0.97         | 55.57                | 55.64 | 55.77 | 56.00 | 55.52 | 55.87 | 56.26 | 56.70 | 57.09 | 57.09 |



## APPENDIX D: GENERATION CAPACITY AND DISPATCH DETAILS

### D.1 Generation Dispatch Details



The current. The future.

## Appendix D Generation Capacity and Dispatch Details

Table D-1 lists existing and committed future generation and the Registered Capacity<sup>1</sup> of each unit. This is noted for each year up to 2024. All generation capacity figures in Table E- are expressed in exported terms. Exported terms are given by the generation unit output less the unit's own auxiliary load. The units are grouped in these tables on a geographical basis. Generation capacity figures are rounded to the nearest MW.

Table D-2 lists the existing and committed future wind generation. The wind generation included in this table is wind generation that feeds into each 110 kV transmission station, from the distribution system. The results for each year up to 2024 are included. Table D-2 is based on the wind farms that currently have signed connection agreements with the DSO. The connection agreements are based on the best available knowledge as at the beginning of July 2015.

Table D-3 lists the existing and committed dispatchable distribution connected conventional generation in Ireland. Their respective MW capacity over the period of the statement is included.

Table D-4 lists the existing and committed distribution connected renewable generation in Northern Ireland, excluding wind generation. Their respective MW capacity over the period of the statement is included.

Please see EirGrid's website<sup>2</sup> for an update on the Gate 3 generators which have committed to connecting to the transmission system. This commitment is given by executing connection agreements with EirGrid.

Where dual fuel capability exists, the fuel type highlighted in red is utilised to meet peak demand.

---

<sup>1</sup>The Registered Capacity of future units will not be known until the unit enters the Single Electricity Market. Therefore, for future units the Maximum Export Capacity of the unit appears in Table D-1.

<sup>2</sup><http://www.eirgridgroup.com/customer-and-industry/general-customer-information/connections-and-contracts/>

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table D-1 Maximum Export Capacities of Existing and Committed Transmission-Connected Generation

| Area                     | Generation Station | Unit ID | Connected At  |        | Fuel Type | Maximum Export Capacity (MW) |             |             |             |             |             |             |             |             |      |
|--------------------------|--------------------|---------|---------------|--------|-----------|------------------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|------|
|                          |                    |         |               |        |           | 2015                         | 2016        | 2017        | 2018        | 2019        | 2020        | 2021        | 2022        | 2023        | 2024 |
| Dublin                   | Dublin Bay Power   | DB1     | Irishtown     | 220 kV | Gas/DO    | 415                          | 415         | 415         | 415         | 415         | 415         | 415         | 415         | 415         | 415  |
|                          | Huntstown          | HNC     | Huntstown A   | 220 kV | Gas/DO    | 352                          | 352         | 352         | 352         | 352         | 352         | 352         | 352         | 352         | 352  |
|                          | Huntstown          | HN2     | Huntstown B   | 220 kV | Gas/DO    | 412                          | 412         | 412         | 412         | 412         | 412         | 412         | 412         | 412         | 412  |
|                          | North Wall         | NW5     | North Wall    | 220 kV | Gas/DO    | 109                          | 109         | 109         | 109         | 109         | 109         | 109         | 109         | 109         | 109  |
|                          | Poolbeg            | PBC     | Shellybanks   | 220 kV | Gas/DO    | 460                          | 460         | 460         | 460         | 460         | 460         | 460         | 460         | 460         | 460  |
|                          | Liffey Hydro       | LI1     | Pollaphuca    | 110 kV | Hydro     | 15                           | 15          | 15          | 15          | 15          | 15          | 15          | 15          | 15          | 15   |
|                          | Liffey Hydro       | LI2     | Pollaphuca    | 110 kV | Hydro     | 15                           | 15          | 15          | 15          | 15          | 15          | 15          | 15          | 15          | 15   |
|                          | Liffey Hydro       | LI4     | Pollaphuca    | 110 kV | Hydro     | 4                            | 4           | 4           | 4           | 4           | 4           | 4           | 4           | 4           | 4    |
|                          | Turlough Hill      | TH1     | Turlough Hill | 220 kV | Hydro     | 73                           | 73          | 73          | 73          | 73          | 73          | 73          | 73          | 73          | 73   |
|                          | Turlough Hill      | TH2     | Turlough Hill | 220 kV | Hydro     | 73                           | 73          | 73          | 73          | 73          | 73          | 73          | 73          | 73          | 73   |
|                          | Turlough Hill      | TP      | Turlough Hill | 220 kV | Hydro     | 73                           | 73          | 73          | 73          | 73          | 73          | 73          | 73          | 73          | 73   |
|                          | Turlough Hill      | TH4     | Turlough Hill | 220 kV | Hydro     | 73                           | 73          | 73          | 73          | 73          | 73          | 73          | 73          | 73          | 73   |
| <b>Dublin Area Total</b> |                    |         |               |        |           | <b>2074</b>                  | <b>2074</b> | <b>2074</b> | <b>2074</b> | <b>2074</b> | <b>2074</b> | <b>2074</b> | <b>2074</b> | <b>2074</b> |      |



Table D-1 Maximum Export Capacities of Existing and Committed Transmission-Connected Generation (Continued)

| Area                       | Generation Station | Unit ID | Connected At  |        | Fuel Type  | Maximum Export Capacity (MW) |            |            |            |            |            |            |            |            |            |
|----------------------------|--------------------|---------|---------------|--------|------------|------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
|                            |                    |         |               |        |            | 2015                         | 2016       | 2017       | 2018       | 2019       | 2020       | 2021       | 2022       | 2023       | 2024       |
| Midlands                   | Cuilleen OCGT      | -       | Athlone       | 110 kV | Gas/DO     | -                            | -          | -          | -          | -          | 98         | 98         | 98         | 98         | 98         |
|                            | Dooray             | -       | Killinaparson | 110 kV | Wind       | -                            | -          | -          | -          | -          | 55         | 55         | 55         | 55         | 55         |
|                            | Edenderry Power    | ED1     | Cushaling     | 110 kV | Peat       | 122                          | 122        | 122        | 122        | 122        | 122        | 122        | 122        | 122        | 122        |
|                            | Edenderry PCP      | ED3     | Cushaling     | 110 kV | Distillate | 58                           | 58         | 58         | 58         | 58         | 58         | 58         | 58         | 58         | 58         |
|                            | Edenderry PCP      | ED5     | Cushaling     | 110 kV | Distillate | 58                           | 58         | 58         | 58         | 58         | 58         | 58         | 58         | 58         | 58         |
|                            | Kill Hill          | -       | Kill Hill     | 110 kV | Wind       | 59                           | 59         | 59         | 59         | 59         | 59         | 59         | 59         | 59         | 59         |
|                            | Lisheen            | -       | Lisheen       | 110 kV | Wind       | 59                           | 59         | 59         | 59         | 59         | 59         | 59         | 59         | 59         | 59         |
|                            | Mount Lucas        | -       | Mount Lucas   | 110 kV | Wind       | 79                           | 79         | 79         | 79         | 79         | 79         | 79         | 79         | 79         | 79         |
|                            | Rhode PCP          | RP1     | Derryiron     | 110 kV | Distillate | 52                           | 52         | 52         | 52         | 52         | 52         | 52         | 52         | 52         | 52         |
|                            | Rhode PCP          | RP2     | Derryiron     | 110 kV | Distillate | 52                           | 52         | 52         | 52         | 52         | 52         | 52         | 52         | 52         | 52         |
|                            | Suir OCGT          | SUR     | Cahir         | 110 kV | Gas/DO     | -                            | -          | -          | -          | -          | 98         | 98         | 98         | 98         | 98         |
|                            | West Offaly Power  | WO4     | Shannonbridge | 110 kV | Peat       | 141                          | 141        | 141        | 141        | 141        | 141        | 141        | 141        | 141        | 141        |
| <b>Midlands Area Total</b> |                    |         |               |        |            | <b>680</b>                   | <b>680</b> | <b>680</b> | <b>680</b> | <b>680</b> | <b>931</b> | <b>931</b> | <b>931</b> | <b>931</b> | <b>931</b> |

Table D-1 Maximum Export Capacities of Existing and Committed Transmission-Connected Generation (Continued)

| Area       | Generation Station  | Unit ID    | Connected At        |        | Fuel Type | Maximum Export Capacity (MW) |      |      |      |      |      |      |      |      |      |
|------------|---------------------|------------|---------------------|--------|-----------|------------------------------|------|------|------|------|------|------|------|------|------|
|            |                     |            |                     |        |           | 2015                         | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 |
| Mid-West   | Ardnacrusha         | AA1        | Ardnacrusha         | 110 kV | Hydro     | 22                           | 22   | 22   | 22   | 22   | 22   | 22   | 22   | 22   | 22   |
|            | Ardnacrusha         | AA2        | Ardnacrusha         | 110 kV | Hydro     | 22                           | 22   | 22   | 22   | 22   | 22   | 22   | 22   | 22   | 22   |
|            | Ardnacrusha         | AA3        | Ardnacrusha         | 110 kV | Hydro     | 21                           | 21   | 21   | 21   | 21   | 21   | 21   | 21   | 21   | 21   |
|            | Ardnacrusha         | AA4        | Ardnacrusha         | 110 kV | Hydro     | 21                           | 21   | 21   | 21   | 21   | 21   | 21   | 21   | 21   | 21   |
|            | Aughinish           | SK3        | Sealrock            | 110 kV | Gas/DO    | 65                           | 65   | 65   | 65   | 65   | 65   | 65   | 65   | 65   | 65   |
|            | Aughinish           | SK4        | Sealrock            | 110 kV | Gas/DO    | 65                           | 65   | 65   | 65   | 65   | 65   | 65   | 65   | 65   | 65   |
|            | Booltiagh           | -          | Booltiagh           | 110 kV | Wind      | 20                           | 20   | 20   | 20   | 20   | 20   | 20   | 20   | 20   | 20   |
|            | Booltiagh Extension | -          | Booltiagh           | 110 kV | Wind      | 12                           | 12   | 12   | 12   | 12   | 12   | 12   | 12   | 12   | 12   |
|            | Cahernagh Mid Merit | -          | Cahernagh Mid Merit | 110 kV | OCGT      | -                            | -    | -    | -    | -    | 101  | 101  | 101  | 101  | 101  |
|            | Derrybrien          | -          | Derrybrien          | 110 kV | Wind      | 60                           | 60   | 60   | 60   | 60   | 60   | 60   | 60   | 60   | 60   |
|            | Keelderry (1)       | -          | Knockavanna         | 110 kV | Wind      | -                            | -    | -    | -    | -    | 27   | 27   | 27   | 27   | 27   |
|            | Loughaun North      | -          | Ennis               | 110 kV | Wind      | -                            | -    | 27   | 27   | 27   | 27   | 27   | 27   | 27   | 27   |
|            | Moneypoint          | MP1        | Moneypoint          | 380 kV | Coal      | 288                          | 288  | 288  | 288  | 288  | 288  | 288  | 288  | 288  | 288  |
|            | Moneypoint          | MP2        | Moneypoint          | 380 kV | Coal/HFO  | 288                          | 288  | 288  | 288  | 288  | 288  | 288  | 288  | 288  | 288  |
| Moneypoint | MP3                 | Moneypoint | 380 kV              | Coal   | 288       | 288                          | 288  | 288  | 288  | 288  | 288  | 288  | 288  | 288  |      |

Table D-1 Maximum Export Capacities of Existing and Committed Transmission-Connected Generation (Continued)

| Area                       | Generation Station | Unit ID | Connected At |        | Fuel Type | Maximum Export Capacity (MW) |             |             |             |             |             |             |             |             |             |
|----------------------------|--------------------|---------|--------------|--------|-----------|------------------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
|                            |                    |         |              |        |           | 2015                         | 2016        | 2017        | 2018        | 2019        | 2020        | 2021        | 2022        | 2023        | 2024        |
| Mid-West                   | Moneypoint         | -       | Moneypoint   | 110 kV | Wind      | 22                           | 22          | 22          | 22          | 22          | 22          | 22          | 22          | 22          | 22          |
|                            | Tarbert            | TB1     | Tarbert      | 110 kV | HFO       | 54                           | 54          | 54          | 54          | 54          | 54          | 54          | 54          | -           | -           |
|                            | Tarbert            | TB2     | Tarbert      | 110 kV | HFO       | 54                           | 54          | 54          | 54          | 54          | 54          | 54          | 54          | -           | -           |
|                            | Tarbert            | TB3     | Tarbert      | 220 kV | HFO       | 241                          | 241         | 241         | 241         | 241         | 241         | 241         | 241         | -           | -           |
|                            | Tarbert            | TB4     | Tarbert      | 220 kV | HFO       | 241                          | 241         | 241         | 241         | 241         | 241         | 241         | 241         | -           | -           |
|                            | Tynagh             | TY      | Tynagh       | 220 kV | Gas       | 404                          | 404         | 404         | 404         | 404         | 404         | 404         | 404         | 404         | 404         |
| <b>Mid-West Area Total</b> |                    |         |              |        |           | <b>2188</b>                  | <b>2188</b> | <b>2215</b> | <b>2215</b> | <b>2215</b> | <b>2343</b> | <b>2343</b> | <b>2343</b> | <b>1753</b> | <b>1753</b> |

| Area                         | Generation Station | Unit ID | Connected At    |        | Fuel Type | Maximum Export Capacity (MW) |            |            |            |            |            |            |            |            |            |
|------------------------------|--------------------|---------|-----------------|--------|-----------|------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
|                              |                    |         |                 |        |           | 2015                         | 2016       | 2017       | 2018       | 2019       | 2020       | 2021       | 2022       | 2023       | 2024       |
| North-East                   | Bindoo             | -       | Ratrussan       | 110 kV | Wind      | 48                           | 48         | 48         | 48         | 48         | 48         | 48         | 48         | 48         | 48         |
|                              | Bindoo Extension   | -       | Ratrussan       | 110 kV | Wind      | -                            | 22         | 22         | 22         | 22         | 22         | 22         | 22         | 22         | 22         |
|                              | Castletown-moor    | -       | Castletown-moor | 110 kV | Wind      | -                            | -          | -          | -          | -          | 120        | 120        | 120        | 120        | 120        |
|                              | Mountain Lodge     | -       | Ratrussan       | 110 kV | Wind      | 31                           | 31         | 31         | 31         | 31         | 31         | 31         | 31         | 31         | 31         |
|                              | Oriel              | -       | Oriel           | 110kV  | Wind      | -                            | -          | -          | -          | -          | 210        | 210        | 210        | 210        | 210        |
| <b>North-East Area Total</b> |                    |         |                 |        |           | <b>79</b>                    | <b>101</b> | <b>101</b> | <b>101</b> | <b>101</b> | <b>431</b> | <b>431</b> | <b>431</b> | <b>431</b> | <b>431</b> |

Table D-1 Maximum Export Capacities of Existing and Committed Transmission-Connected Generation (Continued)

| Area             | Generation Station     | Unit ID   | Connected At |              | Fuel Type   | Maximum Export Capacity (MW) |      |      |      |      |      |      |      |      |      |
|------------------|------------------------|-----------|--------------|--------------|-------------|------------------------------|------|------|------|------|------|------|------|------|------|
|                  |                        |           |              |              |             | 2015                         | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 |
| Northern Ireland | Ballylumford CCGT10    | B10       | Ballylumford | 110 kV       | Gas/Gas oil | 101                          | 101  | 101  | 101  | 101  | 101  | 101  | 101  | 101  | 101  |
|                  | Ballylumford CCGT31    | B31       | Ballylumford | 275 kV       | Gas/Gas oil | 247                          | 247  | 247  | 247  | 247  | 247  | 247  | 247  | 247  | 247  |
|                  | Ballylumford CCGT32    | B32       | Ballylumford | 275 kV       | Gas/Gas oil | 247                          | 247  | 247  | 247  | 247  | 247  | 247  | 247  | 247  | 247  |
|                  | Ballylumford GT7       | BGT1      | Ballylumford | 110 kV       | Gasoil      | 58                           | 58   | 58   | 58   | 58   | 58   | 58   | 58   | 58   | 58   |
|                  | Ballylumford GT8       | BGT2      | Ballylumford | 110 kV       | Gasoil      | 58                           | 58   | 58   | 58   | 58   | 58   | 58   | 58   | 58   | 58   |
|                  | Ballylumford ST4,5 & 6 | B 4,5 & 6 | Ballylumford | 275 kV       | Gas/HFO     | 510                          | 250  | 250  | 250  | -    | -    | -    | -    | -    | -    |
|                  | Brockaghboy            | -         | Brockaghboy  | 110 kV       | Wind        | -                            | -    | 57   | 57   | 57   | 57   | 57   | 57   | 57   | 57   |
|                  | CAES                   | -         | Ballylumford | 275 kV       | Comp. Air   | -                            | -    | -    | 268  | 268  | 268  | 268  | 268  | 268  | 268  |
|                  | Coolkeeragh CCGT       | C30       | Coolkeeragh  | 275 & 110 kV | Gas/Gas oil | 425                          | 425  | 425  | 425  | 425  | 425  | 425  | 425  | 425  | 425  |
|                  | Coolkeeragh GT8        | CGT8      | Coolkeeragh  | 275 kV       | Gasoil      | 53                           | 53   | 53   | 53   | 53   | 53   | 53   | 53   | 53   | 53   |
|                  | Kilroot GT1            | KGT1      | Kilroot      | 275 kV       | Gasoil      | 29                           | 29   | 29   | 29   | 29   | 29   | 29   | 29   | 29   | 29   |
|                  | Kilroot GT2            | KGT2      | Kilroot      | 275 kV       | Gasoil      | 29                           | 29   | 29   | 29   | 29   | 29   | 29   | 29   | 29   | 29   |
|                  | Kilroot GT3            | KGT3      | Kilroot      | 275 kV       | Gasoil      | 42                           | 42   | 42   | 42   | 42   | 42   | 42   | 42   | 42   | 42   |
|                  | Kilroot GT4            | KGT4      | Kilroot      | 275 kV       | Gasoil      | 42                           | 42   | 42   | 42   | 42   | 42   | 42   | 42   | 42   | 42   |
|                  | Kilroot ST1            | K1        | Kilroot      | 275 kV       | Coal/Oil    | 238                          | 238  | 238  | 238  | 238  | 238  | 238  | 238  | 238  | -    |
| Kilroot ST2      | K2                     | Kilroot   | 275 kV       | Coal/Oil     | 238         | 238                          | 238  | 238  | 238  | 238  | 238  | 238  | 238  | -    |      |

Table D-1 Maximum Export Capacities of Existing and Committed Transmission-Connected Generation (Continued)

| Area                        | Generation Station      | Unit ID | Connected At  |        | Fuel Type | Maximum Export Capacity (MW) |      |      |      |      |      |      |      |      |      |
|-----------------------------|-------------------------|---------|---------------|--------|-----------|------------------------------|------|------|------|------|------|------|------|------|------|
|                             |                         |         |               |        |           | 2015                         | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 |
| Northern Ireland            | Slieve Kirk             | SLK     | Killymallaght | 110 kV | Wind      | 74                           | 83   | 83   | 83   | 83   | 83   | 83   | 83   | 83   | 83   |
|                             | Torr Head and Fair Head | -       | Kells         | 110 kV | Tidal     | -                            | -    | -    | 10   | 10   | 210  | 210  | 210  | 210  | 210  |
| Northern Ireland Area Total |                         |         |               |        |           | 2391                         | 2140 | 2197 | 2475 | 2225 | 2425 | 2425 | 2425 | 2425 | 1949 |

| Area       | Generation Station | Unit ID | Connected At     |        | Fuel Type | Maximum Export Capacity (MW) |      |      |      |      |      |      |      |      |      |
|------------|--------------------|---------|------------------|--------|-----------|------------------------------|------|------|------|------|------|------|------|------|------|
|            |                    |         |                  |        |           | 2015                         | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 |
| North-West | Cronacarkfree      | -       | Cronacarkfree    | 110 kV | Wind      | -                            | -    | 105  | 105  | 105  | 105  | 105  | 105  | 105  | 105  |
|            | Erne               | ER3     | Cathaleen's Fall | 110 kV | Hydro     | 23                           | 23   | 23   | 23   | 23   | 23   | 23   | 23   | 23   | 23   |
|            | Erne               | ER4     | Cathaleen's Fall | 110 kV | Hydro     | 23                           | 23   | 23   | 23   | 23   | 23   | 23   | 23   | 23   | 23   |
|            | Erne               | ER1     | Cliff            | 110 kV | Hydro     | 10                           | 10   | 10   | 10   | 10   | 10   | 10   | 10   | 10   | 10   |
|            | Erne               | ER2     | Cliff            | 110 kV | Hydro     | 10                           | 10   | 10   | 10   | 10   | 10   | 10   | 10   | 10   | 10   |
|            | Golagh             | -       | Golagh           | 110 kV | Wind      | 15                           | 15   | 15   | 15   | 15   | 15   | 15   | 15   | 15   | 15   |
|            | Garvagh            | -       | Garvagh          | 110 kV | Wind      | 26                           | 26   | 26   | 26   | 26   | 32   | 32   | 32   | 32   | 32   |
|            | Garvagh            | -       | Garvagh          | 110 kV | Wind      | 22                           | 22   | 22   | 22   | 22   | 27   | 27   | 27   | 27   | 27   |
|            | Kingsmountain      | -       | Cunghill         | 110 kV | Wind      | 35                           | 35   | 35   | 35   | 35   | 35   | 35   | 35   | 35   | 35   |
|            | Lough Ree Power    | LR4     | Lanesboro        | 110 kV | Peat      | 94                           | 94   | 94   | 94   | 94   | 94   | 94   | 94   | 94   | 94   |

Table D-1 Maximum Export Capacities of Existing and Committed Transmission-Connected Generation (Continued)

| Area                         | Generation Station | Unit ID | Connected At |        | Fuel Type | Maximum Export Capacity (MW) |            |            |            |            |             |             |             |             |      |
|------------------------------|--------------------|---------|--------------|--------|-----------|------------------------------|------------|------------|------------|------------|-------------|-------------|-------------|-------------|------|
|                              |                    |         |              |        |           | 2015                         | 2016       | 2017       | 2018       | 2019       | 2020        | 2021        | 2022        | 2023        | 2024 |
| North-West                   | Meentycat          | -       | Meentycat    | 110 kV | Wind      | 85                           | 85         | 85         | 85         | 85         | 85          | 85          | 85          | 85          | 85   |
|                              | Mulreavy           | -       | Mulreavy     | 110 kV | Wind      | -                            | 82         | 82         | 82         | 82         | 82          | 82          | 82          | 82          | 82   |
|                              | Mulreavy Ext.      | -       | Mulreavy     | 110 kV | Wind      | -                            | 13         | 13         | 13         | 13         | 13          | 13          | 13          | 13          | 13   |
|                              | Oweninney (1)      | -       | Bellacorick  | 400 kV | Wind      | -                            | 89         | 89         | 89         | 89         | 89          | 89          | 89          | 89          | 89   |
|                              | Oweninney (2)      | -       | Bellacorick  | 400 kV | Wind      | -                            | 83         | 83         | 83         | 83         | 83          | 83          | 83          | 83          | 83   |
|                              | Oweninney (5)      | -       | Bellacorick  | 400 kV | Wind      | -                            | -          | -          | -          | -          | 199         | 199         | 199         | 199         | 199  |
|                              | Seecon             | -       | Ugool        | 110 kV | Wind      | -                            | 105        | 105        | 105        | 105        | 105         | 105         | 105         | 105         | 105  |
|                              | Sliabh Bawn        | -       | Sliabh Bawn  | 110 kV | Wind      | -                            | 58         | 58         | 58         | 58         | 58          | 58          | 58          | 58          | 58   |
|                              | Uggool             | -       | Ugool        | 110 kV | Wind      | -                            | 64         | 64         | 64         | 64         | 64          | 64          | 64          | 64          | 64   |
| <b>North-West Area Total</b> |                    |         |              |        |           | <b>343</b>                   | <b>837</b> | <b>942</b> | <b>942</b> | <b>942</b> | <b>1152</b> | <b>1152</b> | <b>1152</b> | <b>1152</b> |      |

| Area                         | Generation Station | Unit ID | Connected At   |        | Fuel Type | Maximum Export Capacity (MW) |            |            |            |            |            |            |            |            |      |
|------------------------------|--------------------|---------|----------------|--------|-----------|------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------|
|                              |                    |         |                |        |           | 2015                         | 2016       | 2017       | 2018       | 2019       | 2020       | 2021       | 2022       | 2023       | 2024 |
| South-East                   | Ballywater         | -       | Ballywater     | 110 kV | Wind      | 42                           | 42         | 42         | 42         | 42         | 42         | 42         | 42         | 42         | 42   |
|                              | Castledockrill     | -       | Castledockrill | 110 kV | Wind      | 41                           | 41         | 41         | 41         | 41         | 41         | 41         | 41         | 41         | 41   |
|                              | Great Island       | GI4     | Great Island   | 220 kV | Gas       | 431                          | 431        | 431        | 431        | 431        | 431        | 431        | 431        | 431        | 431  |
|                              | Nore Power         | NO1     | Nore           | 110 kV | Gas/DO    | -                            | -          | -          | -          | -          | 98         | 98         | 98         | 98         | 98   |
| <b>South-East Area Total</b> |                    |         |                |        |           | <b>514</b>                   | <b>514</b> | <b>514</b> | <b>514</b> | <b>514</b> | <b>612</b> | <b>612</b> | <b>612</b> | <b>612</b> |      |

Table D-1 Maximum Export Capacities of Existing and Committed Transmission-Connected Generation (Continued)

| Area          | Generation Station  | Unit ID       | Connected At |        | Fuel Type | Maximum Export Capacity (MW) |      |      |      |      |      |      |      |      |      |
|---------------|---------------------|---------------|--------------|--------|-----------|------------------------------|------|------|------|------|------|------|------|------|------|
|               |                     |               |              |        |           | 2015                         | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 |
| South-West    | Aghada              | AD1           | Aghada       | 220 kV | Gas       | 258                          | 258  | 258  | 258  | 258  | 258  | 258  | 258  | 258  | 258  |
|               | Aghada              | AT1           | Aghada       | 220 kV | Gas/DO    | 90                           | 90   | 90   | 90   | 90   | 90   | 90   | 90   | 90   | 90   |
|               | Aghada              | AT2           | Aghada       | 220 kV | Gas/DO    | 90                           | 90   | 90   | 90   | 90   | 90   | 90   | 90   | 90   | 90   |
|               | Aghada              | AT4           | Aghada       | 220 kV | Gas/DO    | 90                           | 90   | 90   | 90   | 90   | 90   | 90   | 90   | 90   | 90   |
|               | Aghada CCGT         | AD2           | Longpoint    | 220 kV | Gas       | 431                          | 431  | 431  | 431  | 431  | 431  | 431  | 431  | 431  | 431  |
|               | Athea               | -             | Athea        | 110 kV | Wind      | 53                           | 53   | 53   | 53   | 53   | 99   | 99   | 99   | 99   | 99   |
|               | Barnadivane         | -             | Barnadivane  | 110 kV | Wind      | -                            | 60   | 60   | 60   | 60   | 60   | 60   | 60   | 60   | 60   |
|               | Boggeragh           | -             | Boggeragh    | 110 kV | Wind      | 57                           | 57   | 57   | 57   | 57   | 57   | 57   | 57   | 57   | 57   |
|               | Boggeragh (2)       | -             | Boggeragh    | 110 kV | Wind      | 48                           | 48   | 48   | 48   | 48   | 48   | 48   | 48   | 48   | 48   |
|               | Clahane             | -             | Clahane      | 110 kV | Wind      | 38                           | 38   | 38   | 38   | 38   | 38   | 38   | 38   | 38   | 38   |
|               | Clahane (2)         | -             | Clahane      | 110 kV | Wind      | 14                           | 14   | 14   | 14   | 14   | 14   | 14   | 14   | 14   | 14   |
|               | Cloghboola          | -             | Cloghboola   | 110 kV | Wind      | 46                           | 46   | 46   | 46   | 46   | 46   | 46   | 46   | 46   | 46   |
|               | Cloghboola (2) ext  | -             | Cloghboola   | 110 kV | Wind      | -                            | -    | -    | -    | -    | 10   | 10   | 10   | 10   | 10   |
|               | Coomacheo           | -             | Garrow       | 110 kV | Wind      | 41                           | 41   | 41   | 41   | 41   | 41   | 41   | 41   | 41   | 41   |
|               | Coomacheo Extension | -             | Garrow       | 110 kV | Wind      | 18                           | 18   | 18   | 18   | 18   | 18   | 18   | 18   | 18   | 18   |
| Coomagearlahy | -                   | Coomagearlahy | 110 kV       | Wind   | 43        | 43                           | 43   | 43   | 43   | 43   | 43   | 43   | 43   | 43   |      |

Table D-1 Maximum Export Capacities of Existing and Committed Transmission-Connected Generation (Continued)

| Area                         | Generation Station      | Unit ID   | Connected At  |        | Fuel Type | Maximum Export Capacity (MW) |             |             |             |             |             |             |             |             |             |
|------------------------------|-------------------------|-----------|---------------|--------|-----------|------------------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
|                              |                         |           |               |        |           | 2015                         | 2016        | 2017        | 2018        | 2019        | 2020        | 2021        | 2022        | 2023        | 2024        |
| South-West                   | Coomagearlahy Extension | -         | Coomagearlahy | 110 kV | Wind      | 39                           | 39          | 39          | 39          | 39          | 39          | 39          | 39          | 39          | 39          |
|                              | Cordal                  | -         | Cordal        | 110kV  | Wind      | 84                           | 84          | 84          | 84          | 84          | 101         | 101         | 101         | 101         | 101         |
|                              | Dromada                 | -         | Dromada       | 110 kV | Wind      | 29                           | 29          | 29          | 29          | 29          | 29          | 29          | 29          | 29          | 29          |
|                              | Dromada (1a)            | -         | Dromada       | 110 kV | Wind      | -                            | -           | -           | -           | -           | 18          | 18          | 18          | 18          | 18          |
|                              | Glanlee                 | -         | Glanlee       | 110 kV | Wind      | 30                           | 30          | 30          | 30          | 30          | 30          | 30          | 30          | 30          | 30          |
|                              | Glanlee (2)             | -         | Glanlee       | 110 kV | Wind      | -                            | -           | -           | -           | -           | 6           | 6           | 6           | 6           | 6           |
|                              | Kilgarvan (1)           | -         | Coomataggart  | 110kV  | Wind      | -                            | -           | -           | -           | -           | 62          | 62          | 62          | 62          | 62          |
|                              | Lee Hydro               | LE1       | Inniscarra    | 110 kV | Hydro     | 15                           | 15          | 15          | 15          | 15          | 15          | 15          | 15          | 15          | 15          |
|                              | Lee Hydro               | LE2       | Inniscarra    | 110 kV | Hydro     | 4                            | 4           | 4           | 4           | 4           | 4           | 4           | 4           | 4           | 4           |
|                              | Lee Hydro               | LE3       | Carrigadrohid | 110 kV | Hydro     | 8                            | 8           | 8           | 8           | 8           | 8           | 8           | 8           | 8           | 8           |
|                              | Marina                  | MRT       | Marina        | 110 kV | Gas/DO    | 85                           | 85          | 85          | 85          | 85          | 85          | 85          | 85          | 85          | 85          |
|                              | Whitegen CCGT           | WG        | Glanagow      | 220 kV | Gas/DO    | 445                          | 445         | 445         | 445         | 445         | 445         | 445         | 445         | 445         | 445         |
| Woodhouse                    | -                       | Woodhouse | 110 kV        | Wind   | 23        | 23                           | 23          | 23          | 23          | 23          | 23          | 23          | 23          | 23          |             |
| <b>South-West Area Total</b> |                         |           |               |        |           | <b>2079</b>                  | <b>2139</b> | <b>2139</b> | <b>2139</b> | <b>2139</b> | <b>2298</b> | <b>2298</b> | <b>2298</b> | <b>2298</b> | <b>2298</b> |



Table D-2 Existing and Committed Distribution-Connected Wind Farm Capacity

| Area                     | 110 kV Station | Wind Farm Capacity (MW) |            |            |            |            |            |            |            |            |            |
|--------------------------|----------------|-------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
|                          |                | 2015                    | 2016       | 2017       | 2018       | 2019       | 2020       | 2021       | 2022       | 2023       | 2024       |
| Dublin                   | Glasmore       | 0.8                     | 0.8        | 0.8        | 0.8        | 0.8        | 0.8        | 0.8        | 0.8        | 0.8        | 0.8        |
|                          | Griffinrath    | 0                       | 0          | 0          | 0          | 0          | 0          | 0          | 0          | 0          | 0          |
| <b>Dublin Area Total</b> |                | <b>0.8</b>              | <b>0.8</b> | <b>0.8</b> | <b>0.8</b> | <b>0.8</b> | <b>0.8</b> | <b>0.8</b> | <b>0.8</b> | <b>0.8</b> | <b>0.8</b> |

| Area                       | 110 kV Station | Wind Farm Capacity (MW) |              |              |              |              |              |              |              |              |              |
|----------------------------|----------------|-------------------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
|                            |                | 2015                    | 2016         | 2017         | 2018         | 2019         | 2020         | 2021         | 2022         | 2023         | 2024         |
| Midlands                   | Barrymore      | 39.9                    | 39.9         | 39.9         | 39.9         | 39.9         | 39.9         | 39.9         | 39.9         | 39.9         | 39.9         |
|                            | Cauteen        | 78.4                    | 115.4        | 142.9        | 142.9        | 142.9        | 180.6        | 180.6        | 180.6        | 180.6        | 180.6        |
|                            | Dallow         | 6.8                     | 6.8          | 11.1         | 11.1         | 11.1         | 11.1         | 11.1         | 11.1         | 11.1         | 11.1         |
|                            | Doon           | -                       | 25           | 25           | 25           | 25           | 25           | 25           | 25           | 25           | 25           |
|                            | Dungarvan      | 4.6                     | 4.6          | 38.6         | 38.6         | 38.6         | 38.6         | 38.6         | 38.6         | 38.6         | 38.6         |
|                            | Ikerrin        | 35.9                    | 35.9         | 35.9         | 35.9         | 35.9         | 35.9         | 35.9         | 35.9         | 35.9         | 35.9         |
|                            | Lisheen        | 39.6                    | 39.6         | 39.6         | 39.6         | 39.6         | 39.6         | 39.6         | 39.6         | 39.6         | 39.6         |
|                            | Nenagh         | 14                      | 14           | 14           | 14           | 14           | 14           | 14           | 14           | 14           | 14           |
|                            | Portlaoise     | 9.2                     | 9.2          | 9.2          | 9.2          | 9.2          | 9.2          | 9.2          | 9.2          | 9.2          | 9.2          |
|                            | Thurles        | 11.5                    | 30.1         | 30.1         | 30.1         | 30.1         | 41.8         | 41.8         | 41.8         | 41.8         | 41.8         |
|                            | Tipperary      | 1.6                     | 1.6          | 1.6          | 1.6          | 1.6          | 1.6          | 1.6          | 1.6          | 1.6          | 1.6          |
| <b>Midlands Area Total</b> |                | <b>241.5</b>            | <b>322.1</b> | <b>387.9</b> | <b>387.9</b> | <b>387.9</b> | <b>437.3</b> | <b>437.3</b> | <b>437.3</b> | <b>437.3</b> | <b>437.3</b> |

| Area                        | 110 kV Station | Wind Farm Capacity (MW) |           |            |            |            |            |            |            |            |            |
|-----------------------------|----------------|-------------------------|-----------|------------|------------|------------|------------|------------|------------|------------|------------|
|                             |                | 2015                    | 2016      | 2017       | 2018       | 2019       | 2020       | 2021       | 2022       | 2023       | 2024       |
| Mid-West                    | Ardnacrusha    | 8                       | 8         | 8          | 8          | 8          | 8          | 8          | 8          | 8          | 8          |
|                             | Booltiagh      | -                       | -         | 103        | 103        | 103        | 103        | 103        | 103        | 103        | 103        |
|                             | Tullabrack     | 17.2                    | 31        | 31         | 31         | 31         | 31         | 31         | 31         | 31         | 31         |
| <b>Mid- West Area Total</b> |                | <b>25.2</b>             | <b>39</b> | <b>142</b> | <b>142</b> | <b>142</b> | <b>142</b> | <b>142</b> | <b>142</b> | <b>142</b> | <b>142</b> |

Table D-2 Existing and Committed Distribution-Connected Wind Farm Capacity (Continued)

| Area                  | 110 kV Station | Wind Farm Capacity (MW) |      |      |       |       |       |       |       |       |       |
|-----------------------|----------------|-------------------------|------|------|-------|-------|-------|-------|-------|-------|-------|
|                       |                | 2015                    | 2016 | 2017 | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| North-East            | Drybridge      | 6.5                     | 6.5  | 6.5  | 6.5   | 6.5   | 7     | 7     | 7     | 7     | 7     |
|                       | Dundalk        | 0.5                     | 0.5  | 0.5  | 0.5   | 0.5   | 15.5  | 15.5  | 15.5  | 15.5  | 15.5  |
|                       | Lisdrum        | -                       | -    | 33.1 | 33.1  | 33.1  | 49.2  | 49.2  | 49.2  | 49.2  | 49.2  |
|                       | Meath Hill     | 22.5                    | 24.5 | 50.7 | 68.7  | 68.7  | 68.7  | 68.7  | 68.7  | 68.7  | 68.7  |
|                       | Navan          | -                       | -    | -    | -     | -     | 5     | 5     | 5     | 5     | 5     |
|                       | Shankill       | 3                       | 3    | 3    | 3     | 3     | 3     | 3     | 3     | 3     | 3     |
| North-East Area Total |                | 32.5                    | 34.5 | 93.8 | 111.8 | 111.8 | 148.4 | 148.4 | 148.4 | 148.4 | 148.4 |

| Area       | 110 kV Station     | Wind Farm Capacity (MW) |       |       |       |       |       |       |       |       |       |
|------------|--------------------|-------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|            |                    | 2015                    | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| North-West | Ardnagappary       | 5                       | 13    | 13    | 13    | 13    | 13    | 13    | 13    | 13    | 13    |
|            | Arigna             | 15.6                    | 15.6  | 15.6  | 15.6  | 15.6  | 49.6  | 49.6  | 49.6  | 49.6  | 49.6  |
|            | Bellacorick        | 6.5                     | 25.8  | 25.8  | 25.8  | 35    | 35    | 35    | 35    | 35    | 35    |
|            | Binbane            | 29.3                    | 40.2  | 76.4  | 76.4  | 76.4  | 76.4  | 76.4  | 76.4  | 76.4  | 76.4  |
|            | Carrick on Shannon | -                       | 4.25  | 4.25  | 4.25  | 4.25  | 4.25  | 4.25  | 4.25  | 4.25  | 4.25  |
|            | Castlebar          | 36.2                    | 36.2  | 36.2  | 36.2  | 36.2  | 43    | 43    | 43    | 43    | 43    |
|            | Cathleen Falls     | 29.4                    | 29.4  | 29.4  | 29.4  | 29.4  | 29.4  | 29.4  | 29.4  | 29.4  | 29.4  |
|            | Cloon              | 4.3                     | 4.3   | 4.3   | 4.3   | 4.3   | 4.3   | 4.3   | 4.3   | 4.3   | 4.3   |
|            | Corderry           | 39.5                    | 39.5  | 39.5  | 39.5  | 39.5  | 53    | 53    | 53    | 53    | 53    |
|            | Dalton             | 2.4                     | 43.2  | 43.2  | 43.2  | 43.2  | 43.2  | 43.2  | 43.2  | 43.2  | 43.2  |
|            | Doolick            | -                       | 100.8 | 100.8 | 100.8 | 100.8 | 100.8 | 100.8 | 100.8 | 100.8 | 100.8 |
|            | Glenree            | 36.8                    | 36.8  | 77.3  | 77.3  | 77.3  | 77.3  | 77.3  | 77.3  | 77.3  | 77.3  |
|            | Gortawee           | 3                       | 3     | 3     | 3     | 3     | 3     | 3     | 3     | 3     | 3     |
|            | Knockranny         | -                       | -     | -     | -     | -     | 24    | 24    | 24    | 24    | 24    |
| Lanesboro  | 4.6                | 4.6                     | 4.6   | 4.6   | 4.6   | 4.6   | 4.6   | 4.6   | 4.6   | 4.6   |       |

Table D-2 Existing and Committed Distribution-Connected Wind Farm Capacity (Continued)

| Area                         | 110 kV Station | Wind Farm Capacity (MW) |              |              |              |              |              |              |              |              |              |
|------------------------------|----------------|-------------------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
|                              |                | 2015                    | 2016         | 2017         | 2018         | 2019         | 2020         | 2021         | 2022         | 2023         | 2024         |
| North-West                   | Letterkenny    | 40.9                    | 60.9         | 86.1         | 86.1         | 86.1         | 88.2         | 88.2         | 88.2         | 88.2         | 88.2         |
|                              | Moy            | 6                       | 6            | 6            | 6            | 6            | 6            | 6            | 6            | 6            | 6            |
|                              | Mulreavy       | -                       | -            | 33.1         | 33.1         | 33.1         | 33.1         | 33.1         | 33.1         | 33.1         | 33.1         |
|                              | Salthill       | 46.1                    | 46.1         | 46.1         | 46.1         | 46.1         | 46.1         | 46.1         | 46.1         | 46.1         | 46.1         |
|                              | Screeb         | -                       | 3            | 3            | 3            | 3            | 3            | 3            | 3            | 3            | 3            |
|                              | Sligo          | 13.7                    | 13.7         | 13.7         | 13.7         | 13.7         | 13.7         | 13.7         | 13.7         | 13.7         | 13.7         |
|                              | Somerset       | 7.7                     | 7.7          | 7.7          | 7.7          | 7.7          | 19.5         | 19.5         | 19.5         | 19.5         | 19.5         |
|                              | Sorne Hill     | 54.7                    | 54.7         | 54.7         | 54.7         | 54.7         | 61.3         | 61.3         | 61.3         | 61.3         | 61.3         |
|                              | Tawnaghmore    | -                       | 30           | 30           | 30           | 30           | 30           | 30           | 30           | 30           | 30           |
|                              | Tonroe         | 10                      | 10           | 10           | 10           | 10           | 12.5         | 12.5         | 12.5         | 12.5         | 12.5         |
| Trillick                     | 46.8           | 46.8                    | 46.8         | 46.8         | 46.8         | 46.8         | 46.8         | 46.8         | 46.8         | 46.8         |              |
| <b>North-East Area Total</b> |                | <b>438.5</b>            | <b>675.6</b> | <b>810.6</b> | <b>810.6</b> | <b>819.8</b> | <b>921.1</b> | <b>921.1</b> | <b>921.1</b> | <b>921.1</b> | <b>921.1</b> |

| Area                         | 110 kV Station | Wind Farm Capacity (MW) |              |              |              |              |              |              |              |              |              |
|------------------------------|----------------|-------------------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
|                              |                | 2015                    | 2016         | 2017         | 2018         | 2019         | 2020         | 2021         | 2022         | 2023         | 2024         |
| South-East                   | Arklow         | 49.2                    | 85.7         | 85.7         | 85.7         | 85.7         | 85.7         | 85.7         | 85.7         | 85.7         | 85.7         |
|                              | Ballydine      | -                       | 24           | 24           | 24           | 24           | 24           | 24           | 24           | 24           | 24           |
|                              | Butlerstown    | 1.7                     | 1.7          | 1.7          | 1.7          | 1.7          | 1.7          | 1.7          | 1.7          | 1.7          | 1.7          |
|                              | Carlow         | 34.4                    | 34.4         | 34.4         | 34.4         | 34.4         | 39.4         | 39.4         | 39.4         | 39.4         | 39.4         |
|                              | Crane          | 5                       | 5            | 5            | 5            | 5            | 7.5          | 7.5          | 7.5          | 7.5          | 7.5          |
|                              | Croy           | 61.5                    | 61.5         | 61.5         | 61.5         | 61.5         | 61.5         | 61.5         | 61.5         | 61.5         | 61.5         |
|                              | Waterford      | 18                      | 18           | 18           | 18           | 18           | 18           | 18           | 18           | 18           | 18           |
|                              | Wexford        | 38.9                    | 38.9         | 38.9         | 38.9         | 38.9         | 38.9         | 38.9         | 38.9         | 38.9         | 38.9         |
| <b>South-East Area Total</b> |                | <b>208.7</b>            | <b>269.2</b> | <b>269.2</b> | <b>269.2</b> | <b>269.2</b> | <b>276.7</b> | <b>276.7</b> | <b>276.7</b> | <b>276.7</b> | <b>276.7</b> |

Table D-2 Existing and Committed Distribution-Connected Wind Farm Capacity (Continued)

| Area                          | 110 kV Station | Wind Farm Capacity (MW) |              |              |              |              |               |               |               |               |       |
|-------------------------------|----------------|-------------------------|--------------|--------------|--------------|--------------|---------------|---------------|---------------|---------------|-------|
|                               |                | 2015                    | 2016         | 2017         | 2018         | 2019         | 2020          | 2021          | 2022          | 2023          | 2024  |
| South-West                    | Athea          | -                       | 4            | 4            | 4            | 4            | 4             | 4             | 4             | 4             | 4     |
|                               | Athea-2        | -                       | -            | 77.6         | 77.6         | 77.6         | 77.6          | 77.6          | 77.6          | 77.6          | 77.6  |
|                               | Aughinish      | -                       | -            | 20           | 20           | 20           | 20            | 20            | 20            | 20            | 20    |
|                               | Ballylickey    | 48                      | 48           | 48           | 48           | 48           | 50.3          | 50.3          | 50.3          | 50.3          | 50.3  |
|                               | Bandon         | 4.9                     | 4.9          | 10.7         | 10.7         | 10.7         | 10.7          | 10.7          | 10.7          | 10.7          | 10.7  |
|                               | Boggeragh      | 20                      | 20           | 20           | 20           | 20           | 44            | 44            | 44            | 44            | 44    |
|                               | Charleville    | -                       | 45.3         | 46.7         | 46.7         | 46.7         | 46.7          | 46.7          | 46.7          | 46.7          | 46.7  |
|                               | Coomataggart   | -                       | -            | -            | -            | -            | 116.2         | 116.2         | 116.2         | 116.2         | 116.2 |
|                               | Cordal         | 65.45                   | 65.45        | 65.45        | 65.45        | 65.45        | 69.25         | 69.25         | 69.25         | 69.25         | 69.25 |
|                               | Cloghboola     | 22.6                    | 32.6         | 32.6         | 32.6         | 32.6         | 44.6          | 44.6          | 44.6          | 44.6          | 44.6  |
|                               | Dunmanway      | 24.8                    | 32.6         | 63.6         | 63.6         | 63.6         | 63.6          | 63.6          | 63.6          | 63.6          | 63.6  |
|                               | Garrow         | 15                      | 15           | 15           | 15           | 15           | 15            | 15            | 15            | 15            | 15    |
|                               | Glenlara       | 53                      | 53           | 53           | 53           | 53           | 59            | 59            | 59            | 59            | 59    |
|                               | Kilpaddoge     | -                       | 18           | 18           | 18           | 18           | 18            | 18            | 18            | 18            | 18    |
|                               | Knockacummer   | 105                     | 105          | 105          | 105          | 105          | 105           | 105           | 105           | 105           | 105   |
|                               | Knockearagh    | 13.9                    | 13.9         | 19.3         | 19.3         | 19.3         | 19.3          | 19.3          | 19.3          | 19.3          | 19.3  |
|                               | Macroom        | 34.1                    | 34.1         | 34.1         | 34.1         | 34.1         | 34.1          | 34.1          | 34.1          | 34.1          | 34.1  |
|                               | Midleton       | 1.6                     | 23.2         | 23.2         | 23.2         | 23.2         | 23.2          | 23.2          | 23.2          | 23.2          | 23.2  |
|                               | Oughtragh      | 9.2                     | 9.2          | 9.2          | 9.2          | 9.2          | 9.2           | 9.2           | 9.2           | 9.2           | 9.2   |
|                               | Rathkeale      | 30                      | 30           | 30           | 30           | 30           | 30            | 30            | 30            | 30            | 30    |
| Reamore                       | 57.4           | 96.2                    | 96.2         | 96.2         | 96.2         | 96.2         | 96.2          | 96.2          | 96.2          | 96.2          |       |
| Tralee                        | 45.9           | 45.9                    | 45.9         | 45.9         | 45.9         | 47.6         | 47.6          | 47.6          | 47.6          | 47.6          |       |
| Trien                         | 52.6           | 66.1                    | 66.1         | 66.1         | 66.1         | 66.1         | 66.1          | 66.1          | 66.1          | 66.1          |       |
| <b>South- West Area Total</b> |                | <b>603.5</b>            | <b>762.5</b> | <b>903.7</b> | <b>903.7</b> | <b>903.7</b> | <b>1069.7</b> | <b>1069.7</b> | <b>1069.7</b> | <b>1069.7</b> |       |

Table D-2 Existing and Committed Distribution-Connected Wind Farm Capacity (Continued)

| Area                | 110 kV Station    | Wind Farm Capacity (MW) |       |       |       |       |       |       |       |       |       |
|---------------------|-------------------|-------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|                     |                   | 2015                    | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| Northern<br>Ireland | Aghyoule          | 82.5                    | 82.5  | 82.5  | 82.5  | 82.5  | 82.5  | 82.5  | 82.5  | 82.5  | 82.5  |
|                     | Antrim            | 5                       | 5     | 5     | 5     | 5     | 6.7   | 6.7   | 6.7   | 6.7   | 6.7   |
|                     | Ballymena (Rural) | 5                       | 11    | 55.5  | 55.5  | 55.5  | 58    | 58    | 58    | 58    | 58    |
|                     | CAM               | -                       | -     | -     | -     | -     | 88.5  | 88.5  | 88.5  | 88.5  | 88.5  |
|                     | Carnmoney         | 13.8                    | 13.8  | 13.8  | 13.8  | 13.8  | 13.8  | 13.8  | 13.8  | 13.8  | 13.8  |
|                     | Coleraine         | 108                     | 108   | 108   | 108   | 108   | 108   | 108   | 108   | 108   | 108   |
|                     | Coolkeeragh       | 12                      | 12    | 12    | 12    | 12    | 12    | 12    | 12    | 12    | 12    |
|                     | Curraghmulkin     | -                       | -     | -     | -     | 103.6 | 103.6 | 103.6 | 103.6 | 103.6 | 103.6 |
|                     | Drumnakelly       | -                       | -     | -     | 2.6   | 2.6   | 2.6   | 2.6   | 2.6   | 2.6   | 2.6   |
|                     | Dungannon         | 17.5                    | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  |
|                     | Eden              | 2.5                     | 2.5   | 2.5   | 2.5   | 2.5   | 2.5   | 2.5   | 2.5   | 2.5   | 2.5   |
|                     | Enniskillen       | 16.9                    | 31.9  | 31.9  | 34.4  | 34.4  | 34.4  | 34.4  | 34.4  | 34.4  | 34.4  |
|                     | Garvagh           | -                       | -     | -     | -     | 50.1  | 50.1  | 50.1  | 50.1  | 50.1  | 50.1  |
|                     | Gort              | -                       | -     | 87.7  | 100.2 | 100.2 | 100.2 | 100.2 | 100.2 | 100.2 | 100.2 |
|                     | Kells             | -                       | -     | -     | -     | -     | 85.1  | 85.1  | 85.1  | 85.1  | 85.1  |
|                     | Killymallaght     | 20.7                    | 38.7  | 38.7  | 38.7  | 38.7  | 38.7  | 38.7  | 38.7  | 38.7  | 38.7  |
|                     | Larne             | 15                      | 15    | 15    | 15    | 15    | 15    | 15    | 15    | 15    | 15    |
|                     | Limavady          | 37.7                    | 37.7  | 37.7  | 37.7  | 37.7  | 37.7  | 37.7  | 37.7  | 37.7  | 37.7  |
|                     | Lisaghmore        | 17.5                    | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  | 17.5  |
|                     | Loguestown        | 12                      | 12    | 12    | 12    | 12    | 12    | 12    | 12    | 12    | 12    |
| Magherakeel         | 88.6              | 123.1                   | 123.1 | 123.1 | 123.1 | 123.1 | 123.1 | 123.1 | 123.1 | 123.1 |       |
| Newry               | -                 | 3.8                     | 3.8   | 15.3  | 15.3  | 15.3  | 15.3  | 15.3  | 15.3  | 15.3  |       |
| Newtwonstewart      | -                 | -                       | -     | -     | -     | 126.2 | 126.2 | 126.2 | 126.2 | 126.2 |       |
| Omagh               | 125.7             | 125.7                   | 125.7 | 95.7  | 95.7  | 95.7  | 95.7  | 95.7  | 95.7  | 95.7  |       |

Table D-2 Existing and Committed Distribution-Connected Wind Farm Capacity (Continued)

| Area                        | 110 kV Station | Wind Farm Capacity (MW) |       |       |      |        |        |        |        |        |        |        |
|-----------------------------|----------------|-------------------------|-------|-------|------|--------|--------|--------|--------|--------|--------|--------|
|                             |                | 2015                    | 2016  | 2017  | 2018 | 2019   | 2020   | 2021   | 2022   | 2023   | 2024   |        |
| Northern Ireland            | Rasharkin      | -                       | 54.8  | 54.8  | 54.8 | 54.8   | 54.8   | 54.8   | 54.8   | 54.8   | 54.8   | 54.8   |
|                             | Springtown     | -                       | -     | -     | -    | 45     | 45     | 45     | 45     | 45     | 45     | 45     |
|                             | Strabane       | 27.4                    | 27.4  | 27.4  | 27.4 | 27.4   | 27.4   | 27.4   | 27.4   | 27.4   | 27.4   | 27.4   |
|                             | Tremoge        | -                       | 82.5  | 84.8  | 84.8 | 84.8   | 84.8   | 84.8   | 84.8   | 84.8   | 84.8   | 84.8   |
| Northern Ireland Area Total |                | 607.8                   | 822.4 | 956.9 | 956  | 1154.7 | 1458.7 | 1458.7 | 1458.7 | 1458.7 | 1458.7 | 1458.7 |

Table D-3 Existing and Committed Distribution-Connected Dispatchable Conventional Generation

| Area       | 110 kV Station | Conventional Capacity (MW) |       |       |       |       |       |       |       |       |       |       |
|------------|----------------|----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|            |                | 2014                       | 2015  | 2016  | 2017  | 2018  | 2019  | 2020  | 2021  | 2022  | 2023  | 2024  |
| Dublin     | Ringsend       | -                          | -     | 72    | 72    | 72    | 72    | 72    | 72    | 72    | 72    | 72    |
|            | Derryiron      | -                          | -     | -     | 14.6  | 14.6  | 14.6  | 14.6  | 14.6  | 14.6  | 14.6  | 14.6  |
| North-East | Drybridge      | 20.2                       | 20.2  | 20.2  | 20.2  | 20.2  | 20.2  | 20.2  | 20.2  | 20.2  | 20.2  | 20.2  |
|            | Navan          | -                          | -     | 13    | 13    | 13    | 13    | 13    | 13    | 13    | 13    | 13    |
| North-West | Bellacorick    | -                          | -     | 10    | 10    | 10    | 10    | 10    | 10    | 10    | 10    | 10    |
|            | Tawnaghmore    | 104                        | 104   | 153   | 153   | 153   | 153   | 153   | 153   | 153   | 153   | 153   |
|            | Tullabrack     | -                          | -     | -     | 6     | 6     | 6     | 6     | 6     | 6     | 6     | 6     |
| Midlands   | Thornsberry    | -                          | 10    | 10    | 10    | 10    | 10    | 10    | 10    | 10    | 10    | 10    |
|            | Blake          | 5                          | 5     | 5     | 5     | 5     | 5     | 5     | 5     | 5     | 5     | 5     |
| Total      |                | 129.2                      | 139.2 | 283.2 | 303.8 | 303.8 | 303.8 | 303.8 | 303.8 | 303.8 | 303.8 | 303.8 |

Table D-4 Existing and Committed Distribution-Connected Renewables in Northern Ireland (excluding wind)

| Area             | Generation Station | Unit ID | Connected At |      | Fuel Type | Renewable Capacity (MW) |      |      |      |      |      |      |      |      |      |
|------------------|--------------------|---------|--------------|------|-----------|-------------------------|------|------|------|------|------|------|------|------|------|
|                  |                    |         |              |      |           | 2015                    | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 |
| Northern Ireland | Maydown            | -       | Coolkearagh  | 33kV | biomass   | 17.6                    | 17.6 | 17.6 | 17.6 | 17.6 | 17.6 | 17.6 | 17.6 | 17.6 | 17.6 |
|                  | Lisburn PV         | -       | Lisburn      | 33kV | PV        | -                       | 9.95 | 9.95 | 9.95 | 9.95 | 9.95 | 9.95 | 9.95 | 9.95 | 9.95 |
|                  | Lough Road Solar   | -       | Lisburn      | 33kV | PV        | -                       | 15.2 | 15.2 | 15.2 | 15.2 | 15.2 | 15.2 | 15.2 | 15.2 | 15.2 |
|                  | Bombardier         | -       | Rosebank     | 33kV | biomass   | -                       | 17.6 | 17.6 | 17.6 | 17.6 | 17.6 | 17.6 | 17.6 | 17.6 | 17.6 |
|                  | Ban Road PV        | -       | Rasherkin    | 33kV | PV        | -                       | 19.9 | 19.9 | 19.9 | 19.9 | 19.9 | 19.9 | 19.9 | 19.9 | 19.9 |

## D.1 Generation Dispatch Details

Table D-5 through to Table D-7 lists generation dispatch profiles. These dispatch profiles are used for the purposes of the short circuit current level analyses and power flow diagrams. In the tables the SV column represents the dispatch at summer valley. SP denotes the summer peak dispatch and WP denotes the winter peak dispatch.

For the purpose of short circuit current level studies, wind farms were dispatched at 10% of their rated capacity for winter peak cases. Wind farms were not dispatched in summer valley cases. These dispatches are given in Table D-5 and Table D-6.

For the purpose of power flow diagram dispatches, wind farms were dispatched at 30% of their rated capacity for winter peak and summer peak cases. Wind farms were dispatched at 10% for summer valley cases. These dispatches are given in Table D-7.

The values shown are in exported terms. They are the net of each generation unit's own consumption. They indicate the power delivered to the transmission system.

In all instances, a dispatch of 0 MW indicates that the unit is not synchronised to the system. This means that the generator is effectively off. The only exception to this is the dispatch profiles used for the winter peak short circuit current level studies. For these instances, all generators not dispatched are modelled as synchronised to the system and dispatched at 0 MW.

It should be noted that station demand projections are developed from the system demand forecasts on a top-down basis. The projections use a forecast of transmission losses. The transmission loss figures calculated by the network models used in this TYTFS may differ from the forecast figures. Hence the dispatch totals may differ from the system demand forecasts in Table 2-1 in Chapter 2.

Table D-8 lists the existing and proposed generating plant contract details in Northern Ireland.



Table D-5 Dispatch Profiles – Ireland Short Circuit

| Area                     | Generation Station       | Unit ID    | 2015       |             | 2018       |             | 2021 GW    |             |
|--------------------------|--------------------------|------------|------------|-------------|------------|-------------|------------|-------------|
|                          |                          |            | SV         | WP          | SV         | WP          | SV         | WP          |
| Dublin                   | Dublin Bay Power         | DB1        | 345        | 365         | 236        | 345         | 276        | 325         |
|                          | EWIC                     | EW1        | 100        | 350         | 100        | 350         | 100        | 350         |
|                          | Huntstown                | HNC        | 0          | 294         | 0          | 236         | 0          | 216         |
|                          | Huntstown                | HN2        | 300        | 330         | 300        | 320         | 250        | 380         |
|                          | Liffey Hydro             | Ll1        | 0          | 10          | 0          | 2           | 0          | 3           |
|                          | Liffey Hydro             | Ll2        | 0          | 10          | 0          | 2           | 0          | 3           |
|                          | Liffey Hydro             | Ll4        | 0          | 4           | 0          | 2           | 0          | 3           |
|                          | North Wall               | NW5        | 0          | 0           | 0          | 0           | 0          | 0           |
|                          | Poolbeg                  | PBC        | 0          | 237         | 0          | 295         | 0          | 158         |
|                          | Turlough Hill            | TH 1,2,3,4 | -129       | 273         | -236       | 223         | -247       | 235         |
|                          | Elm Park Development (3) | -          | 0          | 1           | 0          | 0           | 0          | 0           |
|                          | Keelings CHP             | -          | 0          | 1           | 0          | 1           | 1          | 1           |
|                          | Kilbush Nurseries CHP    | -          | 0          | 1           | 0          | 1           | 1          | 1           |
|                          | Installed wind           | -          | 0          | 0           | 0          | 0           | 0          | 56          |
| <b>Dublin Area Total</b> |                          |            | <b>616</b> | <b>1876</b> | <b>400</b> | <b>1777</b> | <b>381</b> | <b>1731</b> |

Table D-5 Dispatch Profiles – Ireland Short Circuit (Continued)

| Area  | Generation Station            | Unit ID | 2015 |     | 2018 |     | 2021 GW |     |
|---|-------------------------------|---------|------|-----|------|-----|---------|-----|
|   |                               |         | SV   | WP  | SV   | WP  | SV      | WP  |
| South-West  | Aghada                        | AD1     | 0    | 96  | 0    | 58  | 0       | 0   |
|   | Aghada                        | AT1     | 0    | 0   | 0    | 0   | 0       | 0   |
|   | Aghada                        | AT2     | 0    | 0   | 0    | 0   | 0       | 0   |
|   | Aghada                        | AT4     | 0    | 0   | 0    | 0   | 0       | 0   |
|   | Aghada CCGT                   | ADC     | 0    | 322 | 225  | 293 | 225     | 332 |
|   | Lee Hydro                     | LE1     | 0    | 15  | 0    | 4   | 0       | 5   |
|   | Lee Hydro                     | LE2     | 0    | 4   | 0    | 2   | 0       | 4   |
|   | Lee Hydro                     | LE3     | 0    | 4   | 0    | 4   | 0       | 5   |
|   | Marina                        | MRT     | 0    | 0   | 0    | 0   | 0       | 0   |
|   | Tarbert                       | TB1     | 0    | 0   | 0    | 0   | 0       | 0   |
|   | Tarbert                       | TB2     | 0    | 0   | 0    | 0   | 0       | 0   |
|   | Pfizer Askeaton               | -       | 0    | 5   | 0    | 5   | 4       | 5   |
|   | Gortadroma Landfill Gas       | -       | 0    | 3   | 0    | 2   | 2       | 2   |
|   | Tarbert                       | TB3     | 0    | 0   | 0    | 0   | 0       | 0   |
|   | Tarbert                       | TB4     | 0    | 0   | 0    | 0   | 0       | 0   |
|   | Whitegate CCGT                | WG      | 297  | 357 | 238  | 361 | 198     | 356 |
|   | Adambridge Manufacturers Ltd  | -       | 0    | 3   | 0    | 3   | 2       | 3   |
|   | Carbery Milk Products CHP (1) | -       | 0    | 4   | 0    | 3   | 3       | 4   |
|   | FMC Gas Turbine Ext.          | -       | 0    | 2   | 0    | 1   | 1       | 0   |
| Shamrock Renewable Fuels formerly Farely Brothers | -                             | 0       | 0    | 0   | 5    | 6   | 7       |     |

Table D-5 Dispatch Profiles – Ireland Short Circuit (Continued)

| Area                         | Generation Station | Unit ID | 2015       |            | 2018       |            | 2021 GW    |            |
|------------------------------|--------------------|---------|------------|------------|------------|------------|------------|------------|
|                              |                    |         | SV         | WP         | SV         | WP         | SV         | WP         |
|                              | Installed Wind     | -       | 0          | 94         | 0          | 152        | 0          | 239        |
| <b>South-West Area Total</b> |                    |         | <b>297</b> | <b>909</b> | <b>463</b> | <b>893</b> | <b>441</b> | <b>962</b> |

| Area                       | Generation Station | Unit ID | 2015       |             | 2018       |             | 2021 GW    |             |
|----------------------------|--------------------|---------|------------|-------------|------------|-------------|------------|-------------|
|                            |                    |         | SV         | WP          | SV         | WP          | SV         | WP          |
| Mid-West                   | Ardnacrusha        | AA1     | 0          | 15          | 0          | 15          | 0          | 9           |
|                            | Ardnacrusha        | AA2     | 0          | 15          | 0          | 15          | 0          | 22          |
|                            | Ardnacrusha        | AA3     | 0          | 15          | 0          | 15          | 0          | 9           |
|                            | Ardnacrusha        | AA4     | 0          | 20          | 0          | 15          | 0          | 23          |
|                            | Aughinish          | SK3     | 50         | 70          | 60         | 70          | 50         | 70          |
|                            | Aughinish          | SK4     | 50         | 70          | 60         | 70          | 50         | 70          |
|                            | Moneypoint         | MP1     | 94         | 234         | 187        | 187         | 131        | 225         |
|                            | Moneypoint         | MP2     | 0          | 234         | 0          | 187         | 131        | 225         |
|                            | Moneypoint         | MP3     | 0          | 234         | 0          | 187         | 0          | 225         |
|                            | Tynagh             | TY      | 0          | 380         | 0          | 316         | 0          | 385         |
|                            | Installed Wind     | -       | 0          | 14          | 0          | 28          | 0          | 31          |
| <b>Mid-West Area Total</b> |                    |         | <b>194</b> | <b>1301</b> | <b>307</b> | <b>1105</b> | <b>362</b> | <b>1294</b> |

Table D-5 Dispatch Profiles – Ireland Short Circuit (Continued)

| Area                         | Generation Station       | Unit ID | 2015       |            | 2018       |            | 2021 GW    |            |
|------------------------------|--------------------------|---------|------------|------------|------------|------------|------------|------------|
|                              |                          |         | SV         | WP         | SV         | WP         | SV         | WP         |
| South-East                   | Cuilleen                 | -       | 0          | 0          | 0          | 0          | 0          | 0          |
|                              | Great Island             | GI4     | 295        | 345        | 236        | 354        | 236        | 344        |
|                              | Ballynagran LFG          | -       | 0          | 3          | 0          | 3          | 2          | 3          |
|                              | Nore Power               | NO1     | 0          | 0          | 0          | 0          | 0          | 0          |
|                              | Ballyshannon Farms (1)   | -       | 0          | 0          | 0          | 0          | 0          | 0          |
|                              | Glanbia Ballyraggett CHP | -       | 0          | 5          | 0          | 0          | 4          | 0          |
|                              | Installed Wind           | -       | 0          | 27         | 0          | 53         | 0          | 59         |
| <b>South-East Area Total</b> |                          |         | <b>295</b> | <b>380</b> | <b>236</b> | <b>410</b> | <b>242</b> | <b>406</b> |

| Area     | Generation Station              | Unit ID | 2015 |     | 2018 |     | 2021 GW |     |
|----------|---------------------------------|---------|------|-----|------|-----|---------|-----|
|          |                                 |         | SV   | WP  | SV   | WP  | SV      | WP  |
| Midlands | Edenderry Power                 | ED1     | 82   | 91  | 64   | 91  | 91      | 101 |
|          | Edenderry PCP                   | ED3     | 0    | 0   | 0    | 0   | 0       | 0   |
|          | Edenderry PCP                   | ED5     | 0    | 0   | 0    | 0   | 0       | 0   |
|          | Lough Ree Power                 | LR4     | 73   | 82  | 64   | 73  | 0       | 0   |
|          | Rhode PCP                       | RP1     | 0    | 0   | 0    | 0   | 0       | 0   |
|          | Rhode PCP                       | RP2     | 0    | 0   | 0    | 0   | 0       | 0   |
|          | Rhode Biomass Plant             | RP2     | 0    | 0   | 0    | 12  | 10      | 10  |
|          | West Offaly Power               | WO4     | 92   | 128 | 55   | 119 | 0       | 0   |
|          | Dublin Waste to Energy Facility | -       | 0    | 1   | 0    | 0   | 35      | 44  |
|          | Dairygold Mitchelstown          | -       | 0    | 3   | 0    | 3   | 3       | 3   |
|          | Derryclure CHP                  | -       | 0    | 8   | 0    | 7   | 5       | 8   |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table D-5 Dispatch Profiles – Ireland Short Circuit (Continued)

| Area                       | Generation Station  | Unit ID | 2015       |            | 2018       |            | 2021 GW    |            |
|----------------------------|---------------------|---------|------------|------------|------------|------------|------------|------------|
|                            |                     |         | SV         | WP         | SV         | WP         | SV         | WP         |
| Midlands                   | Arthurstown LFG (1) | -       | 0          | 0          | 0          | 3          | 3          | 3          |
|                            | Gorteen Lower       | -       | 0          | 1          | 0          | 1          | 1          | 0          |
|                            | Installed Wind      | -       | 0          | 43         | 0          | 79         | 0          | 46         |
| <b>Midlands Area Total</b> |                     |         | <b>247</b> | <b>357</b> | <b>183</b> | <b>388</b> | <b>148</b> | <b>215</b> |

| Area                         | Generation Station                   | Unit ID | 2015      |            | 2018      |            | 2021 GW   |            |
|------------------------------|--------------------------------------|---------|-----------|------------|-----------|------------|-----------|------------|
|                              |                                      |         | SV        | WP         | SV        | WP         | SV        | WP         |
| North-West                   | Erne                                 | ER3     | 0         | 15         | 0         | 15         | 0         | 15         |
|                              | Erne                                 | ER4     | 0         | 15         | 0         | 15         | 0         | 15         |
|                              | Erne                                 | ER1     | 0         | 5          | 0         | 5          | 0         | 10         |
|                              | Erne                                 | ER2     | 0         | 5          | 0         | 5          | 0         | 10         |
|                              | Lough Ree Power                      | LR4     | 73        | 82         | 64        | 73         | 0         | 0          |
|                              | Tawnaghmore Peaking Plant            | -       | 0         | 0          | 0         | 0          | 0         | 0          |
|                              | Tawnaghmore Peaking Plant            | -       | 0         | 0          | 0         | 0          | 0         | 0          |
|                              | AMETS Belmullet (1)                  | -       | 0         | 1          | 0         | 5          | 5         | 5          |
|                              | Clady Hydro                          | -       | 0         | 4          | 0         | 3          | 0         | 0          |
|                              | Connaught Regional Residual Landfill | -       | 0         | 1          | 0         | 0          | 0         | 0          |
|                              | Mayo Renewable Power Biomass CHP     | -       | 0         | 25         | 20        | 45         | 30        | 40         |
|                              | Installed Wind                       | -       | 0         | 86         | 0         | 160        | 0         | 216        |
| <b>North-West Area Total</b> |                                      |         | <b>73</b> | <b>239</b> | <b>84</b> | <b>326</b> | <b>35</b> | <b>311</b> |

Table D-5 Dispatch Profiles – Ireland Short Circuit (Continued)

| Area                         | Generation Station                | Unit ID | 2015     |           | 2018     |           | 2021 GW   |           |
|------------------------------|-----------------------------------|---------|----------|-----------|----------|-----------|-----------|-----------|
|                              |                                   |         | SV       | WP        | SV       | WP        | SV        | WP        |
| North-East                   | Bailie Foods CHP (1)              | -       | 0        | 1         | 0        | 1         | 1         | 1         |
|                              | Corranure LFG                     | -       | 0        | 1         | 0        | 0         | 0         | 1         |
|                              | Knockharley Landfill              | -       | 0        | 4         | 0        | 4         | 3         | 3         |
|                              | Meath Waste- Energy               | -       | 0        | 13        | 9        | 13        | 13        | 14        |
|                              | Rathdrinagh Biogas                | -       | 0        | 1         | 0        | 1         | 2         | 2         |
|                              | Whiteriver Landfill Gas to Energy | -       | 0        | 1         | 0        | 1         | 1         | 1         |
|                              | Installed Wind                    | -       | 0        | 10        | 0        | 25        | 0         | 54        |
| <b>North-East Area Total</b> |                                   |         | <b>0</b> | <b>31</b> | <b>9</b> | <b>45</b> | <b>20</b> | <b>76</b> |

Table D-6 Dispatch Profiles – Northern Ireland Short Circuit Current Level

| Area                               | Generation Station  | Unit ID | 2015       |             | 2018       |             | 2021       |             |
|------------------------------------|---------------------|---------|------------|-------------|------------|-------------|------------|-------------|
|                                    |                     |         | SV         | WP          | SV         | WP          | SV         | WP          |
| Northern Ireland                   | Ballylumford CCGT10 | B10     | 68         | 93          | 68         | 97          | 68         | 78          |
|                                    | Ballylumford CCGT20 | -       | 0          | 151         | 0          | 157         | 0          | 146         |
|                                    | Ballylumford CCGT21 | B31     | 0          | 151         | 0          | 146         | 0          | 146         |
|                                    | Ballylumford CCGT22 | B32     | 0          | 165         | 0          | 136         | 0          | 161         |
|                                    | Ballylumford GT7    | BGT1    | 0          | 0           | 0          | 0           | 0          | 0           |
|                                    | Ballylumford GT8    | BGT2    | 0          | 0           | 0          | 0           | 0          | 0           |
|                                    | Ballylumford ST4    | B4      | 0          | 0           | 0          | 0           | 0          | 0           |
|                                    | Ballylumford ST5    | B5      | 0          | 0           | 0          | 0           | 0          | 0           |
|                                    | Ballylumford ST6    | B6      | 0          | 0           | 0          | 0           | 0          | 0           |
|                                    | CAES                | -       | 0          | 1           | 0          | 0           | 0          | 0           |
|                                    | Coolkeeragh CCGT    | C30     | 253        | 399         | 253        | 399         | 253        | 350         |
|                                    | Coolkeeragh CGT8    | CGT8    | 0          | 0           | 0          | 0           | 0          | 0           |
|                                    | ROSE_BIO            | -       | 0          | 2           | 10         | 15          | 10         | 15          |
|                                    | Bio Maydown         | -       | 10         | 15          | 10         | 15          | 10         | 15          |
|                                    | Kilroot GT1         | KGT1    | 0          | 0           | 0          | 0           | 0          | 0           |
|                                    | Kilroot GT2         | KGT2    | 0          | 0           | 0          | 0           | 0          | 0           |
|                                    | Kilroot GT3         | KGT3    | 0          | 0           | 0          | 0           | 0          | 0           |
|                                    | Kilroot GT4         | KGT4    | 0          | 0           | 0          | 0           | 0          | 0           |
|                                    | Kilroot ST1         | K1      | 102        | 166         | 102        | 175         | 138        | 175         |
|                                    | Kilroot ST2         | K2      | 0          | 166         | 0          | 175         | 0          | 175         |
| Moyle (Import positive)            | -                   | 100     | 150        | 100         | 150        | 100         | 150        |             |
| Installed Wind                     | -                   | 0       | 65         | 0           | 142        | 0           | 212        |             |
| <b>Northern Ireland Area Total</b> |                     |         | <b>533</b> | <b>1524</b> | <b>543</b> | <b>1607</b> | <b>579</b> | <b>1623</b> |

Table D-7 Dispatch Profiles – Power Flow Diagrams

| Area                     | Generation Station | Unit ID   | 2015       |             |             | 2024       |            |             |
|--------------------------|--------------------|-----------|------------|-------------|-------------|------------|------------|-------------|
|                          |                    |           | SNV        | SP          | WP          | SNV        | SP         | WP          |
| Dublin                   | Dublin Bay Power   | DB1       | 250        | 400         | 400         | 170        | 400        | 400         |
|                          | EWIC               | -         | 100        | 350         | 350         | 100        | 350        | 350         |
|                          | Huntstown          | HNC       | 0          | 0           | 150         | 0          | 0          | 0           |
|                          | Huntstown          | HN2       | 0          | 300         | 400         | 0          | 0          | 350         |
|                          | Liffey Hydro       | LI1       | 2          | 5           | 5           | 2          | 5          | 5           |
|                          | Liffey Hydro       | LI2       | 2          | 5           | 5           | 2          | 5          | 5           |
|                          | Liffey Hydro       | LI4       | 0          | 1           | 1           | 0          | 1          | 1           |
|                          | North Wall         | NW4       | 0          | 0           | 0           | 0          | 0          | 0           |
|                          | North Wall         | NW5       | 0          | 0           | 0           | 0          | 0          | 0           |
|                          | Poolbeg            | PBC       | 0          | 0           | 0           | 0          | 0          | 0           |
|                          | Turlough Hill      | TH1,2,3,4 | -126       | 91          | 160         | -134       | 80         | 113         |
|                          | Installed Wind     | -         | 5          | 15          | 15          | 11         | 33         | 33          |
| <b>Dublin Area Total</b> |                    |           | <b>233</b> | <b>1167</b> | <b>1486</b> | <b>151</b> | <b>874</b> | <b>1257</b> |

| Area                         | Generation Station | Unit ID | 2015       |            |             | 2024       |            |             |
|------------------------------|--------------------|---------|------------|------------|-------------|------------|------------|-------------|
|                              |                    |         | SNV        | SP         | WP          | SNV        | SP         | WP          |
| South-West                   | Aghada             | AD1     | 0          | 0          | 0           | 0          | 0          | 0           |
|                              | Aghada             | AT1     | 0          | 0          | 0           | 0          | 0          | 0           |
|                              | Aghada             | AT2     | 0          | 0          | 0           | 0          | 0          | 0           |
|                              | Aghada             | AT4     | 0          | 0          | 0           | 0          | 0          | 0           |
|                              | Aghada CCGT        | ADC     | 0          | 280        | 400         | 0          | 0          | 220         |
|                              | Lee Hydro          | LE1     | 2          | 5          | 5           | 2          | 5          | 5           |
|                              | Lee Hydro          | LE2     | 0          | 1          | 1           | 0          | 1          | 1           |
|                              | Lee Hydro          | LE3     | 1          | 2          | 2           | 1          | 2          | 2           |
|                              | Marina             | MRT     | 0          | 0          | 0           | 0          | 0          | 0           |
|                              | Whitegate CCGT     | WG      | 120        | 280        | 410         | 110        | 120        | 220         |
|                              | Installed Wind     | -       | 97         | 331        | 331         | 206        | 619        | 619         |
| <b>South-West Area Total</b> |                    |         | <b>220</b> | <b>899</b> | <b>1149</b> | <b>319</b> | <b>747</b> | <b>1067</b> |

| Area                       | Generation Station | Unit ID   | 2015       |            |             | 2024       |            |            |
|----------------------------|--------------------|-----------|------------|------------|-------------|------------|------------|------------|
|                            |                    |           | SNV        | SP         | WP          | SNV        | SP         | WP         |
| Mid-West                   | Ardnacrusha        | AA1,2,3,4 | 8          | 25         | 25          | 8          | 25         | 25         |
|                            | Aughinish          | SK3       | 80         | 80         | 80          | 80         | 80         | 80         |
|                            | Aughinish          | SK4       | 80         | 80         | 80          | 80         | 80         | 80         |
|                            | Moneypoint         | MP1       | 100        | 190        | 200         | 0          | 100        | 180        |
|                            | Moneypoint         | MP2       | 100        | 190        | 300         | 170        | 100        | 180        |
|                            | Moneypoint         | MP3       | 0          | 190        | 200         | 0          | 100        | 180        |
|                            | Tarbert            | TB1       | 0          | 0          | 0           | 0          | 0          | 0          |
|                            | Tarbert            | TB2       | 0          | 0          | 0           | 0          | 0          | 0          |
|                            | Tarbert            | TB3       | 0          | 0          | 0           | 0          | 0          | 0          |
|                            | Tarbert            | TB4       | 0          | 0          | 0           | 0          | 0          | 0          |
|                            | Tynagh             | TY        | 0          | 0          | 200         | 0          | 0          | 0          |
|                            | Installed Wind     | -         | 12         | 44         | 44          | 35         | 105        | 105        |
| <b>Mid-West Area Total</b> |                    |           | <b>380</b> | <b>799</b> | <b>1129</b> | <b>373</b> | <b>590</b> | <b>830</b> |



Table D-7 Dispatch Profiles – Power Flow Diagrams (Continued)

| Area                  | Generation Station | Unit ID | 2015 |     |     | 2024 |     |     |
|-----------------------|--------------------|---------|------|-----|-----|------|-----|-----|
|                       |                    |         | SNV  | SP  | WP  | SNV  | SP  | WP  |
| South-East            | Great Island       | GI4     | 240  | 280 | 300 | 0    | 240 | 380 |
|                       | Installed Wind     | -       | 24   | 80  | 80  | 34   | 101 | 101 |
| South-East Area Total |                    |         | 264  | 360 | 380 | 34   | 341 | 481 |

| Area                | Generation Station | Unit ID | 2015 |     |     | 2024 |     |     |
|---------------------|--------------------|---------|------|-----|-----|------|-----|-----|
|                     |                    |         | SNV  | SP  | WP  | SNV  | SP  | WP  |
| Midlands            | Cuilleen           | -       | -    | -   | -   | -    | 0   | 0   |
|                     | Edenderry Power    | ED1     | 130  | 130 | 130 | 130  | 130 | 130 |
|                     | Edenderry PCP      | ED3     | 0    | 0   | 0   | 0    | 0   | 0   |
|                     | Edenderry PCP      | ED5     | 0    | 0   | 0   | 0    | 0   | 0   |
|                     | Rhode PCP          | RP1     | 0    | 0   | 0   | 0    | 0   | 0   |
|                     | Rhode PCP          | RP2     | 0    | 0   | 0   | 0    | 0   | 0   |
|                     | West Offaly Power  | WO4     | 150  | 150 | 150 | 150  | 150 | 150 |
|                     | Installed Wind     | -       | 36   | 115 | 115 | 94   | 283 | 283 |
| Midlands Area Total |                    |         | 316  | 395 | 395 | 374  | 563 | 563 |

| Area                  | Generation Station | Unit ID | 2015 |     |     | 2024 |     |     |
|-----------------------|--------------------|---------|------|-----|-----|------|-----|-----|
|                       |                    |         | SNV  | SP  | WP  | SNV  | SP  | WP  |
| North-West            | Erne               | ER3     | 2    | 7   | 7   | 2    | 7   | 7   |
|                       | Erne               | ER4     | 2    | 7   | 7   | 2    | 7   | 7   |
|                       | Erne               | ER1     | 1    | 3   | 3   | 1    | 3   | 3   |
|                       | Erne               | ER2     | 1    | 3   | 3   | 1    | 3   | 3   |
|                       | Lough Ree Power    | LR4     | 100  | 100 | 100 | 100  | 100 | 100 |
|                       | Tawnaghmore        | TW1     | 0    | 0   | 0   | 0    | 0   | 0   |
|                       | Tawnaghmore        | TW2     | 0    | 0   | 0   | 0    | 0   | 0   |
|                       | Installed Wind     | -       | 55   | 175 | 175 | 193  | 578 | 578 |
| North-West Area Total |                    |         | 161  | 295 | 295 | 299  | 698 | 698 |

| Area                  | Generation Station | Unit ID | 2015 |    |    | 2024 |     |     |
|-----------------------|--------------------|---------|------|----|----|------|-----|-----|
|                       |                    |         | SNV  | SP | WP | SNV  | SP  | WP  |
| North-East            | Installed Wind     | -       | 12   | 36 | 36 | 49   | 147 | 147 |
| North-East Area Total |                    |         | 12   | 36 | 36 | 49   | 147 | 147 |

Table D-7 Dispatch Profiles – Power Flow Diagrams (Continued)

| Area                               | Generation Station      | Unit ID | 2015       |             |             | 2024       |             |             |
|------------------------------------|-------------------------|---------|------------|-------------|-------------|------------|-------------|-------------|
|                                    |                         |         | SNV        | SP          | WP          | SNV        | SP          | WP          |
| Northern Ireland                   | Ballylumford CCGT10     | B10     | 0          | 0           | 100         | 0          | 0           | 0           |
|                                    | Ballylumford CCGT31     | B31     | 0          | 150         | 248         | 0          | 120         | 150         |
|                                    | Ballylumford CCGT32     | B32     | 0          | 150         | 248         | 0          | 120         | 150         |
|                                    | Ballylumford GT7        | BGT1    | 0          | 0           | 0           | -          | -           | -           |
|                                    | Ballylumford GT8        | BGT2    | 0          | 0           | 0           | -          | -           | -           |
|                                    | Ballylumford ST4        | B4      | 0          | 0           | 0           | -          | -           | -           |
|                                    | Ballylumford ST5        | B5      | 0          | 0           | 0           | -          | -           | -           |
|                                    | Ballylumford ST6        | B6      | 0          | 0           | 0           | -          | -           | -           |
|                                    | CAES                    | -       | -          | -           | -           | 27         | 80          | 80          |
|                                    | Coolkeeragh CCGT        | C30     | 165        | 360         | 430         | 110        | 260         | 360         |
|                                    | Coolkeeragh CCGT8       | CGT8    | 0          | 0           | 0           | 0          | 0           | 0           |
|                                    | Kilroot GT1             | KGT1    | 0          | 0           | 0           | 0          | 0           | 0           |
|                                    | Kilroot GT2             | KGT2    | 0          | 0           | 0           | 0          | 0           | 0           |
|                                    | Kilroot GT3             | KGT3    | 0          | 0           | 0           | 0          | 0           | 0           |
|                                    | Kilroot GT4             | KGT4    | 0          | 0           | 0           | 0          | 0           | 0           |
|                                    | Kilroot ST1             | K1      | 120        | 190         | 190         | 110        | 140         | 190         |
|                                    | Kilroot ST2             | K2      | 120        | 190         | 190         | 0          | 0           | 190         |
|                                    | Moyle (Import positive) | -       | 100        | 150         | 150         | 100        | 150         | 150         |
|                                    | Tidal                   | -       | 21         | 63          | 63          | 21         | 63          | 63          |
|                                    | Installed Wind          | -       | 68         | 203         | 210         | 169        | 506         | 506         |
| <b>Northern Ireland Area Total</b> |                         |         | <b>594</b> | <b>1456</b> | <b>1829</b> | <b>537</b> | <b>1439</b> | <b>1839</b> |

Table D-8 Existing and Proposed Northern Ireland Generating Plant Contract Details

| Centrally Dispatched Generating Unit | Fuel Type  | Contract       |                                       |
|--------------------------------------|------------|----------------|---------------------------------------|
|                                      |            | Type           | Details                               |
| Ballylumford ST 4                    | GAS/HFO    | IPP            | See Note 1                            |
| Ballylumford ST 5                    | GAS/HFO    | IPP            | See Note 1                            |
| Ballylumford ST 6                    | GAS/HFO    | IPP            | See Note 1                            |
| Ballylumford CCGT 21                 | GAS/GASOIL | Power NI (PPB) | See Note 2                            |
| Ballylumford CCGT 22                 | GAS/GASOIL | Power NI (PPB) | See Note 2                            |
| Ballylumford CCGT 20                 | STEAM      | Power NI (PPB) | See Note 2                            |
| Ballylumford CCGT 10                 | GAS/GASOIL | Power NI (PPB) | See Note 2                            |
| Ballylumford GT 7                    | GASOIL     | IPP            | Independent from 01/11/12             |
| Ballylumford GT 8                    | GASOIL     | IPP            | Independent from 01/11/12             |
| Kilroot ST 1                         | COAL/OIL   | IPP            | Independent from 01/11/10; See Note 3 |
| Kilroot ST 2                         | COAL/OIL   | IPP            | Independent from 01/11/10; See Note 3 |
| Kilroot GT 1                         | GASOIL     | IPP            | Independent from 01/11/12             |
| Kilroot GT 2                         | GASOIL     | IPP            | Independent from 01/11/12             |
| Kilroot GT 3                         | GASOIL     | IPP            | Commenced Operation 01/03/2009        |
| Kilroot GT 4                         | GASOIL     | IPP            | Commenced Operation 01/03/2009        |
| Coolkeeragh GT8                      | GASOIL     | IPP            | Independent from 01/02/2013           |
| Coolkeeragh CCGT                     | GAS/GASOIL | IPP            | Commenced Operation 01/04/2005        |
| Moyle                                | DC LINK    |                | See Note 4                            |

**NOTE 1:** This is an Independent Power Producer (IPP). At the data freeze date, Ballylumford has in place a contract to provide 250 MW of local reserve. This will see Ballylumford ST4 and ST5 remaining connected (at reduced capacity) until the end of 2018 with an option for SONI to extend this by a further 2 years if deemed required. Ballylumford ST6 will be de-commissioned at the end of 2015.

**NOTE 2:** In a Generator Unit Agreement (GUA) with Power NI Energy Limited's Power Procurement Business (PPB), the contract expiry date is 23<sup>rd</sup> September 2018 (with a five-year extension option)<sup>1</sup>.

**NOTE 3:** Kilroot ST1 and ST2 are currently due to be decommissioned by 2024.


**NOTE 4:** Capacity is auctioned regularly (daily, monthly, seasonally and annually) to the market participants. Capacity is also available in SEM through implicit auction process.

<sup>1</sup> [http://www.uregni.gov.uk/uploads/publications/2014-10-10\\_GUA\\_Decision\\_Paper.pdf](http://www.uregni.gov.uk/uploads/publications/2014-10-10_GUA_Decision_Paper.pdf)



## APPENDIX E: SHORT CIRCUIT CURRENTS

- E.1 Background of Short Circuit Currents
- E.2 The Nature of Short Circuit Currents
- E.3 Duty of Circuit Breakers
- E.4 Short Circuit Current Calculation Methodology
- E.5 Short Circuit Currents in Ireland
- E.6 Short Circuit Currents in Northern Ireland



The current. The future.

## Appendix E Short Circuit Currents

### E.1 Background of Short Circuit Currents

The main driver for calculating short circuit current levels is safety. All transmission system equipment must be capable of carrying very high currents. These high currents typically occur in the event of a short circuit fault. In particular, circuit breakers must be capable of closing onto a fault and opening to isolate a fault.

Their correct operation minimises risk to human life and prevents damage to transmission system equipment. It is also crucial for maintaining transmission system stability, security and quality of supply.

Short circuit current levels also give an indication of the electrical strength of the transmission system at each station. This provides an indication of the suitability of a station for connection of 'voltage sensitive' equipment.

A station with a high short circuit current level will be more attractive to these types of load. This is due to strong generation infeeds minimising distortions in voltage and frequency caused by transmission system disturbances. Similarly, generators will have less difficulty to ride through faults and maintain stability when connected to stations with high short circuit current levels.

Short circuit current levels vary across the transmission system. They are affected by the transmission system topology, system impedance and the available short circuit contribution from rotating machines (i.e. generators and large motors).

Changes in the transmission system topology or the addition/retirement of generation units can bring about an increase/reduction in the short circuit current levels on the transmission system. Similarly, seasonal variations in generation dispatches and demand levels combined with possible transmission system sectionalising or plant outages will result in variations of short circuit current levels at different locations.

To ensure safe and reliable operation of the transmission system and customer's equipment at all times, two types of short circuit current level calculations are carried out:

- Maximum short circuit current levels are required for the specification of transmission system equipment and for connections to the transmission system. Plant in substations is typically subjected to the most onerous short circuit currents. The high capital costs of HV equipment means that it is important to predict the maximum short circuit current the equipment may see in its lifetime, and this must be specified to a rating above the maximum expected short circuit current level. Also, for customers, the design and specification of equipment at lower voltage levels will depend on the short circuit level at the transmission connection point.
- Minimum short circuit current levels are required to guarantee reliable and coordinated operation of protection systems or to assess the suitability of a station for the connection of 'voltage sensitive' equipment. Minimum short circuit current levels are also required at the design stage of generation plants to ensure fault ride through capabilities are in accordance with Grid Code requirements.

## E.2 The Nature of Short Circuit Currents

The plot in Figure E-1 shows a typical short circuit current waveform. Short circuit current is normally made up of a symmetrical AC component, with a decay rate, and a DC offset component, which has a much faster decay rate. The combination of AC and DC components results in an asymmetrical current waveform.

While the AC component is always present in the short circuit current, the DC offset is dependent on the instant that the fault occurs within the voltage waveform. For the purposes of this document, it is assumed that the fault occurs at the instant of maximum DC offset in the short circuit current.




Figure E-1 Typical Short Circuit Current

The DC component of a short circuit current decays exponentially. Its rate of decay is influenced by the individual ratios of the reactance ( $X$ ) to the resistance ( $R$ ) of the paths back to the generators feeding power to the fault (the  $X/R$  ratio). Transmission nodes where large generators can have high  $X/R$  ratios, which may result in a slower decay time for the DC component of the short circuit current.

The AC component of a short circuit current also decays with time. This is due to the changes in the synchronous generators internal reactance and, thus, the AC reduction effect is more pronounced in the vicinity of large generation plants. The internal impedance of a synchronous generator is not constant after the start of the fault. It increases progressively and the short circuit current contribution becomes weaker, passing through three characteristic stages:

- Subtransient: (approx. 0.01 to 0.1 sec). Short-circuit current (RMS value of the AC component) is high: 5 to 10 times permanent rated current. This is called sub-transient short-circuit current,  $I_k''$ .
- Transient: (between 0.1 and 1 sec). Short-circuit current (RMS value of the AC component) drops to between 2 and 6 times rated current. This is called transient short-circuit current,  $I_k'$ .
- Continuous: Short-circuit current (RMS value of the AC component) drops to between 0.5 and 2 times rated current. This is called steady-state short-circuit current,  $I_k$ .

### E.3 Duty of Circuit Breakers

Over the duration of a fault the switchgear has to be able to withstand two events, namely the fault initiation and then the fault clearance. The short circuit currents at these two instances are referred to as the Make current and the Break current respectively.

- (i) The make current ( $I_p$ ) is the maximum instantaneous current that the circuit breaker is called to withstand. The initiation of a fault causes an instantaneous peak current which results in the generation of electromechanical forces along the busbars and transmission lines. An example of such a fault initiation would be a circuit breaker energising a line that is still earthed following maintenance, hence the term Make Current.

Make current is expressed in peak values and is comprised of an AC and a DC component. Essentially, the make current is the maximum instantaneous peak of the short circuit current waveform, and this will occur at approximately 10 milliseconds after the instant of fault (see Figure 8-12), whether the fault is energised through a circuit breaker or it spontaneously occurs on the transmission system. Circuit breakers are typically rated approximately 2.5 times higher for make duty than for break duty, as per IEC 62271-100 standard.

- (ii) After the fault initiation, there is a time period during which the protection scheme will identify the fault, make a decision and then instruct the relevant circuit breaker to open to interrupt the fault. This could take anything from 10 ms in modern fast protection systems to 60 ms in older systems. At this point the circuit breaker begins to open and it takes a certain time period before the contacts actually separate, normally around two cycles or 40 ms in modern switchgear equipment. The total time from the start of the fault until the breaker opening or fault clearance time can vary from 50 ms to 120 ms, depending on the protection system. In some cases; if main protection fails and back-up main protection is not installed; clearance times can be considerably longer than 120 ms.



At the point of physical separation, the short circuit current forms an arc and the thermal energy generated by this arc has to be dissipated as the short circuit current is interrupted. The short circuit current when this interruption occurs is referred to as the Break Current,  $I_b$ . This value is expressed in RMS (root mean square) terms and is comprised of an AC component and a DC component. Circuit breakers designed and tested in accordance with the IEC 62271-100 standard can interrupt any short circuit current up to its rated breaking current containing any AC component up to the rated value and, associated with it, any percentage DC component up to that specified (typically 30%).

The duty of the circuit breaker is calculated from the make and break current as a percentage of the circuit breaker rating.

#### E.4 Short Circuit Current Calculation Methodology

Engineering Recommendation G74 has been applied to all short circuit studies reported in this document. Some of the general assumptions applied include:

- Short circuit level contribution from loads has been considered following G74 recommendations. The demand at each node is assumed to contribute 1 MVA of induction motor fault infeed per MW of load. A constant X/R ratio of 2.76 is assumed for all of the loads,
- A break time of 50 ms is assumed typical for the circuit breakers at 110 kV, 220 kV, 275 kV and 400 kV.

**Winter Peak** study results give an indication of the maximum prospective short circuit current levels on the transmission system. For winter peak studies, all generators have been included in the calculations. A merit order economic dispatch has been used and to enable maximum short circuit current level to be calculated, any generators that were not dispatched have been switched in with 0 MW output, thus contributing to short circuit current levels.

Summer Night Valley study results give an indication of the minimum short circuit current levels to be expected on the transmission system under normal transmission system operating conditions (i.e. maintenance outages are not considered in this section<sup>1</sup>). For summer night valley studies, only generators dispatched on a merit order are considered in the model.

## E.5 Short Circuit Currents in Ireland

### E.5.1 Methodology used in Ireland

Short circuit current levels are calculated in accordance with the UK Engineering Recommendation G74, which is a computer based analysis, based on the International Standard IEC60909. Compliance with G74 includes:

- Short circuit contributions from rotating plant, including induction motors embedded in the general load,
- Comprehensive plant parameters including impedances, transformer winding and earthing configurations,
- Pre-fault voltage levels at each node which should be obtained from a credible, pre-fault load flow study,
- Pre-fault transformer tap settings should also be obtained from the load flow study.

The short circuit current level network model includes the following component parameters:

- Transformer impedance variation with tap position,
- Zero sequence mutual coupling effect,
- Saturated generator reactance values,
- Power station auxiliaries short circuit current level contributions.

---

<sup>1</sup> Minimum fault levels including maintenance outages are currently provided to generator applicants wishing to connect to the transmission system as part of the connection offer process to allow developers to design the plant in accordance with the Grid Code requirements.

The calculation of the X/R ratios, used by EirGrid, is undertaken in accordance with IEC60909-0 Method B. Method B is currently considered to be the most appropriate general purpose method for calculating DC short circuit currents in the transmission system of Ireland. The use of this calculation method is currently under review by EirGrid.

The transmission system of Ireland is designed and operated to maintain RMS break short circuit levels in accordance with EirGrid Grid Code CC.8.6. A summary of these requirements is set out in Table E-6. In designing the system, a 10% safety margin is applied.

It should be noted that the EirGrid Grid Code Version 4.0 (released in December 2011) contains a modification which stipulates that short circuit current levels at designated stations, in Ireland may be allowed to increase to 31.5 kA. If necessary, the equipment at these stations is to be modified or replaced in order to comply with this new rating. The stations currently designated for operation of the 110 kV equipment up to 31.5 kA, as proposed by the TSO, are; Barnahely, Cloghran (future station), College Park, Corduff, Finglas, Kilbarry, Knockraha, Louth, Marina, Raffeen, Tarbert and Trabeg. EirGrid will annually publish an updated list of designated stations.

Circuit breakers with a higher rating than the current levels may be necessary for a number of reasons, including, but not limited to the need to provide an adequate safety margin or to cater for a high DC component in the short circuit current.

Table E-1 Short Circuit Current Levels - Standard Equipment Rating – Republic of Ireland

| Voltage Level |                                      | Standard Equipment Short Circuit Current Rating |
|---------------|--------------------------------------|---|
| 400 kV        |                                      | 50 kA   |
| 220 kV        |                                      | 40 kA   |
| 110 kV        | Outside the Dublin Area <sup>2</sup> | 25 kA   |
|               | Designated sites                     | 31.5kA  |

<sup>2</sup> New equipment installed at 110 kV level must have a short circuit rating of 31.5 kA.

### E.5.2 Analysis

The generation dispatches used in the short circuit analysis are shown in Table D-5 in Appendix D.

The total RMS break current at a busbar is an indication of the short circuit level that one could expect at that point in the transmission system.

However, they do not necessarily represent the short circuit current that could flow through each individual breaker, which may be lower.

### E.5.3 Ireland Short Circuit Currents Level Results

Tables E-9 to E-11 list subtransient ( $I_k''$ ), transient ( $I_k'$ ) currents and X/R ratios for single-phase to earth and balanced three-phase faults for transmission system busbars of Ireland. These are presented for maximum winter peak and minimum summer valley intact system demand conditions for 2012, 2015 and 2018. From these values, the relevant currents required to assess circuit breaker duty can be derived using the following equations:

- Peak Make current ( $I_p$ )

$$I_p = \sqrt{2} \cdot \left[ 1.02 + 0.98 \cdot e^{-3 \frac{R}{X}} \right] \cdot I_k''$$

- AC component ( $I_{RMS\_AC\_b}$ ) of short-circuit current at a selected time of break ( $t_b$ )

$$I_{RMS\_AC\_b} = I_k' + (I_k'' - I_k') \cdot e^{-\frac{t_b}{40ms}}$$

- DC component ( $I_{DC\_b}$ ) of short-circuit current at a selected time of break ( $t_b$ )

$$I_{DC\_b} = \sqrt{2} \cdot I_k'' \cdot e^{-2 \cdot \pi \cdot 50 t_b \cdot \frac{R}{X}}$$

- Break current ( $I_b$ ) at a selected time of break ( $t_b$ )

$$I_b = \sqrt{I_{DC\_b}^2 + I_{RMS\_AC\_b}^2}$$

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-2 Short Circuit Currents for Maximum and Minimum Demand in 2015

| Bus                  | Summer Night Valley 2015 |                       |                       |              |                       |                       | Winter Peak 2015 |                       |                       |              |                       |                       |
|----------------------|--------------------------|-----------------------|-----------------------|--------------|-----------------------|-----------------------|------------------|-----------------------|-----------------------|--------------|-----------------------|-----------------------|
|                      | Three-Phase              |                       |                       | Single-Phase |                       |                       | Three-Phase      |                       |                       | Single-Phase |                       |                       |
|                      | X/R Ratio                | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio    | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio        | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio    | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] |
| Adamstown 110 kV     | -                        | -                     | -                     | -            | -                     | -                     | 13.8             | 12.8                  | 11.3                  | 8.5          | 13.8                  | 13.1                  |
| Agannygal 110 kV     | 2.8                      | 4.6                   | 4.4                   | 3.8          | 4.0                   | 3.9                   | 3.0              | 6.1                   | 5.4                   | 4.2          | 4.8                   | 4.6                   |
| Aghada 110 kV        | 5.1                      | 7.2                   | 6.7                   | 5.9          | 8.7                   | 8.4                   | 4.6              | 9.9                   | 9.4                   | 5.6          | 11.2                  | 10.9                  |
| Aghada A 220 kV      | 8.9                      | 7.4                   | 6.7                   | 9.3          | 9.8                   | 9.3                   | 12.4             | 17.3                  | 15.4                  | 12.5         | 19.4                  | 18.6                  |
| Aghada B 220 kV      | 11.8                     | 8.5                   | 7.5                   | 11.2         | 11.0                  | 10.4                  | 12.8             | 17.8                  | 15.8                  | 14.0         | 20.0                  | 19.1                  |
| Aghada C 220 kV      | 9.0                      | 7.5                   | 6.8                   | 9.7          | 9.9                   | 9.4                   | 13.6             | 17.2                  | 15.3                  | 11.7         | 19.5                  | 18.6                  |
| Aghada D 220 kV      | 8.9                      | 7.4                   | 6.7                   | 9.3          | 9.8                   | 9.3                   | 12.4             | 17.3                  | 15.4                  | 12.5         | 19.4                  | 18.6                  |
| Ahane 110 kV         | 5.3                      | 9.6                   | 8.8                   | 6.0          | 8.6                   | 8.4                   | 4.9              | 14.0                  | 12.9                  | 5.8          | 10.8                  | 10.5                  |
| Anner 110 kV         | 3.8                      | 5.7                   | 5.3                   | 4.3          | 4.3                   | 4.2                   | 3.9              | 7.0                   | 6.5                   | 4.4          | 4.9                   | 4.8                   |
| Ardnacrusha 110 kV   | 5.7                      | 10.2                  | 9.3                   | 6.8          | 11.8                  | 11.4                  | 6.0              | 16.6                  | 14.9                  | 7.6          | 16.7                  | 16.1                  |
| Arigna 110 kV        | 3.7                      | 5.9                   | 5.6                   | 4.7          | 4.7                   | 4.7                   | 3.8              | 7.8                   | 7.1                   | 5.0          | 5.5                   | 5.4                   |
| Arklow 110 kV        | 10.3                     | 7.6                   | 7.2                   | 11.1         | 9.3                   | 9.1                   | 10.4             | 9.4                   | 8.8                   | 11.2         | 11.2                  | 10.9                  |
| Arklow 220 kV        | 9.3                      | 6.8                   | 6.4                   | 10.6         | 6.5                   | 6.4                   | 8.9              | 8.4                   | 7.9                   | 10.4         | 7.5                   | 7.4                   |
| Artane 110 kV        | 13.3                     | 9.6                   | 8.9                   | 6.3          | 11.7                  | 11.3                  | 13.4             | 12.4                  | 11.2                  | 5.9          | 14.5                  | 13.9                  |
| Arva 110 kV          | 3.8                      | 7.8                   | 7.3                   | 4.8          | 6.3                   | 6.2                   | 3.7              | 9.9                   | 9.0                   | 4.9          | 7.2                   | 7.0                   |
| Athea 110 kV         | 4.7                      | 4.1                   | 3.9                   | 5.5          | 4.8                   | 4.7                   | 11.4             | 9.7                   | 8.2                   | 12.2         | 9.6                   | 9.0                   |
| Athlone 110 kV       | 4.5                      | 7.0                   | 6.6                   | 5.8          | 5.4                   | 5.3                   | 4.2              | 8.2                   | 7.6                   | 5.6          | 5.9                   | 5.8                   |
| Athy 110 kV          | 3.3                      | 5.4                   | 5.2                   | 4.5          | 4.5                   | 4.5                   | 3.1              | 6.4                   | 6.1                   | 4.3          | 5.2                   | 5.1                   |
| Aughinish 110 kV     | 8.9                      | 8.7                   | 7.7                   | 10.8         | 9.8                   | 9.3                   | 8.0              | 10.7                  | 9.6                   | 10.1         | 11.1                  | 10.7                  |
| Ballybeg 110 kV      | 9.5                      | 6.1                   | 5.8                   | 9.8          | 7.2                   | 7.1                   | 9.5              | 7.2                   | 6.9                   | 9.8          | 8.3                   | 8.1                   |
| Ballydine 110 kV     | 3.9                      | 6.3                   | 6.0                   | 3.7          | 5.2                   | 5.1                   | 3.9              | 7.7                   | 7.2                   | 3.7          | 5.9                   | 5.8                   |
| Ballylickey 110 kV   | 2.7                      | 2.5                   | 2.4                   | 3.9          | 1.7                   | 1.7                   | 2.9              | 3.3                   | 3.1                   | 4.0          | 1.9                   | 1.9                   |
| Ballyvouskill 110 kV | -                        | -                     | -                     | -            | -                     | -                     | 8.5              | 12.3                  | 11.3                  | 9.4          | 12.3                  | 11.9                  |
| Ballyvouskill 220 kV | -                        | -                     | -                     | -            | -                     | -                     | 7.8              | 9.1                   | 8.5                   | 8.9          | 10.3                  | 10.0                  |
| Ballywater 110 kV    | 4.7                      | 4.9                   | 4.7                   | 3.3          | 5.2                   | 5.1                   | 4.7              | 6.1                   | 5.7                   | 3.2          | 6.0                   | 5.9                   |
| Baltrasna 110 kV     | 6.4                      | 9.4                   | 8.8                   | 7.5          | 7.4                   | 7.3                   | 6.0              | 11.2                  | 10.6                  | 7.2          | 8.3                   | 8.2                   |
| Bancroft 110 kV      | 11.1                     | 12.9                  | 11.7                  | 6.4          | 14.1                  | 13.6                  | 10.5             | 16.5                  | 14.7                  | 5.9          | 17.1                  | 16.3                  |
| Bandon 110 kV        | 3.3                      | 4.9                   | 4.6                   | 4.5          | 4.3                   | 4.2                   | 3.0              | 6.6                   | 6.1                   | 4.1          | 6.2                   | 6.1                   |
| Banoge 110 kV        | 6.1                      | 5.4                   | 5.2                   | 6.8          | 4.9                   | 4.8                   | 5.9              | 6.5                   | 6.1                   | 6.8          | 5.6                   | 5.5                   |
| Barnahealy A 110 kV  | 5.4                      | 9.4                   | 8.5                   | 5.9          | 10.3                  | 9.9                   | 4.5              | 14.0                  | 12.9                  | 5.3          | 13.8                  | 13.4                  |
| Barnahealy B 110 kV  | 7.3                      | 9.1                   | 8.3                   | 7.7          | 9.9                   | 9.5                   | 6.7              | 13.6                  | 12.5                  | 7.3          | 13.2                  | 12.8                  |
| Barnakyle 110 kV     | -                        | -                     | -                     | -            | -                     | -                     | 19.3             | 13.3                  | 11.7                  | 12.1         | 14.0                  | 13.4                  |
| Baroda 110 kV        | 4.3                      | 7.4                   | 6.9                   | 5.1          | 8.5                   | 8.3                   | 4.0              | 9.2                   | 8.5                   | 4.9          | 10.2                  | 9.9                   |
| Barrymore 110 kV     | 4.0                      | 6.5                   | 6.1                   | 4.9          | 4.2                   | 4.1                   | 3.6              | 8.4                   | 7.9                   | 4.8          | 4.7                   | 4.7                   |
| Bellacorick 110 kV   | 2.6                      | 2.9                   | 2.8                   | 3.3          | 3.1                   | 3.1                   | 3.1              | 4.1                   | 3.7                   | 4.1          | 3.9                   | 3.8                   |
| Binbane 110 kV       | 3.2                      | 3.4                   | 3.2                   | 4.3          | 3.3                   | 3.3                   | 3.4              | 4.9                   | 4.4                   | 5.0          | 4.2                   | 4.1                   |
| Blackrock 110 kV     | 8.8                      | 12.2                  | 11.1                  | 2.4          | 10.6                  | 10.3                  | 8.2              | 15.5                  | 13.8                  | 2.2          | 12.3                  | 11.9                  |
| Blake 110 kV         | 4.2                      | 7.1                   | 6.7                   | 5.1          | 5.1                   | 5.0                   | 4.0              | 8.7                   | 8.2                   | 5.0          | 5.7                   | 5.6                   |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-2 Short Circuit Currents for Maximum and Minimum Demand in 2015 (Continued)

| Bus                        | Summer Night Valley 2015 |           |            |              |           |            | Winter Peak 2015 |           |            |              |           |            |
|----------------------------|--------------------------|-----------|------------|--------------|-----------|------------|------------------|-----------|------------|--------------|-----------|------------|
|                            | Three-Phase              |           |            | Single-Phase |           |            | Three-Phase      |           |            | Single-Phase |           |            |
|                            | X/R Ratio                | Ik'' [kA] | Ik''' [kA] | X/R Ratio    | Ik'' [kA] | Ik''' [kA] | X/R Ratio        | Ik'' [kA] | Ik''' [kA] | X/R Ratio    | Ik'' [kA] | Ik''' [kA] |
| Boggeragh 110 kV           | 6.3                      | 5.5       | 5.2        | 7.5          | 6.1       | 6.0        | 6.7              | 8.3       | 7.6        | 8.1          | 8.1       | 7.9        |
| Booltiagh 110 kV           | 2.8                      | 3.3       | 3.2        | 3.9          | 3.1       | 3.1        | 3.1              | 4.5       | 4.1        | 4.6          | 3.7       | 3.6        |
| Brinny A 110 kV            | 3.2                      | 4.5       | 4.3        | 4.3          | 3.8       | 3.7        | 2.9              | 5.9       | 5.5        | 4.0          | 5.1       | 5.0        |
| Brinny B 110 kV            | 3.2                      | 4.5       | 4.3        | 4.3          | 3.8       | 3.7        | 2.9              | 5.9       | 5.5        | 4.0          | 5.2       | 5.1        |
| Butlerstown 110 kV         | 6.2                      | 9.1       | 8.6        | 5.8          | 9.4       | 9.2        | 5.5              | 11.1      | 10.3       | 5.4          | 10.9      | 10.6       |
| Cabra 110 kV               | 12.4                     | 9.3       | 8.7        | 5.2          | 10.6      | 10.3       | 12.3             | 12.0      | 10.8       | 4.8          | 12.9      | 12.5       |
| Cahir 110 kV               | 3.7                      | 6.9       | 6.4        | 4.7          | 5.9       | 5.8        | 4.1              | 9.6       | 8.8        | 5.2          | 7.2       | 7.1        |
| Carlow 110 kV              | 5.3                      | 7.2       | 6.9        | 6.1          | 7.9       | 7.8        | 5.3              | 9.2       | 8.5        | 6.1          | 9.5       | 9.3        |
| Carrickmines 110 kV        | 21.2                     | 14.5      | 13.0       | 16.5         | 16.2      | 15.5       | 22.3             | 19.1      | 16.7       | 16.4         | 20.1      | 19.1       |
| Carrickmines 220 kV        | 14.4                     | 14.4      | 12.6       | 9.7          | 17.8      | 16.7       | 13.8             | 21.4      | 18.8       | 8.5          | 24.7      | 23.4       |
| Carrickmines County 110 kV | 21.2                     | 14.5      | 13.0       | 16.5         | 16.2      | 15.5       | 22.3             | 19.1      | 16.7       | 16.4         | 20.1      | 19.1       |
| Carrick-on-Shannon 110 kV  | 4.4                      | 9.2       | 8.6        | 5.1          | 10.3      | 10.0       | 4.2              | 12.2      | 11.1       | 5.0          | 12.7      | 12.2       |
| Carrigadrohid 110 kV       | 5.9                      | 8.4       | 7.7        | 6.5          | 7.9       | 7.7        | 6.2              | 13.5      | 12.3       | 7.1          | 10.6      | 10.4       |
| Carrowbeg 110 kV           | 2.6                      | 2.4       | 2.3        | 3.5          | 2.3       | 2.2        | 2.6              | 2.8       | 2.6        | 3.7          | 2.5       | 2.4        |
| Cashla 110 kV              | 6.8                      | 11.9      | 10.9       | 7.4          | 15.3      | 14.7       | 7.0              | 17.2      | 15.5       | 7.7          | 20.7      | 19.9       |
| Cashla 220 kV              | 7.9                      | 7.4       | 6.9        | 9.1          | 8.2       | 8.0        | 7.9              | 11.7      | 10.9       | 9.4          | 11.3      | 11.1       |
| Castlebar 110 kV           | 2.9                      | 3.8       | 3.6        | 3.6          | 4.1       | 4.1        | 3.1              | 5.2       | 4.6        | 4.1          | 5.1       | 4.9        |
| Castledockrill 110 kV      | 6.9                      | 6.4       | 6.1        | 4.9          | 7.8       | 7.7        | 6.9              | 8.1       | 7.6        | 4.7          | 9.2       | 9.0        |
| Castlefarm A 110 kV        | 8.1                      | 8.5       | 7.5        | 9.5          | 9.1       | 8.7        | 7.2              | 10.3      | 9.3        | 8.8          | 10.3      | 10.0       |
| Castlefarm B 110 kV        | 8.1                      | 8.4       | 7.5        | 9.5          | 9.1       | 8.7        | 7.2              | 10.2      | 9.2        | 8.8          | 10.3      | 10.0       |
| Castleview 110 kV          | 4.6                      | 9.6       | 8.7        | 4.9          | 7.8       | 7.6        | 3.8              | 14.1      | 13.1       | 4.5          | 9.7       | 9.5        |
| Cathaleen's Fall 110 kV    | 4.2                      | 6.2       | 5.8        | 4.9          | 6.9       | 6.8        | 5.1              | 10.7      | 9.3        | 6.2          | 9.8       | 9.4        |
| Cauteen 110 kV             | 3.0                      | 5.6       | 5.3        | 4.0          | 3.7       | 3.7        | 3.6              | 7.6       | 7.1        | 4.8          | 4.4       | 4.4        |
| Central 110 kV             | 11.1                     | 12.9      | 11.8       | 6.0          | 14.0      | 13.5       | 10.6             | 16.6      | 14.8       | 5.5          | 16.9      | 16.2       |
| Charleville 110 kV         | 4.6                      | 5.2       | 4.9        | 5.3          | 4.3       | 4.2        | 4.6              | 7.6       | 6.8        | 5.4          | 5.3       | 5.1        |
| City West 110 kV           | 6.3                      | 7.2       | 6.6        | 6.2          | 5.5       | 5.4        | 6.0              | 8.6       | 7.6        | 6.0          | 6.1       | 5.9        |
| Clahane 110 kV             | 4.2                      | 5.5       | 5.1        | 4.9          | 5.8       | 5.6        | 3.6              | 5.5       | 5.0        | 4.6          | 5.1       | 4.9        |
| Clashavoon 220 kV          | 8.3                      | 5.9       | 5.4        | 9.2          | 6.4       | 6.2        | 8.2              | 10.1      | 9.3        | 9.1          | 10.2      | 10.0       |
| Clashavoon A 110 kV        | 7.7                      | 9.3       | 8.5        | 8.7          | 10.6      | 10.2       | 7.8              | 15.9      | 14.3       | 9.1          | 15.9      | 15.3       |
| Clashavoon B 110 kV        | 7.7                      | 9.3       | 8.5        | 8.7          | 10.6      | 10.2       | 7.8              | 15.9      | 14.3       | 9.1          | 15.9      | 15.3       |
| Cliff 110 kV               | 3.9                      | 5.1       | 4.8        | 4.9          | 5.2       | 5.1        | 4.6              | 8.0       | 7.2        | 5.9          | 6.8       | 6.6        |
| Cloghboola 110 kV          | 4.1                      | 4.3       | 4.1        | 4.5          | 5.3       | 5.2        | 7.0              | 7.0       | 5.7        | 7.8          | 7.5       | 7.0        |
| Cloghran 110 kV            | 7.3                      | 14.0      | 12.8       | 7.4          | 13.1      | 12.7       | 9.5              | 24.1      | 21.9       | 9.3          | 24.1      | 23.3       |
| Clonkeen A 110 kV          | 5.8                      | 4.8       | 4.6        | 6.4          | 5.6       | 5.5        | 6.5              | 12.0      | 10.6       | 6.1          | 11.6      | 11.2       |
| Clonkeen B 110 kV          | 5.8                      | 4.8       | 4.5        | 6.5          | 5.6       | 5.5        | 6.5              | 12.0      | 10.7       | 6.1          | 11.7      | 11.2       |
| Cloon 110 kV               | 4.4                      | 6.4       | 6.0        | 5.3          | 4.7       | 4.6        | 4.3              | 7.9       | 7.4        | 5.3          | 5.3       | 5.2        |
| College Park 110 kV        | 9.9                      | 17.3      | 15.5       | 7.0          | 19.4      | 18.6       | 9.2              | 22.9      | 20.9       | 6.3          | 24.4      | 23.6       |
| Cookstown 110 kV           | 6.7                      | 8.8       | 8.2        | 5.7          | 7.1       | 7.0        | 6.3              | 10.5      | 9.7        | 5.5          | 8.0       | 7.8        |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-2 Short Circuit Currents for Maximum and Minimum Demand in 2015 (Continued)

| Bus                  | Summer Night Valley 2015 |           |           |              |           |           | Winter Peak 2015 |           |           |              |           |           |
|----------------------|--------------------------|-----------|-----------|--------------|-----------|-----------|------------------|-----------|-----------|--------------|-----------|-----------|
|                      | Three-Phase              |           |           | Single-Phase |           |           | Three-Phase      |           |           | Single-Phase |           |           |
|                      | X/R Ratio                | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] | X/R Ratio        | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] |
| Coolroe 110 kV       | 5.6                      | 7.6       | 7.0       | 6.8          | 7.7       | 7.5       | 5.1              | 11.2      | 10.4      | 6.7          | 9.8       | 9.6       |
| Coomagearlahy 110 kV | 5.7                      | 4.0       | 3.9       | 6.5          | 5.0       | 4.9       | 6.5              | 9.2       | 8.1       | 7.6          | 9.5       | 9.0       |
| Coomataggart110 kV   | -                        | -         | -         | -            | -         | -         | 5.9              | 3.8       | 3.7       | 6.8          | 4.0       | 4.0       |
| Corderry 110 kV      | 3.7                      | 6.1       | 5.7       | 4.6          | 6.2       | 6.0       | 4.0              | 8.8       | 7.8       | 5.2          | 7.9       | 7.6       |
| Corduff 110 kV       | 10.8                     | 19.1      | 17.0      | 11.7         | 21.7      | 20.7      | 10.3             | 26.1      | 23.5      | 11.6         | 27.9      | 26.9      |
| Corduff 220 kV       | 15.1                     | 14.7      | 13.0      | 13.9         | 18.3      | 17.3      | 15.4             | 25.4      | 22.2      | 13.3         | 28.7      | 27.2      |
| Corkagh 110 kV       | -                        | -         | -         | -            | -         | -         | 17.9             | 13.3      | 11.7      | 12.0         | 14.3      | 13.6      |
| Corraclassy 110 kV   | 4.2                      | 5.7       | 5.3       | 5.3          | 4.6       | 4.6       | 4.2              | 7.0       | 6.6       | 5.5          | 5.2       | 5.1       |
| Cow Cross 110 kV     | 4.9                      | 9.4       | 8.6       | 5.2          | 8.7       | 8.5       | 4.1              | 14.1      | 13.0      | 4.7          | 11.2      | 10.9      |
| Crane 110 kV         | 6.5                      | 6.9       | 6.6       | 6.5          | 7.6       | 7.4       | 6.6              | 9.0       | 8.3       | 6.6          | 9.0       | 8.8       |
| Cromcastle A 110 kV  | 12.1                     | 9.5       | 8.6       | 7.5          | 10.7      | 10.3      | 11.9             | 12.3      | 10.9      | 7.2          | 13.1      | 12.5      |
| Cromcastle B 110 kV  | 12.1                     | 9.5       | 8.6       | 7.5          | 10.7      | 10.3      | 11.9             | 12.3      | 10.9      | 7.2          | 13.1      | 12.5      |
| Croy 110 kV          | 8.5                      | 7.2       | 6.9       | 8.9          | 9.1       | 8.9       | 8.8              | 9.3       | 8.7       | 9.0          | 11.0      | 10.7      |
| Cullenagh 110 kV     | 8.2                      | 11.1      | 10.3      | 8.7          | 13.1      | 12.7      | 7.3              | 13.9      | 12.8      | 7.9          | 15.7      | 15.2      |
| Cullenagh 220 kV     | 9.2                      | 7.9       | 7.4       | 9.4          | 8.2       | 8.0       | 8.1              | 9.8       | 9.3       | 8.6          | 9.6       | 9.4       |
| Cunghill 110 kV      | 2.9                      | 4.1       | 3.9       | 3.8          | 4.0       | 3.9       | 3.1              | 5.8       | 5.3       | 4.4          | 4.9       | 4.8       |
| Cushaling 110 kV     | 6.0                      | 7.1       | 6.3       | 7.1          | 8.7       | 8.3       | 7.9              | 10.9      | 9.6       | 9.8          | 12.0      | 11.4      |
| Dallow 110 kV        | 3.5                      | 4.8       | 4.6       | 4.7          | 3.1       | 3.0       | 3.4              | 5.5       | 5.2       | 4.6          | 3.4       | 3.3       |
| Dalton 110 kV        | 3.0                      | 3.5       | 3.3       | 4.0          | 3.1       | 3.1       | 3.0              | 4.3       | 3.9       | 4.2          | 3.5       | 3.4       |
| Dardistown 110 kV    | 15.1                     | 9.6       | 8.7       | 12.1         | 11.1      | 10.7      | 15.5             | 12.5      | 11.1      | 11.9         | 13.7      | 13.0      |
| Derrybrien 110 kV    | 2.6                      | 3.6       | 3.5       | 3.7          | 3.6       | 3.5       | 3.0              | 5.0       | 4.4       | 4.4          | 4.4       | 4.2       |
| Derryiron 110 kV     | 5.6                      | 4.4       | 4.2       | 6.6          | 5.1       | 5.0       | 7.7              | 6.9       | 6.3       | 9.2          | 7.0       | 6.8       |
| Doon 110 kV          | 4.0                      | 6.2       | 5.8       | 4.4          | 4.8       | 4.7       | 4.1              | 7.8       | 7.1       | 4.6          | 5.5       | 5.4       |
| Dromada 110 kV       | 4.3                      | 4.0       | 3.8       | 4.3          | 4.6       | 4.5       | 7.6              | 9.2       | 7.8       | 5.4          | 8.8       | 8.3       |
| Drumkeen 110 kV      | 3.4                      | 4.6       | 4.4       | 4.1          | 4.8       | 4.7       | 3.8              | 7.6       | 6.5       | 4.9          | 6.4       | 6.1       |
| Drumline 110 kV      | 3.5                      | 6.3       | 5.9       | 4.6          | 5.7       | 5.6       | 3.2              | 8.4       | 7.7       | 4.5          | 6.8       | 6.7       |
| Drybridge 110 kV     | 5.8                      | 11.7      | 10.7      | 6.7          | 10.1      | 9.8       | 5.3              | 14.7      | 13.6      | 6.4          | 11.8      | 11.5      |
| Dundalk 110 kV       | 3.8                      | 7.8       | 7.3       | 4.8          | 7.3       | 7.1       | 3.4              | 9.3       | 8.6       | 4.5          | 8.3       | 8.1       |
| Dunfirth 110 kV      | 4.9                      | 4.9       | 4.7       | 6.4          | 4.1       | 4.1       | 4.9              | 5.9       | 5.7       | 6.5          | 4.7       | 4.6       |
| Dungarvan 110 kV     | 6.0                      | 5.4       | 5.1       | 7.8          | 4.6       | 4.5       | 5.8              | 6.6       | 6.2       | 7.7          | 5.3       | 5.2       |
| Dunmanway 110 kV     | 3.4                      | 4.8       | 4.5       | 4.5          | 4.4       | 4.3       | 3.3              | 6.8       | 6.2       | 4.5          | 5.6       | 5.4       |
| Dunstown 220 kV      | 12.9                     | 14.6      | 13.0      | 11.8         | 14.6      | 14.0      | 10.9             | 19.9      | 18.1      | 10.5         | 18.2      | 17.7      |
| Dunstown 400 kV      | 21.7                     | 4.4       | 4.1       | 15.3         | 3.9       | 3.8       | 20.6             | 5.6       | 5.4       | 14.4         | 4.7       | 4.6       |
| Ennis 110 kV         | 3.9                      | 7.4       | 6.9       | 4.9          | 7.2       | 7.1       | 3.7              | 10.5      | 9.4       | 5.0          | 9.1       | 8.8       |
| Fassaroe East 110 kV | 5.2                      | 8.4       | 7.9       | 5.5          | 6.2       | 6.1       | 4.9              | 10.1      | 9.3       | 5.3          | 6.9       | 6.8       |
| Fassaroe West 110 kV | 5.0                      | 8.4       | 7.8       | 5.2          | 6.2       | 6.1       | 4.6              | 10.0      | 9.3       | 5.1          | 6.9       | 6.8       |
| Finglas 220 kV       | 14.6                     | 14.1      | 12.4      | 14.2         | 18.0      | 17.0      | 16.3             | 25.2      | 21.9      | 14.8         | 29.4      | 27.7      |
| Finglas A 110 kV     | 27.2                     | 10.9      | 9.8       | 25.9         | 12.4      | 11.9      | 34.1             | 14.6      | 12.8      | 29.9         | 15.6      | 14.9      |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-2 Short Circuit Currents for Maximum and Minimum Demand in 2015 (Continued)

| Bus                     | Summer Night Valley 2015 |           |           |              |           |           | Winter Peak 2015 |           |           |              |           |           |
|-------------------------|--------------------------|-----------|-----------|--------------|-----------|-----------|------------------|-----------|-----------|--------------|-----------|-----------|
|                         | Three-Phase              |           |           | Single-Phase |           |           | Three-Phase      |           |           | Single-Phase |           |           |
|                         | X/R Ratio                | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] | X/R Ratio        | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] |
| Finglas B 110 kV        | 9.2                      | 15.5      | 14.1      | 6.5          | 13.9      | 13.5      | 8.9              | 21.7      | 20.0      | 6.6          | 18.1      | 17.7      |
| Flagford 110 kV         | 4.7                      | 9.6       | 8.9       | 5.4          | 11.8      | 11.4      | 4.5              | 12.8      | 11.6      | 5.4          | 14.9      | 14.3      |
| Flagford 220 kV         | 7.1                      | 6.0       | 5.6       | 9.0          | 5.9       | 5.7       | 7.3              | 7.8       | 7.4       | 9.6          | 7.0       | 6.9       |
| Francis Street A 110 kV | 11.3                     | 10.0      | 9.2       | 5.8          | 12.3      | 11.9      | 11.0             | 12.2      | 11.1      | 5.5          | 14.5      | 14.0      |
| Francis Street B 110 kV | 13.1                     | 10.9      | 10.1      | 6.9          | 13.4      | 12.9      | 12.7             | 13.3      | 12.3      | 6.5          | 15.9      | 15.4      |
| Galway 110 kV           | 4.8                      | 9.4       | 8.7       | 5.4          | 10.5      | 10.1      | 4.6              | 12.8      | 11.6      | 5.3          | 13.1      | 12.6      |
| Garrow 110 kV           | 4.7                      | 4.2       | 4.0       | 4.6          | 4.9       | 4.8       | 6.6              | 11.7      | 10.6      | 6.2          | 11.5      | 11.1      |
| Garvagh 110 kV          | 3.9                      | 4.8       | 4.6       | 5.1          | 4.7       | 4.6       | 4.4              | 6.7       | 5.9       | 5.9          | 5.8       | 5.6       |
| Gilra 110 kV            | 3.3                      | 5.6       | 5.4       | 4.1          | 4.5       | 4.5       | 3.1              | 6.7       | 6.3       | 4.0          | 5.0       | 5.0       |
| Glanagow 220 kV         | 12.1                     | 8.8       | 7.7       | 12.3         | 11.4      | 10.7      | 14.1             | 17.7      | 15.7      | 13.5         | 20.3      | 19.3      |
| Glanlee 110 kV          | 5.7                      | 4.0       | 3.8       | 6.2          | 4.9       | 4.8       | 6.4              | 8.7       | 7.7       | 6.8          | 9.1       | 8.7       |
| Glasmore 110 kV         | 5.0                      | 6.1       | 5.7       | 5.4          | 4.5       | 4.4       | 4.7              | 7.5       | 6.8       | 5.2          | 5.0       | 4.9       |
| Glenlara A 110 kV       | 3.0                      | 2.5       | 2.4       | 3.2          | 3.0       | 3.0       | 4.2              | 4.3       | 3.6       | 4.3          | 4.6       | 4.3       |
| Glenlara B 110 kV       | 3.0                      | 2.5       | 2.4       | 3.2          | 3.0       | 3.0       | 4.2              | 4.3       | 3.6       | 4.3          | 4.6       | 4.3       |
| Glenree 110 kV          | 2.7                      | 3.1       | 2.9       | 3.4          | 3.0       | 3.0       | 3.5              | 4.8       | 4.4       | 4.4          | 3.8       | 3.7       |
| Golagh 110 kV           | 3.1                      | 3.6       | 3.5       | 4.0          | 2.7       | 2.7       | 3.2              | 5.0       | 4.5       | 4.2          | 3.2       | 3.1       |
| Gorman 110 kV           | 6.8                      | 12.4      | 11.4      | 7.7          | 13.9      | 13.4      | 6.1              | 15.6      | 14.3      | 7.1          | 16.6      | 16.1      |
| Gorman 220 kV           | 9.6                      | 9.6       | 8.8       | 10.3         | 8.3       | 8.1       | 8.5              | 12.2      | 11.6      | 9.6          | 9.8       | 9.6       |
| Gortawee 110 kV         | 4.3                      | 5.5       | 5.2       | 5.7          | 4.7       | 4.6       | 4.4              | 6.7       | 6.2       | 6.0          | 5.2       | 5.1       |
| Grange 110 kV           | 12.9                     | 9.6       | 8.8       | 4.6          | 10.2      | 9.9       | 12.9             | 12.7      | 11.2      | 4.3          | 12.4      | 11.9      |
| Grange Castle 110 kV    | 12.9                     | 11.2      | 10.1      | 9.2          | 14.1      | 13.4      | 18.2             | 13.5      | 11.8      | 12.8         | 14.7      | 13.9      |
| Great Island 110 kV     | 7.9                      | 11.1      | 10.4      | 8.7          | 14.5      | 14.1      | 6.9              | 13.7      | 12.6      | 7.8          | 17.3      | 16.7      |
| Great Island 220 kV     | 12.4                     | 10.3      | 9.6       | 13.8         | 12.5      | 12.1      | 10.6             | 12.5      | 11.7      | 12.0         | 14.4      | 14.0      |
| Griffinrath A 110 kV    | 7.6                      | 9.0       | 8.4       | 7.8          | 9.3       | 9.1       | 7.0              | 11.0      | 10.4      | 7.4          | 10.9      | 10.7      |
| Griffinrath B 110 kV    | 8.2                      | 9.2       | 8.7       | 8.0          | 9.3       | 9.1       | 7.6              | 11.4      | 10.7      | 7.5          | 10.9      | 10.6      |
| Harolds 110 kV          | 11.5                     | 10.0      | 9.2       | 5.5          | 12.3      | 11.8      | 11.2             | 12.2      | 11.1      | 5.2          | 14.5      | 13.9      |
| Heuston 110 kV          | 14.1                     | 11.1      | 10.3      | 8.3          | 13.7      | 13.3      | 13.8             | 13.6      | 12.5      | 7.8          | 16.4      | 15.8      |
| Huntstown A 220 kV      | 14.0                     | 13.6      | 12.1      | 12.7         | 17.5      | 16.5      | 15.6             | 24.2      | 21.2      | 12.9         | 28.3      | 26.7      |
| Huntstown B 220 kV      | 15.1                     | 13.9      | 12.4      | 11.7         | 17.3      | 16.4      | 14.7             | 22.7      | 20.1      | 10.4         | 26.0      | 24.8      |
| Ikerrin 110 kV          | 5.2                      | 4.1       | 3.9       | 6.0          | 3.2       | 3.1       | 5.8              | 5.6       | 5.1       | 6.5          | 3.8       | 3.7       |
| Inchicore 220 kV        | 14.5                     | 16.2      | 14.0      | 11.3         | 20.2      | 18.9      | 13.7             | 25.6      | 22.1      | 10.0         | 29.5      | 27.8      |
| Inchicore A 110 kV      | 27.0                     | 12.1      | 11.1      | 24.4         | 15.3      | 14.8      | 29.6             | 15.1      | 13.7      | 25.8         | 18.6      | 17.9      |
| Inchicore B 110 kV      | 38.3                     | 12.1      | 10.9      | 31.8         | 15.5      | 14.8      | 46.7             | 15.5      | 13.5      | 35.5         | 19.2      | 18.1      |
| Inniscarra 110 kV       | 5.1                      | 7.3       | 6.8       | 6.2          | 7.2       | 7.0       | 4.7              | 10.8      | 10.0      | 6.1          | 9.2       | 8.9       |
| Irishtown 220 kV        | 15.2                     | 15.4      | 13.3      | 12.5         | 19.4      | 18.2      | 15.2             | 24.2      | 20.9      | 11.5         | 28.3      | 26.7      |
| Kellis 110 kV           | 6.4                      | 7.8       | 7.4       | 7.4          | 9.3       | 9.1       | 6.2              | 9.8       | 9.1       | 7.3          | 11.2      | 10.9      |
| Kellis 220 kV           | 8.2                      | 7.0       | 6.7       | 9.9          | 6.2       | 6.1       | 7.7              | 8.5       | 8.1       | 9.6          | 7.0       | 6.9       |
| Kilbarry 110 kV         | 7.5                      | 12.9      | 11.3      | 8.0          | 14.5      | 13.8      | 7.2              | 23.8      | 20.6      | 8.0          | 22.5      | 21.4      |



TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-2 Short Circuit Currents for Maximum and Minimum Demand in 2015 (Continued)

| Bus                 | Summer Night Valley 2015 |           |            |              |           |            | Winter Peak 2015 |           |            |              |           |            |
|---------------------|--------------------------|-----------|------------|--------------|-----------|------------|------------------|-----------|------------|--------------|-----------|------------|
|                     | Three-Phase              |           |            | Single-Phase |           |            | Three-Phase      |           |            | Single-Phase |           |            |
|                     | X/R Ratio                | Ik'' [kA] | Ik''' [kA] | X/R Ratio    | Ik'' [kA] | Ik''' [kA] | X/R Ratio        | Ik'' [kA] | Ik''' [kA] | X/R Ratio    | Ik'' [kA] | Ik''' [kA] |
| Kildonan 110 kV     | 9.2                      | 15.5      | 14.1       | 6.5          | 13.9      | 13.5       | 8.9              | 21.7      | 20.0       | 6.6          | 18.1      | 17.7       |
| Kilkenny 110 kV     | 3.0                      | 4.7       | 4.5        | 4.3          | 4.3       | 4.2        | 3.0              | 5.6       | 5.2        | 4.3          | 4.8       | 4.7        |
| Kill Hill 110 kV    | 4.4                      | 4.7       | 4.5        | 5.4          | 4.4       | 4.3        | 5.5              | 7.1       | 6.4        | 6.6          | 5.6       | 5.5        |
| Kilnaparson 110kV   | 5.1                      | 5.7       | 5.4        | 6.8          | 4.5       | 4.5        | 4.9              | 6.5       | 6.2        | 6.7          | 5.0       | 4.9        |
| Killonan 110 kV     | 6.6                      | 12.5      | 11.2       | 7.6          | 14.6      | 13.9       | 6.4              | 20.7      | 18.4       | 7.9          | 21.2      | 20.3       |
| Killonan 220 kV     | 7.7                      | 7.2       | 6.6        | 9.5          | 7.5       | 7.3        | 7.6              | 11.5      | 10.7       | 10.0         | 10.3      | 10.1       |
| Killoteran 110 kV   | 6.3                      | 9.7       | 9.1        | 5.4          | 10.8      | 10.5       | 5.7              | 11.9      | 10.9       | 5.0          | 12.6      | 12.2       |
| Kilmahud 110 kV     | 11.2                     | 10.9      | 9.8        | 7.4          | 13.5      | 12.9       | 17.7             | 13.4      | 11.7       | 12.1         | 14.5      | 13.8       |
| Kilmore 110 kV      | 14.6                     | 9.8       | 9.0        | 9.7          | 11.2      | 10.8       | 14.9             | 13.0      | 11.4       | 9.3          | 13.9      | 13.2       |
| Kilteel 110 kV      | 4.6                      | 6.8       | 6.4        | 5.6          | 6.3       | 6.2        | 4.3              | 8.2       | 7.7        | 5.4          | 7.2       | 7.0        |
| Kinnegad 110 kV     | 5.2                      | 4.2       | 4.0        | 6.4          | 4.2       | 4.1        | 5.8              | 5.7       | 5.3        | 7.3          | 5.1       | 5.0        |
| Knockacummer 110 kV | 2.9                      | 2.3       | 2.2        | 3.2          | 2.9       | 2.8        | 4.1              | 4.0       | 3.3        | 4.7          | 4.4       | 4.1        |
| Knockanure 110 kV   | -                        | -         | -          | -            | -         | -          | 15.1             | 12.0      | 10.0       | 14.1         | 12.2      | 11.5       |
| Knockanure 220 kV   | -                        | -         | -          | -            | -         | -          | 8.5              | 10.6      | 9.5        | 9.4          | 10.5      | 10.1       |
| Knockearagh 110 kV  | 5.5                      | 4.5       | 4.3        | 6.7          | 4.5       | 4.4        | 5.6              | 7.6       | 6.9        | 7.1          | 6.2       | 6.1        |
| Knockraha A 110 kV  | 9.3                      | 14.4      | 12.6       | 9.9          | 16.0      | 15.2       | 9.0              | 26.0      | 22.9       | 9.8          | 24.3      | 23.3       |
| Knockraha A 220 kV  | 10.3                     | 9.1       | 8.1        | 10.6         | 11.1      | 10.5       | 11.2             | 19.3      | 17.1       | 11.2         | 19.6      | 18.8       |
| Knockraha B 110 kV  | 9.3                      | 14.4      | 12.6       | 9.9          | 16.0      | 15.2       | 9.0              | 26.0      | 22.9       | 9.8          | 24.3      | 23.3       |
| Knockraha B 220 kV  | 10.3                     | 9.1       | 8.1        | 10.6         | 11.1      | 10.5       | 11.2             | 19.3      | 17.1       | 11.2         | 19.6      | 18.8       |
| Knockraha C 110 kV  | 9.3                      | 14.4      | 12.6       | 9.9          | 16.0      | 15.2       | 9.0              | 26.0      | 22.9       | 9.8          | 24.3      | 23.3       |
| Knockumber 110 kV   | 3.9                      | 7.6       | 7.1        | 4.7          | 5.8       | 5.7        | 3.6              | 8.8       | 8.2        | 4.5          | 6.3       | 6.2        |
| Lanesboro 110 kV    | 4.2                      | 9.1       | 8.3        | 5.4          | 9.4       | 9.1        | 3.7              | 10.6      | 9.7        | 4.9          | 10.5      | 10.2       |
| Letterkenny 110 kV  | 3.7                      | 5.4       | 5.0        | 4.4          | 6.2       | 6.1        | 4.3              | 9.2       | 7.8        | 5.4          | 9.0       | 8.5        |
| Liberty A 110 kV    | 6.3                      | 11.5      | 10.2       | 5.5          | 13.5      | 12.9       | 5.7              | 20.0      | 17.6       | 4.8          | 20.5      | 19.5       |
| Liberty B 110 kV    | 6.2                      | 11.4      | 10.2       | 5.3          | 13.5      | 12.8       | 5.6              | 19.9      | 17.5       | 4.7          | 20.4      | 19.5       |
| Limerick 110 kV     | 5.5                      | 11.2      | 10.1       | 6.2          | 11.5      | 11.0       | 5.0              | 17.6      | 15.8       | 6.0          | 15.5      | 15.0       |
| Lisdrum 110 kV      | 2.9                      | 4.6       | 4.5        | 4.1          | 4.1       | 4.0        | 2.7              | 5.3       | 5.0        | 4.1          | 4.4       | 4.3        |
| Lisheen 110 kV      | 3.9                      | 3.2       | 3.0        | 3.9          | 4.8       | 4.6        | 5.0              | 5.2       | 4.4        | 5.0          | 7.7       | 7.2        |
| Lodgewood 110 kV    | 8.5                      | 7.2       | 6.9        | 8.9          | 9.1       | 8.9        | 8.8              | 9.3       | 8.7        | 9.0          | 11.0      | 10.7       |
| Lodgewood 220 kV    | 9.0                      | 6.5       | 6.2        | 10.2         | 6.5       | 6.4        | 8.8              | 8.0       | 7.6        | 9.9          | 7.5       | 7.3        |
| Longpoint 220 kV    | 8.8                      | 7.4       | 6.7        | 9.2          | 9.7       | 9.3        | 12.5             | 17.5      | 15.6       | 12.3         | 19.5      | 18.6       |
| Louth 220 kV        | 10.7                     | 12.6      | 11.2       | 11.6         | 15.0      | 14.3       | 9.4              | 18.9      | 17.4       | 10.6         | 20.6      | 19.9       |
| Louth A 110 kV      | 7.3                      | 11.0      | 10.2       | 8.3          | 13.5      | 13.0       | 6.6              | 13.6      | 12.7       | 7.7          | 16.1      | 15.6       |
| Louth B 110 kV      | 7.9                      | 11.8      | 10.9       | 8.7          | 14.8      | 14.3       | 7.1              | 14.7      | 13.7       | 8.0          | 17.8      | 17.3       |
| Macetown 110 kV     | 7.9                      | 15.2      | 13.8       | 7.6          | 15.3      | 14.8       | 7.3              | 20.2      | 18.6       | 7.3          | 18.9      | 18.4       |
| Macroom 110 kV      | 6.6                      | 9.1       | 8.3        | 7.1          | 9.1       | 8.8        | 6.3              | 15.0      | 13.6       | 7.1          | 12.5      | 12.2       |
| Mallow 110 kV       | 5.3                      | 5.6       | 5.2        | 6.8          | 4.9       | 4.8        | 5.1              | 7.4       | 6.9        | 6.9          | 5.9       | 5.8        |
| Marina 110 kV       | 7.2                      | 12.3      | 10.9       | 8.0          | 14.7      | 14.0       | 7.1              | 22.7      | 19.7       | 8.3          | 23.2      | 22.1       |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-2 Short Circuit Currents for Maximum and Minimum Demand in 2015 (Continued)

| Bus                  | Summer Night Valley 2015 |                        |                         |              |                        |                         | Winter Peak 2015 |                        |                         |              |                        |                         |
|----------------------|--------------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|
|                      | Three-Phase              |                        |                         | Single-Phase |                        |                         | Three-Phase      |                        |                         | Single-Phase |                        |                         |
|                      | X/R Ratio                | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio        | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] |
| Maynooth A 110 kV    | 11.8                     | 10.9                   | 10.2                    | 12.3         | 13.6                   | 13.2                    | 11.2             | 13.9                   | 12.9                    | 11.9         | 16.7                   | 16.2                    |
| Maynooth A 220 kV    | 11.3                     | 13.7                   | 12.2                    | 10.7         | 13.7                   | 13.1                    | 9.7              | 18.9                   | 17.2                    | 9.6          | 17.2                   | 16.7                    |
| Maynooth B 110 kV    | 8.9                      | 14.6                   | 13.3                    | 10.4         | 14.5                   | 14.0                    | 7.8              | 18.3                   | 17.0                    | 9.4          | 17.2                   | 16.8                    |
| Maynooth B 220 kV    | 11.8                     | 15.1                   | 13.3                    | 10.9         | 15.2                   | 14.5                    | 9.8              | 22.1                   | 20.0                    | 9.6          | 19.9                   | 19.3                    |
| McDermott 110 kV     | 15.5                     | 9.9                    | 9.1                     | 6.4          | 11.7                   | 11.4                    | 16.1             | 12.8                   | 11.5                    | 6.0          | 14.6                   | 14.0                    |
| Meath Hill 110 kV    | 4.1                      | 7.9                    | 7.4                     | 5.2          | 6.7                    | 6.6                     | 3.8              | 9.4                    | 8.8                     | 5.1          | 7.5                    | 7.4                     |
| Meentycat 110 kV     | 3.2                      | 4.0                    | 3.8                     | 4.0          | 4.1                    | 4.0                     | 3.7              | 6.3                    | 5.5                     | 5.0          | 5.3                    | 5.1                     |
| Midleton 110 kV      | 4.1                      | 8.3                    | 7.6                     | 5.0          | 7.1                    | 6.9                     | 3.4              | 11.6                   | 10.8                    | 4.6          | 8.7                    | 8.5                     |
| Milltown A 110 kV    | 15.1                     | 10.7                   | 9.8                     | 7.5          | 13.3                   | 12.8                    | 15.0             | 13.2                   | 11.9                    | 7.1          | 15.9                   | 15.2                    |
| Milltown B 110 kV    | 9.2                      | 9.9                    | 9.3                     | 4.3          | 12.0                   | 11.6                    | 8.8              | 12.0                   | 11.1                    | 4.0          | 14.1                   | 13.6                    |
| Misery Hill 110 kV   | 13.8                     | 10.5                   | 9.6                     | 8.2          | 13.1                   | 12.7                    | 13.6             | 12.9                   | 11.7                    | 7.8          | 15.7                   | 15.0                    |
| Moneteen 110 kV      | 5.7                      | 8.8                    | 8.0                     | 6.5          | 7.2                    | 7.1                     | 5.3              | 12.0                   | 11.1                    | 6.3          | 8.6                    | 8.4                     |
| Moneypoint 110 kV    | 2.5                      | 2.1                    | 2.0                     | 3.7          | 1.5                    | 1.5                     | 2.9              | 2.7                    | 2.5                     | 4.2          | 1.7                    | 1.7                     |
| Moneypoint 220 kV    | 8.5                      | 5.1                    | 4.8                     | 8.3          | 6.0                    | 5.9                     | 12.5             | 10.5                   | 9.8                     | 9.9          | 10.1                   | 9.9                     |
| Moneypoint G1 400 kV | 19.7                     | 4.9                    | 4.5                     | 17.8         | 5.5                    | 5.3                     | 23.3             | 7.2                    | 6.8                     | 18.9         | 7.1                    | 6.9                     |
| Moneypoint G2 400 kV | 13.3                     | 1.9                    | 1.8                     | 13.7         | 2.4                    | 2.3                     | 29.1             | 3.9                    | 3.7                     | 23.1         | 4.1                    | 4.0                     |
| Moneypoint G3 400 kV | 19.7                     | 4.9                    | 4.5                     | 17.8         | 5.5                    | 5.3                     | 23.3             | 7.2                    | 6.8                     | 18.9         | 7.1                    | 6.9                     |
| Monread 110 kV       | 4.3                      | 6.7                    | 6.3                     | 5.1          | 6.8                    | 6.6                     | 4.0              | 8.1                    | 7.6                     | 5.0          | 7.8                    | 7.6                     |
| Mount Lucas 110 kV   | 4.5                      | 4.2                    | 3.9                     | 5.6          | 4.1                    | 4.0                     | 5.1              | 5.9                    | 5.5                     | 6.5          | 5.1                    | 5.0                     |
| Moy 110 kV           | 2.7                      | 2.9                    | 2.8                     | 3.1          | 3.5                    | 3.5                     | 4.0              | 4.9                    | 4.5                     | 5.0          | 5.2                    | 5.0                     |
| Mullagharlin 110 kV  | 3.9                      | 7.9                    | 7.4                     | 4.9          | 7.8                    | 7.6                     | 3.5              | 9.3                    | 8.7                     | 4.6          | 8.8                    | 8.6                     |
| Mullingar 110 kV     | 2.8                      | 4.1                    | 3.9                     | 3.9          | 4.2                    | 4.1                     | 2.7              | 4.6                    | 4.3                     | 3.8          | 4.7                    | 4.5                     |
| Mungret A 110 kV     | 5.4                      | 8.4                    | 7.7                     | 6.1          | 6.8                    | 6.6                     | 4.9              | 11.4                   | 10.5                    | 5.9          | 8.0                    | 7.8                     |
| Mungret B 110 kV     | 5.4                      | 8.5                    | 7.7                     | 6.1          | 6.8                    | 6.6                     | 4.9              | 11.4                   | 10.5                    | 5.9          | 8.0                    | 7.8                     |
| Nangor 110 kV        | 11.8                     | 11.0                   | 9.9                     | 7.7          | 13.7                   | 13.1                    | 15.7             | 13.2                   | 11.5                    | 10.2         | 14.2                   | 13.5                    |
| Navan 110 kV         | 5.8                      | 11.0                   | 10.2                    | 6.5          | 11.0                   | 10.7                    | 5.2              | 13.6                   | 12.5                    | 6.1          | 12.8                   | 12.5                    |
| Nenagh 110 kV        | 2.7                      | 3.2                    | 3.1                     | 3.8          | 1.9                    | 1.9                     | 2.7              | 3.9                    | 3.6                     | 3.9          | 2.1                    | 2.1                     |
| Newbridge 110 kV     | 4.6                      | 8.4                    | 7.8                     | 5.2          | 8.4                    | 8.2                     | 4.3              | 11.0                   | 10.0                    | 5.1          | 10.2                   | 9.9                     |
| Newbury 110kV        | 13.9                     | 9.8                    | 8.9                     | 7.3          | 10.9                   | 10.5                    | 14.0             | 12.8                   | 11.3                    | 6.9          | 13.4                   | 12.8                    |
| North Quays 110 kV   | 17.9                     | 10.9                   | 9.9                     | 7.1          | 13.3                   | 12.8                    | 18.1             | 13.4                   | 12.1                    | 6.6          | 15.9                   | 15.3                    |
| North Wall 220 kV    | 13.7                     | 13.0                   | 11.6                    | 9.5          | 15.5                   | 14.7                    | 14.7             | 22.7                   | 19.9                    | 8.5          | 23.7                   | 22.6                    |
| Oldcourt A 110 kV    | 4.4                      | 8.2                    | 7.6                     | 4.8          | 6.9                    | 6.8                     | 3.6              | 11.6                   | 10.8                    | 4.4          | 8.4                    | 8.2                     |
| Oldcourt B 100 kV    | 4.4                      | 8.2                    | 7.6                     | 4.8          | 6.9                    | 6.8                     | 3.6              | 11.6                   | 10.9                    | 4.4          | 8.5                    | 8.3                     |
| Oldstreet 220 kV     | 13.2                     | 6.8                    | 6.4                     | 11.9         | 8.0                    | 7.8                     | 15.2             | 11.0                   | 10.4                    | 12.5         | 11.6                   | 11.4                    |
| Oldstreet 400 kV     | 15.7                     | 5.3                    | 4.9                     | 11.2         | 5.5                    | 5.3                     | 17.7             | 7.7                    | 7.3                     | 10.9         | 7.2                    | 7.0                     |
| Oughtagh 110 kV      | 3.8                      | 3.8                    | 3.6                     | 4.8          | 2.7                    | 2.7                     | 3.7              | 4.9                    | 4.6                     | 4.8          | 3.1                    | 3.0                     |
| Pelletstown 110 kV   | 13.7                     | 9.4                    | 8.7                     | 8.1          | 10.4                   | 10.1                    | 13.9             | 12.1                   | 10.9                    | 7.8          | 12.7                   | 12.2                    |
| Platin 110 kV        | 5.3                      | 10.9                   | 10.1                    | 5.8          | 8.6                    | 8.4                     | 4.7              | 13.4                   | 12.4                    | 5.5          | 9.7                    | 9.5                     |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-2 Short Circuit Currents for Maximum and Minimum Demand in 2015 (Continued)

| Bus                  | Summer Night Valley 2015 |                        |                         |              |                        |                         | Winter Peak 2015 |                        |                         |              |                        |                         |
|----------------------|--------------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|
|                      | Three-Phase              |                        |                         | Single-Phase |                        |                         | Three-Phase      |                        |                         | Single-Phase |                        |                         |
|                      | X/R Ratio                | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio        | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] |
| Pollaphuca 110 kV    | 2.8                      | 2.4                    | 2.3                     | 4.0          | 2.2                    | 2.2                     | 3.3              | 3.1                    | 3.0                     | 4.7          | 2.6                    | 2.6                     |
| Poolbeg A 110 kV     | 23.9                     | 11.3                   | 10.3                    | 20.7         | 14.5                   | 13.9                    | 25.6             | 14.1                   | 12.7                    | 21.3         | 17.5                   | 16.8                    |
| Poolbeg A 220 kV     | 14.3                     | 13.1                   | 11.7                    | 8.3          | 14.8                   | 14.1                    | 15.5             | 22.8                   | 20.0                    | 7.2          | 22.3                   | 21.3                    |
| Poolbeg B 110 kV     | 23.9                     | 11.3                   | 10.3                    | 20.7         | 14.5                   | 13.9                    | 25.6             | 14.0                   | 12.7                    | 21.3         | 17.5                   | 16.8                    |
| Poolbeg B 220 kV     | 13.9                     | 15.3                   | 13.3                    | 10.7         | 18.0                   | 17.0                    | 13.1             | 23.5                   | 20.5                    | 9.6          | 25.4                   | 24.1                    |
| Poolbeg C 110 kV     | 19.6                     | 11.1                   | 10.1                    | 8.1          | 13.6                   | 13.1                    | 20.2             | 13.7                   | 12.4                    | 7.7          | 16.3                   | 15.6                    |
| Poppintree 110 kV    | 15.4                     | 10.1                   | 9.2                     | 9.8          | 11.5                   | 11.1                    | 15.9             | 13.3                   | 11.8                    | 9.5          | 14.2                   | 13.6                    |
| Portan 400 kV        | 20.1                     | 6.3                    | 5.8                     | 19.1         | 7.3                    | 7.0                     | 19.6             | 8.9                    | 8.5                     | 18.9         | 10.0                   | 9.8                     |
| Portlaoise 110 kV    | 4.2                      | 7.2                    | 6.7                     | 5.5          | 6.2                    | 6.1                     | 3.9              | 9.1                    | 8.4                     | 5.4          | 7.3                    | 7.1                     |
| Pottery 110 kV       | 13.1                     | 13.5                   | 12.2                    | 4.4          | 13.7                   | 13.2                    | 12.7             | 17.5                   | 15.5                    | 4.1          | 16.4                   | 15.7                    |
| Prospect 220 kV      | 8.0                      | 6.1                    | 5.6                     | 8.2          | 7.4                    | 7.1                     | 11.1             | 13.6                   | 12.4                    | 9.9          | 13.4                   | 13.0                    |
| Raffeen 220 kV       | 11.2                     | 8.6                    | 7.6                     | 11.2         | 11.1                   | 10.5                    | 12.4             | 18.4                   | 16.3                    | 11.7         | 20.9                   | 19.9                    |
| Raffeen A 110 kV     | 6.5                      | 10.6                   | 9.5                     | 7.1          | 13.0                   | 12.4                    | 5.6              | 16.7                   | 15.2                    | 6.5          | 18.8                   | 18.1                    |
| Raffeen B 110 kV     | 8.9                      | 10.3                   | 9.2                     | 9.6          | 12.6                   | 12.0                    | 8.7              | 16.1                   | 14.6                    | 9.6          | 18.1                   | 17.4                    |
| Rathkeale 110 kV     | 3.6                      | 5.8                    | 5.4                     | 4.8          | 4.9                    | 4.8                     | 3.4              | 7.9                    | 7.4                     | 4.8          | 5.9                    | 5.8                     |
| Ratrussan 110 kV     | 3.1                      | 5.8                    | 5.5                     | 3.9          | 6.6                    | 6.5                     | 3.6              | 8.0                    | 6.8                     | 4.7          | 8.3                    | 7.8                     |
| Reamore 110 kV       | 4.5                      | 5.1                    | 4.8                     | 3.6          | 5.0                    | 4.9                     | 4.5              | 7.0                    | 6.3                     | 3.6          | 5.9                    | 5.8                     |
| Richmond A 110 kV    | 3.3                      | 6.3                    | 5.9                     | 4.5          | 5.7                    | 5.6                     | 3.1              | 7.2                    | 6.7                     | 4.3          | 6.4                    | 6.2                     |
| Richmond B 110 kV    | 3.3                      | 6.3                    | 5.9                     | 4.5          | 5.7                    | 5.6                     | 3.1              | 7.2                    | 6.7                     | 4.3          | 6.4                    | 6.2                     |
| Rinawade 110 kV      | 5.2                      | 9.3                    | 8.7                     | 6.1          | 7.1                    | 6.9                     | 4.8              | 11.1                   | 10.6                    | 5.9          | 7.9                    | 7.8                     |
| Ringaskiddy 110 kV   | 6.5                      | 8.9                    | 8.1                     | 6.7          | 9.3                    | 9.0                     | 5.7              | 13.1                   | 12.1                    | 6.2          | 12.2                   | 11.9                    |
| Ringsend 110 kV      | 23.9                     | 11.3                   | 10.3                    | 21.4         | 14.5                   | 13.9                    | 25.5             | 14.1                   | 12.7                    | 22.1         | 17.6                   | 16.8                    |
| Ryebrook 110 kV      | 6.0                      | 12.9                   | 11.7                    | 7.0          | 11.4                   | 11.1                    | 5.1              | 15.4                   | 14.3                    | 6.2          | 13.2                   | 12.9                    |
| Salthill 110 kV      | 4.4                      | 8.5                    | 7.9                     | 4.1          | 9.3                    | 9.0                     | 4.2              | 11.4                   | 10.4                    | 3.9          | 11.5                   | 11.1                    |
| Screeb 110 kV        | 3.4                      | 2.3                    | 2.2                     | 4.4          | 1.4                    | 1.3                     | 3.3              | 2.6                    | 2.4                     | 4.3          | 1.4                    | 1.4                     |
| Seal Rock A 110 kV   | 8.6                      | 8.6                    | 7.6                     | 10.3         | 9.6                    | 9.2                     | 7.7              | 10.5                   | 9.4                     | 9.5          | 11.0                   | 10.6                    |
| Seal Rock B 110 kV   | 8.7                      | 8.6                    | 7.6                     | 10.3         | 9.6                    | 9.2                     | 7.7              | 10.5                   | 9.4                     | 9.5          | 11.0                   | 10.6                    |
| Shankill 110 kV      | 3.5                      | 7.0                    | 6.5                     | 4.5          | 6.6                    | 6.4                     | 3.5              | 9.1                    | 8.0                     | 4.7          | 7.9                    | 7.6                     |
| Shannonbridge 110 kV | 7.1                      | 14.0                   | 12.4                    | 8.7          | 15.9                   | 15.2                    | 6.1              | 17.2                   | 15.4                    | 7.7          | 18.7                   | 17.9                    |
| Shannonbridge 220 kV | 8.2                      | 6.2                    | 5.8                     | 10.5         | 5.6                    | 5.5                     | 7.2              | 7.6                    | 7.3                     | 9.8          | 6.4                    | 6.3                     |
| Shellybanks A 220 kV | 14.1                     | 13.1                   | 11.6                    | 8.3          | 16.2                   | 15.4                    | 15.3             | 22.7                   | 20.0                    | 7.0          | 25.5                   | 24.2                    |
| Shellybanks B 220 kV | 14.5                     | 14.9                   | 12.9                    | 11.0         | 18.6                   | 17.5                    | 14.6             | 23.3                   | 20.3                    | 10.0         | 27.0                   | 25.4                    |
| Shelton Abbey 110 kV | 7.6                      | 6.8                    | 6.5                     | 7.6          | 7.3                    | 7.2                     | 7.3              | 8.3                    | 7.8                     | 7.4          | 8.5                    | 8.3                     |
| Singland 110 kV      | 6.2                      | 10.7                   | 9.7                     | 7.1          | 11.4                   | 11.0                    | 6.2              | 16.8                   | 15.2                    | 7.4          | 15.5                   | 15.0                    |
| Sligo 110 kV         | 3.8                      | 6.9                    | 6.4                     | 4.5          | 7.0                    | 6.8                     | 3.7              | 10.0                   | 9.0                     | 4.7          | 8.9                    | 8.6                     |
| Somerset 110 kV      | 3.2                      | 6.9                    | 6.5                     | 4.1          | 4.6                    | 4.5                     | 2.9              | 8.1                    | 7.6                     | 4.0          | 5.1                    | 5.0                     |
| Sorne Hill 110 kV    | 2.7                      | 2.2                    | 2.1                     | 3.3          | 2.6                    | 2.5                     | 3.5              | 3.6                    | 3.2                     | 4.4          | 3.6                    | 3.5                     |
| Srananagh 110 kV     | 4.6                      | 7.8                    | 7.3                     | 5.3          | 9.0                    | 8.8                     | 4.7              | 11.7                   | 10.4                    | 5.7          | 12.2                   | 11.6                    |

## TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-2 Short Circuit Currents for Maximum and Minimum Demand in 2015 (Continued)

| Bus                  | Summer Night Valley 2015 |                       |                       |              |                       |                       | Winter Peak 2015 |                       |                       |              |                       |                       |
|----------------------|--------------------------|-----------------------|-----------------------|--------------|-----------------------|-----------------------|------------------|-----------------------|-----------------------|--------------|-----------------------|-----------------------|
|                      | Three-Phase              |                       |                       | Single-Phase |                       |                       | Three-Phase      |                       |                       | Single-Phase |                       |                       |
|                      | X/R Ratio                | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio    | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio        | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio    | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] |
| Srananagh 220 kV     | 6.5                      | 3.8                   | 3.7                   | 8.6          | 3.3                   | 3.3                   | 7.3              | 4.9                   | 4.6                   | 9.7          | 3.8                   | 3.8                   |
| Stevenstown 110 kV   | 4.8                      | 5.2                   | 4.9                   | 5.2          | 3.6                   | 3.5                   | 4.6              | 6.1                   | 5.7                   | 5.1          | 3.9                   | 3.8                   |
| Stratford 110 kV     | 3.2                      | 3.6                   | 3.5                   | 4.1          | 3.0                   | 2.9                   | 3.4              | 4.6                   | 4.3                   | 4.4          | 3.4                   | 3.3                   |
| Taney 110 kV         | 7.2                      | 11.3                  | 10.4                  | 2.7          | 10.9                  | 10.6                  | 6.6              | 14.1                  | 12.7                  | 2.5          | 12.7                  | 12.3                  |
| Tarbert 110 kV       | 8.3                      | 10.5                  | 9.5                   | 9.5          | 12.4                  | 11.9                  | 12.3             | 20.8                  | 18.6                  | 14.5         | 19.3                  | 18.6                  |
| Tarbert 220 kV       | 8.2                      | 6.5                   | 6.0                   | 9.0          | 8.5                   | 8.2                   | 13.4             | 16.3                  | 14.4                  | 14.5         | 18.1                  | 17.3                  |
| Tawnaghmore A 110 kV | 2.6                      | 2.5                   | 2.4                   | 3.2          | 2.8                   | 2.8                   | 3.8              | 4.0                   | 3.8                   | 5.0          | 3.9                   | 3.8                   |
| Tawnaghmore B 110 kV | 2.6                      | 2.5                   | 2.4                   | 3.1          | 3.1                   | 3.0                   | 3.9              | 4.1                   | 3.8                   | 5.0          | 4.4                   | 4.2                   |
| Thornsberry 110 kV   | 3.6                      | 2.7                   | 2.6                   | 4.5          | 2.9                   | 2.9                   | 3.8              | 3.9                   | 3.6                   | 5.0          | 3.8                   | 3.7                   |
| Thurles 110 kV       | 4.8                      | 4.1                   | 3.9                   | 5.2          | 4.7                   | 4.6                   | 6.1              | 6.5                   | 5.6                   | 6.4          | 6.7                   | 6.3                   |
| Tipperary 110 kV     | 3.1                      | 5.5                   | 5.2                   | 4.0          | 3.7                   | 3.7                   | 4.0              | 7.4                   | 6.9                   | 5.2          | 4.6                   | 4.5                   |
| Tonroe 110 kV        | 2.7                      | 3.0                   | 3.0                   | 3.7          | 1.9                   | 1.9                   | 2.7              | 3.5                   | 3.3                   | 3.8          | 2.1                   | 2.1                   |
| Trabeg 110 kV        | 7.2                      | 12.3                  | 10.8                  | 7.8          | 14.4                  | 13.7                  | 7.1              | 22.3                  | 19.4                  | 8.0          | 22.6                  | 21.4                  |
| Tralee 110 kV        | 5.0                      | 6.3                   | 5.8                   | 5.8          | 6.2                   | 6.0                   | 5.2              | 9.0                   | 8.0                   | 6.3          | 7.5                   | 7.2                   |
| Trien A 110 kV       | 4.5                      | 5.7                   | 5.3                   | 5.0          | 6.8                   | 6.6                   | 3.2              | 4.2                   | 3.8                   | 4.4          | 4.0                   | 3.8                   |
| Trien B 110 kV       | 4.5                      | 5.7                   | 5.3                   | 5.0          | 6.8                   | 6.6                   | 10.7             | 9.4                   | 7.8                   | 8.9          | 8.9                   | 8.3                   |
| Trillick 110 kV      | 2.7                      | 2.4                   | 2.3                   | 3.4          | 2.6                   | 2.6                   | 3.6              | 4.0                   | 3.4                   | 4.5          | 3.6                   | 3.5                   |
| Tullabrack 110 kV    | 2.6                      | 2.2                   | 2.1                   | 3.7          | 1.6                   | 1.6                   | 2.9              | 2.9                   | 2.6                   | 4.2          | 1.8                   | 1.8                   |
| Turlough 220 kV      | 12.2                     | 10.8                  | 9.7                   | 13.4         | 9.9                   | 9.6                   | 10.7             | 12.8                  | 11.9                  | 12.3         | 11.1                  | 10.8                  |
| Tynagh 220 kV        | 10.4                     | 6.5                   | 6.2                   | 11.4         | 8.2                   | 8.0                   | 14.8             | 12.4                  | 11.4                  | 16.5         | 13.3                  | 13.0                  |
| Waterford 110 kV     | 7.5                      | 10.5                  | 9.8                   | 7.6          | 11.8                  | 11.5                  | 6.7              | 13.0                  | 12.0                  | 7.0          | 14.0                  | 13.6                  |
| Wexford 110 kV       | 4.0                      | 5.6                   | 5.4                   | 5.1          | 5.2                   | 5.1                   | 4.1              | 7.2                   | 6.4                   | 5.3          | 6.1                   | 5.9                   |
| Whitegate 110 kV     | 4.8                      | 7.7                   | 7.1                   | 5.5          | 8.3                   | 8.1                   | 4.2              | 10.7                  | 10.1                  | 5.1          | 10.6                  | 10.4                  |
| Wolfe Tone 110 kV    | 14.0                     | 9.7                   | 9.0                   | 5.9          | 11.4                  | 11.1                  | 14.2             | 12.5                  | 11.3                  | 5.5          | 14.1                  | 13.5                  |
| Woodhouse 110 kV     | 6.0                      | 5.3                   | 5.0                   | 7.3          | 4.1                   | 4.0                   | 5.9              | 6.5                   | 6.1                   | 7.3          | 4.6                   | 4.6                   |
| Woodland 220 kV      | 14.3                     | 15.3                  | 13.5                  | 13.7         | 17.4                  | 16.5                  | 12.4             | 23.7                  | 21.4                  | 12.3         | 24.7                  | 23.8                  |
| Woodland 400 kV      | 21.2                     | 6.3                   | 5.8                   | 20.5         | 7.3                   | 7.1                   | 21.3             | 9.0                   | 8.5                   | 20.7         | 10.0                  | 9.8                   |

## TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-3 Short Circuit Currents for Maximum and Minimum Demand in 2018

| Bus                  | Summer Night Valley 2015 |           |           |              |           |           | Winter Peak 2015 |           |           |              |           |           |
|----------------------|--------------------------|-----------|-----------|--------------|-----------|-----------|------------------|-----------|-----------|--------------|-----------|-----------|
|                      | Three-Phase              |           |           | Single-Phase |           |           | Three-Phase      |           |           | Single-Phase |           |           |
|                      | X/R Ratio                | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] | X/R Ratio        | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] |
| Adamstown 110 kV     | 13.9                     | 10.8      | 9.6       | 8.8          | 12.0      | 11.5      | 13.7             | 13.6      | 11.8      | 8.4          | 14.4      | 13.7      |
| Agannygal 110 kV     | 2.8                      | 4.9       | 4.7       | 3.9          | 4.1       | 4.1       | 3.0              | 6.4       | 5.7       | 4.2          | 4.9       | 4.7       |
| Aghada 110 kV        | 5.1                      | 8.3       | 7.9       | 6.1          | 9.6       | 9.4       | 4.6              | 10.1      | 9.6       | 5.7          | 11.4      | 11.1      |
| Aghada A 220 kV      | 13.1                     | 11.8      | 10.6      | 12.4         | 14.7      | 14.1      | 15.6             | 22.3      | 19.6      | 16.6         | 26.4      | 25.0      |
| Aghada B 220 kV      | 13.1                     | 11.8      | 10.6      | 12.4         | 14.7      | 14.1      | 15.6             | 22.3      | 19.6      | 16.6         | 26.4      | 25.0      |
| Aghada C 220 kV      | 12.1                     | 12.0      | 10.8      | 13.1         | 14.5      | 13.9      | 15.6             | 22.3      | 19.6      | 16.6         | 26.4      | 25.0      |
| Aghada D 220 kV      | 11.8                     | 11.7      | 10.6      | 11.9         | 14.2      | 13.6      | 14.5             | 21.3      | 18.8      | 13.2         | 25.3      | 24.0      |
| Ahane 110 kV         | 5.6                      | 10.8      | 10.2      | 6.1          | 9.4       | 9.2       | 5.0              | 15.1      | 14.0      | 5.8          | 9.3       | 9.1       |
| Anner 110 kV         | 4.1                      | 5.9       | 5.6       | 4.5          | 4.4       | 4.4       | 4.0              | 7.5       | 7.0       | 4.5          | 5.1       | 5.0       |
| Ardnacrusha 110 kV   | 6.3                      | 11.8      | 10.9      | 7.5          | 13.1      | 12.7      | 6.5              | 18.2      | 16.5      | 8.5          | 16.9      | 16.4      |
| Ardnagappary 110 kV  | 2.8                      | 1.8       | 1.8       | 3.9          | 1.2       | 1.2       | 2.9              | 2.5       | 2.3       | 4.2          | 1.3       | 1.3       |
| Arigna 110 kV        | 4.4                      | 6.1       | 5.9       | 5.4          | 5.2       | 5.1       | 4.5              | 8.3       | 7.6       | 5.7          | 6.1       | 6.0       |
| Arklow 110 kV        | 10.3                     | 7.5       | 7.2       | 11.1         | 9.4       | 9.2       | 10.6             | 9.7       | 9.1       | 11.4         | 11.5      | 11.2      |
| Arklow 220 kV        | 9.1                      | 6.9       | 6.5       | 10.5         | 6.6       | 6.5       | 8.9              | 8.5       | 8.1       | 10.4         | 7.7       | 7.6       |
| Artane 110 kV        | 13.2                     | 9.7       | 9.1       | 6.3          | 11.8      | 11.5      | 13.3             | 12.4      | 11.3      | 5.9          | 14.5      | 14.0      |
| Arva 110 kV          | 3.9                      | 7.9       | 7.5       | 5.0          | 6.5       | 6.4       | 3.8              | 10.3      | 9.4       | 5.1          | 7.5       | 7.3       |
| Athea 110 kV         | 11.1                     | 6.8       | 6.6       | 10.9         | 7.7       | 7.6       | 11.8             | 11.8      | 9.9       | 11.2         | 11.3      | 10.6      |
| Athlone 110 kV       | 4.4                      | 7.2       | 6.8       | 5.8          | 5.5       | 5.4       | 4.1              | 8.4       | 7.8       | 5.5          | 5.9       | 5.8       |
| Athy 110 kV          | 3.2                      | 5.6       | 5.4       | 4.4          | 4.7       | 4.7       | 3.0              | 6.6       | 6.3       | 4.3          | 5.3       | 5.2       |
| Aughinish 110 kV     | 9.1                      | 9.6       | 8.6       | 11.0         | 10.7      | 10.2      | 8.2              | 11.2      | 10.0      | 10.2         | 11.8      | 11.4      |
| Ballybeg 110 kV      | 9.7                      | 5.9       | 5.7       | 10.0         | 7.1       | 7.0       | 9.8              | 7.1       | 6.8       | 10.0         | 8.2       | 8.1       |
| Ballydine 110 kV     | 4.1                      | 6.6       | 6.3       | 3.8          | 5.3       | 5.3       | 4.0              | 8.3       | 7.7       | 3.7          | 6.1       | 6.0       |
| Ballylickey 110 kV   | 2.8                      | 3.0       | 2.9       | 3.9          | 1.9       | 1.9       | 2.9              | 3.8       | 3.6       | 4.1          | 2.1       | 2.1       |
| Ballynahulla 110 kV  | 11.8                     | 7.5       | 7.2       | 11.6         | 8.2       | 8.1       | 13.2             | 11.4      | 10.3      | 12.3         | 10.9      | 10.6      |
| Ballynahulla 220 kV  | 7.0                      | 6.9       | 6.5       | 7.4          | 8.0       | 7.8       | 6.9              | 11.0      | 10.1      | 7.3          | 11.1      | 10.8      |
| Ballyragget 110 kV   | 11.8                     | 7.9       | 7.6       | 12.3         | 9.1       | 8.9       | 12.6             | 11.7      | 10.6      | 13.0         | 12.0      | 11.7      |
| Ballyvouskill 110 kV | 6.8                      | 7.5       | 7.1       | 7.5          | 9.2       | 8.9       | 6.4              | 12.2      | 11.1      | 7.4          | 13.2      | 12.8      |
| Ballyvouskill 220 kV | 11.8                     | 7.9       | 7.6       | 12.3         | 9.1       | 8.9       | 12.6             | 11.7      | 10.6      | 13.0         | 12.0      | 11.7      |
| Ballywater 110 kV    | 4.6                      | 4.9       | 4.8       | 3.3          | 5.2       | 5.2       | 4.6              | 6.2       | 5.8       | 3.2          | 6.0       | 5.9       |
| Baltrasna 110 kV     | 6.4                      | 9.6       | 9.1       | 7.5          | 7.6       | 7.5       | 5.9              | 11.3      | 10.8      | 7.2          | 8.4       | 8.3       |
| Bancroft 110 kV      | 12.5                     | 11.1      | 10.1      | 7.2          | 13.0      | 12.5      | 12.2             | 13.4      | 12.3      | 6.8          | 15.2      | 14.7      |
| Bandon 110 kV        | 3.3                      | 5.9       | 5.6       | 4.4          | 5.8       | 5.7       | 3.0              | 7.4       | 6.9       | 4.2          | 6.8       | 6.6       |
| Banoge 110 kV        | 6.1                      | 5.4       | 5.2       | 6.8          | 5.0       | 4.9       | 5.9              | 6.6       | 6.2       | 6.7          | 5.6       | 5.5       |
| Barnadivane 110 kV   | 4.2                      | 7.3       | 7.0       | 4.9          | 7.2       | 7.1       | 4.1              | 11.1      | 10.0      | 4.9          | 9.6       | 9.4       |
| Barnahealy A 110 kV  | 6.1                      | 11.2      | 10.4      | 6.6          | 11.7      | 11.4      | 5.3              | 14.7      | 13.6      | 6.0          | 14.3      | 13.9      |
| Barnahealy B 110 kV  | 7.4                      | 10.8      | 10.1      | 7.8          | 11.2      | 10.9      | 6.4              | 14.1      | 13.1      | 7.1          | 13.6      | 13.3      |
| Barnakyle 110 kV     | 18.8                     | 11.1      | 9.9       | 12.3         | 12.2      | 11.7      | 19.4             | 14.1      | 12.2      | 12.1         | 14.8      | 14.0      |
| Baroda 110 kV        | 4.2                      | 7.8       | 7.3       | 4.9          | 9.2       | 9.0       | 3.9              | 9.6       | 9.0       | 4.7          | 10.9      | 10.6      |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-3 Short Circuit Currents for Maximum and Minimum Demand in 2018 (Continued)

| Bus                       | Summer Night Valley 2015 |                        |                         |              |                        |                         | Winter Peak 2015 |                        |                         |              |                        |                         |
|---------------------------|--------------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|
|                           | Three-Phase              |                        |                         | Single-Phase |                        |                         | Three-Phase      |                        |                         | Single-Phase |                        |                         |
|                           | X/R Ratio                | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio        | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] |
| Barrymore 110 kV          | 3.9                      | 6.9                    | 6.6                     | 5.5          | 5.6                    | 5.5                     | 3.7              | 8.8                    | 8.3                     | 5.5          | 6.4                    | 6.3                     |
| Belcamp 110 kV            | 14.5                     | 12.8                   | 11.7                    | 9.0          | 14.5                   | 13.9                    | 14.9             | 16.9                   | 15.1                    | 8.6          | 17.9                   | 17.2                    |
| Belcamp 220 kV            | 11.9                     | 13.7                   | 12.3                    | 10.2         | 17.1                   | 16.3                    | 11.5             | 22.6                   | 20.1                    | 9.3          | 25.8                   | 24.6                    |
| Bellacorick 110 kV        | 3.4                      | 3.4                    | 3.2                     | 3.8          | 4.3                    | 4.2                     | 5.2              | 7.0                    | 6.0                     | 5.9          | 7.5                    | 7.1                     |
| Binbane 110 kV            | 3.2                      | 3.4                    | 3.3                     | 4.3          | 3.4                    | 3.4                     | 3.6              | 5.9                    | 5.2                     | 5.4          | 4.7                    | 4.5                     |
| Blackpool 110 kV          | -                        | -                      | -                       | -            | -                      | -                       | 6.9              | 24.6                   | 21.5                    | 7.3          | 23.3                   | 22.3                    |
| Blackrock 110 kV          | 11.2                     | 9.6                    | 8.9                     | 3.0          | 8.8                    | 8.6                     | 10.9             | 11.6                   | 10.6                    | 2.8          | 10.0                   | 9.8                     |
| Blake 110 kV              | 4.1                      | 7.4                    | 7.0                     | 5.1          | 5.2                    | 5.2                     | 3.9              | 8.9                    | 8.4                     | 5.0          | 5.9                    | 5.8                     |
| Boggeragh 110 kV          | 6.2                      | 6.3                    | 6.1                     | 7.5          | 6.7                    | 6.6                     | 6.3              | 9.1                    | 8.4                     | 7.8          | 8.6                    | 8.4                     |
| Booltiagh 110 kV          | 6.3                      | 6.3                    | 6.1                     | 7.9          | 5.5                    | 5.5                     | 6.8              | 9.1                    | 8.3                     | 8.7          | 6.7                    | 6.6                     |
| Bracklone 110 kV          | 3.9                      | 7.4                    | 7.0                     | 4.9          | 7.1                    | 7.0                     | 3.7              | 9.1                    | 8.5                     | 4.8          | 8.2                    | 8.0                     |
| Brinny A 110 kV           | 3.2                      | 5.3                    | 5.1                     | 4.2          | 4.8                    | 4.7                     | 2.9              | 6.6                    | 6.1                     | 4.1          | 5.5                    | 5.4                     |
| Brinny B 110 kV           | 3.2                      | 5.3                    | 5.1                     | 4.2          | 4.8                    | 4.8                     | 2.9              | 6.6                    | 6.2                     | 4.1          | 5.6                    | 5.5                     |
| Bunkimalta 110 kV         | 5.3                      | 5.1                    | 4.9                     | 5.5          | 5.3                    | 5.3                     | 6.6              | 8.1                    | 7.1                     | 6.6          | 7.3                    | 7.0                     |
| Butlerstown 110 kV        | 6.1                      | 9.4                    | 8.9                     | 5.8          | 9.7                    | 9.5                     | 5.4              | 11.4                   | 10.6                    | 5.3          | 11.2                   | 10.9                    |
| Cabra 110 kV              | 12.3                     | 9.4                    | 8.8                     | 5.1          | 10.7                   | 10.4                    | 12.3             | 12.0                   | 10.9                    | 4.8          | 13.0                   | 12.5                    |
| Cahernagh 110 kV          | 4.3                      | 4.6                    | 4.5                     | 5.3          | 5.1                    | 5.0                     | 4.0              | 5.2                    | 5.1                     | 5.1          | 5.5                    | 5.4                     |
| Cahir 110 kV              | 4.4                      | 7.4                    | 7.0                     | 5.4          | 6.3                    | 6.2                     | 4.5              | 10.3                   | 9.4                     | 5.7          | 7.6                    | 7.4                     |
| Carlow 110 kV             | 5.2                      | 7.3                    | 7.0                     | 6.0          | 8.1                    | 7.9                     | 5.2              | 9.3                    | 8.6                     | 6.0          | 9.6                    | 9.3                     |
| Carrickmines 220 kV       | 14.0                     | 15.2                   | 13.4                    | 9.9          | 18.9                   | 17.8                    | 13.7             | 22.6                   | 20.0                    | 8.8          | 26.2                   | 24.9                    |
| Carrickmines A 110 kV     | 27.9                     | 10.9                   | 10.0                    | 23.2         | 12.1                   | 11.7                    | 31.5             | 13.5                   | 12.2                    | 24.4         | 14.3                   | 13.8                    |
| Carrickmines B 110 kV     | 23.2                     | 12.2                   | 11.1                    | 19.9         | 14.7                   | 14.2                    | 25.0             | 14.9                   | 13.7                    | 20.5         | 17.5                   | 16.9                    |
| Carrick-on-Shannon 110 kV | 4.4                      | 9.6                    | 9.0                     | 5.1          | 10.6                   | 10.4                    | 4.2              | 13.1                   | 11.9                    | 5.0          | 13.3                   | 12.9                    |
| Carrigadrohid 110 kV      | 6.6                      | 10.1                   | 9.5                     | 7.6          | 10.4                   | 10.1                    | 5.9              | 16.3                   | 14.8                    | 6.9          | 14.8                   | 14.3                    |
| Carrowbeg 110 kV          | 2.7                      | 2.5                    | 2.4                     | 3.5          | 2.4                    | 2.3                     | 2.7              | 3.2                    | 3.0                     | 3.7          | 2.8                    | 2.7                     |
| Cashla 110 kV             | 7.0                      | 12.6                   | 11.6                    | 7.7          | 16.0                   | 15.5                    | 7.3              | 21.6                   | 18.9                    | 8.3          | 25.0                   | 23.7                    |
| Cashla 220 kV             | 8.1                      | 7.9                    | 7.4                     | 9.3          | 8.6                    | 8.4                     | 8.7              | 13.0                   | 12.1                    | 10.2         | 12.1                   | 11.9                    |
| Castlebar 110 kV          | 3.1                      | 4.2                    | 3.9                     | 3.7          | 4.6                    | 4.5                     | 3.3              | 6.4                    | 5.6                     | 4.1          | 6.2                    | 5.9                     |
| Castledockrill 110 kV     | 6.8                      | 6.4                    | 6.2                     | 4.9          | 7.8                    | 7.7                     | 6.9              | 8.2                    | 7.7                     | 4.7          | 9.4                    | 9.1                     |
| Castlefarm A 110 kV       | 8.1                      | 9.3                    | 8.3                     | 9.5          | 10.0                   | 9.6                     | 7.3              | 10.7                   | 9.6                     | 8.8          | 10.9                   | 10.5                    |
| Castlefarm B 110 kV       | 8.2                      | 9.2                    | 8.3                     | 9.5          | 9.9                    | 9.5                     | 7.3              | 10.7                   | 9.6                     | 8.8          | 10.9                   | 10.5                    |
| Castletown 110 kV         | 6.0                      | 9.2                    | 8.7                     | 5.8          | 7.8                    | 7.7                     | 5.5              | 11.0                   | 10.4                    | 5.5          | 8.7                    | 8.6                     |
| Castleview 110 kV         | 4.3                      | 10.8                   | 10.1                    | 4.8          | 8.3                    | 8.2                     | 3.7              | 14.1                   | 13.2                    | 4.5          | 9.7                    | 9.5                     |
| Cathaleen's Fall 110 kV   | 4.3                      | 6.3                    | 6.0                     | 4.9          | 7.3                    | 7.1                     | 5.3              | 13.0                   | 11.0                    | 6.3          | 11.7                   | 11.1                    |
| Cauteen 110 kV            | 5.4                      | 6.4                    | 6.1                     | 6.3          | 4.3                    | 4.3                     | 5.7              | 8.8                    | 8.2                     | 6.6          | 4.9                    | 4.8                     |
| Central 110 kV            | 14.4                     | 10.0                   | 9.3                     | 7.9          | 10.9                   | 10.6                    | 14.3             | 12.2                   | 11.1                    | 7.6          | 12.7                   | 12.3                    |
| Charleville 110 kV        | 4.6                      | 5.5                    | 5.3                     | 6.0          | 5.2                    | 5.1                     | 4.7              | 7.6                    | 7.0                     | 6.5          | 6.5                    | 6.3                     |
| Cherrywood 110 kV         | 10.5                     | 9.3                    | 8.6                     | 7.7          | 9.6                    | 9.4                     | 10.2             | 11.3                   | 10.3                    | 7.4          | 11.1                   | 10.7                    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-3 Short Circuit Currents for Maximum and Minimum Demand in 2018 (Continued)

| Bus                  | Summer Night Valley 2015 |                        |                         |              |                        |                         | Winter Peak 2015 |                        |                         |              |                        |                         |
|----------------------|--------------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|
|                      | Three-Phase              |                        |                         | Single-Phase |                        |                         | Three-Phase      |                        |                         | Single-Phase |                        |                         |
|                      | X/R Ratio                | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio        | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] |
| City West 110 kV     | 6.2                      | 7.3                    | 6.7                     | 6.1          | 5.6                    | 5.4                     | 5.9              | 8.9                    | 7.9                     | 6.0          | 6.3                    | 6.1                     |
| Clahane 110 kV       | 4.2                      | 6.3                    | 6.0                     | 5.2          | 6.0                    | 5.9                     | 4.0              | 8.4                    | 7.8                     | 5.1          | 7.0                    | 6.9                     |
| Clashavoon 220 kV    | 7.9                      | 7.7                    | 7.3                     | 8.4          | 8.6                    | 8.4                     | 7.4              | 12.4                   | 11.4                    | 8.0          | 12.0                   | 11.7                    |
| Clashavoon A 110 kV  | 8.0                      | 11.9                   | 11.1                    | 8.8          | 12.2                   | 11.9                    | 7.2              | 19.7                   | 17.5                    | 7.5          | 18.3                   | 17.6                    |
| Clashavoon B 110 kV  | 8.0                      | 11.9                   | 11.1                    | 8.8          | 12.2                   | 11.9                    | 7.2              | 19.7                   | 17.5                    | 7.5          | 18.3                   | 17.6                    |
| Cliff 110 kV         | 4.0                      | 5.2                    | 4.9                     | 5.0          | 5.3                    | 5.3                     | 4.6              | 9.2                    | 8.1                     | 6.0          | 7.5                    | 7.3                     |
| Cloghboola 110 kV    | 6.5                      | 4.8                    | 4.7                     | 6.9          | 5.7                    | 5.6                     | 6.7              | 7.7                    | 6.3                     | 7.3          | 8.1                    | 7.6                     |
| Clogher 110 kV       | 3.9                      | 5.3                    | 5.0                     | 4.2          | 6.3                    | 6.2                     | 5.2              | 11.9                   | 9.6                     | 5.5          | 11.3                   | 10.5                    |
| Cloghran 110 kV      | 9.9                      | 18.5                   | 16.7                    | 9.7          | 19.8                   | 19.1                    | 9.3              | 24.5                   | 22.4                    | 9.2          | 24.4                   | 23.7                    |
| Clonkeen A 110 kV    | 5.8                      | 5.5                    | 5.3                     | 6.9          | 4.0                    | 4.0                     | 5.4              | 6.7                    | 6.3                     | 6.7          | 4.5                    | 4.4                     |
| Clonkeen B 110 kV    | 5.8                      | 5.1                    | 4.9                     | 5.5          | 5.9                    | 5.8                     | 6.4              | 7.7                    | 6.8                     | 5.7          | 8.0                    | 7.7                     |
| Cloon 110 kV         | 4.4                      | 6.7                    | 6.4                     | 5.8          | 6.0                    | 5.9                     | 4.1              | 8.7                    | 8.1                     | 5.7          | 7.1                    | 6.9                     |
| College Park 110 kV  | 9.7                      | 17.8                   | 16.1                    | 6.8          | 20.0                   | 19.2                    | 9.0              | 23.3                   | 21.4                    | 6.2          | 24.7                   | 24.0                    |
| Cookstown 110 kV     | 7.4                      | 7.9                    | 7.4                     | 6.0          | 6.8                    | 6.6                     | 7.1              | 9.2                    | 8.6                     | 5.8          | 7.6                    | 7.4                     |
| Coolroe 110 kV       | 5.4                      | 8.6                    | 8.2                     | 6.7          | 8.4                    | 8.2                     | 4.8              | 11.8                   | 11.0                    | 6.3          | 10.3                   | 10.1                    |
| Coomagearlahy 110 kV | 5.7                      | 4.2                    | 4.1                     | 6.2          | 5.1                    | 5.1                     | 6.7              | 6.7                    | 5.8                     | 7.4          | 7.4                    | 7.0                     |
| Coomataggart 110 kV  | 6.7                      | 3.2                    | 3.2                     | 7.5          | 3.5                    | 3.5                     | 6.4              | 3.7                    | 3.6                     | 7.3          | 4.0                    | 3.9                     |
| Cordal 110 kV        | 10.0                     | 6.6                    | 6.4                     | 8.4          | 6.4                    | 6.4                     | 10.6             | 9.7                    | 8.9                     | 8.2          | 8.0                    | 7.8                     |
| Corderry 110 kV      | 4.0                      | 6.3                    | 6.0                     | 5.0          | 6.4                    | 6.3                     | 4.2              | 9.3                    | 8.2                     | 5.5          | 8.3                    | 8.0                     |
| Corduff 110 kV       | 10.7                     | 19.8                   | 17.7                    | 11.7         | 22.5                   | 21.6                    | 10.1             | 26.5                   | 24.2                    | 11.3         | 28.4                   | 27.4                    |
| Corduff 220 kV       | 14.7                     | 15.6                   | 13.8                    | 13.6         | 19.4                   | 18.4                    | 15.0             | 25.9                   | 22.9                    | 13.1         | 29.4                   | 27.9                    |
| Corkagh 110 kV       | 17.6                     | 11.2                   | 9.9                     | 12.2         | 12.4                   | 11.8                    | 18.0             | 14.2                   | 12.2                    | 11.9         | 15.1                   | 14.2                    |
| Corraclassy 110 kV   | 4.3                      | 5.8                    | 5.5                     | 5.4          | 4.7                    | 4.6                     | 4.3              | 7.3                    | 6.9                     | 5.5          | 5.3                    | 5.2                     |
| Cow Cross 110 kV     | 5.1                      | 11.1                   | 10.4                    | 5.4          | 9.9                    | 9.7                     | 4.3              | 14.5                   | 13.4                    | 4.9          | 11.8                   | 11.5                    |
| Crane 110 kV         | 6.4                      | 7.0                    | 6.7                     | 6.5          | 7.6                    | 7.5                     | 6.6              | 9.1                    | 8.4                     | 6.5          | 9.2                    | 8.9                     |
| Cromcastle A 110 kV  | 12.3                     | 12.5                   | 11.4                    | 8.0          | 14.2                   | 13.7                    | 12.2             | 16.4                   | 14.7                    | 7.5          | 17.6                   | 16.9                    |
| Cromcastle B 110 kV  | 12.3                     | 12.5                   | 11.4                    | 8.0          | 14.2                   | 13.7                    | 12.2             | 16.4                   | 14.7                    | 7.5          | 17.6                   | 16.9                    |
| Cronacarkfree 220 kV | 4.3                      | 3.4                    | 3.2                     | 4.4          | 4.1                    | 4.1                     | 6.0              | 6.9                    | 5.7                     | 5.7          | 7.1                    | 6.6                     |
| Croy 110 kV          | 8.4                      | 7.3                    | 7.0                     | 8.8          | 9.1                    | 9.0                     | 8.8              | 9.4                    | 8.8                     | 9.0          | 11.1                   | 10.8                    |
| Cullenagh 110 kV     | 8.2                      | 11.6                   | 10.9                    | 8.7          | 13.5                   | 13.2                    | 7.1              | 14.5                   | 13.4                    | 7.8          | 16.2                   | 15.7                    |
| Cullenagh 220 kV     | 9.0                      | 8.5                    | 8.0                     | 9.2          | 8.6                    | 8.4                     | 8.0              | 10.0                   | 9.6                     | 8.5          | 9.7                    | 9.6                     |
| Cunghill 110 kV      | 3.3                      | 4.5                    | 4.3                     | 3.7          | 4.4                    | 4.3                     | 3.2              | 6.6                    | 6.1                     | 3.8          | 5.5                    | 5.4                     |
| Cureeny 110 kV       | 5.4                      | 6.2                    | 6.0                     | 5.2          | 6.1                    | 6.0                     | 6.2              | 9.6                    | 8.5                     | 5.5          | 7.9                    | 7.6                     |
| Cushaling 110 kV     | 5.7                      | 8.6                    | 7.8                     | 6.8          | 10.3                   | 9.9                     | 7.0              | 12.7                   | 11.3                    | 8.8          | 13.5                   | 12.9                    |
| Dallow 110 kV        | 3.5                      | 4.9                    | 4.7                     | 4.6          | 3.1                    | 3.1                     | 3.4              | 5.6                    | 5.3                     | 4.6          | 3.4                    | 3.4                     |
| Dalton 110 kV        | 3.1                      | 3.7                    | 3.5                     | 4.1          | 3.2                    | 3.2                     | 3.2              | 5.2                    | 4.7                     | 4.5          | 3.9                    | 3.8                     |
| Dardistown 110 kV    | 13.6                     | 12.4                   | 11.3                    | 10.5         | 14.3                   | 13.8                    | 13.8             | 16.2                   | 14.5                    | 10.2         | 17.7                   | 17.0                    |
| Derrybrien 110 kV    | 2.6                      | 3.8                    | 3.7                     | 3.7          | 3.7                    | 3.6                     | 3.0              | 5.1                    | 4.5                     | 4.4          | 4.5                    | 4.3                     |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-3 Short Circuit Currents for Maximum and Minimum Demand in 2018 (Continued)

| Bus                       | Summer Night Valley 2015 |                        |                         |              |                        |                         | Winter Peak 2015 |                        |                         |              |                        |                         |
|---------------------------|--------------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|
|                           | Three-Phase              |                        |                         | Single-Phase |                        |                         | Three-Phase      |                        |                         | Single-Phase |                        |                         |
|                           | X/R Ratio                | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio        | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] |
| Derryiron 110 kV          | 4.9                      | 7.2                    | 6.8                     | 6.1          | 7.7                    | 7.6                     | 5.8              | 10.5                   | 9.8                     | 7.4          | 10.0                   | 9.8                     |
| Doon 110 kV               | 4.4                      | 6.4                    | 6.1                     | 4.7          | 5.0                    | 4.9                     | 4.4              | 8.4                    | 7.7                     | 4.7          | 5.8                    | 5.7                     |
| Dromada 110 kV            | 7.9                      | 6.5                    | 6.3                     | 5.6          | 7.2                    | 7.1                     | 7.2              | 11.0                   | 9.3                     | 4.8          | 10.2                   | 9.6                     |
| Drumkeen 110 kV           | 3.5                      | 4.8                    | 4.5                     | 4.2          | 5.0                    | 4.9                     | 3.8              | 9.2                    | 7.8                     | 4.9          | 7.5                    | 7.1                     |
| Drumline 110 kV           | 3.6                      | 7.2                    | 6.8                     | 4.7          | 6.2                    | 6.1                     | 3.2              | 9.2                    | 8.6                     | 4.6          | 7.2                    | 7.0                     |
| Drybridge 110 kV          | 5.9                      | 12.1                   | 11.2                    | 6.7          | 10.3                   | 10.1                    | 5.2              | 15.0                   | 13.9                    | 6.3          | 11.9                   | 11.7                    |
| Dundalk 110 kV            | 3.8                      | 7.8                    | 7.4                     | 4.7          | 7.3                    | 7.2                     | 3.4              | 9.4                    | 8.8                     | 4.4          | 8.3                    | 8.1                     |
| Dunfirth 110 kV           | 4.7                      | 5.9                    | 5.7                     | 6.3          | 4.7                    | 4.6                     | 4.6              | 6.8                    | 6.6                     | 6.3          | 5.1                    | 5.1                     |
| Dungarvan 110 kV          | 6.0                      | 5.5                    | 5.3                     | 7.7          | 4.7                    | 4.6                     | 5.9              | 7.2                    | 6.7                     | 7.9          | 5.6                    | 5.5                     |
| Dunmanway 110 kV          | 4.3                      | 6.9                    | 6.6                     | 5.2          | 6.3                    | 6.2                     | 4.3              | 10.0                   | 9.0                     | 5.4          | 7.9                    | 7.7                     |
| Dunstown 220 kV           | 12.8                     | 15.7                   | 14.0                    | 12.4         | 18.3                   | 17.5                    | 10.8             | 21.4                   | 19.7                    | 10.8         | 23.6                   | 22.9                    |
| Dunstown 400 kV           | 17.8                     | 6.2                    | 5.7                     | 20.0         | 6.8                    | 6.6                     | 16.4             | 8.0                    | 7.7                     | 19.0         | 8.5                    | 8.3                     |
| Ennis 110 kV              | 5.0                      | 9.4                    | 8.8                     | 6.2          | 8.7                    | 8.5                     | 4.8              | 13.2                   | 12.0                    | 6.4          | 10.7                   | 10.4                    |
| Fassaroe East 110 kV      | 5.4                      | 7.4                    | 7.0                     | 5.4          | 5.7                    | 5.6                     | 5.0              | 8.6                    | 8.1                     | 5.3          | 6.4                    | 6.3                     |
| Fassaroe West 110 kV      | 5.5                      | 7.6                    | 7.1                     | 5.5          | 5.9                    | 5.8                     | 5.2              | 8.8                    | 8.3                     | 5.4          | 6.6                    | 6.5                     |
| Finglas 220 kV            | 14.3                     | 14.9                   | 13.2                    | 13.9         | 19.1                   | 18.1                    | 15.9             | 25.7                   | 22.5                    | 14.6         | 30.2                   | 28.5                    |
| Finglas A 110 kV          | 20.3                     | 13.7                   | 12.4                    | 17.3         | 15.7                   | 15.1                    | 23.8             | 18.4                   | 16.3                    | 18.4         | 19.8                   | 18.9                    |
| Finglas B 110 kV          | 26.9                     | 10.8                   | 10.0                    | 25.7         | 13.7                   | 13.2                    | 34.2             | 14.0                   | 12.7                    | 30.3         | 17.2                   | 16.5                    |
| Flagford 110 kV           | 4.7                      | 10.0                   | 9.4                     | 5.5          | 12.2                   | 11.9                    | 4.5              | 13.7                   | 12.5                    | 5.4          | 15.7                   | 15.2                    |
| Flagford 220 kV           | 7.2                      | 6.2                    | 5.8                     | 9.1          | 6.0                    | 5.9                     | 7.3              | 8.2                    | 7.8                     | 9.7          | 7.2                    | 7.1                     |
| Francis Street A 110 kV   | 11.2                     | 10.1                   | 9.4                     | 5.8          | 12.4                   | 12.0                    | 10.4             | 13.7                   | 12.5                    | 5.0          | 15.9                   | 15.3                    |
| Francis Street B 110 kV   | 12.9                     | 11.1                   | 10.3                    | 6.8          | 13.5                   | 13.1                    | 12.7             | 13.5                   | 12.5                    | 6.4          | 16.1                   | 15.6                    |
| Galway 110 kV             | 4.9                      | 9.8                    | 9.1                     | 5.4          | 10.8                   | 10.5                    | 5.5              | 17.1                   | 14.7                    | 6.2          | 15.8                   | 15.0                    |
| Garrow 110 kV             | 8.9                      | 5.9                    | 5.7                     | 8.8          | 6.7                    | 6.6                     | 9.7              | 8.9                    | 8.0                     | 9.2          | 9.0                    | 8.7                     |
| Garvagh 110 kV            | 4.2                      | 4.9                    | 4.7                     | 5.4          | 4.8                    | 4.8                     | 4.6              | 6.9                    | 6.2                     | 6.1          | 6.0                    | 5.8                     |
| Gilra 110 kV              | 3.2                      | 5.8                    | 5.5                     | 4.1          | 4.6                    | 4.5                     | 3.0              | 6.9                    | 6.6                     | 4.0          | 5.1                    | 5.1                     |
| Glanagow 220 kV           | 13.7                     | 12.3                   | 11.0                    | 13.7         | 15.4                   | 14.6                    | 15.3             | 21.4                   | 18.8                    | 14.5         | 25.3                   | 24.0                    |
| Glanlee 110 kV            | 5.6                      | 4.1                    | 4.0                     | 5.9          | 5.0                    | 5.0                     | 6.6              | 6.4                    | 5.6                     | 6.8          | 7.2                    | 6.8                     |
| Glasmore 110 kV           | 4.4                      | 6.8                    | 6.4                     | 4.9          | 4.8                    | 4.8                     | 4.1              | 8.3                    | 7.7                     | 4.7          | 5.4                    | 5.3                     |
| Glenlara A 110 kV         | 2.9                      | 2.6                    | 2.5                     | 4.2          | 2.3                    | 2.2                     | 3.1              | 3.3                    | 3.0                     | 4.6          | 2.7                    | 2.6                     |
| Glenlara B 110 kV         | 8.7                      | 5.6                    | 5.5                     | 6.8          | 5.7                    | 5.7                     | 9.3              | 8.3                    | 7.5                     | 6.6          | 7.4                    | 7.2                     |
| Glenree 110 kV            | 3.4                      | 3.8                    | 3.5                     | 4.1          | 3.7                    | 3.6                     | 4.0              | 6.5                    | 5.8                     | 5.0          | 5.1                    | 4.9                     |
| Glentanemacelligot 110 kV | 8.5                      | 5.3                    | 5.2                     | 8.3          | 4.5                    | 4.5                     | 8.2              | 6.9                    | 6.5                     | 8.1          | 5.1                    | 5.0                     |
| Golagh 110 kV             | 3.6                      | 4.6                    | 4.4                     | 4.0          | 4.7                    | 4.7                     | 4.0              | 9.1                    | 7.6                     | 4.6          | 7.1                    | 6.8                     |
| Gorman 110 kV             | 6.7                      | 12.6                   | 11.7                    | 7.6          | 14.1                   | 13.7                    | 6.0              | 16.0                   | 14.8                    | 7.0          | 16.9                   | 16.4                    |
| Gorman 220 kV             | 9.5                      | 9.8                    | 9.0                     | 10.1         | 8.5                    | 8.3                     | 8.4              | 12.5                   | 11.9                    | 9.5          | 9.9                    | 9.7                     |
| Gortawee 110 kV           | 4.4                      | 5.6                    | 5.3                     | 5.8          | 4.8                    | 4.7                     | 4.4              | 6.9                    | 6.4                     | 6.0          | 5.3                    | 5.2                     |
| Grange 110 kV             | 12.1                     | 12.4                   | 11.3                    | 6.1          | 13.7                   | 13.2                    | 11.9             | 16.2                   | 14.6                    | 5.6          | 16.9                   | 16.2                    |



TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-3 Short Circuit Currents for Maximum and Minimum Demand in 2018 (Continued)

| Bus                     | Summer Night Valley 2015 |           |           |              |           |           | Winter Peak 2015 |           |           |              |           |           |
|-------------------------|--------------------------|-----------|-----------|--------------|-----------|-----------|------------------|-----------|-----------|--------------|-----------|-----------|
|                         | Three-Phase              |           |           | Single-Phase |           |           | Three-Phase      |           |           | Single-Phase |           |           |
|                         | X/R Ratio                | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] | X/R Ratio        | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] |
| Grange Castle 110 kV    | 17.8                     | 11.3      | 10.0      | 13.0         | 12.7      | 12.1      | 18.2             | 14.4      | 12.3      | 12.8         | 15.4      | 14.6      |
| Great Island 110 kV     | 7.8                      | 11.4      | 10.8      | 8.6          | 14.9      | 14.5      | 6.8              | 14.0      | 13.0      | 7.6          | 17.7      | 17.1      |
| Great Island 220 kV     | 12.0                     | 10.9      | 10.2      | 13.4         | 13.1      | 12.7      | 10.4             | 12.7      | 12.0      | 11.9         | 14.5      | 14.2      |
| Griffinrath A 110 kV    | 7.2                      | 9.5       | 8.9       | 7.5          | 9.7       | 9.5       | 6.7              | 11.4      | 10.8      | 7.1          | 11.2      | 11.0      |
| Griffinrath B 110 kV    | 7.7                      | 9.8       | 9.2       | 7.7          | 9.7       | 9.5       | 7.2              | 11.8      | 11.2      | 7.3          | 11.1      | 10.9      |
| Harolds 110 kV          | 11.4                     | 10.2      | 9.4       | 5.5          | 12.4      | 12.0      | 10.6             | 13.7      | 12.5      | 4.7          | 15.8      | 15.2      |
| Hartnett's Cross 110 kV | 4.5                      | 8.2       | 7.8       | 5.3          | 7.1       | 6.9       | 3.8              | 12.1      | 11.2      | 4.7          | 9.2       | 9.0       |
| Heuston 110 kV          | 13.9                     | 11.3      | 10.5      | 8.2          | 13.9      | 13.5      | 13.8             | 13.8      | 12.8      | 7.8          | 16.6      | 16.1      |
| Huntstown A 220 kV      | 13.7                     | 14.4      | 12.8      | 12.5         | 18.5      | 17.6      | 15.3             | 24.7      | 21.7      | 12.6         | 29.1      | 27.5      |
| Huntstown B 220 kV      | 14.7                     | 14.7      | 13.2      | 11.4         | 18.4      | 17.5      | 14.4             | 23.0      | 20.6      | 10.2         | 26.5      | 25.3      |
| Ikerrin 110 kV          | 5.3                      | 4.2       | 4.0       | 6.1          | 3.2       | 3.2       | 5.8              | 5.7       | 5.2       | 6.5          | 3.8       | 3.7       |
| Inchicore 220 kV        | 14.1                     | 17.4      | 15.0      | 10.8         | 21.5      | 20.2      | 13.6             | 27.4      | 23.8      | 9.5          | 31.5      | 29.7      |
| Inchicore A 110 kV      | 26.7                     | 12.3      | 11.4      | 24.1         | 15.6      | 15.0      | 30.2             | 15.3      | 14.1      | 25.9         | 18.8      | 18.2      |
| Inchicore B 110 kV      | 38.0                     | 12.7      | 11.2      | 31.4         | 16.1      | 15.3      | 48.7             | 16.3      | 14.0      | 36.1         | 20.2      | 18.9      |
| Inniscarra 110 kV       | 5.0                      | 8.3       | 7.9       | 6.1          | 7.9       | 7.7       | 4.4              | 11.4      | 10.6      | 5.8          | 9.7       | 9.5       |
| Irishtown 220 kV        | 14.8                     | 16.4      | 14.3      | 12.1         | 20.8      | 19.5      | 15.1             | 25.5      | 22.3      | 11.3         | 30.0      | 28.3      |
| Kellis 110 kV           | 6.2                      | 7.9       | 7.5       | 7.2          | 9.4       | 9.3       | 6.1              | 9.9       | 9.2       | 7.2          | 11.3      | 11.0      |
| Kellis 220 kV           | 8.1                      | 7.2       | 6.9       | 9.8          | 6.3       | 6.2       | 7.6              | 8.6       | 8.3       | 9.5          | 7.2       | 7.1       |
| Kilbarry 110 kV         | 7.9                      | 15.7      | 14.2      | 8.5          | 16.9      | 16.3      | 7.1              | 24.9      | 21.7      | 8.0          | 23.8      | 22.8      |
| Kildonan 110 kV         | 9.3                      | 17.0      | 15.4      | 7.0          | 15.3      | 14.9      | 8.7              | 22.1      | 20.4      | 6.5          | 18.3      | 17.9      |
| Kilkenny 110 kV         | 3.0                      | 4.7       | 4.5       | 4.2          | 4.3       | 4.3       | 3.0              | 5.6       | 5.2       | 4.3          | 4.9       | 4.8       |
| Kill Hill 110 kV        | 4.9                      | 4.9       | 4.7       | 5.9          | 4.5       | 4.4       | 5.8              | 7.4       | 6.6       | 6.9          | 5.8       | 5.6       |
| Killinaparson 110 kV    | 5.1                      | 5.8       | 5.6       | 6.8          | 4.7       | 4.6       | 4.8              | 6.7       | 6.4       | 6.7          | 5.1       | 5.1       |
| Killonan 110 kV         | 7.5                      | 14.6      | 13.4      | 8.5          | 16.7      | 16.2      | 7.2              | 23.3      | 20.8      | 7.5          | 16.2      | 15.8      |
| Killonan 220 kV         | 8.3                      | 8.7       | 8.1       | 10.3         | 8.6       | 8.4       | 8.0              | 12.2      | 11.5      | 10.8         | 9.8       | 9.7       |
| Killoteran 110 kV       | 6.3                      | 10.0      | 9.5       | 5.4          | 11.1      | 10.9      | 5.5              | 12.2      | 11.3      | 4.9          | 12.9      | 12.5      |
| Kilmahud 110 kV         | 17.4                     | 11.2      | 9.9       | 12.3         | 12.6      | 12.0      | 17.7             | 14.2      | 12.2      | 12.1         | 15.3      | 14.4      |
| Kilmore 110 kV          | 16.1                     | 13.2      | 11.9      | 11.8         | 15.1      | 14.5      | 17.1             | 17.5      | 15.6      | 11.6         | 18.9      | 18.1      |
| Kilpaddoge 110 kV       | 11.9                     | 13.5      | 12.5      | 12.3         | 17.3      | 16.7      | 12.1             | 20.1      | 18.4      | 12.6         | 24.0      | 23.2      |
| Kilpaddoge A 220 kV     | 12.2                     | 11.7      | 10.7      | 11.2         | 15.5      | 14.9      | 15.2             | 24.5      | 22.0      | 11.9         | 29.3      | 28.0      |
| Kilpaddoge B 220 kV     | 12.2                     | 11.7      | 10.7      | 11.2         | 15.5      | 14.9      | 15.2             | 24.5      | 22.0      | 11.9         | 29.3      | 28.0      |
| Kilteel 110 kV          | 4.5                      | 7.0       | 6.6       | 5.5          | 6.5       | 6.4       | 4.2              | 8.4       | 7.9       | 5.4          | 7.3       | 7.1       |
| Kinnegad 110 kV         | 4.6                      | 7.1       | 6.8       | 5.9          | 6.6       | 6.5       | 4.6              | 9.1       | 8.6       | 6.2          | 7.6       | 7.5       |
| Knockacummer 110 kV     | 5.9                      | 4.8       | 4.7       | 6.0          | 5.2       | 5.1       | 6.1              | 6.8       | 6.2       | 6.2          | 6.7       | 6.5       |
| Knockanure 110 kV       | 15.0                     | 8.4       | 8.0       | 12.3         | 10.2      | 10.0      | 15.9             | 14.6      | 12.2      | 11.5         | 15.6      | 14.6      |
| Knockanure 220 Kv       | 8.5                      | 8.4       | 7.9       | 6.1          | 11.1      | 10.8      | 8.3              | 14.7      | 13.4      | 5.1          | 17.9      | 17.2      |
| Knockavanna 110 kV      | 2.7                      | 4.0       | 3.9       | 3.8          | 3.7       | 3.7       | 3.0              | 5.4       | 4.8       | 4.4          | 4.5       | 4.4       |
| Knockearagh 110 kV      | 5.5                      | 5.0       | 4.8       | 7.2          | 4.4       | 4.3       | 5.3              | 6.3       | 5.9       | 7.3          | 5.1       | 5.0       |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-3 Short Circuit Currents for Maximum and Minimum Demand in 2018 (Continued)

| Bus                  | Summer Night Valley 2015 |                        |                         |              |                        |                         | Winter Peak 2015 |                        |                         |              |                        |                         |
|----------------------|--------------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|
|                      | Three-Phase              |                        |                         | Single-Phase |                        |                         | Three-Phase      |                        |                         | Single-Phase |                        |                         |
|                      | X/R Ratio                | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio        | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] |
| Knockraha A 110 kV   | 27.8                     | 6.1                    | 5.9                     | 28.5         | 6.2                    | 6.1                     | 7.8              | 25.3                   | 22.6                    | 8.7          | 22.9                   | 22.1                    |
| Knockraha A 220 kV   | 9.2                      | 17.0                   | 15.4                    | 9.8          | 17.6                   | 17.0                    | 10.6             | 20.5                   | 18.4                    | 10.5         | 19.8                   | 19.0                    |
| Knockraha B 110 kV   | 11.7                     | 12.8                   | 11.6                    | 11.8         | 14.4                   | 13.8                    | 7.8              | 25.3                   | 22.6                    | 8.7          | 22.9                   | 22.1                    |
| Knockraha B 220 kV   | 11.7                     | 12.8                   | 11.6                    | 11.8         | 14.4                   | 13.8                    | 10.6             | 20.5                   | 18.4                    | 10.5         | 19.8                   | 19.0                    |
| Knockranny 110 kV    | 3.7                      | 3.8                    | 3.6                     | 4.4          | 2.4                    | 2.4                     | 4.7              | 5.9                    | 5.3                     | 5.0          | 2.9                    | 2.8                     |
| Knockumber 110 kV    | 3.9                      | 7.7                    | 7.2                     | 4.7          | 5.9                    | 5.8                     | 3.5              | 9.0                    | 8.5                     | 4.5          | 6.5                    | 6.4                     |
| Lanesboro 110 kV     | 4.1                      | 9.9                    | 9.1                     | 5.2          | 10.4                   | 10.1                    | 3.7              | 12.1                   | 11.0                    | 5.0          | 12.0                   | 11.6                    |
| Letterkenny110 kV    | 3.8                      | 5.5                    | 5.2                     | 4.4          | 6.4                    | 6.3                     | 4.2              | 11.2                   | 9.3                     | 5.4          | 10.5                   | 9.8                     |
| Liberty A 110 kV     | 6.6                      | 13.8                   | 12.6                    | 5.5          | 15.7                   | 15.2                    | 5.8              | 20.8                   | 18.4                    | 4.8          | 21.5                   | 20.6                    |
| Liberty B 110 kV     | 6.5                      | 13.7                   | 12.6                    | 5.3          | 15.7                   | 15.2                    | 5.7              | 20.8                   | 18.4                    | 4.7          | 21.4                   | 20.5                    |
| Limerick 110 kV      | 5.8                      | 12.9                   | 11.9                    | 6.4          | 12.7                   | 12.3                    | 5.1              | 19.1                   | 17.2                    | 6.4          | 14.7                   | 14.3                    |
| Lisdrum 110 kV       | 2.9                      | 4.7                    | 4.5                     | 4.2          | 4.2                    | 4.1                     | 2.8              | 5.7                    | 5.3                     | 4.2          | 4.6                    | 4.5                     |
| Lisheen 110 kV       | 4.0                      | 3.2                    | 3.1                     | 4.0          | 4.9                    | 4.7                     | 5.0              | 5.3                    | 4.6                     | 5.0          | 7.9                    | 7.4                     |
| Lodgewood 110 kV     | 8.4                      | 7.3                    | 7.0                     | 8.8          | 9.1                    | 9.0                     | 8.8              | 9.4                    | 8.8                     | 9.0          | 11.1                   | 10.8                    |
| Lodgewood 220 kV     | 8.8                      | 6.7                    | 6.4                     | 10.0         | 6.6                    | 6.5                     | 8.7              | 8.2                    | 7.8                     | 9.9          | 7.6                    | 7.5                     |
| Longpoint 220 kV     | 12.1                     | 11.9                   | 10.7                    | 12.2         | 14.3                   | 13.7                    | 14.8             | 21.8                   | 19.2                    | 12.5         | 25.4                   | 24.1                    |
| Louth 220 kV         | 10.5                     | 12.8                   | 11.5                    | 11.1         | 15.4                   | 14.7                    | 9.1              | 19.2                   | 17.8                    | 10.3         | 20.8                   | 20.3                    |
| Louth A 110 kV       | 7.3                      | 11.2                   | 10.4                    | 8.3          | 13.6                   | 13.2                    | 6.4              | 14.0                   | 13.0                    | 7.5          | 16.4                   | 15.9                    |
| Louth B 110 kV       | 7.8                      | 11.9                   | 11.1                    | 8.6          | 14.9                   | 14.5                    | 6.9              | 15.2                   | 14.2                    | 7.8          | 18.3                   | 17.8                    |
| Macetown 110 kV      | 7.9                      | 16.0                   | 14.6                    | 7.7          | 16.0                   | 15.5                    | 7.2              | 20.5                   | 19.0                    | 7.2          | 19.1                   | 18.7                    |
| Macroom 110 kV       | 6.7                      | 11.0                   | 10.3                    | 7.4          | 11.4                   | 11.1                    | 6.0              | 19.1                   | 17.0                    | 6.5          | 17.9                   | 17.3                    |
| Mallow 110 kV        | 5.3                      | 6.0                    | 5.7                     | 6.9          | 5.3                    | 5.2                     | 5.2              | 7.5                    | 7.0                     | 7.1          | 6.1                    | 6.0                     |
| Marina 110 kV        | 7.9                      | 15.1                   | 13.7                    | 8.8          | 17.4                   | 16.7                    | 7.4              | 23.8                   | 20.7                    | 8.6          | 24.6                   | 23.4                    |
| Maynooth A 110 kV    | 11.1                     | 11.7                   | 10.9                    | 11.7         | 14.4                   | 14.0                    | 10.4             | 14.5                   | 13.6                    | 11.1         | 17.3                   | 16.9                    |
| Maynooth A 220 kV    | 11.1                     | 14.5                   | 12.9                    | 10.5         | 14.3                   | 13.7                    | 9.5              | 19.9                   | 18.2                    | 9.4          | 17.9                   | 17.4                    |
| Maynooth B 110 kV    | 8.6                      | 15.1                   | 13.8                    | 9.9          | 15.0                   | 14.5                    | 7.6              | 18.7                   | 17.6                    | 9.2          | 17.6                   | 17.2                    |
| Maynooth B 220 kV    | 11.5                     | 16.0                   | 14.2                    | 10.6         | 15.9                   | 15.2                    | 9.6              | 23.1                   | 21.1                    | 9.4          | 20.7                   | 20.1                    |
| McDermott 110 kV     | 15.4                     | 10.0                   | 9.3                     | 6.4          | 11.9                   | 11.5                    | 16.0             | 12.8                   | 11.6                    | 6.0          | 14.6                   | 14.1                    |
| Meath Hill 110 kV    | 4.1                      | 7.9                    | 7.5                     | 5.2          | 6.8                    | 6.7                     | 3.9              | 9.9                    | 9.3                     | 5.2          | 7.7                    | 7.6                     |
| Meentycat 110 kV     | 3.3                      | 4.1                    | 3.9                     | 4.1          | 4.2                    | 4.1                     | 3.6              | 7.4                    | 6.4                     | 4.9          | 5.9                    | 5.7                     |
| Midleton 110 kV      | 3.9                      | 9.3                    | 8.7                     | 4.9          | 7.6                    | 7.5                     | 3.5              | 11.8                   | 11.0                    | 4.7          | 8.7                    | 8.6                     |
| Milltown A 110 kV    | 15.0                     | 10.8                   | 10.0                    | 7.4          | 13.5                   | 13.0                    | 14.8             | 14.9                   | 13.5                    | 6.6          | 17.5                   | 16.9                    |
| Milltown B 110 kV    | 9.1                      | 10.1                   | 9.4                     | 4.3          | 12.1                   | 11.8                    | 8.7              | 12.2                   | 11.3                    | 4.0          | 14.2                   | 13.8                    |
| Misery Hill 110 kV   | 13.7                     | 10.6                   | 9.8                     | 8.1          | 13.3                   | 12.8                    | 13.2             | 14.5                   | 13.2                    | 7.2          | 17.3                   | 16.6                    |
| Moneteen 110 kV      | 5.9                      | 9.8                    | 9.1                     | 6.6          | 7.7                    | 7.5                     | 5.3              | 12.6                   | 11.7                    | 6.4          | 8.5                    | 8.3                     |
| Moneypoint 110 kV    | 13.9                     | 7.9                    | 7.6                     | 16.1         | 8.3                    | 8.1                     | 15.5             | 10.5                   | 10.0                    | 17.9         | 10.0                   | 9.8                     |
| Moneypoint 220 kV    | 12.6                     | 11.8                   | 10.8                    | 11.7         | 15.6                   | 15.0                    | 15.9             | 24.0                   | 21.7                    | 12.6         | 28.9                   | 27.7                    |
| Moneypoint G1 400 kV | 16.1                     | 7.3                    | 6.7                     | 17.2         | 9.1                    | 8.8                     | 24.3             | 13.8                   | 12.7                    | 24.1         | 15.4                   | 15.0                    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-3 Short Circuit Currents for Maximum and Minimum Demand in 2018 (Continued)

| Bus                  | Summer Night Valley 2015 |                       |                       |              |                       |                       | Winter Peak 2015 |                       |                       |              |                       |                       |
|----------------------|--------------------------|-----------------------|-----------------------|--------------|-----------------------|-----------------------|------------------|-----------------------|-----------------------|--------------|-----------------------|-----------------------|
|                      | Three-Phase              |                       |                       | Single-Phase |                       |                       | Three-Phase      |                       |                       | Single-Phase |                       |                       |
|                      | X/R Ratio                | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio    | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio        | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio    | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] |
| Moneypoint G2 400 kV | 16.1                     | 7.3                   | 6.7                   | 17.2         | 9.1                   | 8.8                   | 24.3             | 13.8                  | 12.7                  | 24.1         | 15.4                  | 15.0                  |
| Moneypoint G3 400 kV | 16.1                     | 7.3                   | 6.7                   | 17.2         | 9.1                   | 8.8                   | 24.3             | 13.8                  | 12.7                  | 24.1         | 15.4                  | 15.0                  |
| Monread 110 kV       | 4.2                      | 6.9                   | 6.5                   | 5.0          | 7.0                   | 6.9                   | 3.9              | 8.3                   | 7.8                   | 4.9          | 8.0                   | 7.8                   |
| Mount Lucas 110 kV   | 4.4                      | 6.2                   | 5.8                   | 5.6          | 5.8                   | 5.7                   | 4.8              | 8.6                   | 8.0                   | 6.2          | 7.2                   | 7.1                   |
| Moy 110 kV           | 3.7                      | 3.8                   | 3.5                   | 4.4          | 4.5                   | 4.4                   | 5.7              | 7.5                   | 6.6                   | 7.0          | 7.3                   | 7.0                   |
| Mullagharlin 110 kV  | 3.9                      | 8.0                   | 7.6                   | 4.9          | 7.8                   | 7.7                   | 3.5              | 9.6                   | 8.9                   | 4.6          | 8.9                   | 8.7                   |
| Mullingar 110 kV     | 3.6                      | 6.5                   | 6.2                   | 4.9          | 6.2                   | 6.1                   | 3.4              | 7.7                   | 7.3                   | 4.9          | 7.0                   | 6.9                   |
| Mulreavy 110 kV      | 3.6                      | 4.7                   | 4.5                   | 3.9          | 5.7                   | 5.6                   | 4.5              | 10.1                  | 8.2                   | 5.0          | 10.0                  | 9.3                   |
| Mungret A 110 kV     | 5.5                      | 9.3                   | 8.7                   | 6.2          | 7.2                   | 7.0                   | 5.0              | 11.8                  | 11.0                  | 6.1          | 7.8                   | 7.7                   |
| Mungret B 110 kV     | 5.5                      | 9.3                   | 8.7                   | 6.2          | 7.2                   | 7.1                   | 4.9              | 11.9                  | 11.0                  | 6.1          | 7.9                   | 7.7                   |
| Nangor 110 kV        | 15.6                     | 11.0                  | 9.8                   | 10.4         | 12.4                  | 11.8                  | 15.7             | 14.0                  | 12.0                  | 10.1         | 15.0                  | 14.2                  |
| Navan 110 kV         | 5.7                      | 11.2                  | 10.4                  | 6.5          | 11.2                  | 10.9                  | 5.2              | 14.0                  | 13.0                  | 6.1          | 13.1                  | 12.8                  |
| Nenagh 110 kV        | 3.3                      | 3.5                   | 3.4                   | 4.1          | 2.4                   | 2.4                   | 3.3              | 4.6                   | 4.2                   | 4.1          | 2.7                   | 2.7                   |
| Newbridge 110 kV     | 4.4                      | 9.1                   | 8.5                   | 5.1          | 9.4                   | 9.2                   | 4.1              | 11.7                  | 10.8                  | 4.9          | 11.2                  | 10.9                  |
| Newbury 110 kV       | 14.2                     | 12.9                  | 11.7                  | 7.7          | 14.4                  | 13.9                  | 14.5             | 17.1                  | 15.2                  | 7.2          | 17.9                  | 17.2                  |
| North Quays 110 kV   | 17.7                     | 11.0                  | 10.1                  | 7.0          | 13.5                  | 13.0                  | 18.6             | 15.2                  | 13.8                  | 6.1          | 17.6                  | 16.9                  |
| North Wall 220 kV    | 13.4                     | 13.7                  | 12.3                  | 9.3          | 16.2                  | 15.4                  | 14.5             | 23.1                  | 20.4                  | 8.2          | 24.2                  | 23.1                  |
| Oldcourt A 110 kV    | 4.3                      | 9.4                   | 8.9                   | 4.8          | 7.6                   | 7.5                   | 3.7              | 11.9                  | 11.1                  | 4.5          | 8.7                   | 8.6                   |
| Oldcourt B 110 kV    | 4.4                      | 9.5                   | 8.9                   | 4.9          | 7.6                   | 7.5                   | 3.8              | 11.9                  | 11.2                  | 4.5          | 8.8                   | 8.7                   |
| Oldstreet 220 kV     | 13.1                     | 7.1                   | 6.7                   | 11.6         | 8.3                   | 8.1                   | 15.6             | 11.6                  | 11.0                  | 12.3         | 12.2                  | 11.9                  |
| Oldstreet 400 kV     | 14.3                     | 6.0                   | 5.6                   | 10.0         | 6.1                   | 5.9                   | 16.2             | 9.2                   | 8.7                   | 9.6          | 8.2                   | 8.0                   |
| Oriel 220 kV         | 9.8                      | 10.2                  | 9.4                   | 8.3          | 10.7                  | 10.4                  | 8.5              | 13.6                  | 13.0                  | 7.9          | 10.0                  | 9.9                   |
| Oughtragh 110 kV     | 3.7                      | 4.1                   | 4.0                   | 4.8          | 2.8                   | 2.8                   | 3.6              | 5.0                   | 4.7                   | 4.8          | 3.1                   | 3.0                   |
| Oweninney 110 kV     | 3.4                      | 3.4                   | 3.2                   | 3.8          | 4.3                   | 4.2                   | 5.2              | 7.0                   | 6.0                   | 5.9          | 7.5                   | 7.1                   |
| Pelletstown 110 kV   | 13.6                     | 9.5                   | 8.9                   | 8.1          | 10.5                  | 10.3                  | 13.8             | 12.1                  | 11.0                  | 7.8          | 12.7                  | 12.3                  |
| Platin 110 kV        | 5.2                      | 11.2                  | 10.4                  | 5.8          | 8.7                   | 8.6                   | 4.6              | 13.6                  | 12.7                  | 5.5          | 9.8                   | 9.7                   |
| Pollaphuca 110 kV    | 2.8                      | 2.4                   | 2.4                   | 4.0          | 2.2                   | 2.2                   | 3.3              | 3.1                   | 3.0                   | 4.7          | 2.6                   | 2.6                   |
| Poolbeg A 110 kV     | 23.7                     | 11.5                  | 10.6                  | 20.5         | 14.7                  | 14.2                  | 28.3             | 16.0                  | 14.5                  | 22.1         | 19.5                  | 18.7                  |
| Poolbeg A 220 kV     | 14.0                     | 13.8                  | 12.4                  | 8.1          | 15.5                  | 14.8                  | 15.3             | 23.2                  | 20.6                  | 7.0          | 22.7                  | 21.8                  |
| Poolbeg B 110 kV     | 23.7                     | 11.5                  | 10.5                  | 20.5         | 14.7                  | 14.1                  | 28.3             | 15.9                  | 14.4                  | 22.1         | 19.4                  | 18.6                  |
| Poolbeg B 220 kV     | 13.5                     | 16.3                  | 14.1                  | 10.3         | 19.0                  | 17.9                  | 13.2             | 25.2                  | 22.1                  | 9.3          | 26.8                  | 25.5                  |
| Poolbeg C 110 kV     | 19.5                     | 11.2                  | 10.3                  | 8.0          | 13.8                  | 13.3                  | 21.3             | 15.6                  | 14.1                  | 7.1          | 18.0                  | 17.3                  |
| Poppintree 110 kV    | 13.5                     | 12.8                  | 11.7                  | 8.5          | 14.6                  | 14.1                  | 13.7             | 17.0                  | 15.2                  | 8.0          | 18.2                  | 17.5                  |
| Portan 400 kV        | 18.9                     | 6.6                   | 6.2                   | 18.1         | 7.7                   | 7.5                   | 18.5             | 9.5                   | 9.1                   | 17.9         | 10.4                  | 10.2                  |
| Portlaoise 110 kV    | 4.0                      | 7.9                   | 7.4                   | 5.3          | 7.5                   | 7.4                   | 3.8              | 9.9                   | 9.2                   | 5.2          | 8.7                   | 8.5                   |
| Pottery 110 kV       | 17.1                     | 10.4                  | 9.6                   | 5.9          | 10.7                  | 10.4                  | 17.4             | 12.7                  | 11.5                  | 5.6          | 12.4                  | 12.0                  |
| Prospect 220 kV      | 11.4                     | 10.5                  | 9.7                   | 8.9          | 12.2                  | 11.8                  | 12.5             | 19.6                  | 18.1                  | 8.2          | 19.2                  | 18.6                  |
| Raffeen 220 kV       | 12.6                     | 12.5                  | 11.2                  | 12.1         | 15.5                  | 14.8                  | 12.6             | 19.7                  | 17.6                  | 10.5         | 22.7                  | 21.6                  |

## TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-3 Short Circuit Currents for Maximum and Minimum Demand in 2018 (Continued)

| Bus                  | Summer Night Valley 2015 |                       |                       |              |                       |                       | Winter Peak 2015 |                       |                       |              |                       |                       |
|----------------------|--------------------------|-----------------------|-----------------------|--------------|-----------------------|-----------------------|------------------|-----------------------|-----------------------|--------------|-----------------------|-----------------------|
|                      | Three-Phase              |                       |                       | Single-Phase |                       |                       | Three-Phase      |                       |                       | Single-Phase |                       |                       |
|                      | X/R Ratio                | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio    | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio        | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio    | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] |
| Raffeen A 110 kV     | 8.1                      | 12.9                  | 11.9                  | 8.9          | 15.3                  | 14.9                  | 7.2              | 17.5                  | 16.0                  | 8.1          | 19.7                  | 19.0                  |
| Raffeen B 110 kV     | 9.4                      | 12.4                  | 11.5                  | 10.1         | 14.7                  | 14.3                  | 8.3              | 16.8                  | 15.4                  | 9.2          | 18.8                  | 18.2                  |
| Rathkeale 110 kV     | 3.6                      | 6.5                   | 6.2                   | 4.8          | 5.4                   | 5.3                   | 3.4              | 8.0                   | 7.5                   | 4.8          | 6.0                   | 5.9                   |
| Ratrussan 110 kV     | 3.2                      | 5.8                   | 5.6                   | 4.0          | 6.6                   | 6.5                   | 3.8              | 8.4                   | 7.1                   | 5.0          | 8.6                   | 8.1                   |
| Reamore 110 kV       | 4.4                      | 5.8                   | 5.6                   | 3.6          | 5.5                   | 5.4                   | 4.5              | 8.0                   | 7.2                   | 3.5          | 6.5                   | 6.3                   |
| Richmond A 110 kV    | 3.2                      | 6.7                   | 6.3                   | 4.4          | 6.1                   | 6.0                   | 3.0              | 7.8                   | 7.3                   | 4.2          | 6.8                   | 6.7                   |
| Richmond B 110 kV    | 3.2                      | 6.7                   | 6.3                   | 4.4          | 6.1                   | 6.0                   | 3.0              | 7.8                   | 7.3                   | 4.2          | 6.8                   | 6.7                   |
| Rinawade 110 kV      | 5.1                      | 9.8                   | 9.2                   | 6.0          | 7.3                   | 7.2                   | 4.7              | 11.6                  | 11.1                  | 5.8          | 8.1                   | 8.0                   |
| Ringaskiddy 110 kV   | 6.4                      | 10.5                  | 9.8                   | 6.6          | 10.4                  | 10.2                  | 5.5              | 13.6                  | 12.7                  | 6.0          | 12.5                  | 12.2                  |
| Ringsend 110 kV      | 23.7                     | 11.5                  | 10.5                  | 21.2         | 14.7                  | 14.2                  | 28.8             | 16.1                  | 14.5                  | 23.4         | 19.6                  | 18.8                  |
| Ryebrook 110 kV      | 5.6                      | 12.9                  | 11.8                  | 6.5          | 11.7                  | 11.4                  | 5.1              | 15.6                  | 14.5                  | 6.1          | 13.4                  | 13.1                  |
| Salthill 110 kV      | 4.5                      | 8.9                   | 8.3                   | 4.1          | 9.6                   | 9.3                   | 4.7              | 14.9                  | 12.9                  | 4.1          | 13.6                  | 13.0                  |
| Screeb 110 kV        | 3.5                      | 2.3                   | 2.2                   | 4.5          | 1.3                   | 1.3                   | 4.4              | 3.5                   | 3.0                   | 5.1          | 1.5                   | 1.4                   |
| Seal Rock A 110 kV   | 8.7                      | 9.5                   | 8.5                   | 10.3         | 10.6                  | 10.1                  | 7.8              | 10.9                  | 9.8                   | 9.5          | 11.7                  | 11.2                  |
| Seal Rock B 110 kV   | 8.8                      | 9.5                   | 8.5                   | 10.3         | 10.6                  | 10.1                  | 7.8              | 11.0                  | 9.8                   | 9.5          | 11.7                  | 11.2                  |
| Shankill 110 kV      | 3.7                      | 7.1                   | 6.7                   | 4.7          | 6.7                   | 6.6                   | 3.7              | 9.6                   | 8.5                   | 5.0          | 8.2                   | 7.9                   |
| Shannonbridge 110 kV | 6.8                      | 14.6                  | 13.1                  | 8.4          | 16.6                  | 15.9                  | 5.8              | 17.5                  | 15.8                  | 7.4          | 18.8                  | 18.1                  |
| Shannonbridge 220 kV | 8.0                      | 6.4                   | 6.1                   | 10.4         | 5.7                   | 5.6                   | 7.1              | 7.7                   | 7.4                   | 9.8          | 6.4                   | 6.3                   |
| Shellybanks A 220 kV | 13.8                     | 13.8                  | 12.3                  | 8.1          | 17.1                  | 16.3                  | 15.0             | 23.2                  | 20.5                  | 6.8          | 26.1                  | 24.8                  |
| Shellybanks B 220 kV | 14.1                     | 15.8                  | 13.8                  | 10.6         | 19.8                  | 18.6                  | 14.5             | 24.5                  | 21.5                  | 9.6          | 28.3                  | 26.8                  |
| Shelton Abbey 110 kV | 7.6                      | 6.8                   | 6.5                   | 7.6          | 7.3                   | 7.2                   | 7.3              | 8.5                   | 8.0                   | 7.4          | 8.7                   | 8.5                   |
| Singland 110 kV      | 6.8                      | 12.3                  | 11.4                  | 7.7          | 12.6                  | 12.3                  | 6.7              | 18.5                  | 16.8                  | 7.8          | 14.3                  | 13.9                  |
| Sliabh Bawn 110 kV   | 3.5                      | 8.2                   | 7.7                   | 4.4          | 7.9                   | 7.8                   | 3.4              | 10.6                  | 9.6                   | 4.6          | 9.3                   | 9.1                   |
| Sligo 110 kV         | 4.0                      | 7.3                   | 6.9                   | 4.5          | 7.3                   | 7.2                   | 3.6              | 10.8                  | 9.8                   | 4.4          | 9.5                   | 9.2                   |
| Somerset 110 kV      | 3.1                      | 7.0                   | 6.7                   | 4.1          | 4.6                   | 4.6                   | 2.9              | 8.2                   | 7.7                   | 3.9          | 5.1                   | 5.0                   |
| Sorne Hill 110 kV    | 2.7                      | 2.2                   | 2.2                   | 3.3          | 2.6                   | 2.6                   | 3.3              | 3.7                   | 3.3                   | 4.3          | 3.7                   | 3.6                   |
| Srananagh 110 kV     | 4.8                      | 8.2                   | 7.7                   | 5.5          | 9.4                   | 9.2                   | 4.6              | 12.7                  | 11.4                  | 5.6          | 12.9                  | 12.4                  |
| Srananagh 220 kV     | 6.7                      | 4.0                   | 3.8                   | 8.8          | 3.4                   | 3.4                   | 7.4              | 5.1                   | 4.9                   | 9.7          | 3.9                   | 3.9                   |
| Stevenstown 110 kV   | 4.3                      | 5.7                   | 5.4                   | 4.8          | 3.8                   | 3.7                   | 4.1              | 6.7                   | 6.3                   | 4.7          | 4.1                   | 4.1                   |
| Stratford 110 kV     | 3.1                      | 3.7                   | 3.6                   | 4.1          | 3.0                   | 3.0                   | 3.3              | 4.6                   | 4.3                   | 4.4          | 3.4                   | 3.3                   |
| Taney 110 kV         | 9.0                      | 9.0                   | 8.4                   | 3.4          | 9.0                   | 8.8                   | 8.7              | 10.8                  | 9.9                   | 3.2          | 10.3                  | 10.0                  |
| Tarbert 110 kV       | 20.6                     | 10.5                  | 10.0                  | 23.2         | 11.6                  | 11.4                  | 34.6             | 16.9                  | 15.8                  | 34.8         | 16.0                  | 15.6                  |
| Tarbert 220 kV       | 11.8                     | 11.4                  | 10.5                  | 11.6         | 15.0                  | 14.5                  | 15.1             | 24.1                  | 21.7                  | 13.2         | 28.0                  | 26.8                  |
| Tawnaghmore A 110 kV | 3.3                      | 3.1                   | 2.9                   | 4.1          | 3.3                   | 3.3                   | 4.6              | 5.8                   | 5.2                   | 6.0          | 4.9                   | 4.8                   |
| Tawnaghmore B 110 kV | 3.9                      | 3.4                   | 3.2                   | 4.7          | 4.0                   | 3.9                   | 5.5              | 6.2                   | 5.5                   | 7.1          | 6.0                   | 5.8                   |
| Thornsberry 110 kV   | 4.1                      | 5.6                   | 5.4                   | 5.2          | 5.4                   | 5.3                   | 4.2              | 7.7                   | 7.2                   | 5.6          | 6.7                   | 6.6                   |
| Thurles 110 kV       | 5.1                      | 4.2                   | 4.0                   | 5.5          | 4.8                   | 4.7                   | 6.2              | 6.8                   | 5.9                   | 6.5          | 6.8                   | 6.5                   |
| Tievebrack 110 kV    | 3.4                      | 3.3                   | 3.1                   | 4.5          | 2.6                   | 2.6                   | 3.7              | 5.1                   | 4.6                   | 5.1          | 3.2                   | 3.1                   |

Table E-3 Short Circuit Currents for Maximum and Minimum Demand in 2018 (Continued)

| Bus               | Summer Night Valley 2015 |                       |                       |              |                       |                       | Winter Peak 2015 |                       |                       |              |                       |                       |
|-------------------|--------------------------|-----------------------|-----------------------|--------------|-----------------------|-----------------------|------------------|-----------------------|-----------------------|--------------|-----------------------|-----------------------|
|                   | Three-Phase              |                       |                       | Single-Phase |                       |                       | Three-Phase      |                       |                       | Single-Phase |                       |                       |
|                   | X/R Ratio                | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio    | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio        | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio    | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] |
| Tipperary 110 kV  | 5.0                      | 6.1                   | 5.9                   | 6.1          | 4.3                   | 4.2                   | 5.2              | 8.1                   | 7.6                   | 6.3          | 4.8                   | 4.7                   |
| Tonroe 110 kV     | 2.7                      | 3.1                   | 3.0                   | 3.7          | 2.0                   | 1.9                   | 2.7              | 3.6                   | 3.4                   | 3.8          | 2.1                   | 2.1                   |
| Trabeg 110 kV     | 8.0                      | 15.0                  | 13.6                  | 8.8          | 17.1                  | 16.5                  | 7.4              | 23.4                  | 20.5                  | 8.4          | 23.9                  | 22.8                  |
| Tralee 110 kV     | 5.0                      | 7.3                   | 6.9                   | 6.0          | 6.8                   | 6.7                   | 5.0              | 10.4                  | 9.3                   | 6.2          | 8.2                   | 8.0                   |
| Trien A 110 kV    | 4.7                      | 6.7                   | 6.3                   | 5.8          | 6.2                   | 6.1                   | 4.4              | 8.8                   | 8.1                   | 5.7          | 7.3                   | 7.1                   |
| Trien B 110 kV    | 10.5                     | 6.5                   | 6.3                   | 8.8          | 7.1                   | 7.0                   | 10.4             | 10.7                  | 9.0                   | 8.2          | 10.0                  | 9.4                   |
| Trillick 110 kV   | 2.7                      | 2.4                   | 2.3                   | 3.4          | 2.6                   | 2.6                   | 3.4              | 4.1                   | 3.6                   | 4.4          | 3.7                   | 3.6                   |
| Trinity 110 kV    | 12.3                     | 10.4                  | 9.6                   | 6.9          | 12.9                  | 12.5                  | 11.6             | 14.1                  | 12.8                  | 6.0          | 16.6                  | 16.0                  |
| Tullabrack 110 kV | 6.8                      | 6.2                   | 6.0                   | 7.4          | 5.1                   | 5.0                   | 6.7              | 8.0                   | 7.6                   | 7.4          | 5.8                   | 5.7                   |
| Turlough 220 kV   | 12.0                     | 11.1                  | 10.1                  | 13.0         | 10.3                  | 9.9                   | 10.5             | 13.2                  | 12.3                  | 11.9         | 11.4                  | 11.2                  |
| Tynagh 220 kV     | 10.3                     | 6.7                   | 6.4                   | 11.3         | 8.4                   | 8.2                   | 15.0             | 13.0                  | 12.0                  | 16.7         | 13.9                  | 13.5                  |
| Uggool 110 kV     | 5.5                      | 5.7                   | 5.4                   | 6.5          | 6.7                   | 6.5                   | 8.2              | 10.6                  | 8.7                   | 10.1         | 10.5                  | 9.8                   |
| Waterford 110 kV  | 7.4                      | 10.8                  | 10.3                  | 7.6          | 12.1                  | 11.9                  | 6.5              | 13.4                  | 12.4                  | 6.9          | 14.3                  | 13.9                  |
| Wexford 110 kV    | 3.9                      | 5.7                   | 5.5                   | 5.0          | 5.5                   | 5.4                   | 4.0              | 7.2                   | 6.6                   | 5.3          | 6.4                   | 6.2                   |
| Whitegate 110 kV  | 4.8                      | 8.9                   | 8.4                   | 5.5          | 9.2                   | 9.0                   | 4.3              | 11.0                  | 10.4                  | 5.1          | 10.8                  | 10.5                  |
| Wolfe Tone 110 kV | 13.9                     | 9.8                   | 9.1                   | 5.9          | 11.5                  | 11.2                  | 14.2             | 12.5                  | 11.4                  | 5.5          | 14.1                  | 13.6                  |
| Woodhouse 110 kV  | 5.9                      | 5.4                   | 5.2                   | 7.3          | 4.1                   | 4.1                   | 5.9              | 6.9                   | 6.5                   | 7.4          | 4.8                   | 4.7                   |
| Woodland 220 kV   | 13.9                     | 16.1                  | 14.4                  | 13.3         | 18.2                  | 17.4                  | 12.1             | 24.6                  | 22.4                  | 12.0         | 25.4                  | 24.6                  |
| Woodland 400 kV   | 20.1                     | 6.7                   | 6.2                   | 19.5         | 7.7                   | 7.5                   | 20.0             | 9.6                   | 9.1                   | 19.6         | 10.5                  | 10.3                  |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-4 Short Circuit Currents for Maximum and Minimum Demand in 2021<sup>1</sup>

| Bus                  | Summer Night Valley 2015 |                       |                       |              |                       |                       | Winter Peak 2015 |                       |                       |              |                       |                       |
|----------------------|--------------------------|-----------------------|-----------------------|--------------|-----------------------|-----------------------|------------------|-----------------------|-----------------------|--------------|-----------------------|-----------------------|
|                      | Three-Phase              |                       |                       | Single-Phase |                       |                       | Three-Phase      |                       |                       | Single-Phase |                       |                       |
|                      | X/R Ratio                | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio    | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio        | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] | X/R Ratio    | I <sub>k''</sub> [kA] | I <sub>k''</sub> [kA] |
| Adamstown 110 kV     | 12.1                     | 10.7                  | 9.9                   | 6.6          | 12.9                  | 12.5                  | 11.6             | 12.9                  | 11.6                  | 6.2          | 15.1                  | 14.5                  |
| Agannygal 110 kV     | 2.8                      | 4.7                   | 4.6                   | 3.8          | 4.1                   | 4.0                   | 3.1              | 6.9                   | 6.0                   | 4.5          | 5.0                   | 4.9                   |
| Aghada 110 kV        | 5.1                      | 8.3                   | 7.9                   | 6.1          | 9.7                   | 9.5                   | 4.6              | 10.3                  | 9.8                   | 5.6          | 11.5                  | 11.3                  |
| Aghada A 220 kV      | 14.6                     | 13.4                  | 12.0                  | 15.7         | 17.3                  | 16.5                  | 15.0             | 22.5                  | 19.9                  | 16.1         | 26.5                  | 25.1                  |
| Aghada B 220 kV      | 14.6                     | 13.4                  | 12.0                  | 15.7         | 17.3                  | 16.5                  | 15.0             | 22.5                  | 19.9                  | 16.1         | 26.5                  | 25.1                  |
| Aghada C 220 kV      | 14.6                     | 13.4                  | 12.0                  | 15.7         | 17.3                  | 16.5                  | 15.0             | 22.5                  | 19.9                  | 16.1         | 26.5                  | 25.1                  |
| Aghada D 220 kV      | 14.0                     | 13.0                  | 11.7                  | 13.5         | 16.8                  | 16.0                  | 14.0             | 21.5                  | 19.1                  | 12.8         | 25.4                  | 24.2                  |
| Ahane 110 kV         | 5.5                      | 10.9                  | 10.2                  | 6.0          | 8.0                   | 7.8                   | 5.0              | 15.5                  | 14.4                  | 5.8          | 9.5                   | 9.3                   |
| Anner 110 kV         | 4.0                      | 5.9                   | 5.6                   | 4.5          | 4.8                   | 4.7                   | 4.3              | 8.2                   | 7.6                   | 4.8          | 5.7                   | 5.6                   |
| Ardnacrusha 110 kV   | 6.3                      | 11.8                  | 11.0                  | 7.8          | 12.8                  | 12.4                  | 6.4              | 18.7                  | 17.0                  | 8.4          | 17.5                  | 17.0                  |
| Ardnagappary 110 kV  | 2.8                      | 1.9                   | 1.8                   | 3.9          | 1.2                   | 1.2                   | 2.9              | 2.5                   | 2.3                   | 4.2          | 1.3                   | 1.3                   |
| Arigna 110 kV        | 4.4                      | 6.1                   | 5.8                   | 5.4          | 5.2                   | 5.1                   | 4.8              | 9.0                   | 8.2                   | 6.0          | 6.4                   | 6.2                   |
| Arklow 110 kV        | 10.4                     | 7.6                   | 7.3                   | 11.2         | 9.4                   | 9.2                   | 10.5             | 9.6                   | 9.0                   | 11.4         | 11.4                  | 11.1                  |
| Arklow 220 kV        | 9.1                      | 6.9                   | 6.6                   | 10.5         | 6.6                   | 6.5                   | 8.8              | 8.5                   | 8.1                   | 10.4         | 7.6                   | 7.5                   |
| Artane 110 kV        | 13.4                     | 9.9                   | 9.3                   | 6.3          | 12.0                  | 11.7                  | 13.2             | 12.3                  | 11.3                  | 5.8          | 14.4                  | 13.9                  |
| Arva 110 kV          | 3.9                      | 8.0                   | 7.5                   | 5.0          | 6.5                   | 6.4                   | 3.8              | 10.5                  | 9.6                   | 5.1          | 7.5                   | 7.4                   |
| Athea 110 kV         | 13.2                     | 7.5                   | 7.3                   | 12.7         | 8.3                   | 8.2                   | 13.6             | 13.6                  | 11.5                  | 12.8         | 12.4                  | 11.7                  |
| Athlone 110 kV       | 4.1                      | 6.4                   | 6.1                   | 4.7          | 7.3                   | 7.2                   | 4.9              | 9.9                   | 9.2                   | 5.8          | 9.9                   | 9.7                   |
| Athy 110 kV          | 5.0                      | 6.8                   | 6.5                   | 6.0          | 5.7                   | 5.7                   | 4.6              | 7.9                   | 7.5                   | 5.8          | 6.4                   | 6.3                   |
| Aughinish 110 kV     | 9.1                      | 9.7                   | 8.7                   | 11.1         | 10.8                  | 10.3                  | 8.0              | 11.2                  | 10.2                  | 10.1         | 11.7                  | 11.3                  |
| Ballybeg 110 kV      | 10.0                     | 6.1                   | 5.8                   | 10.2         | 7.2                   | 7.1                   | 9.8              | 7.0                   | 6.7                   | 10.0         | 8.1                   | 8.0                   |
| Ballydine 110 kV     | 4.0                      | 6.6                   | 6.3                   | 3.8          | 5.5                   | 5.4                   | 4.2              | 8.8                   | 8.2                   | 3.9          | 6.5                   | 6.4                   |
| Ballylickey 110 kV   | 2.8                      | 3.0                   | 2.9                   | 3.9          | 1.9                   | 1.9                   | 2.9              | 3.8                   | 3.6                   | 4.1          | 2.1                   | 2.1                   |
| Ballynahulla 110 kV  | 12.7                     | 7.5                   | 7.2                   | 12.3         | 8.1                   | 8.0                   | 14.5             | 13.1                  | 11.6                  | 12.9         | 11.9                  | 11.4                  |
| Ballynahulla 220 kV  | 7.4                      | 7.2                   | 6.8                   | 7.7          | 8.2                   | 8.1                   | 7.4              | 12.4                  | 11.4                  | 7.8          | 12.2                  | 11.9                  |
| Ballyragget 110 kV   | 5.1                      | 6.2                   | 6.0                   | 6.2          | 4.5                   | 4.5                   | 4.8              | 7.1                   | 6.8                   | 5.8          | 5.2                   | 5.2                   |
| Ballyvouskill 110 kV | 12.3                     | 7.9                   | 7.6                   | 12.8         | 9.0                   | 8.8                   | 12.8             | 13.1                  | 11.8                  | 13.2         | 13.0                  | 12.5                  |
| Ballyvouskill 220 kV | 6.9                      | 7.7                   | 7.2                   | 7.7          | 9.3                   | 9.1                   | 6.8              | 13.5                  | 12.3                  | 7.8          | 14.3                  | 13.9                  |
| Ballywater 110 kV    | 4.6                      | 4.9                   | 4.8                   | 3.3          | 5.2                   | 5.2                   | 4.6              | 6.1                   | 5.8                   | 3.2          | 6.0                   | 5.9                   |
| Baltrasna 110 kV     | 6.4                      | 9.7                   | 9.2                   | 7.5          | 7.6                   | 7.5                   | 5.8              | 11.4                  | 10.8                  | 7.1          | 8.4                   | 8.3                   |
| Bancroft 110 kV      | 12.6                     | 11.1                  | 10.2                  | 7.2          | 13.0                  | 12.6                  | 12.1             | 13.2                  | 12.1                  | 6.8          | 15.0                  | 14.5                  |
| Bandon 110 kV        | 3.3                      | 5.9                   | 5.6                   | 4.4          | 5.8                   | 5.7                   | 3.0              | 7.5                   | 7.0                   | 4.2          | 6.8                   | 6.6                   |
| Banoge 110 kV        | 6.1                      | 5.4                   | 5.2                   | 6.8          | 5.0                   | 4.9                   | 5.9              | 6.5                   | 6.2                   | 6.7          | 5.6                   | 5.5                   |
| Barnadivane 110 kV   | 4.1                      | 7.5                   | 7.2                   | 4.8          | 7.5                   | 7.3                   | 4.0              | 11.2                  | 10.2                  | 4.9          | 9.7                   | 9.5                   |
| Barnahealy A 110 kV  | 6.0                      | 11.2                  | 10.5                  | 6.5          | 11.8                  | 11.5                  | 5.2              | 14.9                  | 13.8                  | 6.0          | 14.4                  | 14.1                  |
| Barnahealy B 110 kV  | 7.3                      | 10.8                  | 10.1                  | 7.7          | 11.2                  | 11.0                  | 6.3              | 14.4                  | 13.4                  | 7.0          | 13.8                  | 13.4                  |

<sup>1</sup> The results presented for the 2021 maximum and minimum demand short circuit currents are based on Grid West option (see Chapter 2) data that produced the most onerous fault level. It should be noted that short circuit current values may potentially change in future TYTFS versions as the project matures and further detailed analysis/information becomes available.

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-4 Short Circuit Currents for Maximum and Minimum Demand in 2021 (Continued)

| Bus                       | Summer Night Valley 2015 |                        |                         |              |                        |                         | Winter Peak 2015 |                        |                         |              |                        |                         |
|---------------------------|--------------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|
|                           | Three-Phase              |                        |                         | Single-Phase |                        |                         | Three-Phase      |                        |                         | Single-Phase |                        |                         |
|                           | X/R Ratio                | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio        | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] |
| Barnakyle 110 kV          | 22.1                     | 15.0                   | 13.6                    | 21.9         | 11.7                   | 11.4                    | 21.9             | 17.8                   | 16.4                    | 21.7         | 13.0                   | 12.7                    |
| Baroda 110 kV             | 4.2                      | 8.3                    | 7.8                     | 4.9          | 9.7                    | 9.5                     | 3.9              | 10.0                   | 9.4                     | 4.7          | 11.2                   | 10.9                    |
| Barrymore 110 kV          | 4.0                      | 7.1                    | 6.8                     | 5.5          | 5.7                    | 5.6                     | 3.7              | 9.2                    | 8.7                     | 5.4          | 6.7                    | 6.6                     |
| Belcamp 110 kV            | 14.7                     | 13.1                   | 12.0                    | 9.0          | 14.7                   | 14.2                    | 14.8             | 16.9                   | 15.2                    | 8.5          | 17.9                   | 17.2                    |
| Belcamp 220 kV            | 12.2                     | 14.3                   | 12.8                    | 10.4         | 17.8                   | 16.9                    | 11.3             | 23.6                   | 21.0                    | 9.1          | 26.7                   | 25.5                    |
| Bellacorick A 110 kV      | 3.5                      | 3.5                    | 3.3                     | 3.8          | 4.5                    | 4.4                     | 5.2              | 7.0                    | 6.0                     | 5.6          | 7.9                    | 7.4                     |
| Bellacorick B 110 kV      | 12.6                     | 3.9                    | 3.8                     | 12.1         | 5.0                    | 5.0                     | 15.8             | 6.6                    | 5.9                     | 14.0         | 7.9                    | 7.5                     |
| Binbane 110 kV            | 3.2                      | 3.4                    | 3.3                     | 4.3          | 3.4                    | 3.4                     | 3.6              | 5.9                    | 5.2                     | 5.4          | 4.7                    | 4.5                     |
| Blackpool 110 kV          | 7.7                      | 15.8                   | 14.3                    | 7.8          | 17.1                   | 16.5                    | 6.8              | 25.0                   | 22.1                    | 7.2          | 23.5                   | 22.6                    |
| Blackrock 110 kV          | 11.3                     | 9.5                    | 8.9                     | 3.0          | 8.8                    | 8.6                     | 10.9             | 11.5                   | 10.4                    | 2.8          | 9.9                    | 9.6                     |
| Blake 110 kV              | 4.1                      | 7.7                    | 7.4                     | 5.1          | 5.4                    | 5.3                     | 3.8              | 9.1                    | 8.7                     | 5.0          | 5.9                    | 5.8                     |
| Boggeragh 110 kV          | 6.0                      | 6.4                    | 6.2                     | 7.2          | 6.9                    | 6.8                     | 6.4              | 9.4                    | 8.6                     | 7.9          | 8.8                    | 8.6                     |
| Booltiagh 110 kV          | 6.4                      | 6.4                    | 6.1                     | 8.0          | 5.6                    | 5.5                     | 6.8              | 9.2                    | 8.5                     | 8.7          | 6.9                    | 6.7                     |
| Bracklone 110 kV          | 4.0                      | 8.4                    | 8.0                     | 5.0          | 7.8                    | 7.7                     | 3.7              | 10.1                   | 9.6                     | 4.8          | 8.8                    | 8.6                     |
| Brinny A 110 kV           | 3.2                      | 5.3                    | 5.1                     | 4.2          | 4.8                    | 4.7                     | 2.9              | 6.6                    | 6.2                     | 4.1          | 5.5                    | 5.4                     |
| Brinny B 110 kV           | 3.2                      | 5.3                    | 5.1                     | 4.2          | 4.8                    | 4.8                     | 2.9              | 6.7                    | 6.2                     | 4.1          | 5.5                    | 5.4                     |
| Bunkimalta 110 kV         | 5.3                      | 5.1                    | 4.9                     | 5.6          | 5.2                    | 5.2                     | 6.6              | 8.2                    | 7.2                     | 6.6          | 7.4                    | 7.1                     |
| Butlerstown 110 kV        | 6.0                      | 9.6                    | 9.1                     | 5.7          | 9.8                    | 9.6                     | 5.3              | 11.7                   | 11.0                    | 5.2          | 11.4                   | 11.1                    |
| Cabra 110 kV              | 12.4                     | 9.5                    | 9.0                     | 5.1          | 10.8                   | 10.6                    | 12.2             | 11.9                   | 10.9                    | 4.7          | 12.8                   | 12.4                    |
| Cahernagh 110 kV          | 4.3                      | 4.6                    | 4.5                     | 5.3          | 5.1                    | 5.1                     | 5.6              | 7.2                    | 6.8                     | 7.2          | 6.7                    | 6.6                     |
| Cahir 110 kV              | 4.4                      | 7.4                    | 7.0                     | 5.0          | 8.3                    | 8.1                     | 5.7              | 12.8                   | 11.5                    | 6.6          | 12.1                   | 11.7                    |
| Carlow 110 kV             | 5.7                      | 7.9                    | 7.6                     | 6.4          | 8.6                    | 8.4                     | 5.6              | 10.0                   | 9.3                     | 6.4          | 10.1                   | 9.9                     |
| Carrickmines 220 kV       | 14.6                     | 15.3                   | 13.5                    | 10.0         | 18.9                   | 17.9                    | 13.6             | 22.6                   | 20.0                    | 8.7          | 26.2                   | 24.9                    |
| Carrickmines A 110 kV     | 29.1                     | 10.9                   | 10.1                    | 23.8         | 12.0                   | 11.7                    | 31.3             | 13.3                   | 12.0                    | 24.4         | 14.1                   | 13.6                    |
| Carrickmines B 110 kV     | 24.1                     | 12.2                   | 11.2                    | 20.4         | 14.7                   | 14.2                    | 24.9             | 14.8                   | 13.5                    | 20.4         | 17.2                   | 16.6                    |
| Carrick-on-Shannon 110 kV | 4.4                      | 9.2                    | 8.7                     | 5.0          | 10.5                   | 10.3                    | 4.3              | 13.8                   | 12.5                    | 5.1          | 14.1                   | 13.7                    |
| Carrigadrohid 110 kV      | 6.4                      | 11.0                   | 10.3                    | 7.1          | 11.5                   | 11.2                    | 5.9              | 16.7                   | 15.3                    | 6.9          | 15.1                   | 14.7                    |
| Carrowbeg 110 kV          | 2.7                      | 2.5                    | 2.4                     | 3.6          | 2.4                    | 2.3                     | 2.7              | 3.3                    | 3.0                     | 3.7          | 2.8                    | 2.7                     |
| Cashla 110 kV             | 7.3                      | 12.4                   | 11.4                    | 7.9          | 15.9                   | 15.3                    | 7.2              | 22.0                   | 19.3                    | 8.2          | 25.4                   | 24.1                    |
| Cashla 220 kV             | 8.3                      | 7.9                    | 7.4                     | 9.3          | 8.7                    | 8.4                     | 8.6              | 13.4                   | 12.5                    | 10.1         | 12.4                   | 12.1                    |
| Castlebar 110 kV          | 3.2                      | 4.2                    | 4.0                     | 3.7          | 4.7                    | 4.6                     | 3.4              | 6.5                    | 5.7                     | 4.1          | 6.2                    | 6.0                     |
| Castledockrill 110 kV     | 6.8                      | 6.4                    | 6.2                     | 4.8          | 7.9                    | 7.7                     | 6.8              | 8.2                    | 7.7                     | 4.6          | 9.3                    | 9.1                     |
| Castlefarm A 110 kV       | 8.1                      | 9.4                    | 8.4                     | 9.5          | 10.0                   | 9.6                     | 7.2              | 10.8                   | 9.8                     | 8.7          | 10.9                   | 10.5                    |
| Castlefarm B 110 kV       | 8.1                      | 9.3                    | 8.4                     | 9.5          | 10.0                   | 9.6                     | 7.2              | 10.8                   | 9.8                     | 8.7          | 10.8                   | 10.5                    |
| Castletown 110 kV         | 6.0                      | 9.4                    | 8.9                     | 5.8          | 7.9                    | 7.8                     | 6.3              | 13.0                   | 11.7                    | 5.9          | 9.4                    | 9.2                     |
| Castleview 110 kV         | 4.4                      | 11.0                   | 10.3                    | 4.8          | 8.4                    | 8.3                     | 3.6              | 14.4                   | 13.4                    | 4.4          | 9.8                    | 9.6                     |
| Cathaleen's Fall 110 kV   | 4.3                      | 6.3                    | 6.0                     | 4.9          | 7.2                    | 7.1                     | 5.3              | 13.0                   | 11.1                    | 6.3          | 11.7                   | 11.1                    |
| Cauteen 110 kV            | 5.4                      | 6.4                    | 6.1                     | 6.3          | 4.4                    | 4.4                     | 5.9              | 9.4                    | 8.7                     | 6.7          | 5.3                    | 5.2                     |
| Central 110 kV            | 14.6                     | 10.0                   | 9.3                     | 7.9          | 10.8                   | 10.6                    | 14.3             | 12.1                   | 11.0                    | 7.6          | 12.5                   | 12.1                    |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-4 Short Circuit Currents for Maximum and Minimum Demand in 2021 (Continued)

| Bus                  | Summer Night Valley 2015 |           |           |              |           |           | Winter Peak 2015 |           |           |              |           |           |
|----------------------|--------------------------|-----------|-----------|--------------|-----------|-----------|------------------|-----------|-----------|--------------|-----------|-----------|
|                      | Three-Phase              |           |           | Single-Phase |           |           | Three-Phase      |           |           | Single-Phase |           |           |
|                      | X/R Ratio                | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] | X/R Ratio        | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] |
| Charleville 110 kV   | 4.5                      | 5.6       | 5.4       | 6.0          | 5.2       | 5.1       | 4.7              | 7.7       | 7.0       | 6.5          | 6.4       | 6.3       |
| Cherrywood 110 kV    | 10.5                     | 9.3       | 8.7       | 7.7          | 9.6       | 9.3       | 10.1             | 11.1      | 10.1      | 7.4          | 10.9      | 10.6      |
| City West 110 kV     | 6.2                      | 7.2       | 6.7       | 6.1          | 5.5       | 5.4       | 5.9              | 8.4       | 7.6       | 6.0          | 6.0       | 5.9       |
| Clahane 110 kV       | 4.2                      | 6.4       | 6.1       | 5.2          | 6.0       | 5.9       | 4.0              | 8.7       | 8.1       | 5.1          | 7.2       | 7.1       |
| Clashavoon 220 kV    | 8.0                      | 7.9       | 7.4       | 8.4          | 8.7       | 8.5       | 7.3              | 13.6      | 12.5      | 7.9          | 12.8      | 12.4      |
| Clashavoon A 110 kV  | 7.5                      | 12.4      | 11.6      | 7.7          | 13.5      | 13.1      | 7.3              | 20.5      | 18.3      | 7.5          | 18.8      | 18.2      |
| Clashavoon B 110 kV  | 7.5                      | 12.4      | 11.6      | 7.7          | 13.5      | 13.1      | 7.3              | 20.5      | 18.3      | 7.5          | 18.8      | 18.2      |
| Cliff 110 kV         | 4.0                      | 5.2       | 4.9       | 5.0          | 5.3       | 5.3       | 4.6              | 9.3       | 8.2       | 6.0          | 7.5       | 7.3       |
| Cloghboola 110 kV    | 6.7                      | 5.1       | 5.0       | 7.2          | 6.0       | 5.9       | 7.0              | 8.6       | 7.1       | 7.6          | 8.8       | 8.2       |
| Clogher 110 kV       | 3.9                      | 5.3       | 5.0       | 4.2          | 6.3       | 6.2       | 5.1              | 12.0      | 9.7       | 5.5          | 11.3      | 10.5      |
| Cloghran 110 kV      | 10.1                     | 18.8      | 17.0      | 9.9          | 20.1      | 19.4      | 9.1              | 24.8      | 22.8      | 9.1          | 24.5      | 23.9      |
| Clonkeen A 110 kV    | 5.7                      | 5.5       | 5.3       | 6.8          | 4.0       | 4.0       | 5.4              | 6.8       | 6.4       | 6.7          | 4.5       | 4.5       |
| Clonkeen B 110 kV    | 5.8                      | 5.0       | 4.8       | 5.5          | 5.8       | 5.7       | 6.1              | 8.2       | 7.3       | 5.5          | 8.4       | 8.0       |
| Cloon 110 kV         | 4.5                      | 6.6       | 6.3       | 5.8          | 5.9       | 5.9       | 4.1              | 8.8       | 8.2       | 5.7          | 7.1       | 7.0       |
| College Park 110 kV  | 9.8                      | 18.1      | 16.4      | 6.8          | 20.3      | 19.5      | 8.9              | 23.5      | 21.7      | 6.1          | 24.8      | 24.1      |
| Cookstown 110 kV     | 7.4                      | 7.9       | 7.4       | 6.0          | 6.8       | 6.7       | 7.1              | 9.0       | 8.5       | 5.8          | 7.4       | 7.3       |
| Coolroe 110 kV       | 5.2                      | 8.8       | 8.4       | 6.5          | 8.6       | 8.4       | 4.7              | 12.0      | 11.2      | 6.3          | 10.4      | 10.1      |
| Coomagearlahy 110 kV | 5.7                      | 4.2       | 4.1       | 6.3          | 5.1       | 5.0       | 6.4              | 7.0       | 6.1       | 7.2          | 7.7       | 7.2       |
| Coomataggart 110 kV  | 6.7                      | 3.2       | 3.1       | 7.5          | 3.4       | 3.4       | 8.0              | 5.7       | 5.0       | 8.9          | 5.1       | 4.9       |
| Cordal 110 kV        | 10.5                     | 6.5       | 6.3       | 8.5          | 6.2       | 6.2       | 11.4             | 11.1      | 10.0      | 8.3          | 8.6       | 8.4       |
| Corderry 110 kV      | 4.0                      | 6.3       | 6.0       | 5.0          | 6.4       | 6.3       | 4.4              | 9.9       | 8.8       | 5.7          | 8.6       | 8.3       |
| Corduff 110 kV       | 11.0                     | 20.1      | 18.1      | 12.1         | 22.8      | 21.9      | 9.9              | 27.0      | 24.7      | 11.2         | 28.6      | 27.7      |
| Corduff 220 kV       | 15.5                     | 16.3      | 14.5      | 14.1         | 20.3      | 19.2      | 14.8             | 27.5      | 24.4      | 12.9         | 31.0      | 29.5      |
| Corkagh 110 kV       | 22.9                     | 15.2      | 13.7      | 22.9         | 11.9      | 11.5      | 22.8             | 17.9      | 16.5      | 22.8         | 13.1      | 12.9      |
| Corraclassy 110 kV   | 4.3                      | 5.7       | 5.5       | 5.4          | 4.7       | 4.6       | 4.3              | 7.4       | 7.0       | 5.5          | 5.4       | 5.3       |
| Cow Cross 110 kV     | 5.0                      | 11.2      | 10.5      | 5.3          | 10.0      | 9.8       | 4.2              | 14.7      | 13.7      | 4.9          | 11.9      | 11.7      |
| Crane 110 kV         | 6.3                      | 7.0       | 6.7       | 6.4          | 7.7       | 7.5       | 6.5              | 9.1       | 8.4       | 6.5          | 9.2       | 8.9       |
| Cromcastle A 110 kV  | 12.4                     | 12.7      | 11.7      | 8.0          | 14.4      | 14.0      | 12.1             | 16.4      | 14.7      | 7.5          | 17.5      | 16.8      |
| Cromcastle B 110 kV  | 12.4                     | 12.7      | 11.7      | 8.0          | 14.4      | 14.0      | 12.1             | 16.4      | 14.7      | 7.5          | 17.5      | 16.8      |
| Cronacarkfree 220 kV | 4.3                      | 3.4       | 3.3       | 4.4          | 4.1       | 4.1       | 6.0              | 6.9       | 5.7       | 5.6          | 7.1       | 6.6       |
| Croy 110 kV          | 8.3                      | 7.3       | 7.0       | 8.8          | 9.2       | 9.0       | 8.7              | 9.4       | 8.8       | 8.9          | 11.1      | 10.8      |
| Cuilleen 110 kV      | 3.9                      | 6.1       | 5.9       | 4.7          | 7.1       | 7.0       | 4.7              | 9.5       | 8.8       | 6.0          | 9.7       | 9.4       |
| Cullenagh 110 kV     | 8.0                      | 11.7      | 11.1      | 8.5          | 13.7      | 13.4      | 6.9              | 15.0      | 13.9      | 7.6          | 16.6      | 16.2      |
| Cullenagh 220 kV     | 8.9                      | 8.5       | 8.1       | 9.2          | 8.6       | 8.5       | 8.0              | 10.3      | 9.8       | 8.5          | 9.9       | 9.8       |
| Cunghill 110 kV      | 3.3                      | 4.5       | 4.3       | 3.8          | 4.4       | 4.3       | 3.2              | 6.7       | 6.1       | 3.8          | 5.6       | 5.4       |
| Cureeny 110 kV       | 5.4                      | 6.3       | 6.0       | 5.2          | 5.9       | 5.8       | 6.2              | 9.7       | 8.6       | 5.5          | 8.0       | 7.7       |
| Cushaling 110 kV     | 5.8                      | 9.5       | 8.6       | 7.1          | 11.2      | 10.8      | 6.9              | 13.3      | 12.0      | 8.8          | 13.9      | 13.4      |
| Dallow 110 kV        | 3.5                      | 4.6       | 4.5       | 4.5          | 3.1       | 3.1       | 3.5              | 5.8       | 5.5       | 4.7          | 3.4       | 3.4       |
| Dalton 110 kV        | 3.1                      | 3.7       | 3.6       | 4.1          | 3.3       | 3.2       | 3.2              | 5.3       | 4.8       | 4.5          | 3.9       | 3.8       |



TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-4 Short Circuit Currents for Maximum and Minimum Demand in 2021 (Continued)

| Bus                  | Summer Night Valley 2015 |                        |                         |              |                        |                         | Winter Peak 2015 |                        |                         |              |                        |                         |
|----------------------|--------------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|
|                      | Three-Phase              |                        |                         | Single-Phase |                        |                         | Three-Phase      |                        |                         | Single-Phase |                        |                         |
|                      | X/R Ratio                | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio        | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] |
| Dardistown 110 kV    | 13.8                     | 12.6                   | 11.6                    | 10.6         | 14.6                   | 14.1                    | 13.7             | 16.2                   | 14.6                    | 10.1         | 17.6                   | 17.0                    |
| Derrybrien 110 kV    | 2.7                      | 3.7                    | 3.7                     | 3.7          | 3.6                    | 3.6                     | 3.2              | 5.6                    | 4.7                     | 4.8          | 4.7                    | 4.5                     |
| Derrycarney 110 kV   | 6.3                      | 5.7                    | 5.4                     | 7.3          | 7.0                    | 6.8                     | 7.8              | 8.2                    | 8.0                     | 9.4          | 9.5                    | 9.4                     |
| Derryiron 110 kV     | 5.1                      | 7.6                    | 7.2                     | 6.2          | 8.1                    | 7.9                     | 5.7              | 10.5                   | 9.9                     | 7.3          | 10.0                   | 9.8                     |
| Doon 110 kV          | 4.3                      | 6.4                    | 6.1                     | 4.7          | 5.4                    | 5.3                     | 4.8              | 9.2                    | 8.5                     | 5.1          | 6.6                    | 6.5                     |
| Dromada 110 kV       | 8.6                      | 7.2                    | 7.0                     | 5.8          | 7.7                    | 7.6                     | 7.5              | 12.7                   | 10.8                    | 4.8          | 11.1                   | 10.6                    |
| Drumkeen 110 kV      | 3.5                      | 4.8                    | 4.5                     | 4.2          | 5.0                    | 4.9                     | 3.8              | 9.2                    | 7.8                     | 4.9          | 7.5                    | 7.1                     |
| Drumline 110 kV      | 3.6                      | 7.2                    | 6.8                     | 4.8          | 6.2                    | 6.1                     | 3.2              | 9.3                    | 8.7                     | 4.6          | 7.3                    | 7.2                     |
| Drybridge 110 kV     | 5.8                      | 12.3                   | 11.4                    | 6.7          | 10.4                   | 10.2                    | 5.0              | 15.6                   | 14.4                    | 6.2          | 12.1                   | 11.8                    |
| Dundalk 110 kV       | 3.8                      | 7.9                    | 7.5                     | 4.7          | 7.4                    | 7.3                     | 3.3              | 9.7                    | 9.1                     | 4.4          | 8.5                    | 8.3                     |
| Dunfirth 110 kV      | 4.7                      | 5.9                    | 5.7                     | 6.3          | 4.7                    | 4.7                     | 4.5              | 6.8                    | 6.6                     | 6.3          | 5.1                    | 5.1                     |
| Dungarvan 110 kV     | 5.9                      | 5.6                    | 5.4                     | 7.7          | 4.7                    | 4.7                     | 5.9              | 7.3                    | 6.7                     | 7.9          | 5.6                    | 5.5                     |
| Dunmanway 110 kV     | 4.3                      | 7.0                    | 6.7                     | 5.2          | 6.4                    | 6.3                     | 4.2              | 10.1                   | 9.2                     | 5.4          | 8.0                    | 7.7                     |
| Dunstown 220 kV      | 13.0                     | 16.3                   | 14.6                    | 12.6         | 18.9                   | 18.1                    | 10.7             | 22.1                   | 20.4                    | 10.7         | 24.2                   | 23.5                    |
| Dunstown 400 kV      | 17.2                     | 6.7                    | 6.2                     | 19.0         | 7.5                    | 7.3                     | 15.4             | 8.7                    | 8.3                     | 16.6         | 9.3                    | 9.2                     |
| Clonkeen A 110 kV    | 5.7                      | 5.5                    | 5.3                     | 6.8          | 4.0                    | 4.0                     | 5.4              | 6.8                    | 6.4                     | 6.7          | 4.5                    | 4.5                     |
| Clonkeen B 110 kV    | 5.8                      | 5.0                    | 4.8                     | 5.5          | 5.8                    | 5.7                     | 6.1              | 8.2                    | 7.3                     | 5.5          | 8.4                    | 8.0                     |
| Cloon 110 kV         | 4.5                      | 6.6                    | 6.3                     | 5.8          | 5.9                    | 5.9                     | 4.1              | 8.8                    | 8.2                     | 5.7          | 7.1                    | 7.0                     |
| College Park 110 kV  | 9.8                      | 18.1                   | 16.4                    | 6.8          | 20.3                   | 19.5                    | 8.9              | 23.5                   | 21.7                    | 6.1          | 24.8                   | 24.1                    |
| Cookstown 110 kV     | 7.4                      | 7.9                    | 7.4                     | 6.0          | 6.8                    | 6.7                     | 7.1              | 9.0                    | 8.5                     | 5.8          | 7.4                    | 7.3                     |
| Coolroe 110 kV       | 5.2                      | 8.8                    | 8.4                     | 6.5          | 8.6                    | 8.4                     | 4.7              | 12.0                   | 11.2                    | 6.3          | 10.4                   | 10.1                    |
| Coomagearlahy 110 kV | 5.7                      | 4.2                    | 4.1                     | 6.3          | 5.1                    | 5.0                     | 6.4              | 7.0                    | 6.1                     | 7.2          | 7.7                    | 7.2                     |
| Coomataggart 110 kV  | 6.7                      | 3.2                    | 3.1                     | 7.5          | 3.4                    | 3.4                     | 8.0              | 5.7                    | 5.0                     | 8.9          | 5.1                    | 4.9                     |
| Cordal 110 kV        | 10.5                     | 6.5                    | 6.3                     | 8.5          | 6.2                    | 6.2                     | 11.4             | 11.1                   | 10.0                    | 8.3          | 8.6                    | 8.4                     |
| Corderry 110 kV      | 4.0                      | 6.3                    | 6.0                     | 5.0          | 6.4                    | 6.3                     | 4.4              | 9.9                    | 8.8                     | 5.7          | 8.6                    | 8.3                     |
| Corduff 110 kV       | 11.0                     | 20.1                   | 18.1                    | 12.1         | 22.8                   | 21.9                    | 9.9              | 27.0                   | 24.7                    | 11.2         | 28.6                   | 27.7                    |
| Corduff 220 kV       | 15.5                     | 16.3                   | 14.5                    | 14.1         | 20.3                   | 19.2                    | 14.8             | 27.5                   | 24.4                    | 12.9         | 31.0                   | 29.5                    |
| Corkagh 110 kV       | 22.9                     | 15.2                   | 13.7                    | 22.9         | 11.9                   | 11.5                    | 22.8             | 17.9                   | 16.5                    | 22.8         | 13.1                   | 12.9                    |
| Corraclassy 110 kV   | 4.3                      | 5.7                    | 5.5                     | 5.4          | 4.7                    | 4.6                     | 4.3              | 7.4                    | 7.0                     | 5.5          | 5.4                    | 5.3                     |
| Cow Cross 110 kV     | 5.0                      | 11.2                   | 10.5                    | 5.3          | 10.0                   | 9.8                     | 4.2              | 14.7                   | 13.7                    | 4.9          | 11.9                   | 11.7                    |
| Crane 110 kV         | 6.3                      | 7.0                    | 6.7                     | 6.4          | 7.7                    | 7.5                     | 6.5              | 9.1                    | 8.4                     | 6.5          | 9.2                    | 8.9                     |
| Cromcastle A 110 kV  | 12.4                     | 12.7                   | 11.7                    | 8.0          | 14.4                   | 14.0                    | 12.1             | 16.4                   | 14.7                    | 7.5          | 17.5                   | 16.8                    |
| Cromcastle B 110 kV  | 12.4                     | 12.7                   | 11.7                    | 8.0          | 14.4                   | 14.0                    | 12.1             | 16.4                   | 14.7                    | 7.5          | 17.5                   | 16.8                    |
| Cronacarkfree 220 kV | 4.3                      | 3.4                    | 3.3                     | 4.4          | 4.1                    | 4.1                     | 6.0              | 6.9                    | 5.7                     | 5.6          | 7.1                    | 6.6                     |
| Croy 110 kV          | 8.3                      | 7.3                    | 7.0                     | 8.8          | 9.2                    | 9.0                     | 8.7              | 9.4                    | 8.8                     | 8.9          | 11.1                   | 10.8                    |
| Cuilleen 110 kV      | 3.9                      | 6.1                    | 5.9                     | 4.7          | 7.1                    | 7.0                     | 4.7              | 9.5                    | 8.8                     | 6.0          | 9.7                    | 9.4                     |
| Cullenagh 110 kV     | 8.0                      | 11.7                   | 11.1                    | 8.5          | 13.7                   | 13.4                    | 6.9              | 15.0                   | 13.9                    | 7.6          | 16.6                   | 16.2                    |
| Cullenagh 220 kV     | 8.9                      | 8.5                    | 8.1                     | 9.2          | 8.6                    | 8.5                     | 8.0              | 10.3                   | 9.8                     | 8.5          | 9.9                    | 9.8                     |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-4 Short Circuit Currents for Maximum and Minimum Demand in 2021 (Continued)

| Bus                     | Summer Night Valley 2015 |           |            |              |           |            | Winter Peak 2015 |           |            |              |           |            |
|-------------------------|--------------------------|-----------|------------|--------------|-----------|------------|------------------|-----------|------------|--------------|-----------|------------|
|                         | Three-Phase              |           |            | Single-Phase |           |            | Three-Phase      |           |            | Single-Phase |           |            |
|                         | X/R Ratio                | Ik'' [kA] | Ik''' [kA] | X/R Ratio    | Ik'' [kA] | Ik''' [kA] | X/R Ratio        | Ik'' [kA] | Ik''' [kA] | X/R Ratio    | Ik'' [kA] | Ik''' [kA] |
| Cunghill 110 kV         | 3.3                      | 4.5       | 4.3        | 3.8          | 4.4       | 4.3        | 3.2              | 6.7       | 6.1        | 3.8          | 5.6       | 5.4        |
| Cureeny 110 kV          | 5.4                      | 6.3       | 6.0        | 5.2          | 5.9       | 5.8        | 6.2              | 9.7       | 8.6        | 5.5          | 8.0       | 7.7        |
| Cushaling 110 kV        | 5.8                      | 9.5       | 8.6        | 7.1          | 11.2      | 10.8       | 6.9              | 13.3      | 12.0       | 8.8          | 13.9      | 13.4       |
| Dallow 110 kV           | 3.5                      | 4.6       | 4.5        | 4.5          | 3.1       | 3.1        | 3.5              | 5.8       | 5.5        | 4.7          | 3.4       | 3.4        |
| Dalton 110 kV           | 3.1                      | 3.7       | 3.6        | 4.1          | 3.3       | 3.2        | 3.2              | 5.3       | 4.8        | 4.5          | 3.9       | 3.8        |
| Dardistown 110 kV       | 13.8                     | 12.6      | 11.6       | 10.6         | 14.6      | 14.1       | 13.7             | 16.2      | 14.6       | 10.1         | 17.6      | 17.0       |
| Derrybrien 110 kV       | 2.7                      | 3.7       | 3.7        | 3.7          | 3.6       | 3.6        | 3.2              | 5.6       | 4.7        | 4.8          | 4.7       | 4.5        |
| Derrycarney 110 kV      | 6.3                      | 5.7       | 5.4        | 7.3          | 7.0       | 6.8        | 7.8              | 8.2       | 8.0        | 9.4          | 9.5       | 9.4        |
| Derryiron 110 kV        | 5.1                      | 7.6       | 7.2        | 6.2          | 8.1       | 7.9        | 5.7              | 10.5      | 9.9        | 7.3          | 10.0      | 9.8        |
| Doon 110 kV             | 4.3                      | 6.4       | 6.1        | 4.7          | 5.4       | 5.3        | 4.8              | 9.2       | 8.5        | 5.1          | 6.6       | 6.5        |
| Dromada 110 kV          | 8.6                      | 7.2       | 7.0        | 5.8          | 7.7       | 7.6        | 7.5              | 12.7      | 10.8       | 4.8          | 11.1      | 10.6       |
| Drumkeen 110 kV         | 3.5                      | 4.8       | 4.5        | 4.2          | 5.0       | 4.9        | 3.8              | 9.2       | 7.8        | 4.9          | 7.5       | 7.1        |
| Drumline 110 kV         | 3.6                      | 7.2       | 6.8        | 4.8          | 6.2       | 6.1        | 3.2              | 9.3       | 8.7        | 4.6          | 7.3       | 7.2        |
| Drybridge 110 kV        | 5.8                      | 12.3      | 11.4       | 6.7          | 10.4      | 10.2       | 5.0              | 15.6      | 14.4       | 6.2          | 12.1      | 11.8       |
| Dundalk 110 kV          | 3.8                      | 7.9       | 7.5        | 4.7          | 7.4       | 7.3        | 3.3              | 9.7       | 9.1        | 4.4          | 8.5       | 8.3        |
| Dunfirth 110 kV         | 4.7                      | 5.9       | 5.7        | 6.3          | 4.7       | 4.7        | 4.5              | 6.8       | 6.6        | 6.3          | 5.1       | 5.1        |
| Dungarvan 110 kV        | 5.9                      | 5.6       | 5.4        | 7.7          | 4.7       | 4.7        | 5.9              | 7.3       | 6.7        | 7.9          | 5.6       | 5.5        |
| Dunmanway 110 kV        | 4.3                      | 7.0       | 6.7        | 5.2          | 6.4       | 6.3        | 4.2              | 10.1      | 9.2        | 5.4          | 8.0       | 7.7        |
| Dunstown 220 kV         | 13.0                     | 16.3      | 14.6       | 12.6         | 18.9      | 18.1       | 10.7             | 22.1      | 20.4       | 10.7         | 24.2      | 23.5       |
| Dunstown 400 kV         | 17.2                     | 6.7       | 6.2        | 19.0         | 7.5       | 7.3        | 15.4             | 8.7       | 8.3        | 16.6         | 9.3       | 9.2        |
| Ennis 110 kV            | 5.1                      | 9.3       | 8.8        | 6.3          | 8.7       | 8.5        | 4.7              | 13.5      | 12.3       | 6.4          | 10.9      | 10.6       |
| Fassaroe East 110 kV    | 5.3                      | 7.4       | 7.0        | 5.4          | 5.7       | 5.6        | 5.0              | 8.5       | 8.0        | 5.3          | 6.2       | 6.2        |
| Fassaroe West 110 kV    | 5.5                      | 7.6       | 7.1        | 5.5          | 5.9       | 5.8        | 5.2              | 8.7       | 8.1        | 5.4          | 6.5       | 6.4        |
| Finglas 220 kV          | 15.0                     | 15.5      | 13.8       | 14.5         | 19.9      | 18.9       | 15.6             | 27.1      | 23.8       | 14.4         | 31.6      | 29.9       |
| Finglas A 110 kV        | 21.2                     | 14.0      | 12.7       | 17.7         | 16.0      | 15.4       | 23.8             | 18.5      | 16.4       | 18.3         | 19.7      | 18.9       |
| Finglas B 110 kV        | 28.4                     | 10.9      | 10.2       | 26.9         | 13.9      | 13.5       | 34.3             | 14.0      | 12.7       | 30.4         | 17.1      | 16.4       |
| Flagford 110 kV         | 4.7                      | 9.6       | 9.0        | 5.3          | 12.1      | 11.8       | 4.6              | 14.5      | 13.2       | 5.5          | 17.0      | 16.3       |
| Flagford 220 kV         | 7.1                      | 6.1       | 5.7        | 7.8          | 7.4       | 7.2        | 7.9              | 9.2       | 8.7        | 8.9          | 10.3      | 10.0       |
| Flagford 400 kV         | 10.8                     | 2.2       | 2.1        | 10.9         | 2.7       | 2.6        | 13.6             | 3.2       | 3.0        | 12.8         | 3.6       | 3.6        |
| Francis Street A 110 kV | 10.9                     | 11.7      | 10.8       | 5.3          | 13.9      | 13.5       | 10.4             | 13.7      | 12.5       | 5.0          | 15.9      | 15.3       |
| Francis Street B 110 kV | 13.1                     | 11.1      | 10.4       | 6.8          | 13.5      | 13.2       | 12.7             | 13.3      | 12.3       | 6.4          | 15.9      | 15.4       |
| Galway 110 kV           | 5.0                      | 9.7       | 9.0        | 5.5          | 10.7      | 10.4       | 5.4              | 17.4      | 15.0       | 6.1          | 16.0      | 15.2       |
| Garrow 110 kV           | 9.1                      | 5.8       | 5.6        | 8.9          | 6.6       | 6.5        | 9.4              | 9.7       | 8.6        | 9.0          | 9.5       | 9.2        |
| Garvagh 110 kV          | 4.2                      | 4.9       | 4.7        | 5.4          | 4.8       | 4.8        | 4.8              | 7.3       | 6.5        | 6.4          | 6.1       | 5.9        |
| Gilra 110 kV            | 3.3                      | 5.7       | 5.4        | 4.0          | 4.6       | 4.6        | 3.0              | 7.1       | 6.8        | 3.9          | 5.3       | 5.2        |
| Glanagow 220 kV         | 14.9                     | 13.2      | 11.8       | 14.7         | 17.1      | 16.2       | 14.8             | 21.6      | 19.2       | 14.1         | 25.4      | 24.2       |
| Glanlee 110 kV          | 5.7                      | 4.0       | 4.0        | 6.0          | 5.0       | 4.9        | 6.3              | 6.8       | 5.9        | 6.6          | 7.4       | 7.0        |
| Glasmore A 110 kV       | 4.4                      | 6.9       | 6.6        | 4.9          | 4.9       | 4.8        | 4.1              | 8.3       | 7.6        | 4.7          | 5.3       | 5.2        |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-4 Short Circuit Currents for Maximum and Minimum Demand in 2021 (Continued)

| Bus                        | Summer Night Valley 2015 |           |           |              |           |           | Winter Peak 2015 |           |           |              |           |           |
|----------------------------|--------------------------|-----------|-----------|--------------|-----------|-----------|------------------|-----------|-----------|--------------|-----------|-----------|
|                            | Three-Phase              |           |           | Single-Phase |           |           | Three-Phase      |           |           | Single-Phase |           |           |
|                            | X/R Ratio                | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] | X/R Ratio        | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] |
| Glenlara A 110 kV          | 2.9                      | 2.6       | 2.5       | 4.2          | 2.3       | 2.3       | 3.1              | 3.3       | 3.0       | 4.6          | 2.7       | 2.6       |
| Glenlara B 110 kV          | 9.0                      | 5.5       | 5.4       | 6.9          | 5.7       | 5.6       | 9.2              | 9.1       | 8.1       | 6.5          | 7.8       | 7.5       |
| Glenree 110 kV             | 3.4                      | 3.8       | 3.6       | 4.2          | 3.7       | 3.6       | 4.0              | 6.5       | 5.8       | 5.0          | 5.1       | 4.9       |
| Glentane macelligot 110 kV | 8.7                      | 5.2       | 5.1       | 8.5          | 4.4       | 4.3       | 8.7              | 8.0       | 7.4       | 8.4          | 5.5       | 5.4       |
| Golagh 110 kV              | 3.6                      | 4.6       | 4.4       | 4.0          | 4.7       | 4.7       | 3.9              | 9.1       | 7.7       | 4.5          | 7.1       | 6.8       |
| Gorman 110 kV              | 6.7                      | 13.0      | 12.0      | 7.6          | 14.3      | 13.9      | 6.5              | 18.1      | 16.2      | 7.6          | 18.3      | 17.6      |
| Gorman 220 kV              | 9.6                      | 9.9       | 9.2       | 10.2         | 8.5       | 8.4       | 8.7              | 13.1      | 12.4      | 9.8          | 10.1      | 9.9       |
| Gortawee 110 kV            | 4.4                      | 5.6       | 5.3       | 5.8          | 4.8       | 4.7       | 4.4              | 7.0       | 6.5       | 6.0          | 5.4       | 5.3       |
| Grange 110 kV              | 12.2                     | 12.6      | 11.6      | 6.0          | 14.0      | 13.5      | 11.8             | 16.2      | 14.6      | 5.6          | 16.8      | 16.2      |
| Grange Castle 110 kV       | 14.5                     | 11.3      | 10.4      | 9.5          | 14.1      | 13.6      | 14.1             | 13.8      | 12.4      | 9.1          | 16.6      | 15.9      |
| Great Island 110 kV        | 7.6                      | 11.8      | 11.2      | 8.4          | 15.3      | 15.0      | 6.6              | 14.6      | 13.6      | 7.4          | 18.3      | 17.8      |
| Great Island 220 kV        | 12.0                     | 10.9      | 10.3      | 13.4         | 13.1      | 12.8      | 10.4             | 12.9      | 12.3      | 11.9         | 14.8      | 14.5      |
| Griffinrath A 110 kV       | 7.1                      | 9.6       | 9.1       | 7.5          | 9.8       | 9.6       | 6.6              | 11.4      | 10.8      | 7.1          | 11.2      | 11.0      |
| Griffinrath B 110 kV       | 7.7                      | 10.0      | 9.4       | 7.6          | 9.8       | 9.6       | 7.1              | 11.8      | 11.2      | 7.2          | 11.1      | 10.9      |
| Harolds 110 kV             | 11.1                     | 11.7      | 10.8      | 5.0          | 13.9      | 13.5      | 10.6             | 13.8      | 12.5      | 4.7          | 15.8      | 15.3      |
| Hartnett's Cross 110 kV    | 4.3                      | 8.8       | 8.4       | 5.0          | 7.6       | 7.5       | 3.7              | 12.4      | 11.5      | 4.7          | 9.3       | 9.1       |
| Heuston 110 kV             | 14.2                     | 11.3      | 10.5      | 8.2          | 13.9      | 13.5      | 13.8             | 13.6      | 12.6      | 7.8          | 16.4      | 15.8      |
| Huntstown A 220 kV         | 14.3                     | 15.0      | 13.4      | 12.9         | 19.2      | 18.3      | 14.9             | 25.9      | 22.9      | 12.3         | 30.3      | 28.8      |
| Huntstown B 220 kV         | 15.4                     | 15.3      | 13.7      | 11.7         | 19.1      | 18.2      | 14.2             | 24.3      | 21.8      | 10.0         | 27.8      | 26.6      |
| Ikerrin 110 kV             | 5.1                      | 4.0       | 3.9       | 5.9          | 3.2       | 3.1       | 5.8              | 5.8       | 5.3       | 6.5          | 3.8       | 3.8       |
| Inchicore 220 kV           | 14.8                     | 17.4      | 15.2      | 11.0         | 21.5      | 20.3      | 13.5             | 27.0      | 23.6      | 9.4          | 31.0      | 29.4      |
| Inchicore A 110 kV         | 28.1                     | 12.3      | 11.5      | 25.0         | 15.5      | 15.1      | 29.9             | 15.1      | 13.8      | 25.7         | 18.6      | 17.9      |
| Inchicore B 110 kV         | 41.1                     | 12.2      | 11.2      | 32.8         | 15.5      | 14.9      | 47.9             | 15.0      | 13.4      | 35.2         | 18.6      | 17.7      |
| Inniscarra 110 kV          | 4.8                      | 8.5       | 8.1       | 5.9          | 8.1       | 7.9       | 4.4              | 11.6      | 10.8      | 5.8          | 9.8       | 9.6       |
| Irishtown 220 kV           | 15.4                     | 16.2      | 14.2      | 12.4         | 20.4      | 19.3      | 14.9             | 25.4      | 22.2      | 11.2         | 29.9      | 28.3      |
| Kellis 110 kV              | 6.8                      | 8.5       | 8.2       | 7.8          | 10.1      | 9.9       | 6.5              | 10.6      | 9.9       | 7.6          | 12.0      | 11.7      |
| Kellis 220 kV              | 8.5                      | 7.4       | 7.0       | 10.1         | 6.4       | 6.3       | 7.9              | 8.7       | 8.4       | 9.7          | 7.2       | 7.2       |
| Kilbarray 110 kV           | 7.8                      | 15.9      | 14.5      | 8.4          | 17.4      | 16.7      | 6.9              | 25.4      | 22.4      | 7.9          | 24.1      | 23.1      |
| Kildonan 110 kV            | 9.4                      | 17.3      | 15.8      | 7.0          | 15.5      | 15.1      | 8.5              | 22.3      | 20.7      | 6.5          | 18.3      | 17.9      |
| Kilkenny 110 kV            | 4.0                      | 6.8       | 6.5       | 5.3          | 5.8       | 5.8       | 3.7              | 7.9       | 7.4       | 4.3          | 8.7       | 8.5       |
| Kill Hill 110 kV           | 4.8                      | 4.8       | 4.6       | 5.7          | 4.7       | 4.6       | 6.3              | 8.0       | 7.2       | 7.2          | 6.4       | 6.2       |
| Kilnaparson 110 kV         | 5.4                      | 6.1       | 5.9       | 7.0          | 4.9       | 4.8       | 5.9              | 8.0       | 7.5       | 7.7          | 5.7       | 5.6       |
| Killonan 110 kV            | 7.4                      | 14.7      | 13.5      | 7.6          | 12.7      | 12.3      | 7.1              | 24.1      | 21.6      | 7.4          | 16.7      | 16.2      |
| Killonan 220 kV            | 7.9                      | 8.7       | 8.1       | 10.0         | 8.1       | 7.9       | 7.6              | 12.8      | 12.1      | 10.3         | 10.2      | 10.1      |
| Killoteran 110 kV          | 6.1                      | 10.2      | 9.7       | 5.3          | 11.2      | 11.0      | 5.4              | 12.6      | 11.7      | 4.8          | 13.2      | 12.8      |
| Kilmahud 110 kV            | 22.5                     | 15.1      | 13.6      | 22.6         | 11.8      | 11.5      | 22.3             | 17.8      | 16.4      | 22.5         | 13.1      | 12.8      |
| Kilmore 110 kV             | 16.4                     | 13.5      | 12.3      | 11.9         | 15.4      | 14.8      | 17.0             | 17.6      | 15.7      | 11.5         | 18.8      | 18.1      |
| Kilpaddoge 110 kV          | 12.7                     | 14.1      | 13.0      | 13.2         | 18.0      | 17.3      | 12.2             | 22.3      | 20.4      | 12.8         | 26.1      | 25.2      |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-4 Short Circuit Currents for Maximum and Minimum Demand in 2021 (Continued)

| Bus                 | Summer Night Valley 2015 |           |           |              |           |           | Winter Peak 2015 |           |           |              |           |           |
|---------------------|--------------------------|-----------|-----------|--------------|-----------|-----------|------------------|-----------|-----------|--------------|-----------|-----------|
|                     | Three-Phase              |           |           | Single-Phase |           |           | Three-Phase      |           |           | Single-Phase |           |           |
|                     | X/R Ratio                | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] | X/R Ratio        | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] |
| Kilpaddoge 220 kV   | 13.5                     | 12.6      | 11.6      | 12.9         | 16.8      | 16.1      | 15.5             | 26.7      | 24.1      | 13.4         | 31.8      | 30.5      |
| Kilteel 110 kV      | 4.5                      | 7.3       | 6.9       | 5.5          | 6.6       | 6.5       | 4.2              | 8.5       | 8.0       | 5.3          | 7.3       | 7.2       |
| Kinnegad 110 kV     | 4.6                      | 7.3       | 7.0       | 6.0          | 6.7       | 6.6       | 4.6              | 9.1       | 8.7       | 6.1          | 7.6       | 7.5       |
| Knockacummer 110 kV | 5.9                      | 4.6       | 4.5       | 6.1          | 5.1       | 5.1       | 5.8              | 7.3       | 6.6       | 6.0          | 6.9       | 6.7       |
| Knockanure 110 kV   | 22.1                     | 9.5       | 9.1       | 17.5         | 11.3      | 11.1      | 21.7             | 17.1      | 14.6      | 15.6         | 17.6      | 16.6      |
| Knockanure 220 kV   | 11.9                     | 10.7      | 9.9       | 8.4          | 14.1      | 13.6      | 12.3             | 20.4      | 18.6      | 7.0          | 24.5      | 23.6      |
| Knockavanna 110 kV  | 2.7                      | 4.0       | 3.9       | 3.8          | 3.7       | 3.7       | 3.3              | 5.9       | 5.0       | 4.8          | 4.8       | 4.5       |
| Knockearagh 110 kV  | 5.5                      | 5.1       | 4.9       | 7.2          | 4.4       | 4.3       | 5.2              | 6.4       | 6.0       | 7.2          | 5.1       | 5.0       |
| Knockraha A 110 kV  | 9.2                      | 17.1      | 15.5      | 9.6          | 17.6      | 17.0      | 7.6              | 25.9      | 23.3      | 8.6          | 23.4      | 22.6      |
| Knockraha A 220 kV  | 11.7                     | 12.8      | 11.6      | 11.5         | 14.2      | 13.6      | 10.3             | 21.0      | 19.0      | 10.3         | 20.2      | 19.6      |
| Knockraha B 110 kV  | 9.2                      | 17.1      | 15.5      | 9.6          | 17.6      | 17.0      | 7.6              | 25.9      | 23.3      | 8.6          | 23.4      | 22.6      |
| Knockraha B 220 kV  | 11.7                     | 12.8      | 11.6      | 11.5         | 14.2      | 13.6      | 10.3             | 21.0      | 19.0      | 10.3         | 20.2      | 19.6      |
| Knockranny 110 kV   | 3.8                      | 3.8       | 3.7       | 4.4          | 2.5       | 2.5       | 4.7              | 6.0       | 5.4       | 5.0          | 2.9       | 2.8       |
| Knockumber 110 kV   | 3.8                      | 7.8       | 7.4       | 4.7          | 5.9       | 5.9       | 3.5              | 9.5       | 8.8       | 4.5          | 6.6       | 6.5       |
| Lanesboro 110 kV    | 3.2                      | 7.7       | 7.3       | 4.0          | 8.6       | 8.5       | 3.7              | 12.3      | 11.2      | 4.9          | 12.0      | 11.7      |
| Laois 110 kV        | 7.7                      | 12.1      | 11.4      | 8.0          | 15.2      | 14.9      | 7.0              | 14.9      | 14.1      | 7.4          | 18.2      | 17.8      |
| Laois 400 kV        | 15.4                     | 6.3       | 5.9       | 10.8         | 6.3       | 6.1       | 13.9             | 8.1       | 7.8       | 11.9         | 8.2       | 8.1       |
| Letterkenny 110 kV  | 3.8                      | 5.5       | 5.2       | 4.4          | 6.4       | 6.2       | 4.2              | 11.2      | 9.4       | 5.4          | 10.4      | 9.8       |
| Liberty A 110 kV    | 6.5                      | 13.9      | 12.7      | 5.4          | 15.9      | 15.4      | 5.7              | 21.1      | 18.9      | 4.8          | 21.7      | 20.8      |
| Liberty B 110 kV    | 6.4                      | 13.9      | 12.7      | 5.2          | 15.9      | 15.4      | 5.6              | 21.1      | 18.9      | 4.6          | 21.6      | 20.7      |
| Limerick 110 kV     | 5.8                      | 13.0      | 12.0      | 6.7          | 11.8      | 11.5      | 5.0              | 19.6      | 17.8      | 6.4          | 15.0      | 14.7      |
| Lisdrum 110 kV      | 2.9                      | 4.7       | 4.6       | 4.2          | 4.2       | 4.1       | 2.8              | 6.0       | 5.5       | 4.3          | 4.7       | 4.6       |
| Lisheen 110 kV      | 3.9                      | 3.2       | 3.0       | 3.9          | 4.8       | 4.7       | 5.0              | 5.5       | 4.8       | 5.0          | 8.2       | 7.6       |
| Lodgewood 110 kV    | 8.3                      | 7.3       | 7.0       | 8.8          | 9.2       | 9.0       | 8.7              | 9.4       | 8.8       | 8.9          | 11.1      | 10.8      |
| Lodgewood 220 kV    | 8.8                      | 6.7       | 6.4       | 10.0         | 6.6       | 6.5       | 8.6              | 8.2       | 7.8       | 9.8          | 7.6       | 7.5       |
| Longpoint 220 kV    | 14.4                     | 13.3      | 11.9      | 13.1         | 16.9      | 16.1      | 14.3             | 22.0      | 19.5      | 12.2         | 25.5      | 24.3      |
| Louth 220 kV        | 11.0                     | 13.3      | 12.0      | 11.6         | 15.8      | 15.2      | 9.6              | 21.4      | 19.6      | 10.5         | 23.0      | 22.2      |
| Louth A 110 kV      | 7.3                      | 11.3      | 10.6      | 8.3          | 13.8      | 13.4      | 6.3              | 14.4      | 13.4      | 7.5          | 16.8      | 16.3      |
| Louth B 110 kV      | 7.9                      | 12.2      | 11.4      | 8.7          | 15.2      | 14.7      | 6.8              | 15.9      | 14.8      | 7.7          | 19.0      | 18.4      |
| Macetown 110 kV     | 7.9                      | 16.2      | 14.9      | 7.7          | 16.2      | 15.7      | 7.1              | 20.6      | 19.2      | 7.1          | 19.1      | 18.7      |
| Macroom 110 kV      | 6.5                      | 12.1      | 11.3      | 6.8          | 13.2      | 12.9      | 5.9              | 19.8      | 17.7      | 6.4          | 18.4      | 17.7      |
| Mallow 110 kV       | 5.2                      | 6.0       | 5.8       | 6.9          | 5.3       | 5.2       | 5.1              | 7.6       | 7.1       | 7.0          | 6.1       | 6.0       |
| Marina 110 kV       | 7.8                      | 15.2      | 13.8      | 8.7          | 17.6      | 16.9      | 7.2              | 24.2      | 21.3      | 8.4          | 24.8      | 23.6      |
| Maynooth A 110 kV   | 11.1                     | 12.0      | 11.2      | 11.8         | 14.7      | 14.3      | 10.3             | 14.6      | 13.7      | 11.0         | 17.4      | 17.0      |
| Maynooth A 220 kV   | 11.2                     | 15.3      | 13.7      | 10.5         | 15.0      | 14.5      | 9.2              | 21.0      | 19.3      | 9.2          | 18.8      | 18.3      |
| Maynooth B 110 kV   | 8.6                      | 15.4      | 14.2      | 10.0         | 15.2      | 14.8      | 7.6              | 18.8      | 17.7      | 9.2          | 17.5      | 17.2      |
| Maynooth B 220 kV   | 11.8                     | 17.0      | 15.1      | 10.6         | 17.1      | 16.4      | 9.6              | 24.9      | 22.7      | 9.1          | 22.2      | 21.6      |
| McDermott 110 kV    | 15.7                     | 10.1      | 9.5       | 6.4          | 12.0      | 11.7      | 15.9             | 12.8      | 11.6      | 5.9          | 14.5      | 14.0      |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-4 Short Circuit Currents for Maximum and Minimum Demand in 2021 (Continued)

| Bus                  | Summer Night Valley 2015 |           |           |              |           |           | Winter Peak 2015 |           |           |              |           |           |
|----------------------|--------------------------|-----------|-----------|--------------|-----------|-----------|------------------|-----------|-----------|--------------|-----------|-----------|
|                      | Three-Phase              |           |           | Single-Phase |           |           | Three-Phase      |           |           | Single-Phase |           |           |
|                      | X/R Ratio                | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] | X/R Ratio        | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] |
| Meath Hill 110 kV    | 4.1                      | 8.1       | 7.7       | 5.2          | 6.9       | 6.8       | 3.8              | 10.2      | 9.5       | 5.1          | 7.9       | 7.7       |
| Meentycat 110 kV     | 3.3                      | 4.1       | 3.9       | 4.1          | 4.2       | 4.1       | 3.6              | 7.4       | 6.4       | 4.9          | 5.9       | 5.7       |
| Midleton 110 kV      | 3.9                      | 9.3       | 8.8       | 4.9          | 7.6       | 7.5       | 3.5              | 12.0      | 11.3      | 4.6          | 8.8       | 8.7       |
| Milltown A 110 kV    | 15.2                     | 12.6      | 11.6      | 6.9          | 15.3      | 14.8      | 14.8             | 14.9      | 13.6      | 6.6          | 17.5      | 16.9      |
| Milltown B 110 kV    | 9.2                      | 10.1      | 9.5       | 4.2          | 12.1      | 11.8      | 8.7              | 12.0      | 11.2      | 4.0          | 14.0      | 13.6      |
| Misery Hill 110 kV   | 13.6                     | 12.3      | 11.4      | 7.6          | 15.0      | 14.5      | 13.2             | 14.6      | 13.2      | 7.2          | 17.3      | 16.6      |
| Moneteen 110 kV      | 5.9                      | 9.9       | 9.2       | 6.7          | 7.5       | 7.4       | 5.2              | 12.8      | 11.9      | 6.4          | 8.6       | 8.4       |
| Moneypoint 110 kV    | 14.7                     | 8.1       | 7.8       | 17.2         | 8.4       | 8.3       | 15.5             | 10.8      | 10.3      | 18.5         | 10.3      | 10.1      |
| Moneypoint 220 kV    | 13.8                     | 12.7      | 11.6      | 13.2         | 16.9      | 16.2      | 15.9             | 26.3      | 23.8      | 13.7         | 31.5      | 30.2      |
| Moneypoint G1 400 kV | 18.5                     | 8.9       | 8.0       | 19.8         | 10.9      | 10.4      | 23.4             | 14.5      | 13.4      | 23.7         | 16.1      | 15.6      |
| Moneypoint G2 400 kV | 18.5                     | 8.9       | 8.0       | 19.8         | 10.9      | 10.4      | 23.4             | 14.5      | 13.4      | 23.7         | 16.1      | 15.6      |
| Moneypoint G3 400 kV | 18.5                     | 8.9       | 8.0       | 19.8         | 10.9      | 10.4      | 23.4             | 14.5      | 13.4      | 23.7         | 16.1      | 15.6      |
| Monread 110 kV       | 4.2                      | 7.2       | 6.9       | 5.0          | 7.2       | 7.1       | 3.9              | 8.4       | 8.0       | 4.8          | 8.0       | 7.9       |
| Mount Lucas 110 kV   | 4.5                      | 6.6       | 6.2       | 5.7          | 6.1       | 6.0       | 4.7              | 8.8       | 8.2       | 6.2          | 7.3       | 7.2       |
| Moy 110 kV           | 3.8                      | 3.8       | 3.6       | 4.4          | 4.5       | 4.4       | 5.7              | 7.4       | 6.5       | 6.9          | 7.2       | 6.9       |
| Mullagharlin 110 kV  | 3.9                      | 8.1       | 7.7       | 4.9          | 7.9       | 7.8       | 3.4              | 9.9       | 9.2       | 4.5          | 9.1       | 8.9       |
| Mullingar 110 kV     | 3.6                      | 6.4       | 6.1       | 4.9          | 6.1       | 6.1       | 3.4              | 7.7       | 7.3       | 4.8          | 7.0       | 6.8       |
| Mulreavy 110 kV      | 3.6                      | 4.7       | 4.5       | 3.9          | 5.7       | 5.6       | 4.5              | 10.1      | 8.2       | 5.0          | 10.0      | 9.3       |
| Mungret A 110 kV     | 5.5                      | 9.4       | 8.8       | 6.3          | 7.0       | 6.9       | 4.9              | 12.1      | 11.3      | 6.0          | 8.0       | 7.8       |
| Mungret B 110 kV     | 5.5                      | 9.4       | 8.8       | 6.3          | 7.0       | 6.9       | 4.9              | 12.1      | 11.3      | 6.0          | 8.0       | 7.9       |
| Nangor 110 kV        | 13.0                     | 11.1      | 10.2      | 7.9          | 13.7      | 13.2      | 12.6             | 13.4      | 12.1      | 7.5          | 16.1      | 15.4      |
| Navan 110 kV         | 5.7                      | 11.5      | 10.7      | 6.5          | 11.4      | 11.1      | 5.3              | 15.5      | 14.0      | 6.3          | 13.8      | 13.4      |
| Nenagh 110 kV        | 3.3                      | 3.5       | 3.4       | 4.1          | 2.4       | 2.4       | 3.3              | 4.6       | 4.2       | 4.1          | 2.7       | 2.7       |
| Newbridge 110 kV     | 4.5                      | 10.0      | 9.4       | 5.2          | 10.0      | 9.8       | 4.1              | 12.5      | 11.6      | 4.9          | 11.7      | 11.4      |
| Newbury 110 kV       | 14.4                     | 13.2      | 12.0      | 7.7          | 14.7      | 14.2      | 14.4             | 17.1      | 15.3      | 7.1          | 17.8      | 17.1      |
| North Mayo 110 kV    | 14.2                     | 4.2       | 4.1       | 13.9         | 5.9       | 5.8       | 17.3             | 7.0       | 6.3       | 16.1         | 9.4       | 9.0       |
| North Mayo 400 kV    | 11.0                     | 1.6       | 1.5       | 11.7         | 2.0       | 2.0       | 13.9             | 2.4       | 2.3       | 14.6         | 2.9       | 2.9       |
| North Quays 110 kV   | 18.7                     | 12.9      | 11.9      | 6.5          | 15.3      | 14.8      | 18.5             | 15.3      | 13.8      | 6.1          | 17.6      | 16.9      |
| North Wall 220 kV    | 14.0                     | 14.2      | 12.8      | 9.3          | 16.7      | 16.0      | 14.1             | 24.0      | 21.4      | 8.0          | 24.8      | 23.7      |
| Oldcourt A 110 kV    | 4.3                      | 9.5       | 9.0       | 4.8          | 7.6       | 7.5       | 3.7              | 12.0      | 11.3      | 4.5          | 8.8       | 8.7       |
| Oldcourt B 110 kV    | 4.3                      | 9.5       | 9.0       | 4.8          | 7.7       | 7.6       | 3.7              | 12.1      | 11.4      | 4.5          | 8.9       | 8.8       |
| Oldstreet 220 kV     | 13.8                     | 7.4       | 7.0       | 12.0         | 8.7       | 8.5       | 15.5             | 11.9      | 11.4      | 12.2         | 12.4      | 12.2      |
| Oldstreet 400 kV     | 14.5                     | 6.8       | 6.3       | 9.8          | 6.7       | 6.5       | 15.2             | 9.8       | 9.4       | 9.2          | 8.5       | 8.4       |
| Oriel 220 kV         | 9.9                      | 10.4      | 9.6       | 8.4          | 10.8      | 10.5      | 9.4              | 15.9      | 14.6      | 7.7          | 14.3      | 13.9      |
| Oughtragh 110 kV     | 3.7                      | 4.1       | 4.0       | 4.8          | 2.8       | 2.8       | 3.5              | 5.1       | 4.8       | 4.8          | 3.1       | 3.1       |
| Oweniney 110 kV      | 3.5                      | 3.4       | 3.2       | 3.8          | 4.4       | 4.3       | 5.3              | 6.8       | 5.8       | 5.8          | 7.9       | 7.4       |
| Pelletstown 110 kV   | 13.8                     | 9.6       | 9.1       | 8.1          | 10.6      | 10.4      | 13.7             | 12.0      | 11.0      | 7.7          | 12.6      | 12.2      |
| Platin 110 kV        | 5.2                      | 11.4      | 10.6      | 5.8          | 8.8       | 8.6       | 4.5              | 14.1      | 13.1      | 5.4          | 9.9       | 9.7       |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-4 Short Circuit Currents for Maximum and Minimum Demand in 2021 (Continued)

| Bus                  | Summer Night Valley 2015 |                        |                         |              |                        |                         | Winter Peak 2015 |                        |                         |              |                        |                         |
|----------------------|--------------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|------------------|------------------------|-------------------------|--------------|------------------------|-------------------------|
|                      | Three-Phase              |                        |                         | Single-Phase |                        |                         | Three-Phase      |                        |                         | Single-Phase |                        |                         |
|                      | X/R Ratio                | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio        | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] | X/R Ratio    | I <sub>k</sub> '' [kA] | I <sub>k</sub> ''' [kA] |
| Pollaphuca 110 kV    | 2.8                      | 2.5                    | 2.4                     | 4.0          | 2.3                    | 2.3                     | 3.3              | 3.2                    | 3.1                     | 4.7          | 2.6                    | 2.6                     |
| Poolbeg A 110 kV     | 27.2                     | 13.4                   | 12.3                    | 22.0         | 16.8                   | 16.2                    | 28.3             | 16.0                   | 14.5                    | 22.1         | 19.5                   | 18.7                    |
| Poolbeg A 220 kV     | 14.6                     | 14.3                   | 12.9                    | 8.1          | 16.0                   | 15.3                    | 14.9             | 24.2                   | 21.5                    | 6.8          | 23.2                   | 22.3                    |
| Poolbeg B 110 kV     | 27.2                     | 13.4                   | 12.3                    | 22.0         | 16.7                   | 16.1                    | 28.2             | 16.0                   | 14.4                    | 22.0         | 19.4                   | 18.6                    |
| Poolbeg B 220 kV     | 14.5                     | 16.6                   | 14.6                    | 10.7         | 19.3                   | 18.2                    | 13.2             | 24.9                   | 22.0                    | 9.3          | 26.6                   | 25.3                    |
| Poolbeg C 110 kV     | 21.2                     | 13.1                   | 12.1                    | 7.5          | 15.6                   | 15.1                    | 21.2             | 15.6                   | 14.1                    | 7.1          | 18.0                   | 17.3                    |
| Poppintree 110 kV    | 13.7                     | 13.1                   | 12.0                    | 8.4          | 14.9                   | 14.4                    | 13.6             | 17.0                   | 15.2                    | 7.9          | 18.1                   | 17.4                    |
| Portan 400 kV        | 18.4                     | 8.5                    | 7.7                     | 16.5         | 9.6                    | 9.3                     | 15.9             | 12.5                   | 11.9                    | 14.7         | 13.2                   | 13.0                    |
| Portlaoise 110 kV    | 5.9                      | 11.3                   | 10.6                    | 6.8          | 11.1                   | 10.9                    | 5.4              | 14.2                   | 13.3                    | 6.5          | 13.0                   | 12.7                    |
| Pottery 110 kV       | 17.4                     | 10.4                   | 9.6                     | 5.8          | 10.6                   | 10.4                    | 17.4             | 12.6                   | 11.4                    | 5.6          | 12.3                   | 11.9                    |
| Prospect 220 kV      | 12.2                     | 11.1                   | 10.3                    | 9.2          | 12.8                   | 12.4                    | 12.4             | 20.7                   | 19.1                    | 8.1          | 20.1                   | 19.5                    |
| Raffeen 220 kV       | 13.0                     | 12.4                   | 11.2                    | 11.5         | 15.6                   | 14.9                    | 12.2             | 20.0                   | 17.9                    | 10.2         | 22.9                   | 21.9                    |
| Raffeen A 110 kV     | 8.0                      | 12.9                   | 12.0                    | 8.8          | 15.4                   | 14.9                    | 7.0              | 17.8                   | 16.4                    | 8.0          | 19.9                   | 19.3                    |
| Raffeen B 110 kV     | 9.3                      | 12.4                   | 11.5                    | 10.0         | 14.8                   | 14.4                    | 8.1              | 17.2                   | 15.8                    | 9.1          | 19.2                   | 18.6                    |
| Rathkeale 110 kV     | 3.7                      | 6.7                    | 6.3                     | 4.9          | 5.4                    | 5.4                     | 3.4              | 8.2                    | 7.8                     | 4.8          | 6.1                    | 6.0                     |
| Ratrussan 110 kV     | 3.2                      | 5.9                    | 5.7                     | 4.0          | 6.6                    | 6.5                     | 3.7              | 8.6                    | 7.3                     | 4.9          | 8.7                    | 8.2                     |
| Reamore 110 kV       | 4.4                      | 5.9                    | 5.6                     | 3.6          | 5.4                    | 5.4                     | 4.4              | 8.2                    | 7.5                     | 3.4          | 6.6                    | 6.5                     |
| Richmond A 110 kV    | 2.9                      | 5.6                    | 5.4                     | 3.8          | 5.5                    | 5.4                     | 3.0              | 7.9                    | 7.4                     | 4.2          | 6.8                    | 6.7                     |
| Richmond B 110 kV    | 2.9                      | 5.6                    | 5.4                     | 3.8          | 5.5                    | 5.4                     | 3.0              | 7.9                    | 7.4                     | 4.2          | 6.8                    | 6.7                     |
| Rinawade 110 kV      | 5.1                      | 9.9                    | 9.4                     | 6.0          | 7.3                    | 7.2                     | 4.7              | 11.5                   | 11.1                    | 5.8          | 8.0                    | 8.0                     |
| Ringaskiddy 110 kV   | 6.3                      | 10.5                   | 9.9                     | 6.5          | 10.4                   | 10.2                    | 5.5              | 13.9                   | 13.0                    | 5.9          | 12.7                   | 12.4                    |
| Ringsend 110 kV      | 27.7                     | 13.5                   | 12.4                    | 23.2         | 16.9                   | 16.3                    | 28.8             | 16.1                   | 14.6                    | 23.4         | 19.6                   | 18.8                    |
| Ryebrook 110 kV      | 5.6                      | 13.1                   | 12.0                    | 6.5          | 11.8                   | 11.5                    | 5.0              | 15.6                   | 14.6                    | 6.1          | 13.3                   | 13.0                    |
| Salthill 110 kV      | 4.6                      | 8.8                    | 8.2                     | 4.2          | 9.5                    | 9.3                     | 4.7              | 15.1                   | 13.2                    | 4.1          | 13.7                   | 13.1                    |
| Screeb 110 kV        | 3.5                      | 2.3                    | 2.3                     | 4.5          | 1.3                    | 1.3                     | 4.4              | 3.5                    | 3.1                     | 5.1          | 1.5                    | 1.4                     |
| Seal Rock A 110 kV   | 8.7                      | 9.6                    | 8.6                     | 10.3         | 10.6                   | 10.2                    | 7.7              | 11.0                   | 10.0                    | 9.4          | 11.5                   | 11.1                    |
| Seal Rock B 110 kV   | 8.7                      | 9.6                    | 8.6                     | 10.3         | 10.7                   | 10.2                    | 7.7              | 11.0                   | 10.0                    | 9.4          | 11.5                   | 11.1                    |
| Shankill 110 kV      | 3.7                      | 7.1                    | 6.8                     | 4.7          | 6.7                    | 6.6                     | 3.7              | 9.8                    | 8.7                     | 4.9          | 8.3                    | 8.0                     |
| Shannonbridge 110 kV | 5.1                      | 10.9                   | 10.2                    | 5.9          | 13.6                   | 13.3                    | 6.4              | 19.3                   | 17.5                    | 8.0          | 21.5                   | 20.7                    |
| Shannonbridge 220 kV | 6.6                      | 6.0                    | 5.7                     | 7.4          | 7.2                    | 7.1                     | 8.2              | 8.7                    | 8.5                     | 9.3          | 9.8                    | 9.7                     |
| Shellybanks A 220 kV | 14.4                     | 14.3                   | 12.9                    | 8.0          | 17.7                   | 16.9                    | 14.6             | 24.1                   | 21.5                    | 6.6          | 27.0                   | 25.7                    |
| Shellybanks B 220 kV | 14.6                     | 15.6                   | 13.8                    | 10.8         | 19.4                   | 18.4                    | 14.3             | 24.4                   | 21.5                    | 9.6          | 28.3                   | 26.8                    |
| Shelton Abbey 110 kV | 7.6                      | 6.8                    | 6.6                     | 7.6          | 7.3                    | 7.2                     | 7.3              | 8.4                    | 7.9                     | 7.4          | 8.6                    | 8.4                     |
| Singland 110 kV      | 6.8                      | 12.3                   | 11.4                    | 7.7          | 11.3                   | 11.1                    | 6.6              | 18.9                   | 17.3                    | 7.7          | 14.6                   | 14.2                    |
| Sluabh Bawn 110 kV   | 3.1                      | 7.1                    | 6.8                     | 4.0          | 7.2                    | 7.1                     | 3.4              | 10.7                   | 9.8                     | 4.5          | 9.3                    | 9.1                     |
| Sligo 110 kV         | 4.0                      | 7.2                    | 6.8                     | 4.5          | 7.3                    | 7.2                     | 3.6              | 11.2                   | 10.1                    | 4.4          | 9.7                    | 9.4                     |
| Somerset 110 kV      | 3.1                      | 6.4                    | 6.1                     | 4.0          | 4.5                    | 4.5                     | 2.8              | 8.5                    | 8.0                     | 3.9          | 5.2                    | 5.1                     |
| Sorne Hill 110 kV    | 2.7                      | 2.2                    | 2.2                     | 3.3          | 2.6                    | 2.6                     | 3.4              | 3.8                    | 3.3                     | 4.3          | 3.7                    | 3.6                     |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-4 Short Circuit Currents for Maximum and Minimum Demand in 2021 (Continued)

| Bus                  | Summer Night Valley 2015 |           |           |              |           |           | Winter Peak 2015 |           |           |              |           |           |
|----------------------|--------------------------|-----------|-----------|--------------|-----------|-----------|------------------|-----------|-----------|--------------|-----------|-----------|
|                      | Three-Phase              |           |           | Single-Phase |           |           | Three-Phase      |           |           | Single-Phase |           |           |
|                      | X/R Ratio                | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] | X/R Ratio        | Ik'' [kA] | Ik'' [kA] | X/R Ratio    | Ik'' [kA] | Ik'' [kA] |
| Srananagh 110 kV     | 4.8                      | 8.1       | 7.7       | 5.5          | 9.4       | 9.2       | 4.7              | 13.3      | 11.9      | 5.6          | 13.4      | 12.9      |
| Srananagh 220 kV     | 6.7                      | 3.9       | 3.8       | 8.3          | 3.5       | 3.5       | 7.6              | 5.4       | 5.1       | 9.5          | 4.2       | 4.1       |
| Stevenstown 110 kV   | 4.3                      | 5.8       | 5.5       | 4.8          | 3.8       | 3.8       | 4.0              | 6.6       | 6.2       | 4.7          | 4.0       | 4.0       |
| Stratford 110 kV     | 3.2                      | 3.8       | 3.7       | 4.2          | 3.0       | 3.0       | 3.3              | 4.7       | 4.5       | 4.4          | 3.4       | 3.4       |
| Suir 110 kV          | 4.3                      | 6.8       | 6.5       | 5.1          | 8.1       | 7.9       | 5.8              | 11.9      | 10.7      | 7.2          | 12.0      | 11.5      |
| Taney 110 kV         | 9.0                      | 9.0       | 8.4       | 3.3          | 8.9       | 8.8       | 8.6              | 10.7      | 9.8       | 3.2          | 10.1      | 9.8       |
| Tarbert 110 kV       | 22.7                     | 10.9      | 10.4      | 25.5         | 11.9      | 11.7      | 35.2             | 17.4      | 16.3      | 35.9         | 16.3      | 16.0      |
| Tarbert 220 kV       | 12.9                     | 12.2      | 11.2      | 12.8         | 15.9      | 15.3      | 15.0             | 25.6      | 23.2      | 13.9         | 29.6      | 28.4      |
| Tawnaghmore A 110 kV | 3.4                      | 3.1       | 2.9       | 4.2          | 3.4       | 3.3       | 4.6              | 5.7       | 5.2       | 6.0          | 4.9       | 4.8       |
| Tawnaghmore B 110 kV | 4.0                      | 3.4       | 3.2       | 4.8          | 4.0       | 3.9       | 5.5              | 6.1       | 5.4       | 7.0          | 5.8       | 5.6       |
| Thornsberry 110 kV   | 4.2                      | 6.1       | 5.8       | 5.5          | 5.7       | 5.6       | 4.2              | 7.7       | 7.3       | 5.6          | 6.7       | 6.6       |
| Thurles 110 kV       | 5.0                      | 4.1       | 3.9       | 5.4          | 4.8       | 4.7       | 6.4              | 7.1       | 6.2       | 6.6          | 7.2       | 6.8       |
| Tievebrack 110 kV    | 3.4                      | 3.3       | 3.2       | 4.5          | 2.6       | 2.6       | 3.6              | 5.1       | 4.6       | 5.1          | 3.2       | 3.1       |
| Tipperary 110 kV     | 5.0                      | 6.1       | 5.9       | 6.0          | 4.6       | 4.6       | 5.6              | 8.9       | 8.3       | 6.5          | 5.5       | 5.5       |
| Tonroe 110 kV        | 2.7                      | 3.1       | 3.0       | 3.7          | 2.0       | 2.0       | 2.7              | 3.7       | 3.5       | 3.8          | 2.1       | 2.1       |
| Trabeg 110 kV        | 7.9                      | 15.1      | 13.8      | 8.6          | 17.3      | 16.7      | 7.2              | 23.8      | 21.0      | 8.2          | 24.1      | 23.1      |
| Tralee 110 kV        | 5.0                      | 7.4       | 7.0       | 6.0          | 6.8       | 6.7       | 4.9              | 10.8      | 9.7       | 6.1          | 8.5       | 8.2       |
| Trien A 110 kV       | 4.7                      | 6.7       | 6.4       | 5.8          | 6.2       | 6.1       | 4.3              | 9.2       | 8.5       | 5.6          | 7.5       | 7.4       |
| Trien B 110 kV       | 12.2                     | 7.1       | 6.9       | 9.8          | 7.6       | 7.5       | 11.2             | 12.1      | 10.3      | 8.7          | 10.8      | 10.3      |
| Trillick 110 kV      | 2.7                      | 2.4       | 2.3       | 3.4          | 2.6       | 2.6       | 3.5              | 4.2       | 3.6       | 4.4          | 3.7       | 3.6       |
| Trinity 110 kV       | 12.0                     | 12.0      | 11.1      | 6.4          | 14.5      | 14.0      | 11.6             | 14.2      | 12.9      | 6.0          | 16.6      | 16.0      |
| Tullabrack 110 kV    | 6.9                      | 6.3       | 6.1       | 7.5          | 5.1       | 5.0       | 6.7              | 8.2       | 7.8       | 7.4          | 5.9       | 5.8       |
| Turlough 220 kV      | 11.9                     | 11.3      | 10.3      | 13.0         | 10.4      | 10.1      | 10.3             | 13.4      | 12.5      | 11.8         | 11.5      | 11.2      |
| Tynagh 220 kV        | 10.6                     | 7.0       | 6.6       | 11.7         | 8.6       | 8.5       | 14.8             | 13.3      | 12.4      | 16.5         | 14.2      | 13.8      |
| Uggool 110 kV        | 5.6                      | 5.7       | 5.4       | 6.6          | 6.7       | 6.6       | 8.2              | 10.8      | 8.9       | 10.0         | 10.6      | 9.9       |
| Waterford 110 kV     | 7.3                      | 11.1      | 10.5      | 7.4          | 12.4      | 12.1      | 6.3              | 13.9      | 12.8      | 6.7          | 14.7      | 14.3      |
| West Dublin 110 kV   | 23.9                     | 15.3      | 13.8      | 24.5         | 12.0      | 11.7      | 23.9             | 18.1      | 16.7      | 24.5         | 13.3      | 13.1      |
| West Dublin 220 kV   | 12.8                     | 17.6      | 15.4      | 10.5         | 19.3      | 18.3      | 10.7             | 26.3      | 23.4      | 9.0          | 26.0      | 24.9      |
| Wexford 110 kV       | 3.9                      | 5.7       | 5.5       | 5.0          | 5.5       | 5.5       | 4.0              | 7.3       | 6.6       | 5.3          | 6.4       | 6.3       |
| Whitegate 110 kV     | 4.8                      | 8.9       | 8.5       | 5.5          | 9.2       | 9.1       | 4.2              | 11.2      | 10.6      | 5.1          | 10.9      | 10.7      |
| Wolfe Tone 110 kV    | 14.1                     | 9.9       | 9.3       | 5.8          | 11.7      | 11.4      | 14.1             | 12.5      | 11.3      | 5.4          | 14.0      | 13.5      |
| Woodhouse 110 kV     | 5.9                      | 5.5       | 5.3       | 7.3          | 4.2       | 4.1       | 5.8              | 7.0       | 6.5       | 7.4          | 4.8       | 4.7       |
| Woodland 220 kV      | 15.3                     | 17.3      | 15.4      | 14.3         | 19.5      | 18.6      | 12.6             | 27.2      | 24.8      | 12.3         | 27.5      | 26.6      |
| Woodland 400 kV      | 19.8                     | 8.5       | 7.8       | 18.3         | 9.7       | 9.4       | 17.6             | 12.6      | 12.0      | 16.6         | 13.4      | 13.1      |

## E.6 Short Circuit Currents in Northern Ireland

### E.6.1 Methodology used in Northern Ireland

Short circuit current levels are calculated in accordance with the UK Engineering Recommendation G74, which is a computer based analysis, based on the International Standard IEC60909. Compliance with G74 includes:

- Short circuit current contributions from all synchronous and non-synchronous rotating plant including induction motors embedded in the general load,
- Comprehensive plant parameters including time-dependent impedances, transformer winding and earthing configurations,
- Pre-fault voltage levels at each node which should be obtained from a credible, pre-fault load flow study,
- Pre-fault transformer tap settings should also be obtained from the load flow study.

The short circuit current level network model includes the following component parameters:

- Transformer impedance variation with tap position,
- Zero sequence mutual coupling effect,
- Unsaturated generator reactance values,
- Power station auxiliaries fault level contributions.

The calculation of the X/R ratios, used by SONI, is undertaken in accordance with IEC60909-0 Method C, which is known as the equivalent frequency method. The equivalent frequency method is considered to be the most appropriate general purpose method for calculating the D.C. component of short circuit currents on the Northern Ireland transmission system.

The Northern Ireland transmission system is designed and operated to maintain short circuit current levels below the ratings of equipment at each substation Table E-1 below, indicates the range of circuit breaker RMS ratings that are currently installed on the Northern Ireland transmission system, for the respective voltage levels currently operated.



Table E-5 Short Circuit Current Levels - Equipment Rating Range – Northern Ireland

| Voltage Level | Short Circuit Current Equipment Rating Range |
|---------------|--|
| 275 kV        | 26.5 kA – 31.5 kA                            |
| 110 kV        | 18.4kA – 40 kA                               |

### E.6.2 Analysis

The generation dispatches used in the short circuit analysis are shown in Table D-6 in Appendix D.

The total RMS break current at a busbar is an indication of the short circuit level that one could expect at that point in the transmission system. However, they do not necessarily represent the short circuit current that could flow through each individual breaker, which may be lower.

### E.6.3 Northern Ireland Short Circuit Current Level Results

Tables E-2 to E-4 contain the following three-phase and single-phase short circuit current level results for maximum winter peak and minimum summer valley system demand conditions for 2015, 2018 and 2021:

- **Initial Short Circuit Current ( $I''$ )**

This is the initial RMS value of the AC component of the short circuit current, prior to contact separation time. It is calculated using generator sub-transient reactances.

- **Peak Make Current ( $i_p$ )**

The largest peak current occurs around 10ms, and is the short circuit current that equipment must be able to withstand, for example, when a circuit breaker is closed directly onto an earthed section of network, thus energising a fault. All equipment in the fault current path will be subjected to the peak make current, and therefore should be rated to withstand this.

- **RMS Break Current (IB)**

This is the RMS value of the AC component of the short circuit current at the time of circuit breaker contact separation. The break time at which contact separation occurs varies from circuit to circuit, and depends on protection settings, fault location, circuit breaker design etc. For the purposes of this report, we have used a short circuit current break time of 50ms for all 275 kV and 110 kV calculations.

- **Asymmetrical Break Current (asym B)**

This is based on the first peak during contact separation (peak break current). It is the highest short circuit current that a circuit breaker is required to extinguish and is the combination of AC and DC components. The asymmetrical break current is expressed as the equivalent RMS value of this peak break current.

In the Northern Ireland results tables, the RMS Break, Peak Make and Asymmetrical Break ratings of the existing nodes are shown. It should be noted that both the Ballylumford and Kells 110 kV nodes (highlighted in the tables with \*) have separate ratings for three-phase and single-phase faults; these are indicated in the tables. All ratings are in kA.

Single phase to earth short circuit currents tend to be larger than three phase short circuit currents in heavily meshed transmission networks. This is due to the multiplicity of zero phase sequence paths available to earth fault currents. In all tables, any nodes where short circuit currents exceed 90% of the corresponding existing rating are highlighted in **orange**. Any nodes where short circuit currents exceed the corresponding existing ratings are highlighted in **red**.

Table E-6 Northern Ireland Short Circuit Current Levels for Summer Night Valley 2015

| Node            | Rating      |              |              | Three Phase  |             |            |            |                | Single Phase |             |            |            |                |
|-----------------|-------------|--------------|--------------|--------------|-------------|------------|------------|----------------|--------------|-------------|------------|------------|----------------|
|                 | RMS<br>[kA] | Peak<br>[kA] | Asym<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] | X/R<br>X/R   | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] |
| 275kV           |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Ballylumford    | 31.5        | 79           | 35.65        | 11.19        | 8.14        | 20.37      | 7.14       | 8.41           | 11.78        | 10.97       | 27.61      | 10.00      | 11.85          |
| Castlereagh     | 31.5        | 79           | 35.65        | 10.51        | 8.17        | 20.29      | 7.14       | 8.27           | 10.43        | 9.90        | 24.57      | 9.07       | 10.45          |
| Coolkeeragh     | 31.5        | 79           | 35.3         | 11.13        | 8.11        | 20.29      | 7.19       | 8.78           | 11.84        | 9.11        | 22.95      | 8.52       | 10.41          |
| Hannahstown     | 31.5        | 79           | 35.65        | 10.50        | 7.96        | 19.78      | 6.98       | 8.07           | 10.57        | 9.80        | 24.37      | 8.99       | 10.44          |
| Kells           | 31.5        | 79           | 35.65        | 11.58        | 8.81        | 22.13      | 7.67       | 9.21           | 10.92        | 10.80       | 26.95      | 9.90       | 11.54          |
| Kilroot         | 31.5        | 79           | 45.3         | 12.16        | 8.74        | 22.08      | 7.62       | 9.32           | 12.96        | 11.65       | 29.61      | 10.62      | 13.09          |
| Magherafelt     | 31.5        | 79           | 35.65        | 11.67        | 9.35        | 23.50      | 8.14       | 9.72           | 9.32         | 10.09       | 24.68      | 9.33       | 10.15          |
| Moyle           | 31.5        | 79           | 35.65        | 11.15        | 8.07        | 20.18      | 7.08       | 8.33           | 11.66        | 10.80       | 27.15      | 9.86       | 11.62          |
| Tandragee       | 31.5        | 79           | 35.65        | 10.81        | 9.83        | 24.50      | 8.54       | 9.97           | 10.17        | 11.54       | 28.55      | 10.56      | 12.14          |
| Tamnamore       | 40          | 100          | 45.6         | 10.85        | 8.39        | 20.93      | 7.41       | 8.51           | 9.53         | 8.88        | 21.78      | 8.27       | 9.13           |
| 110kV           |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Aghyoule        | 40          | 100          |              | 2.94         | 2.97        | 5.77       | 2.88       | 2.88           | 3.82         | 3.27        | 6.79       | 3.20       | 3.21           |
| Antrim          | 40          | 100          |              | 4.74         | 7.75        | 16.89      | 7.30       | 7.43           | 4.88         | 8.27        | 18.12      | 7.99       | 8.31           |
| Ballylumford*   | 21.9        | 55           | 25.88        | 10.16        | 13.95       | 34.51      | 12.64      | 15.57          | 11.13        |             |            |            |                |
|                 | 26.2        | 65           | 29.7         |              |             |            |            |                |              | 17.79       | 44.50      | 16.68      | 20.84          |
| Ballymena       | 40          | 100          |              | 4.90         | 7.48        | 16.42      | 7.05       | 7.21           | 5.45         | 8.17        | 18.33      | 7.89       | 8.36           |
| Banbridge       | 18.4        | 46.8         |              | 4.18         | 5.86        | 12.42      | 5.59       | 5.64           | 5.14         | 6.00        | 13.30      | 5.85       | 6.08           |
| Ballyvallyagh   | 18.4        | 46.8         | 23           | 5.46         | 11.17       | 25.04      | 10.28      | 10.40          | 5.01         | 11.51       | 25.37      | 11.00      | 11.11          |
| Ballynahinch    | 18.4        | 46.8         |              | 4.25         | 5.06        | 10.77      | 4.82       | 4.88           | 5.03         | 5.26        | 11.60      | 5.11       | 5.33           |
| Belfast Central | 31.5        | 79           |              | 8.34         | 11.07       | 26.68      | 10.08      | 11.02          | 5.56         | 13.95       | 31.40      | 13.07      | 14.17          |
| Carmoney        | 31.5        | 79           | 45           | 4.09         | 7.13        | 15.03      | 6.72       | 6.78           | 4.67         | 7.49        | 16.27      | 7.25       | 7.47           |
| Castlereagh     | 26.2        | 65           | 33.5         | 10.65        | 13.03       | 32.42      | 11.69      | 14.10          | 11.18        | 17.37       | 43.46      | 16.03      | 19.35          |
| Coleraine       | 40          | 100          | 42.5         | 3.69         | 6.33        | 13.02      | 5.96       | 5.96           | 4.25         | 7.59        | 16.14      | 7.30       | 7.32           |
| Coolkeeragh     | 31.5        | 80           | 33.5         | 11.78        | 15.71       | 39.53      | 13.96      | 18.13          | 12.11        | 20.03       | 50.57      | 18.59      | 23.88          |
| Creagh          | 31.5        | 80           | 33.5         | 3.67         | 6.71        | 13.78      | 6.35       | 6.35           | 4.45         | 7.33        | 15.75      | 7.10       | 7.15           |
| Cregagh         | 26.2        | 65           |              | 9.14         | 12.05       | 29.42      | 10.89      | 12.31          | 7.39         | 15.57       | 36.84      | 14.48      | 16.06          |
| Donegall North  | 31.5        | 79           | 33.5         | 8.39         | 12.45       | 30.03      | 11.31      | 12.41          | 5.62         | 16.02       | 36.32      | 14.97      | 15.78          |
| Donegall South  |             |              |              | 6.13         | 10.08       | 23.11      | 9.31       | 9.56           | 5.07         | 11.49       | 25.40      | 10.94      | 11.29          |
| Drumnakelly     | 31.5        | 79           | 42.5         | 7.80         | 14.34       | 34.21      | 12.91      | 14.14          | 7.74         | 16.65       | 39.67      | 15.57      | 17.16          |
| Dungannon       | 18.4        | 46.8         | 23           | 5.85         | 12.16       | 27.63      | 11.10      | 11.64          | 6.27         | 13.14       | 30.24      | 12.45      | 13.36          |
| Eden            | 25          | 62.5         | 45           | 4.24         | 7.78        | 16.54      | 7.32       | 7.37           | 4.67         | 8.14        | 17.67      | 7.86       | 8.06           |
| Enniskillen     | 31.5        | 79           | 33.5         | 3.47         | 5.87        | 11.89      | 5.55       | 5.55           | 4.08         | 7.38        | 15.55      | 7.09       | 7.10           |
| Finaghy         | 31.5        | 79           |              | 9.34         | 12.77       | 31.27      | 11.58      | 13.11          | 6.85         | 16.85       | 39.38      | 15.70      | 16.94          |
| Glengormley     | 18.4        | 46.8         |              | 3.47         | 4.84        | 9.80       | 4.64       | 4.64           | 4.19         | 4.92        | 10.43      | 4.81       | 4.86           |
| Hannahstown     | 31.5        | 80           | 33.5         | 10.50        | 13.82       | 34.33      | 12.44      | 14.83          | 10.84        | 18.61       | 46.40      | 17.23      | 20.63          |

Table E-6 Northern Ireland Short Circuit Current Levels for Summer Night Valley 2015 (Continued)

| Node          | Rating      |              |              | Three Phase  |             |            |            |                | Single Phase |             |            |            |                |
|---------------|-------------|--------------|--------------|--------------|-------------|------------|------------|----------------|--------------|-------------|------------|------------|----------------|
|               | RMS<br>[kA] | Peak<br>[kA] | Asym<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] | X/R<br>X/R   | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] |
| 110kV         |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Kells*        | 21.9        | 55.9         | 27.4         | 9.04         | 13.52       | 32.95      | 12.24      | 14.71          | 9.46         |             |            |            |                |
|               | 26.2        | 65           | 29.7         |              |             |            |            |                |              | 17.77       | 43.57      | 16.59      | 19.99          |
| Killymallaght | 40          | 100          | 45           | 6.13         | 9.44        | 21.63      | 8.77       | 8.94           | 5.91         | 9.65        | 21.97      | 9.29       | 9.70           |
| Knock         | 18.4        | 46.8         |              | 5.22         | 11.53       | 25.63      | 10.45      | 10.65          | 3.39         | 12.83       | 25.85      | 12.09      | 12.91          |
| Larne         | 18.4        | 46.8         | 42.5         | 4.61         | 7.56        | 16.38      | 7.13       | 7.16           | 5.25         | 7.70        | 17.14      | 7.47       | 7.65           |
| Limavady      | 18.4        | 46.8         | 23           | 3.62         | 5.93        | 12.14      | 5.62       | 5.62           | 4.28         | 6.68        | 14.23      | 6.47       | 6.50           |
| Lisburn       | 18.4        | 46.8         | 23           | 5.36         | 9.83        | 21.97      | 9.10       | 9.25           | 4.92         | 10.37       | 22.77      | 9.92       | 10.29          |
| Lisaghmore    | 31.5        | 79           |              | 4.83         | 8.45        | 18.48      | 7.89       | 8.01           | 5.05         | 8.59        | 18.95      | 8.30       | 8.64           |
| Loguestown    | 26.2        | 65           |              | 3.41         | 4.80        | 9.69       | 4.58       | 4.58           | 3.99         | 5.44        | 11.41      | 5.29       | 5.30           |
| Magherakeel   | 40          | 100          | 45           | 4.08         | 3.10        | 6.54       | 3.02       | 3.02           | 5.04         | 3.70        | 8.16       | 3.63       | 3.65           |
| Newtownards   | 40          | 100          |              | 4.77         | 6.73        | 14.69      | 6.34       | 6.42           | 5.74         | 6.74        | 15.27      | 6.52       | 6.79           |
| Newry         | 18.4        | 46.8         | 23           | 4.01         | 5.02        | 10.53      | 4.80       | 4.85           | 4.92         | 5.14        | 11.29      | 5.01       | 5.21           |
| Omagh         | 40          | 100          | 42.5         | 4.09         | 9.12        | 19.22      | 8.46       | 8.47           | 4.68         | 10.09       | 21.91      | 9.63       | 9.74           |
| Rathgael      | 26.2        | 65           |              | 4.31         | 5.39        | 11.49      | 5.12       | 5.17           | 5.02         | 5.56        | 12.26      | 5.40       | 5.61           |
| Rosebank      | 40          | 100          |              | 9.09         | 12.45       | 30.37      | 11.22      | 12.69          | 8.75         | 16.33       | 39.61      | 15.14      | 16.91          |
| Slieve Kirk   | 40          | 100          |              | 4.57         | 7.08        | 15.30      | 6.69       | 6.71           | 5.02         | 6.33        | 13.95      | 6.17       | 6.47           |
| Springtown    | 31.5        | 79           | 33.6         | 5.07         | 8.63        | 19.06      | 8.05       | 8.21           | 5.22         | 8.92        | 19.85      | 8.62       | 8.99           |
| Strabane      | 18.4        | 46.8         | 23           | 5.27         | 10.97       | 24.43      | 10.07      | 10.18          | 5.85         | 12.69       | 28.83      | 12.05      | 12.45          |
| Tandragee     | 31.5        | 79           | 33.6         | 9.47         | 15.45       | 37.89      | 13.83      | 16.55          | 10.09        | 19.50       | 48.21      | 18.06      | 21.83          |
| Tamnamore     | 40          | 100          | 45           | 7.46         | 10.90       | 25.83      | 10.07      | 11.74          | 8.47         | 11.90       | 28.75      | 11.36      | 13.39          |
| Waringstown   | 18.4        | 46.8         |              | 5.13         | 7.20        | 15.95      | 6.80       | 6.93           | 5.74         | 7.23        | 16.38      | 7.01       | 7.36           |

Table E-7 Northern Ireland Short Circuit Current Levels for Winter Peak 2015

| Node            | Rating      |              |              | Three Phase  |             |            |            |                | Single Phase |             |            |            |                |
|-----------------|-------------|--------------|--------------|--------------|-------------|------------|------------|----------------|--------------|-------------|------------|------------|----------------|
|                 | RMS<br>[kA] | Peak<br>[kA] | Asym<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] |
| <b>275kV</b>    |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Ballylumford    | 31.5        | 79           | 35.65        | 15.74        | 21.24       | 54.97      | 18.76      | 25.04          | 16.79        | 24.82       | 64.59      | 23.12      | 30.78          |
| Castlereagh     | 31.5        | 79           | 35.65        | 10.67        | 16.75       | 41.70      | 14.88      | 17.06          | 10.49        | 17.10       | 42.47      | 16.01      | 18.36          |
| Coolkeeragh     | 31.5        | 79           | 35.3         | 8.66         | 12.56       | 30.44      | 11.59      | 12.88          | 10.01        | 12.57       | 31.03      | 12.07      | 13.81          |
| Hannahstown     | 31.5        | 79           | 35.65        | 11.00        | 16.78       | 41.90      | 14.92      | 17.29          | 10.95        | 17.36       | 43.34      | 16.27      | 19.07          |
| Kells           | 31.5        | 79           | 35.65        | 12.73        | 19.11       | 48.48      | 17.02      | 20.50          | 11.10        | 19.52       | 48.80      | 18.40      | 21.21          |
| Kilroot         | 31.5        | 79           | 45.3         | 14.12        | 18.78       | 48.12      | 16.69      | 20.97          | 15.68        | 22.36       | 57.84      | 20.92      | 26.82          |
| Magherafelt     | 31.5        | 79           | 35.65        | 11.70        | 18.53       | 46.61      | 16.64      | 19.20          | 8.80         | 16.47       | 39.99      | 15.67      | 16.62          |
| Moyle           | 31.5        | 79           | 35.65        | 15.34        | 20.69       | 53.44      | 18.33      | 24.11          | 15.98        | 23.90       | 61.94      | 22.31      | 29.02          |
| Tandragee       | 31.5        | 79           | 35.65        | 10.36        | 19.06       | 47.28      | 17.02      | 19.11          | 9.64         | 19.04       | 46.79      | 17.91      | 20.01          |
| Tamnamore       | 40          | 100          | 45.6         | 10.45        | 14.74       | 36.61      | 13.48      | 14.85          | 8.92         | 12.85       | 31.25      | 12.32      | 13.25          |
| <b>110kV</b>    |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Aghyoule        | 40          | 100          |              | 4.05         | 4.07        | 8.56       | 3.83       | 3.99           | 5.37         | 4.07        | 9.09       | 3.91       | 4.25           |
| Antrim          | 40          | 100          |              | 4.15         | 9.81        | 20.75      | 9.39       | 9.49           | 4.47         | 9.73        | 20.94      | 9.49       | 9.81           |
| Ballylumford*   | 21.9        | 55           | 25.88        | 10.99        | 24.01       | 59.96      | 22.12      | 29.09          |              |             |            |            |                |
|                 | 26.2        | 65           | 29.7         |              |             |            |            |                | 12.55        | 27.77       | 70.37      | 26.50      | 35.38          |
| Ballymena       | 40          | 100          |              | 4.35         | 9.46        | 20.22      | 9.01       | 9.16           | 5.07         | 9.68        | 21.39      | 9.41       | 9.90           |
| Banbridge       | 18.4        | 46.8         |              | 3.78         | 6.81        | 14.09      | 6.56       | 6.60           | 4.86         | 6.64        | 14.54      | 6.49       | 6.72           |
| Ballyvallagh    | 18.4        | 46.8         | 23           | 4.56         | 16.40       | 35.43      | 15.38      | 15.43          | 4.43         | 14.80       | 31.77      | 14.34      | 14.41          |
| Ballynahinch    | 18.4        | 46.8         |              | 3.90         | 5.99        | 12.48      | 5.71       | 5.76           | 4.81         | 5.94        | 12.98      | 5.77       | 6.00           |
| Belfast Central | 31.5        | 79           |              | 7.34         | 16.15       | 38.17      | 14.74      | 15.82          | 4.72         | 18.95       | 41.23      | 17.76      | 19.04          |
| Carmoney        | 31.5        | 79           | 45           | 3.58         | 9.00        | 18.38      | 8.60       | 8.65           | 4.31         | 8.77        | 18.70      | 8.55       | 8.77           |
| Castlereagh     | 26.2        | 65           | 33.5         | 9.95         | 20.69       | 51.05      | 18.49      | 22.65          | 10.74        | 26.02       | 64.80      | 23.90      | 29.31          |
| Coleraine       | 40          | 100          | 42.5         | 4.12         | 9.10        | 19.22      | 8.40       | 8.47           | 4.87         | 10.08       | 22.09      | 9.53       | 9.75           |
| Coolkeeragh     | 31.5        | 80           | 33.5         | 9.30         | 22.94       | 56.13      | 20.71      | 24.91          | 10.01        | 27.48       | 67.86      | 25.73      | 31.16          |
| Creagh          | 31.5        | 80           | 33.5         | 3.24         | 8.13        | 16.18      | 7.77       | 7.77           | 4.12         | 8.45        | 17.84      | 8.22       | 8.26           |
| Cregagh         | 26.2        | 65           |              | 8.15         | 18.34       | 44.04      | 16.56      | 18.46          | 6.43         | 22.15       | 51.20      | 20.55      | 22.55          |
| Donegall North  | 31.5        | 79           | 33.5         | 7.68         | 18.65       | 44.41      | 17.14      | 18.51          | 4.80         | 22.47       | 49.44      | 21.16      | 22.03          |
| Donegall South  |             |              |              | 5.35         | 13.81       | 30.84      | 12.93      | 13.13          | 4.52         | 14.49       | 31.24      | 13.92      | 14.27          |
| Drumnakelly     | 31.5        | 79           | 42.5         | 6.56         | 21.41       | 49.67      | 19.51      | 20.74          | 6.82         | 22.66       | 52.92      | 21.36      | 23.08          |
| Dungannon       | 18.4        | 46.8         | 23           | 5.03         | 17.36       | 38.29      | 16.07      | 16.54          | 5.70         | 17.04       | 38.53      | 16.28      | 17.26          |
| Eden            | 25          | 62.5         | 45           | 3.67         | 10.13       | 20.81      | 9.68       | 9.72           | 4.29         | 9.72        | 20.71      | 9.49       | 9.69           |
| Enniskillen     | 31.5        | 79           | 33.5         | 3.70         | 8.53        | 17.56      | 7.90       | 7.91           | 4.59         | 9.98        | 21.59      | 9.43       | 9.49           |
| Finaghy         | 31.5        | 79           |              | 8.85         | 19.35       | 47.01      | 17.75      | 19.94          | 6.02         | 24.11       | 55.06      | 22.63      | 24.11          |
| Glengormley     | 18.4        | 46.8         |              | 3.15         | 5.62        | 11.10      | 5.43       | 5.43           | 3.97         | 5.44        | 11.39      | 5.34       | 5.38           |
| Hannahstown     | 31.5        | 80           | 33.5         | 10.47        | 21.82       | 54.19      | 19.85      | 24.15          | 10.94        | 27.85       | 69.52      | 25.95      | 31.84          |

Table E-7 Northern Ireland Short Circuit Current Levels for Winter Peak 2015  
(Continued)

| Node          | Rating      |              |              | Three Phase  |             |            |            |                | Single Phase |             |            |            |                |
|---------------|-------------|--------------|--------------|--------------|-------------|------------|------------|----------------|--------------|-------------|------------|------------|----------------|
|               | RMS<br>[kA] | Peak<br>[kA] | Asym<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] |
| 110kV         |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Kells*        | 21.9        | 55.9         | 27.4         | 8.19         | 20.93       | 50.31      | 19.31      | 23.15          |              |             |            |            |                |
|               | 26.2        | 65           | 29.7         |              |             |            |            |                | 8.83         | 25.85       | 62.79      | 24.43      | 29.53          |
| Killymallaght | 40          | 100          | 45           | 5.63         | 12.60       | 28.42      | 11.87      | 12.09          | 5.55         | 11.64       | 26.19      | 11.30      | 11.82          |
| Knock         | 18.4        | 46.8         |              | 4.16         | 17.06       | 36.11      | 15.50      | 15.62          | 2.85         | 16.73       | 32.21      | 15.80      | 16.77          |
| Larne         | 18.4        | 46.8         | 42.5         | 4.04         | 9.77        | 20.54      | 9.34       | 9.36           | 4.89         | 9.13        | 20.01      | 8.92       | 9.09           |
| Limavady      | 18.4        | 46.8         | 23           | 3.67         | 7.82        | 16.06      | 7.35       | 7.35           | 4.50         | 8.18        | 17.62      | 7.86       | 7.96           |
| Lisburn       | 18.4        | 46.8         | 23           | 4.61         | 13.17       | 28.52      | 12.39      | 12.49          | 4.44         | 12.66       | 27.19      | 12.22      | 12.60          |
| Lisaghmore    | 31.5        | 79           |              | 4.18         | 10.28       | 21.78      | 9.74       | 9.82           | 4.62         | 9.80        | 21.24      | 9.53       | 9.85           |
| Loguestown    | 26.2        | 65           |              | 3.65         | 6.31        | 12.94      | 5.92       | 5.95           | 4.36         | 6.66        | 14.25      | 6.39       | 6.49           |
| Magherakeel   | 40          | 100          | 45           | 5.04         | 4.21        | 9.28       | 4.02       | 4.13           | 6.24         | 4.60        | 10.57      | 4.44       | 4.63           |
| Newtownards   | 40          | 100          |              | 4.20         | 8.35        | 17.71      | 7.91       | 7.97           | 5.37         | 7.77        | 17.36      | 7.54       | 7.81           |
| Newry         | 18.4        | 46.8         | 23           | 3.74         | 5.80        | 11.96      | 5.55       | 5.59           | 4.76         | 5.71        | 12.45      | 5.56       | 5.77           |
| Omagh         | 40          | 100          | 42.5         | 4.12         | 13.92       | 29.39      | 12.79      | 12.86          | 4.93         | 13.49       | 29.63      | 12.81      | 13.18          |
| Rathgael      | 26.2        | 65           |              | 3.89         | 6.40        | 13.34      | 6.10       | 6.14           | 4.75         | 6.26        | 13.63      | 6.08       | 6.29           |
| Rosebank      | 40          | 100          |              | 8.06         | 19.26       | 46.18      | 17.33      | 19.33          | 7.94         | 23.72       | 56.75      | 21.93      | 24.25          |
| Slieve Kirk   | 40          | 100          |              | 4.36         | 8.94        | 19.12      | 8.57       | 8.62           | 5.04         | 7.30        | 16.11      | 7.16       | 7.66           |
| Springtown    | 31.5        | 79           | 33.6         | 4.34         | 10.47       | 22.38      | 9.94       | 10.04          | 4.75         | 10.20       | 22.23      | 9.92       | 10.26          |
| Strabane      | 18.4        | 46.8         | 23           | 4.62         | 15.80       | 34.23      | 14.58      | 14.68          | 5.45         | 16.63       | 37.28      | 15.86      | 16.34          |
| Tandragee     | 31.5        | 79           | 33.6         | 8.25         | 23.89       | 57.48      | 21.62      | 25.46          | 9.18         | 28.00       | 68.39      | 26.12      | 31.36          |
| Tamnamore     | 40          | 100          | 45           | 6.70         | 14.65       | 34.10      | 13.82      | 15.80          | 7.98         | 14.65       | 35.08      | 14.17      | 16.51          |
| Waringstown   | 18.4        | 46.8         |              | 4.61         | 8.73        | 18.90      | 8.33       | 8.44           | 5.42         | 8.27        | 18.53      | 8.06       | 8.43           |

Table E-8 Northern Ireland Short Circuit Current Levels for Summer Night Valley 2018

| Node            | Rating      |              |              | Three Phase  |             |            |            |                | Single Phase |             |            |            |                |
|-----------------|-------------|--------------|--------------|--------------|-------------|------------|------------|----------------|--------------|-------------|------------|------------|----------------|
|                 | RMS<br>[kA] | Peak<br>[kA] | Asym<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] |
| <b>275kV</b>    |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Ballylumford    | 31.5        | 79           | 35.65        | 11.40        | 8.30        | 20.82      | 7.30       | 8.63           | 12.01        | 11.07       | 27.92      | 10.11      | 12.04          |
| Castlereagh     | 31.5        | 79           | 35.65        | 10.87        | 8.37        | 20.89      | 7.33       | 8.56           | 10.78        | 10.13       | 25.24      | 9.29       | 10.78          |
| Coolkeeragh     | 31.5        | 79           | 35.3         | 11.12        | 8.09        | 20.24      | 7.20       | 8.81           | 12.24        | 9.19        | 23.24      | 8.61       | 10.65          |
| Hannahstown     | 31.5        | 79           | 35.65        | 10.84        | 8.15        | 20.32      | 7.15       | 8.32           | 10.93        | 9.99        | 24.94      | 9.17       | 10.71          |
| Kells           | 31.5        | 79           | 35.65        | 11.73        | 8.95        | 22.53      | 7.82       | 9.40           | 11.08        | 10.93       | 27.31      | 10.03      | 11.73          |
| Kilroot         | 31.5        | 79           | 45.3         | 12.33        | 8.89        | 22.49      | 7.77       | 9.52           | 13.15        | 11.84       | 30.14      | 10.81      | 13.34          |
| Magherafelt     | 31.5        | 79           | 35.65        | 11.52        | 9.33        | 23.43      | 8.16       | 9.70           | 9.49         | 9.69        | 23.77      | 9.01       | 9.90           |
| Moyle           | 31.5        | 79           | 35.65        | 11.36        | 8.23        | 20.64      | 7.24       | 8.54           | 11.90        | 10.91       | 27.48      | 9.97       | 11.82          |
| Tandragee       | 31.5        | 79           | 35.65        | 10.73        | 9.83        | 24.48      | 8.59       | 9.93           | 10.21        | 10.98       | 27.18      | 10.12      | 11.65          |
| Tamnamore       | 40          | 100          | 45.6         | 10.69        | 9.05        | 22.53      | 7.95       | 9.19           | 10.21        | 8.42        | 20.85      | 7.90       | 9.15           |
| <b>110kV</b>    |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Aghyoule        | 40          | 100          |              | 3.01         | 3.02        | 5.91       | 2.93       | 2.93           | 3.91         | 3.32        | 6.92       | 3.25       | 3.26           |
| Antrim          | 40          | 100          |              | 4.74         | 7.84        | 17.07      | 7.39       | 7.52           | 4.88         | 8.32        | 18.23      | 8.05       | 8.36           |
| Ballylumford    | 21.9        | 55           | 25.88        | 10.12        | 14.18       | 35.07      | 12.86      | 15.86          | 11.10        | 18.03       | 45.09      | 16.92      | 21.15          |
| Ballymena       | 40          | 100          |              | 4.91         | 7.56        | 16.60      | 7.13       | 7.30           | 5.46         | 8.24        | 18.47      | 7.96       | 8.43           |
| Banbridge       | 18.4        | 46.8         |              | 4.40         | 5.68        | 12.18      | 5.43       | 5.49           | 5.34         | 5.89        | 13.14      | 5.74       | 5.98           |
| Ballyvally      | 40          | 100          |              | 5.46         | 11.33       | 25.40      | 10.44      | 10.56          | 5.01         | 11.65       | 25.67      | 11.15      | 11.25          |
| Ballynahinch    | 18.4        | 46.8         |              | 4.24         | 5.17        | 10.98      | 4.92       | 4.98           | 5.02         | 5.34        | 11.78      | 5.19       | 5.41           |
| Belfast Central | 31.5        | 79           |              | 8.57         | 11.54       | 27.92      | 10.47      | 11.53          | 5.57         | 14.48       | 32.61      | 13.52      | 14.73          |
| Belfast North   | 18.4        | 46.8         | 1000         | 5.31         | 11.30       | 25.20      | 10.37      | 10.64          | 3.36         | 12.25       | 24.62      | 11.65      | 12.65          |
| Carmoney        | 31.5        | 79           | 45           | 4.08         | 7.27        | 15.30      | 6.85       | 6.91           | 4.66         | 7.61        | 16.51      | 7.36       | 7.58           |
| Castlereagh     | 31.5        | 79           | 33.5         | 11.18        | 13.66       | 34.17      | 12.20      | 14.95          | 11.69        | 18.15       | 45.63      | 16.68      | 20.41          |
| Coleraine       | 40          | 100          | 45.6         | 4.13         | 6.37        | 13.45      | 6.00       | 6.01           | 4.65         | 7.72        | 16.74      | 7.43       | 7.47           |
| Coolkeeragh     | 31.5        | 80           |              | 12.05        | 15.75       | 39.73      | 14.04      | 18.22          | 12.53        | 20.45       | 51.81      | 19.00      | 24.53          |
| Creagh          | 31.5        | 80           | 33.5         | 3.78         | 6.87        | 14.22      | 6.51       | 6.52           | 4.55         | 7.49        | 16.18      | 7.27       | 7.33           |
| Cregagh         |             |              |              | 9.46         | 12.60       | 30.89      | 11.34      | 12.94          | 7.49         | 16.21       | 38.44      | 15.02      | 16.74          |
| Donegal North   | 31.5        | 79           | 33.5         | 8.79         | 12.61       | 30.63      | 11.48      | 12.65          | 5.72         | 16.16       | 36.78      | 15.12      | 16.04          |
| Donegal South   | 1000        | 1000         |              | 6.28         | 10.20       | 23.49      | 9.44       | 9.69           | 5.16         | 11.61       | 25.75      | 11.06      | 11.42          |
| Drumnakelly     | 31.5        | 79           | 42.5         | 8.94         | 12.54       | 30.52      | 11.45      | 12.61          | 8.85         | 14.60       | 35.48      | 13.77      | 15.34          |
| Dungannon       | 40          | 100          | 45.6         | 7.33         | 10.25       | 24.21      | 9.51       | 10.19          | 7.76         | 11.17       | 26.64      | 10.70      | 11.79          |
| Eden            | 25          | 62.5         |              | 4.22         | 7.91        | 16.81      | 7.45       | 7.50           | 4.66         | 8.25        | 17.90      | 7.97       | 8.18           |
| Enniskillen     | 31.5        | 79           |              | 3.68         | 6.03        | 12.39      | 5.72       | 5.72           | 4.27         | 7.60        | 16.18      | 7.32       | 7.33           |
| Finaghy         | 31.5        | 79           | 1000         | 9.85         | 12.93       | 31.87      | 11.75      | 13.34          | 7.12         | 17.03       | 40.05      | 15.88      | 17.16          |
| Glengormley     | 18.4        | 46.8         | 1000         | 3.47         | 4.88        | 9.90       | 4.69       | 4.70           | 4.19         | 4.96        | 10.52      | 4.86       | 4.91           |
| Hannahstown     | 31.5        | 80           |              | 11.21        | 14.00       | 35.04      | 12.63      | 15.14          | 11.67        | 18.79       | 47.24      | 17.42      | 20.98          |
| Kells           | 40          | 100          | 45.6         | 9.23         | 13.72       | 33.52      | 12.45      | 14.96          | 9.67         | 17.99       | 44.24      | 16.83      | 20.27          |

Table E-8 Northern Ireland Short Circuit Current Levels for Summer Night Valley 2018 (Continued)

| Node          | Rating      |              |              | Three Phase  |             |            |            |                | Single Phase |             |            |            |                |
|---------------|-------------|--------------|--------------|--------------|-------------|------------|------------|----------------|--------------|-------------|------------|------------|----------------|
|               | RMS<br>[kA] | Peak<br>[kA] | Asym<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] |
| 110kV         |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Killymallaght | 40          | 100          |              | 6.25         | 9.52        | 21.90      | 8.87       | 9.05           | 5.96         | 9.73        | 22.19      | 9.38       | 9.80           |
| Knock         | 18.4        | 46.8         |              | 5.23         | 12.03       | 26.74      | 10.87      | 11.09          | 3.31         | 13.27       | 26.58      | 12.47      | 13.31          |
| Larne         | 18.4        | 46.8         |              | 4.61         | 7.66        | 16.57      | 7.23       | 7.26           | 5.25         | 7.79        | 17.32      | 7.55       | 7.74           |
| Limavady      | 18.4        | 46.8         |              | 3.79         | 5.96        | 12.33      | 5.65       | 5.65           | 4.43         | 6.71        | 14.41      | 6.51       | 6.55           |
| Lisburn       | 18.4        | 46.8         |              | 6.88         | 9.99        | 23.38      | 9.26       | 9.62           | 5.74         | 10.51       | 23.80      | 10.06      | 10.67          |
| Lisaghmore    | 31.5        | 79           | 1000         | 4.85         | 8.47        | 18.55      | 7.93       | 8.05           | 5.04         | 8.64        | 19.06      | 8.35       | 8.69           |
| Loguestown    | 26.2        | 65           | 1000         | 3.69         | 4.83        | 9.93       | 4.61       | 4.61           | 4.24         | 5.49        | 11.66      | 5.33       | 5.36           |
| Magherakeel   | 40          | 100          |              | 4.33         | 3.16        | 6.76       | 3.09       | 3.09           | 5.33         | 3.76        | 8.39       | 3.70       | 3.72           |
| Newtownards   | 40          | 100          |              | 4.76         | 6.91        | 15.08      | 6.50       | 6.58           | 5.75         | 6.87        | 15.57      | 6.64       | 6.92           |
| Newry         | 18.4        | 46.8         |              | 4.19         | 4.90        | 10.38      | 4.69       | 4.74           | 5.08         | 5.06        | 11.19      | 4.94       | 5.14           |
| Omagh         | 40          | 100          |              | 4.92         | 9.57        | 21.01      | 8.90       | 8.97           | 5.21         | 11.09       | 24.63      | 10.59      | 10.83          |
| Rathgael      | 26.2        | 65           |              | 4.30         | 5.50        | 11.74      | 5.23       | 5.28           | 5.02         | 5.65        | 12.46      | 5.48       | 5.70           |
| Rosebank      | 40          | 100          |              | 10.21        | 12.87       | 31.87      | 11.57      | 13.56          | 11.07        | 16.82       | 42.03      | 15.54      | 18.54          |
| Slieve Kirk   | 40          | 100          |              | 4.61         | 7.14        | 15.46      | 6.76       | 6.78           | 5.08         | 6.39        | 14.13      | 6.24       | 6.54           |
| Springtown    | 31.5        | 79           | 33.6         | 5.10         | 8.65        | 19.13      | 8.09       | 8.24           | 5.23         | 8.98        | 19.96      | 8.68       | 9.05           |
| Strabane      | 18.4        | 46.8         | 23           | 5.47         | 11.13       | 24.96      | 10.25      | 10.38          | 6.01         | 12.87       | 29.40      | 12.26      | 12.70          |
| Tandragee     | 31.5        | 79           | 33.5         | 11.34        | 14.06       | 35.25      | 12.73      | 15.39          | 11.99        | 17.78       | 44.84      | 16.59      | 20.24          |
| Tamnamore     | 40          | 100          | 45           | 9.94         | 12.58       | 31.05      | 11.54      | 14.04          | 10.17        | 14.75       | 36.49      | 13.97      | 16.91          |
| Waringstown   | 18.4        | 46.8         |              | 5.49         | 6.92        | 15.53      | 6.56       | 6.69           | 6.04         | 7.05        | 16.11      | 6.84       | 7.19           |



Table E-9 Northern Ireland Short Circuit Current Levels for Winter Peak 2018

| Node            | Rating      |              |              | Three Phase  |             |            |            |                | Single Phase |             |            |            |                |
|-----------------|-------------|--------------|--------------|--------------|-------------|------------|------------|----------------|--------------|-------------|------------|------------|----------------|
|                 | RMS<br>[kA] | Peak<br>[kA] | Asym<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] |
| <b>275kV</b>    |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Ballylumford    | 31.5        | 79           | 35.65        | 16.05        | 22.12       | 57.34      | 19.68      | 25.91          | 16.97        | 25.63       | 66.73      | 23.85      | 31.52          |
| Castlereagh     | 31.5        | 79           | 35.65        | 10.97        | 17.28       | 43.15      | 15.43      | 17.64          | 10.77        | 17.49       | 43.57      | 16.36      | 18.78          |
| Coolkeeragh     | 31.5        | 79           | 35.3         | 8.57         | 12.73       | 30.79      | 11.82      | 13.07          | 10.35        | 12.84       | 31.85      | 12.32      | 14.20          |
| Hannahstown     | 31.5        | 79           | 35.65        | 11.33        | 17.30       | 43.35      | 15.47      | 17.85          | 11.30        | 17.76       | 44.50      | 16.64      | 19.50          |
| Kells           | 31.5        | 79           | 35.65        | 13.16        | 19.85       | 50.53      | 17.78      | 21.35          | 11.32        | 20.07       | 50.30      | 18.81      | 21.74          |
| Kilroot         | 31.5        | 79           | 45.3         | 14.46        | 19.39       | 49.80      | 17.33      | 21.63          | 16.05        | 23.12       | 59.94      | 21.57      | 27.62          |
| Magherafelt     | 31.5        | 79           | 35.65        | 11.46        | 18.77       | 47.10      | 16.99      | 19.34          | 8.65         | 15.05       | 36.45      | 14.07      | 14.96          |
| Moyle           | 31.5        | 79           | 35.65        | 15.62        | 21.53       | 55.68      | 19.20      | 24.92          | 16.15        | 24.66       | 63.96      | 23.00      | 29.72          |
| Tandragee       | 31.5        | 79           | 35.65        | 10.14        | 18.90       | 46.75      | 17.03      | 18.77          | 9.65         | 17.23       | 42.36      | 16.31      | 18.31          |
| Tamnamore       | 40          | 100          | 45.6         | 10.28        | 17.25       | 42.73      | 15.70      | 17.32          | 9.85         | 12.06       | 29.73      | 10.76      | 12.48          |
| <b>110kV</b>    |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Aghyoule        | 40          | 100          |              | 4.13         | 4.22        | 8.92       | 3.98       | 4.16           | 5.51         | 4.20        | 9.43       | 4.04       | 4.41           |
| Antrim          | 40          | 100          |              | 4.16         | 10.07       | 21.32      | 9.63       | 9.73           | 4.49         | 10.06       | 21.67      | 9.69       | 10.01          |
| Ballylumford    | 21.9        | 55           | 25.88        | 10.76        | 24.39       | 60.77      | 22.56      | 29.44          | 12.33        | 28.25       | 71.46      | 26.88      | 35.76          |
| Ballymena       | 40          | 100          |              | 4.57         | 9.92        | 21.44      | 9.37       | 9.64           | 5.30         | 10.51       | 23.44      | 9.79       | 10.57          |
| Banbridge       | 18.4        | 46.8         |              | 4.00         | 6.58        | 13.81      | 6.33       | 6.37           | 5.07         | 6.52        | 14.41      | 6.37       | 6.60           |
| Ballyvallagh    | 40          | 100          |              | 4.52         | 16.78       | 36.17      | 15.75      | 15.80          | 4.40         | 15.16       | 32.50      | 14.58      | 14.64          |
| Ballynahinch    | 18.4        | 46.8         |              | 3.88         | 6.02        | 12.55      | 5.75       | 5.80           | 4.80         | 5.95        | 13.00      | 5.78       | 6.01           |
| Belfast Central | 31.5        | 79           |              | 7.47         | 16.68       | 39.54      | 15.23      | 16.38          | 4.74         | 19.49       | 42.47      | 18.22      | 19.65          |
| Belfast North   | 18.4        | 46.8         |              | 4.40         | 15.97       | 34.22      | 14.88      | 15.09          | 2.92         | 15.40       | 29.86      | 14.79      | 15.98          |
| Carmoney        | 31.5        | 79           | 45           | 3.57         | 9.10        | 18.57      | 8.71       | 8.76           | 4.31         | 8.87        | 18.94      | 8.65       | 8.88           |
| Castlereagh     | 31.5        | 79           | 33.5         | 10.32        | 21.55       | 53.42      | 19.24      | 23.79          | 11.05        | 27.03       | 67.54      | 24.73      | 30.56          |
| Coleraine       | 40          | 100          | 45.6         | 4.59         | 9.93        | 21.48      | 9.13       | 9.23           | 5.34         | 10.91       | 24.37      | 10.30      | 10.60          |
| Coolkeeragh     | 31.5        | 80           | 33.5         | 9.00         | 23.76       | 57.87      | 21.57      | 25.69          | 9.84         | 29.06       | 71.62      | 27.22      | 32.86          |
| Creagh          | 31.5        | 80           | 33.5         | 3.30         | 8.42        | 16.85      | 8.07       | 8.07           | 4.20         | 8.75        | 18.57      | 8.46       | 8.51           |
| Cregagh         | 26.2        | 65           |              | 8.33         | 19.02       | 45.83      | 17.16      | 19.20          | 6.49         | 22.89       | 53.00      | 21.18      | 23.31          |
| Donegall North  | 31.5        | 79           | 33.5         | 8.02         | 18.80       | 45.07      | 17.35      | 18.75          | 4.85         | 22.53       | 49.70      | 21.23      | 22.22          |
| Donegall South  |             |              |              | 5.45         | 13.89       | 31.14      | 13.05      | 13.24          | 4.57         | 14.56       | 31.46      | 13.98      | 14.33          |
| Drumnakelly     | 31.5        | 79           | 42.5         | 7.82         | 17.89       | 42.69      | 16.41      | 17.59          | 8.06         | 19.02       | 45.59      | 17.97      | 19.73          |
| Dungannon       | 40          | 100          |              | 6.52         | 14.28       | 33.09      | 13.42      | 14.01          | 7.28         | 14.25       | 33.64      | 13.27      | 14.50          |
| Eden            | 25          | 62.5         | 45           | 3.65         | 10.23       | 20.98      | 9.79       | 9.83           | 4.28         | 9.83        | 20.95      | 9.60       | 9.79           |
| Enniskillen     | 31.5        | 79           | 33.5         | 3.98         | 9.20        | 19.26      | 8.53       | 8.58           | 4.88         | 10.78       | 23.62      | 10.15      | 10.30          |
| Finaghy         | 31.5        | 79           |              | 9.33         | 19.51       | 47.74      | 17.96      | 20.15          | 6.23         | 24.26       | 55.77      | 22.78      | 24.25          |
| Glengormley     | 18.4        | 46.8         |              | 3.13         | 5.70        | 11.25      | 5.51       | 5.51           | 3.97         | 5.54        | 11.59      | 5.39       | 5.43           |
| Hannahstown     | 31.5        | 80           | 33.5         | 11.29        | 22.03       | 55.18      | 20.11      | 24.49          | 11.96        | 28.02       | 70.63      | 26.12      | 32.10          |
| Kells           | 40          | 100          | 45.6         | 8.91         | 22.22       | 54.03      | 20.40      | 24.62          | 9.57         | 28.42       | 69.79      | 25.88      | 31.87          |

Table E-9 Northern Ireland Short Circuit Current Levels for Winter Peak 2018  
(Continued)

| Node          | Rating      |              |              | Three Phase  |             |            |            |                | Single Phase |             |            |            |                |
|---------------|-------------|--------------|--------------|--------------|-------------|------------|------------|----------------|--------------|-------------|------------|------------|----------------|
|               | RMS<br>[kA] | Peak<br>[kA] | Asym<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] |
| 110kV         |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Killymallaght | 40          | 100          |              | 5.64         | 13.20       | 29.78      | 12.48      | 12.71          | 5.56         | 12.06       | 27.15      | 11.71      | 12.28          |
| Knock         | 18.4        | 46.8         |              | 4.12         | 17.63       | 37.23      | 16.01      | 16.15          | 2.81         | 17.10       | 32.79      | 16.13      | 17.14          |
| Larne         | 18.4        | 46.8         | 42.5         | 4.02         | 9.89        | 20.76      | 9.47       | 9.49           | 4.88         | 9.25        | 20.28      | 9.00       | 9.17           |
| Limavady      | 18.4        | 46.8         | 23           | 3.71         | 8.09        | 16.66      | 7.61       | 7.62           | 4.55         | 8.38        | 18.10      | 8.06       | 8.16           |
| Lisburn       | 18.4        | 46.8         |              | 6.14         | 13.42       | 30.77      | 12.64      | 12.96          | 6.07         | 12.57       | 28.76      | 12.14      | 12.77          |
| Lisaghmore    | 31.5        | 79           |              | 4.11         | 10.42       | 22.00      | 9.91       | 9.99           | 4.55         | 9.93        | 21.44      | 9.66       | 9.98           |
| Loguestown    | 26.2        | 65           |              | 3.86         | 6.68        | 13.88      | 6.26       | 6.29           | 4.56         | 6.98        | 15.08      | 6.69       | 6.82           |
| Magherakeel   | 40          | 100          |              | 5.53         | 4.53        | 10.18      | 4.34       | 4.55           | 6.95         | 4.90        | 11.49      | 4.74       | 5.10           |
| Newtownards   | 40          | 100          |              | 4.19         | 8.46        | 17.94      | 8.02       | 8.08           | 5.38         | 7.86        | 17.58      | 7.62       | 7.90           |
| Newry         | 18.4        | 46.8         | 23           | 4.06         | 5.73        | 12.05      | 5.44       | 5.54           | 5.06         | 5.62        | 12.41      | 5.45       | 5.74           |
| Omagh         | 40          | 100          | 42.5         | 4.94         | 15.73       | 34.57      | 14.50      | 14.73          | 5.36         | 16.18       | 36.16      | 15.11      | 15.80          |
| Omagh South   | 40          | 100          |              | 3.95         | 11.19       | 23.39      | 10.47      | 10.49          | 3.98         | 10.61       | 22.23      | 10.12      | 10.14          |
| Rathgael      | 26.2        | 65           |              | 3.88         | 6.47        | 13.47      | 6.17       | 6.21           | 4.76         | 6.32        | 13.78      | 6.14       | 6.36           |
| Rosebank      | 40          | 100          |              | 9.15         | 19.62       | 47.89      | 17.67      | 20.44          | 10.39        | 24.12       | 59.83      | 22.25      | 26.50          |
| Slieve Kirk   | 40          | 100          |              | 4.34         | 9.26        | 19.78      | 8.89       | 8.96           | 5.05         | 7.47        | 16.49      | 7.33       | 7.86           |
| Springtown    | 31.5        | 79           | 33.6         | 4.27         | 10.62       | 22.62      | 10.12      | 10.22          | 4.67         | 10.34       | 22.46      | 10.07      | 10.41          |
| Strabane      | 18.4        | 46.8         | 23           | 4.59         | 16.72       | 36.16      | 15.53      | 15.61          | 5.43         | 17.46       | 39.10      | 16.68      | 17.18          |
| Tandragee     | 31.5        | 79           | 33.5         | 10.42        | 21.04       | 52.21      | 19.13      | 22.87          | 11.38        | 24.69       | 61.91      | 23.06      | 28.06          |
| Tamnamore     | 40          | 100          | 45           | 9.35         | 18.97       | 46.43      | 17.72      | 21.17          | 9.78         | 20.31       | 50.01      | 18.10      | 22.17          |
| Waringstown   | 18.4        | 46.8         |              | 4.94         | 8.32        | 18.28      | 7.93       | 8.04           | 5.71         | 8.00        | 18.09      | 7.77       | 8.14           |

Table E-10 Northern Ireland Short Circuit Current Levels for Summer Night Valley 2021

| Node            | Rating      |              |              | Three Phase  |             |            |            |                | Single Phase |             |            |            |                |
|-----------------|-------------|--------------|--------------|--------------|-------------|------------|------------|----------------|--------------|-------------|------------|------------|----------------|
|                 | RMS<br>[kA] | Peak<br>[kA] | Asym<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] |
| 400 kV          |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Turleenan       | 50          | 125          | 57.3         | 14.15        | 8.66        | 22.19      | 7.91       | 9.45           | 11.81        | 9.62        | 24.22      | 9.14       | 10.58          |
| 275kV           |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Ballylumford    | 31.5        | 79           | 35.65        | 14.20        | 12.29       | 31.52      | 11.13      | 13.62          | 14.78        | 15.12       | 38.91      | 14.22      | 17.61          |
| Castlereagh     | 31.5        | 79           | 35.65        | 12.50        | 11.60       | 29.39      | 10.47      | 12.32          | 11.90        | 13.05       | 32.88      | 12.29      | 14.33          |
| Coolkeeragh     | 31.5        | 79           | 35.3         | 15.08        | 10.26       | 26.47      | 9.41       | 11.59          | 15.52        | 10.92       | 28.23      | 10.45      | 13.10          |
| Hannahstown     | 31.5        | 79           | 35.65        | 12.51        | 11.32       | 28.68      | 10.25      | 12.02          | 12.22        | 12.88       | 32.54      | 12.14      | 14.33          |
| Kells           | 31.5        | 79           | 35.65        | 14.39        | 13.06       | 33.54      | 11.73      | 14.48          | 12.40        | 14.64       | 37.04      | 13.79      | 16.25          |
| Kilroot         | 31.5        | 79           | 45.3         | 15.71        | 13.13       | 33.98      | 11.74      | 15.01          | 16.85        | 16.51       | 42.95      | 15.44      | 19.97          |
| Magherafelt     | 31.5        | 79           | 35.65        | 14.46        | 13.75       | 35.33      | 12.36      | 15.21          | 9.83         | 13.15       | 32.41      | 12.49      | 13.52          |
| Moyle           | 31.5        | 79           | 35.65        | 14.05        | 12.12       | 31.05      | 10.99      | 13.38          | 14.52        | 14.82       | 38.09      | 13.95      | 17.14          |
| Tandragee       | 31.5        | 79           | 35.65        | 12.88        | 14.23       | 36.15      | 12.75      | 15.14          | 11.17        | 15.46       | 38.68      | 14.53      | 16.80          |
| Tamnamore       | 40          | 100          | 45.6         | 13.45        | 14.11       | 36.01      | 12.68      | 15.25          | 10.82        | 14.22       | 35.45      | 13.44      | 15.51          |
| Turleenan       | 40          | 100          | 45.6         | 13.48        | 14.33       | 36.56      | 12.86      | 15.48          | 10.66        | 14.52       | 36.13      | 13.71      | 15.72          |
| 110kV           |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Aghyoule        | 40          | 100          |              | 2.96         | 3.04        | 5.91       | 2.97       | 2.97           | 3.87         | 3.34        | 6.95       | 3.29       | 3.29           |
| Airport Road    | 40          | 100          |              | 5.31         | 9.78        | 21.81      | 9.28       | 9.44           | 5.42         | 10.28       | 23.03      | 9.97       | 10.39          |
| Antrim          | 40          | 100          |              | 4.56         | 8.63        | 18.64      | 8.31       | 8.42           | 4.77         | 8.89        | 19.40      | 8.72       | 9.04           |
| Ballylumford    | 40          | 100          | 45.6         | 10.67        | 17.11       | 42.58      | 15.99      | 20.06          | 11.83        | 20.95       | 52.74      | 20.11      | 25.65          |
| Ballymena       | 40          | 100          |              | 4.74         | 8.29        | 18.05      | 7.98       | 8.13           | 5.36         | 8.78        | 19.62      | 8.60       | 9.07           |
| Banbridge       | 18.4        | 46.8         |              | 4.26         | 6.05        | 12.88      | 5.88       | 5.93           | 5.25         | 6.12        | 13.62      | 6.02       | 6.26           |
| Ballyvally      | 40          | 100          | 45.6         | 5.17         | 13.09       | 29.03      | 12.40      | 12.48          | 4.81         | 12.76       | 27.89      | 12.43      | 12.51          |
| Ballynahinch    | 18.4        | 46.8         |              | 4.10         | 5.47        | 11.54      | 5.29       | 5.34           | 4.93         | 5.53        | 12.16      | 5.43       | 5.65           |
| Belfast Central | 31.5        | 79           |              | 8.73         | 13.37       | 32.44      | 12.47      | 13.61          | 5.29         | 16.42       | 36.61      | 15.65      | 16.95          |
| Belfast North   | 18.4        | 46.8         |              | 5.02         | 13.15       | 28.99      | 12.41      | 12.64          | 3.16         | 13.56       | 26.81      | 13.14      | 14.21          |
| Carnmoney       | 31.5        | 79           | 45           | 3.86         | 7.94        | 16.51      | 7.64       | 7.69           | 4.52         | 8.03        | 17.32      | 7.86       | 8.08           |
| Castlereagh     | 31.5        | 79           | 33.5         | 12.34        | 16.34       | 41.33      | 15.02      | 18.71          | 12.75        | 21.37       | 54.24      | 20.09      | 24.90          |
| Coleraine       | 40          | 100          | 45.6         | 4.36         | 6.68        | 14.29      | 6.39       | 6.40           | 4.87         | 8.48        | 18.59      | 8.23       | 8.28           |
| Coolkeeragh     | 31.5        | 80           | 33.5         | 13.09        | 17.52       | 44.57      | 16.00      | 20.90          | 13.49        | 22.38       | 57.11      | 21.16      | 27.52          |
| Creagh          | 31.5        | 80           | 33.5         | 3.61         | 7.42        | 15.17      | 7.17       | 7.17           | 4.43         | 7.92        | 17.01      | 7.77       | 7.82           |
| Cregagh         | 26.2        | 65           |              | 9.87         | 14.83       | 36.57      | 13.73      | 15.61          | 7.35         | 18.72       | 44.26      | 17.72      | 19.64          |
| Donegall North  | 31.5        | 79           | 33.5         | 9.05         | 14.98       | 36.51      | 14.03      | 15.34          | 5.47         | 18.60       | 41.73      | 17.80      | 18.47          |
| Donegall South  |             |              |              | 6.09         | 11.67       | 26.71      | 11.08      | 11.29          | 4.96         | 12.77       | 28.10      | 12.39      | 12.73          |
| Drumnakelly     | 31.5        | 79           | 42.5         | 9.27         | 14.77       | 36.12      | 13.85      | 15.23          | 9.04         | 16.58       | 40.42      | 15.94      | 17.72          |
| Dungannon       | 40          | 100          | 45.6         | 7.51         | 11.66       | 27.65      | 11.08      | 11.85          | 7.87         | 12.45       | 29.75      | 12.09      | 13.31          |
| Eden            | 25          | 62.5         | 45           | 4.00         | 8.69        | 18.23      | 8.36       | 8.40           | 4.51         | 8.75        | 18.86      | 8.57       | 8.77           |
| Enniskillen     | 31.5        | 79           | 33.5         | 3.59         | 6.25        | 12.77      | 6.00       | 6.00           | 4.17         | 7.86        | 16.65      | 7.63       | 7.64           |
| Finaghy         | 31.5        | 79           |              | 10.44        | 15.43       | 38.31      | 14.43      | 16.36          | 7.01         | 19.80       | 46.45      | 18.90      | 20.26          |

Table E-10 Northern Ireland Short Circuit Current Levels for Summer Night Valley 2021 (Continued)

| Node          | Rating      |              |              | Three Phase  |             |            |            |                | Single Phase |             |            |            |                |
|---------------|-------------|--------------|--------------|--------------|-------------|------------|------------|----------------|--------------|-------------|------------|------------|----------------|
|               | RMS<br>[kA] | Peak<br>[kA] | Asym<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] |
| 110kV         |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Glengormley   | 18.4        | 46.8         |              | 3.34         | 5.16        | 10.35      | 5.03       | 5.03           | 4.11         | 5.13        | 10.83      | 5.06       | 5.11           |
| Hannahstown   | 31.5        | 80           | 33.5         | 12.54        | 17.01       | 43.09      | 15.81      | 19.24          | 13.07        | 22.25       | 56.60      | 21.13      | 25.87          |
| Kells         | 40          | 100          | 45.6         | 9.72         | 16.43       | 40.42      | 15.35      | 18.67          | 10.20        | 20.98       | 51.94      | 20.07      | 24.51          |
| Killymallaght | 40          | 100          | 45           | 6.14         | 10.05       | 23.04      | 9.54       | 9.68           | 5.73         | 10.24       | 23.17      | 9.97       | 10.36          |
| Knock         | 18.4        | 46.8         |              | 4.92         | 14.06       | 30.88      | 13.07      | 13.25          | 3.10         | 14.85       | 29.24      | 14.24      | 15.16          |
| Larne         | 18.4        | 46.8         | 42.5         | 4.39         | 8.38        | 17.96      | 8.08       | 8.10           | 5.12         | 8.23        | 18.22      | 8.08       | 8.25           |
| Limavady      | 18.4        | 46.8         | 23           | 4.18         | 6.22        | 13.17      | 5.98       | 5.98           | 4.85         | 6.97        | 15.27      | 6.81       | 6.88           |
| Lisburn       | 18.4        | 46.8         | 23           | 6.93         | 11.48       | 26.88      | 10.91      | 11.25          | 6.42         | 11.20       | 25.87      | 10.90      | 11.47          |
| Lisaghmore    | 31.5        | 79           |              | 4.75         | 8.90        | 19.39      | 8.47       | 8.57           | 4.99         | 8.90        | 19.61      | 8.69       | 9.02           |
| Loguestown    | 26.2        | 65           |              | 3.81         | 4.99        | 10.35      | 4.82       | 4.82           | 4.36         | 5.73        | 12.26      | 5.60       | 5.63           |
| Magherakeel   | 40          | 100          | 45           | 4.27         | 3.18        | 6.76       | 3.13       | 3.13           | 5.25         | 3.79        | 8.43       | 3.75       | 3.77           |
| Newtownards   | 40          | 100          |              | 4.59         | 7.51        | 16.25      | 7.20       | 7.27           | 5.64         | 7.26        | 16.39      | 7.10       | 7.38           |
| Newry         | 18.4        | 46.8         | 23           | 4.06         | 5.15        | 10.85      | 5.01       | 5.06           | 5.00         | 5.22        | 11.50      | 5.13       | 5.33           |
| Omagh         | 40          | 100          | 42.5         | 4.76         | 10.36       | 22.59      | 9.83       | 9.88           | 5.07         | 11.85       | 26.19      | 11.47      | 11.67          |
| Omagh South   | 40          | 100          | 42.5         | 3.92         | 7.87        | 16.43      | 7.54       | 7.54           | 4.05         | 8.68        | 18.26      | 8.45       | 8.46           |
| Rathgael      | 26.2        | 65           |              | 4.15         | 5.85        | 12.38      | 5.65       | 5.70           | 4.92         | 5.87        | 12.89      | 5.75       | 5.97           |
| Rosebank      | 40          | 100          |              | 10.87        | 15.22       | 37.95      | 14.06      | 16.51          | 11.63        | 19.52       | 49.07      | 18.43      | 21.96          |
| Slieve Kirk   | 40          | 100          |              | 4.49         | 7.39        | 15.92      | 7.11       | 7.13           | 5.20         | 7.09        | 15.75      | 6.96       | 7.09           |
| Springtown    | 31.5        | 79           | 33.6         | 5.00         | 9.10        | 20.05      | 8.66       | 8.80           | 5.18         | 9.27        | 20.58      | 9.05       | 9.42           |
| Strabane      | 18.4        | 46.8         | 23           | 5.29         | 11.94       | 26.60      | 11.23      | 11.32          | 5.88         | 13.59       | 30.90      | 13.11      | 13.49          |
| Tandragee     | 31.5        | 79           | 33.5         | 12.79        | 16.96       | 43.05      | 15.78      | 19.61          | 13.52        | 20.94       | 53.46      | 19.95      | 25.02          |
| Tamnamore     | 40          | 100          | 45           | 11.18        | 14.89       | 37.26      | 14.03      | 17.74          | 11.54        | 17.43       | 43.76      | 16.79      | 21.08          |
| Waringstown   | 18.4        | 46.8         |              | 5.36         | 7.51        | 16.78      | 7.25       | 7.38           | 5.99         | 7.45        | 16.99      | 7.30       | 7.67           |

TEN YEAR TRANSMISSION FORECAST STATEMENT 2015

Table E-11 Northern Ireland Short Circuit Current Levels for Winter Peak 2021

| Node            | Rating      |              |              | Three Phase  |             |            |            |                | Single Phase |             |            |            |                |
|-----------------|-------------|--------------|--------------|--------------|-------------|------------|------------|----------------|--------------|-------------|------------|------------|----------------|
|                 | RMS<br>[kA] | Peak<br>[kA] | Asym<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] |
| <b>400 kV</b>   |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Turleenan       | 50          | 125          | 57.3         | 12.97        | 12.33       | 31.34      | 11.51      | 13.14          | 10.83        | 12.65       | 31.55      | 12.16      | 13.67          |
| <b>275kV</b>    |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Ballylumford    | 31.5        | 79           | 35.65        | 14.33        | 21.02       | 53.94      | 18.92      | 23.63          | 15.16        | 23.33       | 60.18      | 21.89      | 27.83          |
| Castlereagh     | 31.5        | 79           | 35.65        | 10.82        | 17.69       | 44.08      | 15.89      | 18.02          | 10.67        | 17.80       | 44.30      | 16.71      | 19.07          |
| Coolkeeragh     | 31.5        | 79           | 35.3         | 13.34        | 13.82       | 35.22      | 12.88      | 15.11          | 14.37        | 13.58       | 34.85      | 13.08      | 15.96          |
| Hannahstown     | 31.5        | 79           | 35.65        | 11.03        | 17.40       | 43.47      | 15.68      | 17.85          | 11.13        | 17.74       | 44.38      | 16.68      | 19.38          |
| Kells           | 31.5        | 79           | 35.65        | 13.30        | 20.76       | 52.90      | 18.77      | 22.37          | 11.18        | 20.69       | 51.76      | 19.53      | 22.42          |
| Kilroot         | 31.5        | 79           | 45.3         | 14.43        | 20.06       | 51.52      | 18.08      | 22.32          | 16.06        | 23.64       | 61.28      | 22.18      | 28.18          |
| Magherafelt     | 31.5        | 79           | 35.65        | 12.61        | 21.27       | 53.92      | 19.34      | 22.52          | 8.59         | 17.28       | 41.82      | 16.53      | 17.39          |
| Moyle           | 31.5        | 79           | 35.65        | 14.05        | 20.50       | 52.52      | 18.50      | 22.86          | 14.73        | 22.62       | 58.20      | 21.26      | 26.65          |
| Tandragee       | 31.5        | 79           | 35.65        | 11.15        | 22.13       | 55.36      | 19.94      | 22.52          | 9.90         | 21.19       | 52.26      | 20.02      | 22.46          |
| Tamnamore       | 40          | 100          | 45.6         | 11.67        | 21.78       | 54.75      | 19.78      | 22.52          | 9.59         | 18.91       | 46.44      | 18.01      | 20.16          |
| Turleenan       | 40          | 100          | 45.6         | 11.66        | 22.09       | 55.54      | 20.05      | 22.82          | 9.40         | 19.30       | 47.29      | 18.38      | 20.41          |
| <b>110kV</b>    |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Aghyoule        | 40          | 100          |              | 4.07         | 4.28        | 9.01       | 4.04       | 4.21           | 5.44         | 4.21        | 9.44       | 4.06       | 4.42           |
| Airport Road    | 40          | 100          |              | 4.67         | 11.43       | 24.82      | 10.72      | 10.85          | 5.00         | 11.46       | 25.25      | 11.00      | 11.43          |
| Antrim          | 40          | 100          |              | 4.01         | 10.61       | 22.26      | 10.20      | 10.29          | 4.39         | 10.32       | 22.10      | 9.97       | 10.29          |
| Ballylumford    | 40          | 100          | 45.6         | 10.07        | 24.39       | 60.27      | 22.68      | 29.05          | 11.60        | 27.98       | 70.31      | 26.70      | 34.97          |
| Ballymena       | 40          | 100          |              | 4.41         | 10.40       | 22.30      | 9.90       | 10.13          | 5.19         | 10.77       | 23.91      | 10.08      | 10.82          |
| Banbridge       | 18.4        | 46.8         |              | 3.97         | 6.63        | 13.88      | 6.39       | 6.44           | 5.04         | 6.50        | 14.35      | 6.36       | 6.59           |
| Ballyvally      | 40          | 100          | 45.6         | 4.34         | 17.27       | 36.91      | 16.32      | 16.36          | 4.30         | 15.35       | 32.73      | 14.81      | 14.86          |
| Ballynahinch    | 18.4        | 46.8         |              | 3.87         | 6.01        | 12.50      | 5.74       | 5.79           | 4.78         | 5.93        | 12.93      | 5.76       | 5.98           |
| Belfast Central | 31.5        | 79           |              | 7.38         | 16.79       | 39.71      | 15.34      | 16.46          | 4.64         | 19.65       | 42.61      | 18.37      | 19.78          |
| Belfast North   | 18.4        | 46.8         |              | 4.34         | 16.03       | 34.27      | 15.00      | 15.20          | 2.90         | 15.40       | 29.79      | 14.81      | 15.98          |
| Carmoney        | 31.5        | 79           | 45           | 3.54         | 9.05        | 18.44      | 8.68       | 8.73           | 4.29         | 8.81        | 18.78      | 8.59       | 8.82           |
| Castlereagh     | 31.5        | 79           | 33.5         | 10.18        | 21.78       | 53.89      | 19.46      | 23.97          | 10.89        | 27.50       | 68.60      | 25.13      | 30.92          |
| Coleraine       | 40          | 100          | 45.6         | 5.35         | 11.35       | 25.36      | 10.09      | 10.44          | 6.07         | 12.99       | 29.72      | 11.87      | 12.64          |
| Coolkeeragh     | 31.5        | 80           | 33.5         | 10.14        | 25.68       | 63.52      | 23.09      | 28.68          | 10.98        | 30.91       | 77.18      | 28.78      | 36.07          |
| Creagh          | 31.5        | 80           | 33.5         | 3.22         | 8.64        | 17.18      | 8.32       | 8.32           | 4.14         | 8.87        | 18.76      | 8.62       | 8.66           |
| Cregagh         | 26.2        | 65           |              | 8.22         | 19.18       | 46.12      | 17.32      | 19.32          | 6.33         | 23.16       | 53.40      | 21.42      | 23.49          |
| Donegall North  | 31.5        | 79           | 33.5         | 7.90         | 18.91       | 45.21      | 17.52      | 18.84          | 4.98         | 22.58       | 49.71      | 21.34      | 22.30          |
| Donegall South  |             |              |              | 5.36         | 13.88       | 31.01      | 13.08      | 13.26          | 4.54         | 14.56       | 31.42      | 14.01      | 14.35          |
| Drumnakelly     | 31.5        | 79           | 42.5         | 8.05         | 18.54       | 44.44      | 17.10      | 18.43          | 8.20         | 19.64       | 47.20      | 18.62      | 20.48          |
| Dungannon       | 40          | 100          | 45.6         | 6.56         | 14.98       | 34.75      | 14.14      | 14.78          | 7.24         | 15.05       | 35.49      | 14.42      | 15.65          |
| Eden            | 25          | 62.5         | 45           | 3.61         | 10.16       | 20.80      | 9.75       | 9.79           | 4.25         | 9.75        | 20.74      | 9.52       | 9.72           |
| Enniskillen     | 31.5        | 79           | 33.5         | 4.06         | 9.72        | 20.46      | 9.01       | 9.08           | 4.91         | 11.42       | 25.07      | 10.74      | 10.95          |
| Finaghy         | 31.5        | 79           |              | 9.18         | 19.63       | 47.93      | 18.15      | 20.23          | 6.14         | 24.33       | 55.77      | 22.91      | 24.30          |
| Glengormley     | 18.4        | 46.8         |              | 3.05         | 5.83        | 11.43      | 5.66       | 5.66           | 3.92         | 5.61        | 11.72      | 5.48       | 5.52           |

Table E-11 Northern Ireland Short Circuit Current Levels for Winter Peak 2021  
(Continued)

| Node          | Rating      |              |              | Three Phase  |             |            |            |                | Single Phase |             |            |            |                |
|---------------|-------------|--------------|--------------|--------------|-------------|------------|------------|----------------|--------------|-------------|------------|------------|----------------|
|               | RMS<br>[kA] | Peak<br>[kA] | Asym<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] | X/R<br>ratio | I''<br>[kA] | ip<br>[kA] | IB<br>[kA] | asym B<br>[kA] |
| 110kV         |             |              |              |              |             |            |            |                |              |             |            |            |                |
| Hannahstown   | 31.5        | 80           | 33.5         | 11.08        | 22.21       | 55.51      | 20.37      | 24.58          | 11.77        | 28.15       | 70.84      | 26.32      | 32.11          |
| Kells         | 40          | 100          | 45.6         | 8.78         | 25.34       | 61.52      | 23.47      | 27.78          | 9.09         | 31.50       | 76.81      | 28.80      | 34.88          |
| Killymallaght | 40          | 100          | 45           | 5.72         | 13.74       | 31.09      | 12.96      | 13.19          | 5.41         | 12.59       | 28.18      | 12.20      | 12.77          |
| Knock         | 18.4        | 46.8         |              | 4.06         | 17.75       | 37.35      | 16.13      | 16.26          | 2.76         | 17.17       | 32.78      | 16.20      | 17.20          |
| Larne         | 18.4        | 46.8         | 42.5         | 3.93         | 10.02       | 20.92      | 9.64       | 9.65           | 4.83         | 9.33        | 20.41      | 9.10       | 9.26           |
| Limavady      | 18.4        | 46.8         | 23           | 4.16         | 8.64        | 18.29      | 8.05       | 8.06           | 5.03         | 8.82        | 19.47      | 8.42       | 8.59           |
| Lisburn       | 18.4        | 46.8         | 23           | 6.07         | 13.51       | 30.91      | 12.77      | 13.07          | 6.03         | 12.59       | 28.77      | 12.18      | 12.80          |
| Lisaghmore    | 31.5        | 79           |              | 4.12         | 10.76       | 22.73      | 10.21      | 10.29          | 4.59         | 10.15       | 21.95      | 9.87       | 10.20          |
| Loguestown    | 26.2        | 65           |              | 4.09         | 7.31        | 15.42      | 6.72       | 6.78           | 4.80         | 7.57        | 16.53      | 7.14       | 7.34           |
| Magherakeel   | 40          | 100          | 45           | 5.54         | 4.60        | 10.34      | 4.41       | 4.62           | 6.98         | 4.95        | 11.61      | 4.79       | 5.15           |
| Newtownards   | 40          | 100          |              | 4.16         | 8.46        | 17.90      | 8.02       | 8.08           | 5.27         | 7.19        | 16.02      | 6.99       | 7.26           |
| Newry         | 18.4        | 46.8         | 23           | 4.05         | 5.77        | 12.14      | 5.50       | 5.59           | 5.05         | 5.64        | 12.46      | 5.48       | 5.78           |
| Omagh         | 40          | 100          | 42.5         | 5.16         | 17.30       | 38.36      | 15.86      | 16.23          | 5.50         | 17.77       | 39.90      | 16.54      | 17.42          |
| Omagh South   | 40          | 100          | 42.5         | 4.29         | 12.44       | 26.52      | 11.57      | 11.70          | 4.78         | 13.26       | 28.93      | 12.51      | 12.86          |
| Rathgael      | 26.2        | 65           |              | 3.86         | 6.45        | 13.42      | 6.15       | 6.20           | 4.76         | 6.35        | 13.85      | 6.16       | 6.38           |
| Rosebank      | 40          | 100          |              | 9.03         | 19.79       | 48.23      | 17.84      | 20.56          | 10.14        | 24.46       | 60.51      | 22.55      | 26.60          |
| Slieve Kirk   | 40          | 100          |              | 4.33         | 9.50        | 20.29      | 9.11       | 9.18           | 5.25         | 8.41        | 18.71      | 8.23       | 8.51           |
| Springtown    | 31.5        | 79           | 33.6         | 4.44         | 11.22       | 24.11      | 10.57      | 10.74          | 4.80         | 10.66       | 23.30      | 10.34      | 10.79          |
| Strabane      | 18.4        | 46.8         | 23           | 4.68         | 17.86       | 38.81      | 16.50      | 16.62          | 5.53         | 18.23       | 40.99      | 17.36      | 17.98          |
| Tandragee     | 31.5        | 79           | 33.5         | 11.11        | 21.97       | 54.93      | 20.08      | 24.58          | 12.17        | 25.88       | 65.35      | 24.25      | 30.16          |
| Tamnamore     | 40          | 100          | 45           | 9.79         | 20.24       | 49.84      | 19.00      | 23.23          | 10.48        | 22.40       | 55.62      | 21.25      | 26.15          |
| Waringstown   | 18.4        | 46.8         |              | 4.94         | 8.44        | 18.56      | 8.07       | 8.19           | 5.71         | 8.07        | 18.25      | 7.85       | 8.23           |



## APPENDIX F: ADDITIONAL INFORMATION ON OPPORTUNITIES

F.1 EirGrid Draft Approach to Consultation



The current. The future.

## Appendix F Additional Information on Opportunities

### F.1 EirGrid Draft Approach to Consultation

In November 2015 EirGrid launched Lines of Communication<sup>1</sup> which outlines our draft approach to consultation. It follows a review of our consultation activities after which we made a commitment to improve the way we engage with the public and stakeholders.

Lines of Communication outlines the way we develop our projects and how the public can engage with us at each stage of project development.

#### Project Development Status

For the purposes of the TYTFS project status is categorised as pre-planning, planning and approved. (In construction and complete are both subsets of approved.) Each project status category is detailed below. We will continue to participate and encourage public engagement at each project status stage, as per our consultation strategy.

1. Pre-planning – the need for the project is identified and consideration of solutions are formulated
2. Planning – outline design of preferred solutions
3. Approved – detailed design of preferred solution and project agreement (PA) with transmission asset owner (TAO) agreed
  - 3.1 In construction – procurement and construction of transmission assets/works
  - 3.2 Complete – commissioning and energisation of assets/works

---

<sup>1</sup> <http://www.eirgridgroup.com/site-files/library/EirGrid/Consultation-Summary.pdf>





## APPENDIX G: REFERENCES



The current. The future.

## Appendix G References

The following documents are referenced in All-Island Ten Year Transmission Forecast Statement 2015:

- Electricity Regulation Act, 1999. This act provides the regulatory framework for the introduction of competition in the generation and supply of electricity in Ireland. The Act provided for the establishment of the Commission for Energy Regulation (CER) (previously called the Commission for Electricity Regulation) and gave it the necessary powers to licence and regulate the generation, distribution, transmission and supply of electricity. Available on [www.cer.ie](http://www.cer.ie).
- Licence to Participate in the Transmission of Electricity Condition 33 requires SONI in consultation with the EirGrid, once every year to prepare a statement (in a form and based on methodologies approved by UREGNI showing, in respect of each of the seven succeeding financial years, circuit capacity, forecast electrical flows and loading on each part of the transmission system and fault levels for each transmission node.
- *All-Island Generation Capacity Statement, 2015-2024*. EirGrid and SONI issued this report in **February** 2015. Its main purpose is to inform market participants, regulatory agencies and policy makers of the likely minimum generation capacity required to achieve an adequate supply and demand balance for electricity for the period 2015 to 2024. Available on [www.eirgrid.com](http://www.eirgrid.com).
- EirGrid Grid **Code Version 5.0, October 2013**. The EirGrid Grid Code covers technical aspects relating to the operation and use of the transmission system, and to plant and apparatus connected to the transmission system or to the distribution system. Available on [www.eirgrid.com](http://www.eirgrid.com).
- The SONI Grid Code is designed to permit the development, maintenance and operation of an efficient, co-ordinated and economical Transmission System in Northern Ireland. The grid code is prepared by the TSO (SONI) pursuant to condition 16 of SONI's Licence. The SONI Grid Code is available at [www.soni.ltd.uk](http://www.soni.ltd.uk)

- Transmission Planning Criteria, October 1998. This document sets out the technical standards by which the adequacy of the grid is determined. Available on [www.eirgrid.com](http://www.eirgrid.com).
- Statutory Instrument no. 445. These Regulations give legal effect to Directive No. 96/92/EC of the European Parliament and of the Council of 19<sup>th</sup> December 1996, concerning common rules for the internal market in electricity, not already implemented by the Electricity Regulation Act, 1999, by providing for the designation of a Transmission System Operator, the designation of a Distribution System Operator, and the unbundling of the accounts of electricity undertakings, and other matters. Available on [www.cer.ie](http://www.cer.ie).
- TSO Licence. On June 29<sup>th</sup> 2006, the CER issued a Transmission System Operator (TSO) Licence to EirGrid plc. pursuant to Section 14(1)(e) of the Electricity Regulation Act, 1999, as inserted by Regulation 32 of S.I. No. 445 of 2000 – European Communities (Internal Market in Electricity) Regulations 2001.
- *Delivering a Sustainable Energy Future for Ireland*. Government White Paper on energy policy out to 2020, published by the Department of Communications, Marine and Natural Resources in March 2007.
- *Treatment of Curtailment in Tie Break Situations*. Single Electricity Market (SEM) decision paper (SEM-13-010) in relation to the treatment of curtailment in tie break situations.


Table G-1: Northern Ireland Licence (System and Security) Standards - References

| Document | Description  |
|----------|--|
| ER P2/5  | Security of Supply, dated October 1978, and NIE amendment sheet Issue 2, dated 7 <sup>th</sup> August 1992.  |
| PLM-SP-1 | Planning Standards of Security for the Connection of Generating Stations to the System Issue 1, dated 1975, and NIE amendment sheet Issue 2, dated 7 <sup>th</sup> August 1992.        |
| PLM-ST-4 | CEGB Criteria for System Transient Stability Studies Issue 1, dated September 1975, and NIE amendment sheet Issue 2, dated 7 <sup>th</sup> August 1992.                                |
| PLM-ST-9 | Voltage Criteria for the Design of 400 kV and 275 kV Supergrid System Issue 1, date 1 <sup>st</sup> December 1985, and NIE amendment sheet Issue 2, dated 7 <sup>th</sup> August 1992. |
| ER-P28   | Planning Limits for Voltage Fluctuations.  |
| ER-P16   | EHV or HV Supplies to Induction Furnaces.  |
| ER-P29   | Planning Limits for Voltage Unbalance.   |
| ER-G5/3  | Limits for Harmonics (To be replaced by ER-G5/4 following UK practice and in conjunction with a joint review with EirGrid).  |
| EPM-1    | Operational Standards of Security and Supply, dated November 2004.   |



## APPENDIX H: POWER FLOW DIAGRAMS

### H.1 Guide to the Power Flow Diagrams



The current. The future.

## Appendix H Power Flow Diagrams

This appendix presents power flow diagrams for the following cases:




- Figure I-1 Summer Night Valley 2015,
- Figure I-2 Summer Peak 2015,
- Figure I-3 Winter Peak 2015,
- Figure I-4 Summer Night Valley 2024,
- Figure I-5 Summer Peak 2024,
- Figure I-6 Winter Peak 2024,

Note that summer cases cover the period between May and August and winter cases cover the period between November and February. As such, the layout of the network in the power flow diagrams may not feature all projects listed in Appendix B for a particular year as these are listed on a yearly basis.

### H.1 Guide to the Power Flow Diagrams

Different colours represent each of the voltage levels:

- 400 kV red
- 275 kV blue
- 220 kV green
- 110 kV black

Generation (>5MW) connected at each bus is shown beside a  symbol, with the generation dispatched in MW shown beside the symbol. Embedded generation is shown at the transmission bus to which it is connected through the distribution system. The East–West interconnector is denoted by a  symbol and the Moyle interconnector is denoted by a  symbol. The magnitude of the power on the interconnectors is given beneath the symbol in MW.

There are two values shown at both ends of each circuit. The value above the line is the MW flow and the value below the line is the Mvar flow. A positive value indicates that the direction of flow is away from the bus; a negative value, towards the bus.




Figure I-1 Power Flow Diagram Summer Night Valley 2015




Figure I-2 Power Flow Diagram Summer Peak 2015




Figure I-3 Power Flow Diagram Winter Peak 2015






Figure I-4 Power Flow Diagram Summer Night Valley 2024




Figure I-5 Power Flow Diagram Summer Peak 2024




Figure I-6 Power Flow Diagram Winter Peak 2024





EirGrid plc  
The Oval  
160 Shelbourne Road  
Ballsbridge  
Dublin 4  
Tel: +353 (0)1 677 1700  
Fax: +353 (0)1 661 5375  
[www.eirgrid.com](http://www.eirgrid.com)



SONI Ltd  
Castlereagh House  
12 Manse Road  
Belfast  
BT6 9RT  
Tel: +44 (0)28 9079 4336  
Fax: +44 (0)28 9070 7560  
[www.soni.ltd.uk](http://www.soni.ltd.uk)