



# DS3 Programme Workshop

## Industry Forum

1<sup>st</sup> February 2016, Dublin



# Agenda

DS3 PROGRAMME		
Time	Agenda Item	Speaker
14:00-14:05	<b>Introduction</b>	Chair: Louis Fisher (5min)
14:05-14:35	<b>DS3 Programme Status Update</b> <ul style="list-style-type: none"> <li>• 2016 focus areas</li> <li>• SNSP Studies / Trial</li> </ul>	Presentation: David Cashman (20 mins)
	<b>Questions and Answers</b>	Chair: Louis Fisher (10 min)
14:35-15:55	<b>Rate of Change of Frequency</b> (General Update)	Presentation: David Cashman (20 min)
	<b>Rate of Change of Frequency</b> (RoCoF Alternatives Technical Presentation)	Presentation: Martin Eager (40 min)
	<b>Questions &amp; Answers</b>	Chair: Louis Fisher (20 min)
15:55-16:00	<b>Closing Remarks</b>	Chair: Louis Fisher (5 min)


# DS3 Programme Status Update

**David Cashman**




# Increase of SNSP to 55% - System Trial

- Builds on the policies and tools brought through the OPR Committee
- Will inform future operational policy



# SNSP Trial – Real Time Experience




# SNSP Trial - Enablers

- Ramping Tool
- Frequency Regulation
- RCUC – RoCoF/Inertia
- WSAT transfers
- High Frequency Analysis
- Etc.




Windfarms With/Without Operational Certificates




# Observations and Next Steps

- SNSP above 50% for 10% of the time
- No observed differences in system behavior at  $50\% < \text{SNSP} < 55\%$
- Analysis of events are ongoing and expected to end Q1 2016
- Further development in operational metrics



# Operational Policies & Related Studies

- Voltage dip induced frequency dip (on-going)
- Voltage trajectory studies (on-going)
- Interim HVDC export limits analysis (on-going)
- Cauteen Nodal Voltage Control Pilot Project (on-going)
- Northern Ireland “smart” voltage control (almost complete)
- Quantitative frequency oscillation analysis (almost complete)
- Report on windfarm frequency response tests (almost complete)



**Operational Policy  
Review Committee**

# Control Centre Tools



Dublin



Belfast



Integrated  
EMSs


The screenshot displays the ABB Grid Control System (GCS) interface. It features several panels:

- SYSTEM OVERVIEW:** Shows system status with columns for Unit, Type, and Status. Includes sections for DECLARATIONS, ACCEPTED INSTRUCTIONS, and ISSUED INSTRUCTIONS.
- RCUC Output Summary for EirGrid:** A large table with columns for Unit, Date, Time, and various numerical values representing system outputs.
- NEW INSTRUCTIONS:** A table for managing new instructions with columns for Unit, Type, Entered, and Status.

The interface includes navigation menus, search bars, and a status bar at the bottom indicating 'ONLINE (NCS)'.

System Services


# Smart Voltage Control



- Realise potential of DSO generation to avoid transmission network reinforcements
- IE: Progress continues on Cauten Nodal Voltage Control Pilot Project
- NI: Study investigating Smart power factor for embedded WFs

# DSM – Residential DSM Scheme

Have a residential consumer based demand response project in operation in 2016



# 2016 Focus Areas

## RoCoF

- Generator Studies
- TSO-DSO project
- Alternatives Report close out

## System Services

- Interim Arrangements: Q4 2016
- Enduring Arrangements: Q4 2017

## Operational Policy

- Voltage dip induced frequency dips
- Grid Code
- High Wind Speed Shut-Down
- Operational Metrics: Fast Frequency Response

## Control Centre Tools


- EMS Integration Project
- System Services Tools
- Off-line WSAT

# RoCoF Project Overview


**David Cashman**




# RoCoF Concept




# RoCoF TSO-DSO Project




# RoCoF TSO-DSO Project




# RoCoF Implementation Project



# Generator Studies Timelines



# RoCoF Remuneration Method



# RoCoF Remuneration - Next Steps

- 6-week consultation on Remuneration paper currently in progress
- Industry comments up to February 8<sup>th</sup>
- SEMC review March/April
- TSO workshop early March
- Remuneration Mechanism to apply from June 1<sup>st</sup> 2016
- Payments back-dated to March 2016 for early submissions

# TSO-DSO Project: Ireland

## DSO Wind

- Requests for protection settings changes issued
- Roll-out of changes on wind farms is continuing
- DSO have provided database of settings to TSO

## Embedded non-wind generation

- D-code modification tabled and agreed in principle
- Meetings with representatives to assess impact on existing fleet
- DSO have provided indicative volumes of generation to TSO
- TSO to perform impact assessment studies based on these volumes

# TSO-DSO Project: Northern Ireland


## Large-scale generation

- Studies to be completed by Q2 with NIE review by Q3 2016
- Commence Roll-out of LoM protection settings Q3 2016
- All large-scale generators have new settings Q3 2017

## Small-scale generation

- D-code modification consulted on and currently under review
- Studies to commence Q2 2016
- Commence Roll-out of LoM protection settings Q4 2016
- All small-scale generators have new settings Q3 2017

# RoCoF Alternatives Objective



# Phase 1 Review

## Highlights

- Both Synchronous and synthetic inertia can provide solutions to RoCoF
- Weighted Scoring Matrix did not favour any specific solution
- Event Detection essential for synthetic devices
- A combination of devices may be required to resolve RoCoF

# Phase 2 Overview

## Synchronous Inertia

- 20,000 MW.s required to maintain RoCoF

## Synthetic Inertia

- Begin to respond within 100 ms
- Ramp to full output in 200 ms
- Control for recovery
- +/- 360 MW

## Combination

- Sensitive to synthetic device performance

# Study Conclusions

- Alternative Solutions are available for the RoCoF issue
- Further analysis required to implement alternatives project
- RoCoF Alternatives Solutions is 'back-up' to primary RoCoF Project and not a procurement exercise
- Generator Studies and TSO-DSO projects progressing
- TSOs welcome feedback on report from industry

# Timelines

Dec. 2015

- RoCoF Alternatives Phase 2 Report

1<sup>st</sup> Feb 2016

- DS3 Industry Forum


19<sup>th</sup> February  
2016

- Submission of industry comments

End March  
2016

- Publication of Final Report

# RoCoF Project Summary




# RoCoF Alternative & Complementary Solutions Phase 2 Study

**Martin Eager**



# RoCoF Phase 2 Outline

- Determine the extra volume of synchronous and/or synthetic inertia to maintain RoCoF within 0.5Hz/s and allow 75% SNSP
- 3 Cases investigated:



# Base Case Generation

Property	Value
SNSP	75 %
RoCoF	1.0 Hz/s
Moyle Interconnector	Import 450 MW / Export 80 MW
East-West Interconnector	Import 500 MW / Export 500 MW
Installed Large Scale Wind Capacity	4732 MW
Number of Must Run Units	Existing constraint disabled
Second North-South Line	In service
Frequency Reserve	Existing constraints disabled

# Acceptance criteria

- A scenario is deemed acceptable if:
  - RoCoF is within  $\pm 0.5$  Hz/s (measured over 500 ms) in 99% of the solved cases following an N-1 event.

# Study Process Flow

Techno-economic studies

Create Power-flows for Basecase

Dynamic Studies

Check Compliance

Results

Increase inertia in scenario (if available)

Approx. 8 million simulations

# Techno Economic Studies



# Techno Economic Studies – Constraints

Techno-economic scenario	Constraints			
	SNSP (%)	RoCoF (Hz/s)	P Min (%)	POR / SOR (% of LSI)
A	75	0.5	Existing limit	-
B			35	-
C			Existing limit	75
D			35	75
E		1	Existing limit	-
F			35	-
G			Existing limit	75
H			35	75

0.5 Hz/s constraint ⇒

System inertia > 20,000MW.s for most the year

Pmin at 35% ⇒

No material impact on the no. of large units dispatched

Reserve constraint ⇒

Equivalent to adding another large unit


Technical simulations will be based on Case E

# Base Case Studies



# Base Case Studies



Approximately 60% of the hours of the year require supplementary inertia within 200ms – 500ms.



# Synchronous Inertia Studies



# Synchronous Inertia Model




20,000MW.s of system inertia required to maintain RoCoF.

Approx. 12,000 MWs of supplementary synchronous inertia is required by the Base Case to meet the acceptance criteria.

# Synthetic Inertia Studies





# Synthetic Inertia Model



# Synthetic Inertia Model

## Frequency triggered – Step response





A trigger of 49.8Hz does not meet the acceptance criteria.

A trigger of 49.9Hz with a step injection of 360MW may meet the criteria but would lead to over-providing active power following small frequency excursions.

# Synthetic Inertia Model



## Time triggered – Step response



To met the acceptance criteria synthetic devices should respond within 100 ms of the event and ramp to full output in 200 ms of the initial device response.

# Synthetic Inertia Model


Step triggered at 49.8Hz followed by droop controlled recovery



A fast initial response maintains initial RoCoF within 0.5Hz/s, while a droop controlled recovery resolves unintended frequency recovery issues.

# Combined sync. & synthetic inertia

**Synthetic inertia injects a step response at 49.8Hz**



The combination results are found to deliver a solution where the different devices responses can complement each other.

Results are highly depend on the synthetic inertia characteristics.

# Key Findings

## Synchronous Inertia

- 20,000 MW.s required to maintain RoCoF
- 12,000 MW.s was added to Base Case

## Synthetic Inertia

- Begin to respond within 100 ms
- Ramp to full output in 200 ms
- Control for recovery
- +/- 360 MW

## Combination

- Sensitive to synthetic device performance

# Closing Remarks and Actions

**Louis Fisher**

