

Introduction

DS3 Industry Forum
4th June 2015

Louis Fisher



Agenda

Time	Agenda Item	Speaker
10:00-10:05	Introduction	Chair: Louis Fisher
10:05- 11:05	DS3 Programme Status Update	Presentation: Robbie Aherne
	Regulatory Authorities Update	Presentation: Andrew McCorrison
	Questions and Answers	Chair: Louis Fisher
11:05-12:15	Rate of Change of Frequency (RoCoF)	Presentation: David Cashman Presentation: Tony Hearne
	System Services	Presentation: Eoin Kennedy
	Questions and Answers	Chair: Louis Fisher
12:15-12:55	Operational Policies <ul style="list-style-type: none"> • VDIFD • Frequency Regulation 	Presentation: Lisa McMullan Presentation: Norman Watson
	Control Centre Tools	Presentation: Michael Burke
	Questions & Answers	Chair: Louis Fisher
12:55-13:00	Closing Remarks	Chair: Louis Fisher



DS3 Programme Status Update

DS3 Industry Forum
4th June 2015

Robbie Aherne



Recent Operational Experience



High Wind Levels in Early 2015

Chart 1: SNSP %





Chart 2: Wind as % of Demand



System Non-Synchronous Penetration (SNSP) was regularly hitting the 50% limit

... at times exports allow wind levels greater than 50% of demand




$$\text{SNSP} = \frac{\text{Wind} + \text{Imports}}{\text{Demand} + \text{Exports}}$$


DS3 Programme



DS3 – Shaping the System of the Future




System Non-Synchronous Penetration



$$\text{SNSP} = \frac{\text{Wind + Imports}}{\text{Demand + Exports}}$$




DS3 System Services Products



Frequency Related Products

Transient Voltage Response



Voltage Related Products

NEW

- Synchronous Inertial Response
- Fast Frequency Response
- Fast Post-Fault Active Power Recovery
- Ramping Margin 1,3,8 hrs


NEW

- Dynamic Reactive Power




System Services

- System Services Project Plan published on 20/05/2015 – published as a three-entity branded document
- TSO Procurement Strategy document published on 03/06/2015 – “living document”



Rate of Change of Frequency (RoCoF) Concept



RoCoF Implementation Project

Plan A: Move to 1 Hz/s over 500ms

Generator Studies Project

TSO-DSO Implementation Project

Plan B: Stay at 0.5 Hz/s

Alternative / Complementary Solutions Project

Can synchronous generators ride through a high RoCoF event?

Great Island GI4 ✓

Can DSOs protect against islanding using different settings or measures to RoCoF?


Can embedded synchronous generators ride through a high RoCoF event?

Investigate and, if appropriate, propose alternatives

Complements requirements for System Services



Realising Potential of Embedded Generation




Established TSO-DSO Governance Arrangements for DS3

Key Issues:

- RoCoF protection setting for island detection – critical to moving standard
- Use of embedded generation for voltage and frequency control
- Impact of active generation / demand on DSO operations and network security

DSM Rapidly Evolving and Growing....



DSM Growth....A Balancing Challenge

Consumer & DSM

Trust, data privacy,
cyber security,
solid commercial
foundation




Power System

Flexibility
requirements,
TSO and DSO
secure
operation,
performance
monitoring




Operational Policies & Related Studies

- Automated Dynamic Studies Tool (operational)
- Frequency regulation (complete)
- Voltage dip induced frequency dip (on-going)
- Quantitative frequency oscillation analysis (on-going)
- Provision of static frequency response (on-going)
- High frequency mitigation analysis (on-going)
- Cauteen Nodal Voltage Control Pilot Project (on-going)
- Northern Ireland Nodal Voltage Control Pilot Project (on hold)



Operational Policy Review Committee




EWIC Export Limit

EWIC Interconnector	MW	B	-526 <MW< 504 Current restriction is -300<MW <504	EWIC Interconnector	This applies to all units registered as EWIC Interconnector units. It ensures that all flows do not exceed an import of 504MW to Ireland and an export of 526MW to UK (values taken from Portan). This is required to ensure that the limits are respected. Current restriction is due to a high frequency limit on the island.
---------------------	----	---	--	---------------------	--

- Largest single out-feed – mitigate potential for high frequency event
- Market flows are unaffected
- High frequency mitigation studies underway (summer)
- Long term: Over Frequency Generation Setting Schedule (studies underway to define)

System Oscillation




1. TSOs frequency oscillation quantitative analysis
2. Alstom(a) frequency oscillation quantitative analysis and (b) “diagnosis and recommendation” report



Control Centre Tools

- WSAT voltage stability transfers (complete)
- Ramping tool and policy (triallying)
- Short circuit tool (triallying)
- EMS integration project (on-going)



**Existing Control
Centre Tools**

2011

Tools Delivered

**WSAT, Short Circuit,
Wind Dispatch,
Synchrophasor....**

2012 - 2015

New Tools

**Regulation, Ramping, Voltage
Trajectory, WSAT Look ahead,
System Services....**


2015 - 2017



Summary




Operational Capability Outlook



Complements 2015 workstream plans

Complementary Progress Essential



DS3 Programme Summary

- RoCoF workstreams progressing
- System Services underway but significant design and implementation issues need to be worked through
- Need to maximise contribution from embedded generation and demand side response – DSO/DNO collaboration key
- Operational policies and tools need to develop in parallel in a considered manner





Regulatory Authorities Update

DS3 Industry Forum
4th June 2015




DS3:

Delivering a Secure, Sustainable Electricity System


RA Update – DS3 Industry Forum

4th June 2015


New Arrangements - 2017



Our Focus: Consumer's Interests



Ramping Renewable Utilisation



Evolving Policy

- DETINI Consultation on CfD Implementation in Northern Ireland may remove 40% NI renewable target
 - Utility Regulator’s early view:
 - DS3 programme would likely remain a positive value proposition for NI consumers
 - SNSP is ‘clipping’ at 50% today; benefits of increasing it are measurable now, at only 20% penetration (Cal 2014)
 - Pragmatic, contextual management of procured System Service Volumes, particularly during ramp (2017 – 2019) can ensure value for money

Evolving Policy

- Workstream Interaction with ETA, CRM:
 - Consumer's interests are promoted when market arrangements are clear and bolt together smoothly in both design and implementation
 - The SEM Committee have instructed all three projects to co-ordinate their activities: total consumer impact takes precedence over outcomes in any one area
 - Opportunities to leverage and combine project milestones are currently being explored
 - Some depth to this area; further liaison will be required with TSOs and stakeholders where specific combining of work or deliverables is identified

Rate of Change of Frequency Update

DS3 Industry Forum
4th June 2015

David Cashman



Presentation Overview

- Updates on status of three key workstreams
- Generator Studies Project
- TSO-DSO Implementation Project
- Alternative / Complementary Solutions Project



RoCoF Implementation Project

Generator Studies
Project

TSO-DSO
Implementation
Project

Alternative /
Complementary
Solutions Project

Timeline Update

- Project start date: 21st Nov 2014
- 6 months since beginning of project



Generation Studies Project

- All phase 1 Generators have commenced project
- CER and SONI quarterly updates published
 - Ireland: 24 Green status and 6 Amber
 - Northern Ireland: 4 Green status and 2 Amber
- Currently all phase 1 generators in IE and NI are on track to conclude by May 2016
- One generator (GI4) has declared compliance to the new standard
- Meetings with generators and OEMs scheduled for June



TSO-DSO Implementation Project

- Managed through existing TSO-DSO governance structure
- Ongoing bi-lateral TSO-DSO meetings taking place
- Loss of Mains (LoM) protection setting change process initiated by DSOs



TSO-DSO Implementation Project

- Ireland:
 - ESNB to finalise frequency injection bench testing of RoCoF relays imminently
 - Settings change requests issued to generators through User Questionnaire form
 - Engagement with embedded generators on RoCoF withstand capability through DCRP
 - Database of Distribution connected settings currently being compiled
- Northern Ireland
 - RoCoF project timelines for settings changes revised based on NIE projections
 - Current plan is to assess the impact of G59 rev 3 setting changes in advance of implementing 1 Hz/s settings
 - Database of settings for distribution connected wind generation has been compiled and work is ongoing to obtain embedded generation settings and volumes
 - Modification of Distribution Code for RoCoF requirements for embedded generators > 100 kW approved



Alternative / Complementary Solutions Project

- Joint project by TSOs
- Communication with industry via DS3 Advisory Council and website/email

Phase 1

- Range of theoretical options assessed at a high level
- Subset of viable options selected for Phase 2 analysis

Phase 2

- More detailed review of the selected options from Phase 1
- Analysis focused on technical and economic aspects of options



Phase 1 Assessment On-going

- DNV GL appointed end of March and due to conclude end June
- Analysis to date:
 - Assessment of non-synchronous device capability to provide RoCoF mitigation
 - Investigation of RoCoF detection methodologies and response times of devices
- Current analysis:
 - High level appraisals of technology types using 'Faceplate' templates
 - Comparison of technology types




Phase 1 Next Steps

- Finalize technology assessments
- Draft final report including technology appraisal and assessment of Non-synchronous device capability
- Publish for industry comment – End June 2015
- 2 Week response time for industry comment



Phase 2 Overview



- More detailed analysis likely including technical and economic studies of shortlisted options:
 - Dynamic simulations
 - Plexos studies
- Due to commence July 2015 with publication of draft results by December 2015
- Industry comment by Q1 2016

Summary

- Generator Studies project progressing and broadly on schedule
- Loss-of-Mains protection setting change process initiated with DSOs
- NI timelines for LoM changes revised based on NIE advice
- Alternative / Complementary Solutions project Phase 1 report due in June
- Alternative / Complementary Solutions project Phase 2 to commence in July







NETWORKS

DS3 Industry Forum ESBN Update

Tony Hearne

4th June 2015

Reactive Power / Voltage Control update

- **Distribution Code DS3 (Reactive Power) Modifications**
- **Analogue Output capability integration with DCC SCADA**
- **WFPS Reactive Power Capability & Control Test Procedure – Type B $\geq 5\text{MW}$**
- **Reactive Power / Voltage Control Nodal Controller Pilot – Cauten Cluster**

ROCOF update

- **Interface Relay Tests**
- **Questionnaire and Settings Change**
- **Alternative LoM Protection**

Conclusion

Reactive Power / Voltage Control Update



The following DS3 modifications were approved by the CER with an effective date of 08 October 2013:

MP 22 – DS3 Fault Ride Through

MP 23 – DS3 Reactive Power Voltage Control

More recently the following related clarification modifications were approved by the CER with an effective date of 23 February 2015:

MP 31 – Fault Ride Through

MP 32 – Voltage Regulation

MP 33 – Voltage Step Change

Historically DCC SCADA did not require AO capability. However, the recently mandated new DS3 reactive power control modes have necessitated the integration of AO capability with DCC SCADA.

ESBN has recently successfully performed a FAT and a SAT (at Leopardstown Road).

ESBN is currently organising a site test at Cauteen after which this new capability will be rolled out to all Type B ≥ 5 MW WFPSs.

ESBN is working with EirGrid on the above-mentioned test procedure which is now near completion and ready for trial.

It is planned to trail this new test procedure at the Cauteen Cluster.

In addition to the test procedure ESBN is also working with EirGrid on the associated business processes which will be required to coordinate the testing between the DSO, TSO and IPP.

Furthermore ESBN has developed the necessary in-house business processes and training material required for this testing.

Nodal Controller Pilot – Cauteen Cluster



A formal project has been initiated within ESN.

The high-level functionality has been agreed between ESN and EirGrid and we are currently working through the lower-level details.

A software simulator with load-flow has been developed which is being used to inform these design decisions.

The hardware design of the Nodal Controller has been concluded.

The pre-requisite communications infrastructure has progressed to the detailed design phase and will be installed at Cauteen imminently.


The participating IPPs have been engaged.

ROCOF Update



Relay 'X' MW connections

- Difficulty testing relay
- This relay represents a significant percentage of MW connections
- Issues a trip signal for all traces provided by EirGrid
- Working with manufactures to resolve problem



Wind Generators

- Instruction to change settings resent to all Wind Farm contacts
- Discussions held with larger developers
- Most will change setting over the coming months

Non-Wind 0 MEC Generators

- Meeting held with stakeholders of non-wind embedded generators
- Instruction to change interface settings sent
- Issues with new voltage settings and FRT capability

Appendix 1

New relay settings to be applied

Instruction / Authorization to change settings

You the customer, or agent appointed to act on your behalf, are hereby instructed and authorized to give effect to the following change to Interface Protection settings unless such settings are already in place. It is understood that in doing so, you may have to break some or all erected by ESB on the relay. It is hereby confirmed that in order to break these relays if necessary.

Your cooperation in this matter is appreciated.

New RoCoF Settings

Please use the drop-down list to populate the generator characteristic on your site. If appropriate apply the new RoCoF setting as indicated in the table below.

Generator Characteristic: (Please use drop-down list)

Max setting to be applied	
	2 Hz/s
	0.5 Hz/s

**** If the above RoCoF settings are not achievable by the relay, please indicate the actual values applied in Appendix 2**

New Under/Over Frequency Settings

Please state the number of Frequency protection stages the relay is capable of and apply the settings as indicated in the table below.

One or Two Stage Relay Protection: (Please use drop-down list)

New Frequency Settings to be Applied		
Stage 1	Under-frequency	47 Hz
	Time	0.5 Hz/s
	Over-frequency	52.5 Hz
Stage 2	Under-frequency	47.5 Hz
	Time	20 Hz/s
	Over-frequency	55 Hz

New Under/Over Voltage Settings

Please state the number of Voltage protection stages the relay is capable of and apply the settings as indicated in the table below.

Nominal Voltage at the point of connection: (Please use drop-down list)

One or Two Stage Relay Protection:

New Voltage Setting to be Applied		
Stage 1	Under-voltage	1.3 [kV]
	Time	0.5 Hz/s
	Over-voltage	11.8 [kV]
Stage 2	Under-voltage	0.7 [kV]
	Time	3 Hz/s
	Over-voltage	11.8 [kV]

**** If the present Over voltage settings are higher or the specified under or over-voltage settings cannot be accommodated on the relay, please**

Please confirm generator protection selectivity with interface protection setting

Confirmation of change

For numerical relays, please attach as copy of the relay settings file, with any changes reflected and confirm that the settings have been changed to the new values specified above.

I hereby confirm that the data indicated reflects the settings applied at this site and where appropriate, that new settings as detailed above, have been applied.

Name: _____


Capacity / Title / Role: _____

Page 1

Alternative LoM Protection

- Where a RoCoF setting of 1Hz/s cannot be applied, alternative LoM protection maybe required
- Selection of Alternative LoM Solutions being explored are:

1. **Supervised RoCoF:** G10 type relay monitors the Transmission system voltage, in the event of a disturbance a blocking signal is sent to a local network G10 relay inhibiting operation. **Trial Project due to begin in coming weeks.**
2. **And RoCoF & Vector Shift:** The relay needs to see both a RoCoF and Vector Shift to initiate a trip signal. This may reduce the sensitivity of relays to grid disturbances. Studies required.
3. **Exchange Relay:** This option will be informed by analysing of the installed fleet of G10 relays. Early indications show that some relays maybe not operate for the sample traces provided by EirGrid using a RoCoF setting of 0.6Hz/s.



**Thanks for Listening
Questions?**

DS3 System Services

DS3 Industry Forum
4th June 2015

Eoin Kennedy




Presentation Overview

- TSO Procurement Strategy
- Project Plan
- I-SEM Interaction
- Stakeholder Engagement
- Next Steps
- Key Messages



System Services Decision



Prepared for all 14 services and in place by Oct 2016


- “Cost-plus” based on a Best New Entrant (BNE) model or similar
- TSO consultations on tariff methodology and resulting tariffs

Allows for

- Early implementation of System Services
- Capability of current fleet to be revealed



Timeline



TSO Procurement Strategy



TSO Procurement Strategy

- “Living” document
- Draft version published on 3rd June provides a good indication of the likely structure and content of the enduring document
- Will be updated periodically during the course of the Implementation Project as decisions are made and key design aspects become clearer

Table of Contents

PART A: Introduction

PART B: TSOs’ Approach to Implementation of DS3 System Services Procurement Design

PART C: DS3 System Service Product Descriptions

PART D: Scenarios and Volumes for DS3 System Services

PART E: Long Term Contracts

PART F: Qualification Process

PART G: Assessment Principles for DS3 System Services Procurement

PART H: Auction and Tariff Implementation Principles

PART I: Information Provision

APPENDIX A: Product Description



DS3 System Services
Draft TSO Procurement Strategy

Dated: 2/5/2015

Project Plan



Workstreams

WS1
Regulated Tariffs

WS2
System Services
Volumes

WS3
Qualification
Process Design

WS4
Auction Design

WS5
Contract Design

WS6
Product Design
and I-SEM


Workstreams
proposed by
SEMC

WS7
TSO Operational
Readiness

- Settlement
- Codes
- Control Centre Tools
- Financial
- System Services Performance Monitoring Infrastructure
- Training and Industry Communications
- Project Management
- Other Operational Readiness Activities




WS1 – Regulated Tariffs



No.	Consultation	Responsible Party	Date
C.3	Methodology for Regulated Tariffs	TSOs	Sept/Oct 2015
C.11	BNE Model and Interim Regulated Tariffs	TSOs	Mar/Apr 2016
C.12	BNE Model, Volumes and Regulated Tariffs	TSOs	Apr/May 2017




WS2 – System Services Volumes



No.	Consultation	Responsible Party	Date
C.1	Scenarios for Volume Calculation	TSOs	Jul/Aug 2015
C.2	Volume Calculation Methodology	TSOs	Jul/Aug 2015
C.9	Volume Analysis Results	TSOs	Feb/Mar 2016




WS3 – Qualification Process Design



No.	Consultation	Responsible Party	Date
C.4	Qualification Criteria and Other Requirements	SEMC	Sept/Oct 2015
C.5	"Competition Metrics"	SEMC	Sept/Oct 2015


WS4 – Auction Design



No.	Consultation	Responsible Party	Date
C.6	Detailed Design of Auction	SEMC	Sept/Oct 2015




WS5 – Contract Design



No.	Consultation	Responsible Party	Date
C.7	Contractual Principles	SEMC	Sept/Oct 2015
C.10	Proposed Template Contract	TSOs	Jan/Feb 2016




WS6 – Product Design and I-SEM



No.	Consultation	Responsible Party	Date
C.8	Scalar / Performance Monitoring Methodology and Enduring Process	TSOs	Sept/Oct 2015



WS7 – TSO Operational Readiness



Summary of Consultations

No.	Consultation	Responsible Party	Date
C.1	Scenarios for Volume Calculation	TSOs	Jul/Aug 2015
C.2	Volume Calculation Methodology	TSOs	Jul/Aug 2015
C.3	Methodology for Regulated Tariffs	TSOs	Sept/Oct 2015
C.4	Qualification Criteria and Other Requirements	SEMC	Sept/Oct 2015
C.5	“Competition Metrics”	SEMC	Sept/Oct 2015
C.6	Detailed Design of Auction	SEMC	Sept/Oct 2015
C.7	Contractual Principles	SEMC	Sept/Oct 2015
C.8	Scalar / Performance Monitoring Methodology and Enduring Process	TSOs	Sept/Oct 2015
C.9	Volume Analysis Results	TSOs	Feb/Mar 2016
C.10	Proposed Template Contract	TSOs	Jan/Feb 2016
C.11	BNE Model and Interim Regulated Tariffs	TSOs	Mar/Apr 2016
C.12	BNE Model, Volumes and Regulated Tariffs	TSOs	Apr/May 2017



Note: Further consultations will be required as part of TSOs’ operational readiness activities

Design and Implementation

- Decision introduces complex design issues
- Key design challenges are the Auction and BNE tariff methodology
- Techno-economic consultancy support and expertise being engaged to assist with the principles and methodologies of these particular design aspects
- After that work, we will be in a better position to validate those aspects of the implementation plan



IS Aspects

- Significant level of IS development required to enable successful delivery and enduring operation of the DS3 System Services arrangements
- TSOs are working to develop greater certainty on the timelines and costs

Settlement
System

Auction
Platform

Performance
Monitoring
and Testing

Scarcity Scalar

Operational
Tools



Implementation

- Implementation work is underway with first consultations planned for summer 2015

Example: Volume Calculation

- Development of the following is progressing well:
 - Principles for creating service provider portfolios
 - Principles/methodology for how to calculate volumes
 - Assumptions used to calculate volumes



I-SEM Interaction



I-SEM Interaction

Design

- E.g. Balancing arrangements

Delivery

- E.g. Timing of consultations
- E.g. Timing of DS3 and CRM auctions

- Quarterly working level meetings between TSOs-RA's DS3 and I-SEM teams to ensure alignment



Stakeholder Engagement




Approach to Consultations

- Aim is to engage and consult with stakeholders to greatest extent practicable
- Consultations will need to be overlapped – may be issued in batches
- Need to balance duration of consultation periods with overall delivery timelines
- 6 week periods allowed for in project plan but may decide to lengthen/shorten depending on importance/complexity of issues




TSO-led Consultations



Note: Where the TSOs have limited involvement in the development of the proposals being consulted on, the consultation will follow the established regulatory process

Interaction with Stakeholders

- Transparent structured approach to engagement necessary
- Communication with stakeholders via consultations and industry forums/workshops (e.g. workshop shortly after opening a consultation)
- May provide opportunity for bilateral meetings during consultation (or batch of consultations) e.g. time set aside for meetings with slots allocated on a first come basis
- Communication on implementation progress and other matters via the DS3 website and email



Example timeline assuming 6 week consultation period

Next Steps




Next Steps

- Techno-economic consultancy support and expertise due to be appointed the week beginning 8th June
- Develop greater certainty on the timelines for IT systems
- Continue to undertake implementation work



Summary of Approach in 2015



Key Messages

- Draft TSO Procurement Strategy and Draft Project Plan published
- Techno-economic consultancy support and expertise being engaged to assist with principles and methodologies of challenging design aspects
- Project Plan will be “firmed up” in September 2015
- Implementation work is underway with first consultations planned for summer 2015





Voltage Dip-Induced Frequency Dip Analysis

DS3 Industry Forum
4th June 2015

Lisa McMullan



Presentation Overview




- Explanation of a VDIFD event
- Validation against real system records
- Simulation results
- Conclusions
- Next Steps



Explanation of a Voltage Dip Induced Frequency Dip Event




Voltage Dip-Induced Frequency Dip



Validation of Wind Farm Fault Ride Through Behaviour



Initial Assumptions for Wind Farm Fault Ride Through Behaviour





Fault applied



Fault cleared

The **WFPS** shall provide at least 90 % of its maximum **AAP** as quickly as the technology allows and in any event within 500 ms of the **Transmission System Voltage** recovering to 90% of nominal **Voltage**, for **Fault Disturbances** cleared within 140 ms.



Turbine 1: Fault Duration of 60ms





Turbine 2: Fault Duration of 67ms




Turbine 3: Fault Duration of 67ms



Turbine 4: Fault Duration of 70ms




Revised Assumptions for Wind Farm Fault Ride Through Behaviour



Validation of Fault Induced Voltage Dip Propagation




Voltage Dip Propagation




- A severe transmission fault depresses voltage at the location of the fault
- This depression propagates with varying degrees across system

Validation of Voltage Dip Propagation

Recorded System Data



Simulated Comparison in WSAT



Review of fault records

Voltages at various stations recorded

WSAT Snapshot case from event time




Fault emulated in the case

Voltages at selected stations recorded

Comparison of Voltage Propagation



Validation of Voltage Dip Propagation




**Clear
Correlation of
Voltage Dip
Propogation**

Simulation Results & Next Steps




3-Phase Busbar Fault

RoCoF Rates (Hz/s) Vs Frequency Nadir (Hz)



RoCoF Relay Operation

- Calculation of RoCoF during a transmission system fault.



Conclusions

- System is secure at current wind levels for fault events analysed thus far
- System inertia as well as levels of wind generation have an impact on VDIFD events
- Wind turbines with slower active power recovery rates contribute to VDIFD events

Next Steps

- Follow up with relevant wind farms on Fault Ride Through performance
- Examination of more severe faults
- Further validation of protection relay modelling
- Studies to inform future operational policies










All-Island System Frequency Regulation Investigation

DS3 Industry Forum
4th June 2015

Norman Watson




Frequency Regulation




Confirmation of correlation between system parameters such as SNSP and frequency regulation

Freq. Regulation Analysis Scope

- Analysis of 2014 Data:
 - Percentage of time that frequency spent outside 49.9 – 50.1 Hz compared to SNSP, Wind and Inertia levels.
 - Analysis of average and maximum 5-second frequency deviations.




2014 Analysis: Average Freq. Deviations



- Increase in average deviations between 45% and 60% SNSP is approximately 0.003Hz based on extrapolation of data.

2014 Analysis: Maximum Freq. Deviations



- Increase in maximum frequency deviations are marginal as SNSP increases.

Summary

- There is a correlation between frequency regulation and parameters such as SNSP
- Historical data indicates that the system could be securely operated at higher levels of SNSP – not an immediate barrier
- An incremental approach should be implemented when increasing SNSP – recognizes weakness of extrapolation
- Frequency regulation will require diligent management into the future





Control Centre Tools and Capability

DS3 Industry Forum
4th June 2015

Michael Burke



Presentation Summary




Workstream
Overview

Where are we now?


Where are we going?



Tools and Capability




Control Centre Tool Types



Recent Developments

- Improved Graphical User Interface
- Regional Forecasts
- Accuracy incentives
- Wind Forecast Tender



Wind Dispatch Tool

RCUC: Inertia & ROCOF

EMS
Integration
Q4 2015


- Online Short Circuit Tool
- WSAT Frequency Security
- WSAT Regional Transfers
- Phasor Monitoring



Real Time Short Circuit Tool



- G74 Methodology, 1ph & 3ph
- Runs automatically & alarms
- Offline Study functionality



More Proactive Network Management

Alarm Summary

1

2

3

4

5

6

7


8

Time	State	Message
01 / 12:47:01	⚠	Short-Circuit Alarm - TOT RMS Break Alarm
01 / 12:47:01	⚠	Short-Circuit Alarm - Peak Make Alarm

Substation	Voltage	Breaker	Fault Id	Type
CRKMINES	220	CKM2ARK1ICBK	CRKMINES220A1_3	3-P
CRKMINES	220	CKM2DSN1ICBK	CRKMINES220A2_3	3-P
FINGLAS	110	FIN1GLA1ICBK	FINGLAS110A1_3P	3-P
FINGLAS	110	FIN1MCD1ICBK	FINGLAS110A2_3P	3-P
FINGLAS	110	FIN1SVN1ICBK	FINGLAS110A3_3P	3-P
FINGLAS	110	FIN1GLA1ICBK	FINGLAS110B1_3P	3-P
FINGLAS	110	FIN1MCD1ICBK	FINGLAS110B2_3P	3-P
FINGLAS	110	FIN1SVN1ICBK	FINGLAS110B3_3P	3-P

Real Time use of Phasor Monitoring




- Higher sampling rate of system
- Oscillation Monitoring
- Post Event Analysis



WSAT Development

- Frequency Security Assessment
 - Predict nadir/zenith
 - Continuous Validation vs PMU data

- Regional Transfers
 - Identify amount of wind constraint necessary
 - Show margin to insecurity
 - Overloads & Voltage monitored




Energy Management System Integration





- Fully integrated all island EMS
- Facilitates more effective all island power system operation
- Improved powerflow analysis
- Q4 2015

EMS – Facilitating DS3



Situational Awareness

- More Information
- More Tools
- More Policies and Procedures
- **Timely & Effective Decision Making**



Thu 26-Feb-2015 15:31:50 50.05Hz

Gas/CCGT Priority Dispatch

UNIT	EMW	MVAR	VV	UNIT	EMW	MVAR	VV
B10	6	1.1		B11	90	2.8	
B20	49	1.2		B14	92	3.0	
B21	—	—		B13	82	3.1	
B22	72	0		B15	81	3.2	
B004	—	—		W04	136	1.0	
B005	—	—					
B006	—	—					

Hydros

UNIT	EMW	MVAR	Remain
C10	110	—	—
C20	138	-1	—
A01	—	—	—
A02	—	—	—
B03	234	31	—
B14	208	-24	—
B10	227	15	—
B11	—	—	—
B12 Tot	227	—	—
B12	—	—	—
B13	—	—	—
B14	—	—	—
B15	—	—	—

Future Tools: Key DS3 Inputs

- Ramping Studies & Policy
- Reserve from Wind
- Regulation Studies

Frequency
Control

- TSO/DSO Nodal Control
- Voltage Trajectory Study
- Voltage Control Policy


Voltage
Control

- Scheduling & Monitoring:
 - Ramping
 - SIR
 - FFR

System
Services


Tools and
Capability

Identification of further requirements



Other Tools?

- Look Ahead Analysis
- Demand Side Management
- Smart Grids
- Intelligent Alarm Processing
- Probabilistic tools



Questions?



Closing Remarks

DS3 Industry Forum
4th June 2015

Louis Fisher

