



DS3: Voltage Control Workstream

2013 Update

CONTEXT

The system voltage is determined by the balance of reactive power production and absorption. Generators have traditionally been a primary source of reactive power, which compensates for the reactive power produced and absorbed by consumers and by the lines and cables on the network itself. Reactive power, unlike active power, is predominately a local phenomenon, i.e. reactive power cannot be transmitted over significant distances.

The management of voltage requires a co-ordinated approach for reactive power control throughout the whole system, both transmission and distribution and Northern Ireland and Ireland, as deficiencies in a local area at a certain point can have an inordinate impact on other voltages, potentially leading to voltage collapse.

The management of system voltage needs to evolve due to the changing nature of the portfolio of plant connected to the power system. Key changes relate to the type of generation connecting to and being decommissioned from the system, the location of said generation and the reactive power capability of connected plant. The report published by the TSOs in July 2011¹ (hereafter referred to as the DS3 Report) outlined the current issues relating to voltage control and the likely challenges that will emerge by 2020.

OBJECTIVE

The key objective is to maintain the voltage as appropriate per the standards in the relevant jurisdiction on the transmission networks. Specifically, this means ensuring that voltages are maintained within acceptable voltage ranges on both the transmission and distribution systems. In addition, the performance of the system following voltage steps and disturbances must remain within the necessary limits and recovery should be achieved in a timely manner.

WORK COMPLETED IN 2012

The work of the DS3 Grid Code workstream formed the basis of the first phase of the Voltage Control workstream in developing and bringing forward changes to the reactive power standards of generators.

Through consultation with industry, the Grid Code Review Panels in Ireland and Northern Ireland and the Joint Grid Code Review Panel, significant progress was made on the development of enhanced reactive power standards for wind farms with the following Grid Code modifications progressed:

¹ http://www.eirgrid.com/media/Ensuring_a_Secure_Reliable_and_Efficient_Power_System_Report.pdf

Reactive Power Control Modes: requires wind farms to be capable of operating in Power Factor control, Reactive Power control or Voltage Regulation Set-Point control modes.

Steady State Reactive Power Capability: requires wind farms to provide a Q/Pmax ratio of 0.33 down to 12% of Registered Capacity and to deliver this capability at the Connection Point (as opposed to the LV terminals of the Grid transformer at present).

Fault Ride Through: requires wind farms to recover their active power output within 500 ms of fault clearance (1 s at present) and requires them to provide reactive current within 100 ms of fault inception. It also allows for the reactive response to be tuned if over-voltages occur.

The table below summarises the implementation status (as of January 2013) of each of these requirements with respect to the individual Grid/Distribution Codes.

	Ireland Grid Code	Northern Ireland Grid Code / Settings Schedule	Ireland Distribution Code	Northern Ireland Distribution Code
Reactive Power Control Mode	Implemented	Recommended for approval	To be progressed	To be progressed
Steady State Q Capability	Recommended for approval	Recommended for approval	To be progressed	To be progressed
Fault Ride Through	Recommended for approval	SONI analysis required	To be progressed	To be progressed

It should be noted that the development of enhanced standards for conventional generation plant on the transmission and distribution systems was not seen as offering any significant benefit and was subsequently not progressed by the respective Grid Code Review Panels.

FOCUS AREAS IN 2013

Implementation of all the enhanced capabilities brought forward under the DS3 Grid Code workstream will form the basis of the next phase of work in the Voltage Control workstream. These deliverables include: RA decisions on the Grid Code changes brought forward in 2012, progress on the assessment and development of equivalent Distribution Code changes, as appropriate, by the DSOs and associated RA decisions on Distribution Code changes. The associated deliverables, responsibilities and due dates are set out in the Grid Code workstream plan which, in summary, expects all Grid/Distribution Code proposals to be completed and RA decisions made by Q3 2013.

Subject to a decision to approve new standards in the Grid and Distribution Codes, a programme of implementation of the new standards on wind farms with associated testing/validation will be initiated. The TSOs will manage this process for transmission-connected wind farms through the

TSOs' Grid Code compliance and testing processes. The DSOs will manage this process for distribution-connected wind farms.

Wind farm models and study methodologies used by the TSOs and DSOs will need to be updated as appropriate to reflect new reactive power standards. The impact of these changes will need to be considered in the real-time analysis of the power system by the TSOs, the studies conducted to assess new wind farm connections and in the planning of the transmission and distribution networks by the TSOs and DSOs.

Development continues of European Network Codes that will be adopted by members of ENTSO-E. These codes will place requirements on system users, TSOs and DSOs in relation to voltage/reactive power control as well as the interaction between the parties in this respect. A review of the Network Codes, other relevant legislation and the standards/settings currently applied in respecting of voltage sensitive devices will be conducted to inform the subsequent development of high level principles for voltage/reactive power control arrangements by, and between, the TSOs and DSOs.

The TSOs and DSOs will work together to identify and develop suitable demonstration projects to trial the operation of the new wind farm standards and control principles. These projects will provide practical examples of how the new capabilities can be utilised and, along with the principles agreed between the TSOs and DSOs will form the basis of future operating protocols that will set out in detail how the TSOs and DSOs cooperate to maintain transmission and distribution voltages within standards.

The following sections set out the original workstream plan as published in December 2011

SCOPE

The scope of this work-stream can be broken into three phases of work. These are as follows:

1. Setting appropriate standards for reactive power capability and control on connecting generation both renewable plants and conventional plant
2. Designing the network while allowing for changed capabilities of connecting generation, particularly embedded in the distribution system
3. Developing appropriate system operational policies to utilise this capability, fully co-ordinated between the transmission and distribution systems of Ireland and Northern Ireland.

1. PHASE 1: REACTIVE POWER STANDARDS (2012 & 2013)

This work area will examine whether standards relating to voltage control need to be updated/clarified for both transmission- and distribution- connected generation. This will involve consultation and discussion leveraging the industry instruments already set up under the appropriate Grid Codes and Distribution Codes in Ireland and Northern Ireland. In addition there will

be a review, where necessary, to examine where these standards are best placed including Connection Agreements, Grid and Distribution Codes.

Steady state Reactive Capability and Voltage Control Modes for Renewable Generators

In order to provide improved operational flexibility to the TSOs in terms of voltage control for increasing number of Controllable WFPS on the Power System, three modes of operation for renewable generators are required in Ireland and Northern Ireland, i.e. 'Q-Mode' or Reactive Power / Mvar Instruction, Power Factor control modes, and Voltage Control with feedback. This, or a relevant standard need to be decided on in the short-term and the standard clarified going forward for all wind farms, both transmission- and distribution-connected, Ireland and Northern Ireland. This workstream will also review the reactive capabilities of new technologies to meet the needs of the system.

Steady State Reactive Capability and Voltage Control Modes for embedded conventional plant

Conventional plant in distribution networks currently has a relatively restricted requirement to provide reactive power control. This needs to be examined in light of the review on wind farms and a decision made should the standards for new embedded conventional plant change.

Dynamic Reactive Power Provision from transmission and distribution connected wind farms

The recent Facilitation of Renewables study showed that the transient stability of the power system would be degraded at very high wind penetrations if sufficient reactive support was not provided. However, the studies showed that these issues can be largely mitigated if wind farms act quickly to restore active power output after fault clearance. In addition, this workstream will optimise the injection of active and reactive currents during faults to maintain voltage stability. This work task will seek to define the requirements for wind farm plant in both the transmission and distribution systems in this regard. While there is a desire to standardise the requirements as much as possible, there may be challenges that require different standards. These issues will be identified and addressed in this workstream.

Covered off by Grid Code workstream

Dynamic Reactive Power Provision for transmission and distribution conventional plant

The capability of conventional plant to assist during voltage disturbances has a material impact on the integrity of the power system during disturbances. An examination of these standards is required to ensure that they are sufficient for the long-term security of the system at high penetrations of wind generation.

Covered off by Grid Code workstream

Controllability of Wind farms

The lack of control of existing wind farms in Ireland, particularly in terms of reactive power, was highlighted as a source of concern in the recent DS3 Report. As the levels of connected wind continue to increase, the continued monitoring of this voltage control capability is essential to ensure that the appropriate standards are adhered to. Key to this is Grid Code compliance testing

and on-going performance monitoring of all wind farms to ensure control is maintained throughout their operational lifetime.

Covered off by Performance Monitoring workstream

2. PHASE 2: SYSTEM OPERATION ALLOWING FOR CHANGING CAPABILITIES OF GENERATION AND WIND FARMS (2013 & 2014)

This phase will consider the implications of any changes in terms of studies and operation of the system following on from changes in phase 1.

Pilot Projects

Some of the changes in standards made (e.g. reactive capability of embedded generation or change in control modes of wind farms) per Phase 1 of this workstream may need to be trialled on a test basis. The TSOs will work with the DSOs to trial this. In particular, demonstrations of how new voltage control modes on wind farms embedded in the distribution system can be used to manage both distribution and transmission system voltage. In addition, if voltage control capabilities are sought from embedded conventional plant this may need to be demonstrated in order to develop appropriate operational policies and practices for managing voltage control.

Planning Studies (TSO & DSO)

The methodology used for both TSO and DSO connection studies will need to be updated to reflect any changes in standards for embedded plant per the Grid Codes and Distribution Codes and how this impacts on future network connection studies and agreements.

Network Solutions (TSO & DSO)

When a clear understanding has been developed of what is expected (in terms of standards of performance) from new generation, modelling of the future network can be performed to examine what deficiencies remain and how the installation of network devices may contribute to alleviating these issues.

3. PHASE 3: DEVELOPING OPERATIONAL POLICIES (2014)

Following changes in standards and analysis of the impacts of these changes, new operational policies will have to be developed and in some cases, existing policies will have to be updated. For some policies, new tools will also have to be developed/updated.

TSO Reactive Power Management Policy

The voltage control practices currently in use in the Control Centres will have to be updated to take into account any changes in reactive power capability. Some of the control tools in use in the Energy Management System will have to be updated to take into account the change in reactive capability. Detailed studies will also have to be carried out in the operational timeframe to assess the impact of any changes. This policy will also need to consider the necessary system tools required to successfully implement these policies in real time.

TSO/DSO Voltage Control Policy

The power system is changing from one of bulk power generation and transmission to load centres into a system with high levels of embedded generation. This means that the transmission and distribution systems need to be capable of a much wider operating range: from peak demand with low embedded generation to minimum demand with high embedded generation. This is a fundamental shift and may increase the range of reactive power control that is required to maintain system voltages within limits.

The traditional method of voltage control on the distribution system is through the use of tap-changers on transformers, line drop compensators and down-line regulators. This method assumed that the voltage dropped away from the primary substation towards the load and was within a given power factor band.

There is an interaction between the actions the TSOs take to manage the High Voltage system and the actions the DSOs take to manage the Medium Voltage and Low Voltage systems. These actions need to be carefully co-ordinated to ensure secure voltage levels on the entire power system. Due to the changing nature of connecting generation, there is a need to investigate the best method for managing the co-ordination of TSO/DSO activities. The outcome of this is an agreed TSO/DSO reactive power operating protocol.

HIGH-LEVEL PLAN

Note: deliverables associated with the DSOs (NIE and ESBN) are to be finalised

TASK NO.	DECISION / DELIVERABLE	RESPONSIBLE	ORIGINAL DUE DATE	DUE DATE
VC.01	Decision: Steady state Reactive Power Control from wind farms	TSOs, DSOs	Q3 2012	COMPLETE
VC.02	Engagement between TSOs and DSOs on universal wind farm standards and appropriate controls for embedded conventional plant	TSOs, DSOs	Q1 2012	COMPLETE
VC.03	Grid Code and Distribution code changes brought to industry for discussion	TSOs, DSO, All	Q2 2012	COMPLETE
VC.04	Decision: Steady-State Reactive Power Control for embedded conventional plant	TSOs, DSOs	Q2 2012	COMPLETE
VC.05	Decision: Dynamic Reactive Power Provision from transmission- and distribution-connected conventional plant	TSOs, DSOs	Q4 2012	COMPLETE
VC.06	Decision: Dynamic Reactive Power Provision from transmission- and distribution-connected wind farms	TSOs, DSOs	Q4 2012	COMPLETE
VC.07	Controllability of Wind farms	TSOs, DSOs	On-going	On-going
VC.08	Complete implementation of new Grid & Distribution Code standards and consideration of retrospection	TSOs, DSOs	Q1 2014	→ Grid Code / Performance Monitoring workstreams
VC.09	Operational & Planning Studies (TSO & DSO)	TSOs, DSOs	Q2 2013	→ Studies workstream
Policy / Protocol Review and Development				
VC.10.01	Review of relevant ENTSO-E Network Codes	TSOs, DSOs	New	Q1 2013
VC.10.02	Review relevant legislation in Northern Ireland	SONI, NIE	New	Q1 2013
VC.10.03	Review relevant legislation in Ireland	EirGrid, ESBN	New	Q1 2013
VC.10.04	Consolidate Network Code / legislation reviews	TSOs, DSOs	New	Q2 2013
VC.10.05	Review of system voltage sensitive device settings (link to frequency control setting review)	TSOs, DSOs	New	Q2 2013
VC.10.06	Draft TSO/DSO principles for voltage/reactive power control	SONI, NIE	New	Q2 2013

VC.10.07	Draft TSO/DSO principles for voltage/reactive power control	EirGrid, ESBN	New	Q2 2013
VC.10.08	Scope 'Distributed Voltage Control and Dynamic Voltage Support Study' (link to Model Development & Studies workstream)	TSOs	New	Q2 2013
VC.10.09	Finalise TSO/DSO principles for voltage/reactive power control	SONI, NIE	New	Q3 2013
VC.10.10	Finalise TSO/DSO principles for voltage/reactive power control	EirGrid, ESBN	New	Q3 2013
VC.10.11	Develop TSOs voltage/reactive power control policy	TSOs	Q1 2014	Q2 2014
VC.10.12	Draft TSO/DSO voltage/reactive power control protocol	SONI, NIE	New	Q1 2014
VC.10.13	Consideration of different network design methodologies	SONI, NIE	New	Q1 2014
VC.10.14	Consideration of different network design methodologies	EirGrid, ESBN	New	Q1 2014
VC.10.15	Draft TSO/DSO voltage/reactive power control protocol	EirGrid, ESBN	New	Q1 2014
VC.10.16	Finalise TSO/DSO voltage/reactive power control protocol	SONI, NIE	Q1 2014	Q4 2014
VC.10.17	Finalise TSO/DSO voltage/reactive power control protocol	EirGrid, ESBN	Q1 2014	Q4 2014
Demonstration Projects				
VC.11.01	Identification and scoping of reactive/voltage control demonstration projects	SONI, NIE	Q1 2013	Q3 2013
VC.11.01	Identification and scoping of reactive/voltage control demonstration projects	EirGrid, ESBN	Q1 2013	Q3 2013
VC.11.02	Initiation of demonstration projects	SONI, NIE	New	Q4 2013
VC.11.02	Initiation of demonstration projects	EirGrid, ESBN	New	Q4 2013
VC.11.03	Ongoing monitoring of demonstration projects	SONI, NIE	New	On-going
VC.11.03	Ongoing monitoring of demonstration projects	EirGrid, ESBN	New	On-going
VC.11.04	Conclusion of demonstration projects	SONI, NIE	New	Q4 2014
VC.11.04	Conclusion of demonstration projects	EirGrid, ESBN	New	Q4 2014
General				
VC.12.01	Provide 2013 workstream progress update and develop workstream plan for 2014	TSOs	New	Q4 2013

Other Workstream Dependencies

Grid Code Workstream Dependencies				
	Wind Farm Steady State Control Modes			
GC.01.2	Discuss WFPS voltage control modes with DSOs	TSOs	Q2 2012	Q1 2013
GC.01.2.1	Develop modification to Ireland Distribution Code and bring to D Code Review Panel	ESBN	New Task	Q2 2013
GC.01.2.2	Send modification to CER for approval	ESBN	New Task	Q2 2013
GC.01.2.3	RA decision on Distribution Code modification	CER	New Task	Q3 2013
	Dynamic Active and Reactive Response			
GC.02.07	Decision on Grid Code proposals	RAs	Q4 2012	Q1 2013
GC.02.09.1	Develop modification to Ireland Distribution Code and bring to D Code Review Panel	ESBN	Q1 2013	Q2 2013
GC.02.09.2	Send modification to CER for approval	ESBN	New Task	Q2 2013
GC.02.09.3	RA decision on Distribution Code modification	CER	New Task	Q3 2013
GC.02.10.1	NIE to carry out review of D Code prior to bringing in new standards (non-DS3 related)	NIE	New Task	Q1 2013
GC.02.10.2	Develop modification to Northern Ireland Distribution Code and bring to D Code Review Panel	NIE	New Task	Q2 2013
GC.02.10.3	Send modification to UReg for approval	NIE	New Task	Q2 2013
GC.02.10.4	RA decision on Distribution Code modification	UReg	New Task	Q3 2013
Performance Monitoring & Testing Workstream Dependencies				
PMT.5.4	Develop standard processes based on new G Code modifications which require testing	TSOs	New Task	Q4 2013
PMT.5.5	Consideration of standardised testing processes arising from D Code Modifications	DSOs	New Task	Q4 2013
Model Development & Studies Workstream Dependencies				
MDV.XX.XX	Distributed Voltage Control and Dynamic Voltage Support Study Scoping	TSOs	2013	Q2 2013
MDV.XX.XX	Distributed Voltage Control and Dynamic Voltage Support Study Analysis	TSOs	New Task	Q4 2013
MDV.XX.XX	PV Analysis and Overcompensation Study	TSOs	2013	Q3 2013
MDV.XX.XX	Develop generic tuneable wind farm models that can represent behaviours set out in the wind farm Grid Code modifications	TSOs	New	Q3 2013