

Enduring Connection Policy

2.1 Constraints Report for

Area K

Solar and Wind

December 2021

Version 1.0

Disclaimer

EirGrid has followed accepted industry practice in the collection and analysis of data available. While all reasonable care has been taken in the preparation of this data, EirGrid is not responsible for any loss that may be attributed to the use of this information. Prior to taking business decisions, interested parties are advised to seek separate and independent opinion in relation to the matters covered by this report and should not rely solely upon data and information contained herein. Information in this document does not amount to a recommendation in respect of any possible investment. This document does not purport to contain all the information that a prospective investor or participant in the Single Electricity Market may need.

For queries relating to the document or to request a copy contact:

info@eirgrid.com

Copyright Notice

All rights reserved. This entire publication is subject to the laws of copyright. This publication may not be reproduced or transmitted in any form or by any means, electronic or manual, including photocopying without the prior written permission of the TSOs.

©EirGrid Plc. 2021

The Oval, 160 Shelbourne Road, Ballsbridge, Dublin 4, D04 FW28, Ireland

Document History

| Version | Date | Comment |
|---------|------------|---------|
| 1.0 | 21/12/2021 | |

Table of Contents

| | |
|--|-----------|
| DOCUMENT STRUCTURE | 6 |
| IMPORTANT NOTE | 7 |
| 1 INTRODUCTION | 8 |
| 1.1 OBJECTIVE | 8 |
| 1.2 BACKGROUND | 8 |
| 1.3 DEFINITION OF OVER-SUPPLY, CURTAILMENT AND CONSTRAINT | 9 |
| 2 OVERVIEW | 11 |
| 2.1 STUDY AREAS | 12 |
| 2.2 STUDY SCENARIOS | 12 |
| 2.3 RENEWABLE GENERATION SCENARIOS | 13 |
| 2.4 STUDY YEAR SCENARIOS | 14 |
| 3 STUDY INPUT ASSUMPTIONS | 15 |
| 3.1 NOTABLE STUDY ASSUMPTIONS | 15 |
| 3.1.1 <i>Valid for these Generation Assumptions</i> | 15 |
| 3.1.2 <i>All Island Model</i> | 15 |
| 3.1.3 <i>Data Freeze</i> | 15 |
| 3.1.4 <i>Transmission Network Outage Programme</i> | 15 |
| 3.1.5 <i>Network Requirement for Batteries and Conventional generators</i> | 15 |
| 3.1.6 <i>Priority Dispatch for Renewable Generation Connecting after July 2019</i> | 16 |
| 3.2 NETWORK | 17 |
| 3.2.1 <i>Transmission Network</i> | 17 |
| 3.2.2 <i>Distribution System</i> | 20 |
| 3.2.3 <i>Ratings and Overload Ratings</i> | 20 |
| 3.2.4 <i>Transmission Reinforcements</i> | 20 |
| 3.3 DEMAND | 20 |
| 3.4 INTERCONNECTION | 21 |
| 3.4.1 <i>North-South Tie Line</i> | 21 |
| 3.4.2 <i>Moyle Interconnector</i> | 21 |
| 3.4.3 <i>East-West Interconnector (EWIC)</i> | 21 |
| 3.4.4 <i>Additional Interconnection</i> | 21 |
| 3.4.5 <i>Interconnector Capacities</i> | 22 |
| 3.5 PRIORITY DISPATCH | 22 |
| 3.5.1 <i>Priority Dispatch for Wind and Solar Generation</i> | 22 |
| 3.6 GENERATION | 22 |
| 3.6.1 <i>Conventional Generation</i> | 22 |
| 3.6.2 <i>Conventional Generation Outages</i> | 23 |
| 3.6.3 <i>Renewable Generation</i> | 23 |
| 3.7 SYSTEM OPERATION | 28 |
| 3.7.1 <i>Safe Operation (Security Constrained N-1)</i> | 28 |
| 3.7.2 <i>Operational Constraint Rules</i> | 28 |
| 4 STUDY METHODOLOGY | 31 |
| 4.1 INTRODUCTION | 31 |
| 4.2 PRODUCTION COST MODELLING | 31 |
| 4.3 THE SOFTWARE: PLEXOS INTEGRATED ENERGY MODEL | 32 |
| 4.4 SYSTEM MODEL | 32 |
| 4.5 SOFTWARE DETERMINATION OF OVER-SUPPLY, CURTAILMENT AND CONSTRAINT | 33 |
| 4.6 APPORTIONING OF OVER-SUPPLY, CURTAILMENT AND CONSTRAINT | 33 |
| 5 RESULTS SUMMARY FOR IRELAND | 34 |
| 6 RESULTS FOR AREA K | 37 |
| 6.1 INTRODUCTION | 37 |
| 6.2 STUDY NOTES | 37 |

| | | |
|---|---|-----------|
| 6.2.1 | <i>Network Outages</i> | 37 |
| 6.2.2 | <i>Benefit of Capacity Factor</i> | 37 |
| 6.2.3 | <i>Notes on Over-supply, Curtailment and Constraint Modelling</i> | 37 |
| 6.3 | GENERATION OVERVIEW..... | 38 |
| 6.3.1 | <i>Connection Works and Generators</i> | 39 |
| 6.4 | NETWORK OVERVIEW | 40 |
| 6.5 | FUTURE GRID SENSITIVITY SCENARIO..... | 40 |
| 6.6 | AREA K – AVERAGE RESULTS | 41 |
| 6.6.1 | <i>Interconnector and Offshore Wind Sensitivity Studies</i> | 41 |
| 6.6.2 | <i>Impact of Article 12</i> | 41 |
| 6.6.3 | <i>Future Grid Sensitivity Study</i> | 41 |
| 6.6.4 | <i>Area Subgroups</i> | 41 |
| 6.7 | CONCLUSION – RESULTS FOR AREA K | 46 |
| APPENDIX A - NETWORK REINFORCEMENT & MAINTENANCE | | 47 |
| A.1 | REINFORCEMENTS IN 2024 | 47 |
| A.2 | REINFORCEMENTS IN 2026 | 49 |
| A.3 | REINFORCEMENTS IN FUTURE GRID | 50 |
| A.4 | MAINTENANCE WITHIN THE PLEXOS MODELLING | 52 |
| APPENDIX B - GENERATOR..... | | 53 |
| B.1 | GENERATION TYPE FOR EACH GENERATOR SCENARIO..... | 54 |
| B.2 | GENERATION TYPE BY AREA FOR EACH GENERATOR SCENARIO..... | 54 |
| B.3 | GENERATION TYPE BY NODE | 56 |
| B.4 | GENERATOR LIST BY NAME | 60 |
| APPENDIX C AREA K NODE RESULTS | | 75 |
| C.1 | BUTLERSTOWN | 76 |
| C.2 | DUNGARVAN..... | 78 |
| C.3 | RATHNASKILLOGE..... | 81 |
| C.4 | WOODHOUSE..... | 83 |
| ABBREVIATION AND TERMS | | 87 |
| REFERENCES..... | | 90 |

Document Structure

This document contains an Abbreviations and Terms section, an Executive Summary, five main sections, and three Appendices.

The structure of the document is as listed below.

Much of this document describes study assumptions and methodology. For customers wishing to see the estimated Total Dispatch Down, please proceed to both Section 6 and Appendix C.

Section 1: Introduction: presents the purpose of the report and the definitions of over-supply, curtailment and constraint.

Section 2: Study Overview: introduces the study areas, the study years and the generation scenarios. Together, these comprise the study scenarios.

Section 3: Study Input Assumptions: describes the study assumptions as they relate to network, demand, interconnection, generation and system operational limits.

Section 4: Study Methodology: provides an overview of the software used and how the model is put together. A description of how Total Dispatch Down results are apportioned is also provided.

Section 5: Results Summary for Ireland: provides an overview of the reduction in renewable generation forecasted by this study at system level for Ireland.

Section 6: Results for Area K: outlines the area covered by this report. The section provides a network diagram of Area K and an overview of the results for Area K.

Appendix A: Network Reinforcements: lists the reinforcements that are included in the study for each study scenario. These reinforcements have a material impact on the resulting constraints. This section also lists the representative transmission outage scheduled included within the analysis.

Appendix B: Generator Details: provides an overview of the generation. It also provides a comprehensive list of the individual generators included in the study.

Appendix C: Area K Node Results: provides a table of results for every node in the area. This table documents the installed capacity, available energy, over-supply, curtailment and constraint for every node in Area K.

The **Abbreviations and Terms** provide a list of the abbreviations and terms used in the document.

Important Note

This ECP 2.1 constraints report presents an estimate of the reduction in available solar and wind generation based on the study assumptions described. The reduction in available generation has been split into three categories for the purposes of this study: over-supply, curtailment and constraint.

The treatment of renewable generation under these three categories of generation reduction will be determined by the implementation of Articles 12 and 13 of the EU's Clean Energy Package. A final decision from the Regulatory Authorities (RAs) in Ireland and Northern Ireland on the implementation of Articles 12 and 13 has yet to be published, and therefore an assumed interpretation has been included in this study, as detailed in this report.

This report uses the term "Total Dispatch Down" to refer to the total reduction in available solar and wind generation i.e. the sum of over-supply, curtailment and constraint. However, it is important to note that the term "dispatch down" is more correctly applicable only to TSO instructions to reduce generation output from a market position as is the case for curtailment and constraint, and is not necessarily applicable to a generator reducing its own output from its availability to a market position so that supply and demand are balanced, as is the case for over-supply.

The results presented in this report are based on the simulation and modelling assumptions described. The findings are indicative only and this report should in no way be read as a guarantee as to future levels of over-supply, curtailment and constraint.


1 Introduction

1.1 Objective

It is a requirement of CRU’s ECP 2 decision, CRU/20/060, that the Transmission System Operator (TSO) carry out system studies to inform applicants about possible generation constraint levels in Ireland. EirGrid will complete this requirement across twelve regional reports. The purpose of these reports is to provide generation developers with information on possible levels of generation output reduction for a range of scenarios.

The reports present results for a range of generation scenarios and indicate the levels of Total Dispatch Down that solar and wind generation might experience in the future, where Total Dispatch Down is defined as follows:

$$\text{Total Dispatch Down}^1 = \text{Over-supply} + \text{Curtailment} + \text{Constraint}$$



The over-supply, curtailment and constraint results for Area K are included in Section 6 and in Appendix C.

1.2 Background

The core study years for this analysis are 2024 and 2026. A further sensitivity study considers a “Future Grid” scenario that aligns with the network assumptions used in the Shaping Our Electricity Future (SOEF) Roadmap.

The evaluation of Total Dispatch Down is impacted by a range of assumptions; generation, demand, interconnection, network and operational limits. A brief summary of each of these is provided below. More details of the study assumptions are provided in Section 3.

Generation

Since Gate 3, EirGrid and ESB Networks have issued an additional 2 GW of wind and solar connection offers under the Non-GPA (Non-Group Processing Approach) rule set CER/09/099. In line with government policy and CRU direction, another 1.8 GW of wind and solar connection offers have been issued under Enduring Connection Policy – Stage 1 (ECP-1). The CRU decision on the Enduring Connection Policy – Stage 2 (ECP-2) mandates that the next stage of the connection policy will progress in three separate batches to be processed in 2021 (ECP-2.1), 2022 (ECP-2.2) and 2023 (ECP-2.3). This report deals with the 1.8 GW wind and solar generation processed under the first of these three batches – ECP-2.1.

It is not clear at this stage which generators will be successful in future renewable support auctions or other funding mechanisms and therefore, the timing and location of future generation connections is uncertain. For this reason, results for various renewable generation scenarios are presented in this report.

¹ For the purposes of this report, the term “Total Dispatch Down” includes over-supply. Note however that “dispatch down” more correctly refers to dispatch away from a market position and as such, includes curtailment and constraint but not necessarily over-supply.

Demand

Demand levels in Ireland have been increasing over a number of years, which has led to a reduction in renewable generation dispatch down levels and in particular, curtailment levels associated with the operational metric SNSP, which is impacted by the demand.

The system demand forecast used in the 2024 and 2026 ECP-2.1 constraints studies is the median demand forecast from the Generation Capacity Statement (GCS) 2021 - 2030. The “Future Grid” study uses the high demand forecast from the GCS 2021 – 2030, this aligns with the demand level used within the Shaping Our Electricity Future Roadmap.

Interconnection

As well as the existing Moyle and East-West (EWIC) HVDC interconnectors, the following future HVDC interconnectors have been assumed in some scenarios:

- 500 MW Greenlink HVDC interconnector to Great Britain;
- 700 MW Celtic HVDC interconnector to France.

In addition to the existing North-South HVAC interconnector between Louth and Tandragee, a second North-South HVAC interconnector between County Tyrone and County Meath has also been assumed in service for some scenarios.

Network

The network reinforcement assumptions used for the core 2024 and 2026 scenarios are aligned with the current estimated delivery dates for existing reinforcement projects.

The network assumed for the “Future Grid” study is aligned with the SOEF roadmap network assumptions.

Operational Limits

Under the SOEF Roadmap, the System Operation workstream sets out a plan for further developing our operation capability to facilitate increases in wind and solar generation levels. This includes evolution of the SNSP, RoCoF, inertia, minimum number of conventional units and system service provision from new, low carbon sources. The current System Operation roadmap assumptions are included in the assumptions for this report.

1.3 Definition of Over-Supply, Curtailment and Constraint

Over-Supply

The reduction of available renewable generation for over-supply reasons is necessary when the total available generation exceeds system demand plus interconnector export flows. In this study, generation reduction for over-supply is applied prior to curtailment and constraint.

Under the EU’s Clean Energy Package, it has been mandated that priority dispatch of renewable generation will continue to apply only to generators which connected prior to July 4th 2019 (Article 12). This will create a new type of generator for consideration in the dispatch process – the non-priority dispatch renewable generator, connected post-July 4th 2019. A final decision in respect of the treatment of non-priority dispatch renewable generators is currently under consideration by the SEM Regulatory Authorities (RAs). An assumption on the implementation of Article 12 has been made for this ECP 2.1 constraints analysis and is summarised below. The final decision on the implementation of Article 12 will not be known until it is published by the RAs, and may differ from the assumption made for this study.

During generation reduction for over-supply reasons, a distinction is made between the treatment of priority and non-priority renewable generators, and non-priority generators are reduced ahead of priority generators. Within, these two categories of generation, over-supply is applied pro-rata across the all-island system for all generators in the category.

Curtailment

In order to operate a safe and secure electricity system, the TSO must operate the system within certain operational limits. These limits include:

- Maximum level of System Non-Synchronous Penetration (SNSP)
- Maximum rate of change of frequency (RoCoF)
- Minimum level of system inertia
- Minimum number of conventional units for stability
- Minimum levels of reserve
- Conventional generator “must run” rules to ensure adequate system voltage and power flow control

Curtailement is applied to reduce the output of renewable generators in order to ensure that operational limits are not breached, and the system can remain secure and stable. Curtailement is applied to all renewable generators across the island on a pro-rata basis with no distinction made between the treatment of priority and non-priority generators.

Constraint

Generators may also need to be dispatched down due to transmission network limitations and, in particular, to ensure that the thermal overload limits of transmission circuits and transformers are not breached. Transmission equipment may become overloaded in an intact network or for network contingencies, where a line may become overloaded if another line were to trip. In order to avoid this, renewable generation may be dispatched down.

Changes in generator output for this reason are referred to as a ‘constraint’. The constraining of generation is location-specific and can be reduced, for example, by transmission network reinforcements. The model accounts for N-1 contingencies, this means that the system will be dispatched in such a way that any single contingency will not cause overloads.

Constraint is applied pro-rata across renewable generators which are effective in managing a particular network limitation, with no distinction made between the treatment of priority and non-priority generators.

2 Overview




Figure 2-1 Areas Designated for Preparing Wind Energy Profiles, Generation Scenarios and Reporting Results

This section presents an overview of the over-supply, curtailment and constraints assessment. Descriptions of the study scenarios are provided which are a combination of generation scenarios and study years.

An overview of the study areas is also provided. These are fundamental to understanding the contents of the individual area reports. It also provides an overview of the demand, generation and network assumptions that are used in the study. Taken together this information provides an overview of this analysis.

2.1 Study Areas

The areas shown in Figure 2-1 are used for preparing wind energy profiles, for setting up generation scenarios and for reporting results. These areas are similar to those used for the Gate 3 and ECP 1 constraints analysis.

2.2 Study Scenarios

Studies were carried out for a number of study years with different network assumptions, and generation scenarios. An overview of the study scenarios can be seen in Figure 2-2 and Table 2-1.

The core ECP 2.1 study scenarios are highlighted in Figure 2-2 and cover the years 2024 and 2026. The core 2024 study does not include future interconnection (i.e. neither Greenlink nor Celtic interconnectors are included). The core 2026 study includes one future interconnector (Greenlink).

During consultations with industry in advance of this review, there were industry requests for a number of sensitivity studies to be carried out as part of the analysis in addition to the core study scenarios. As a result of this, a number of sensitivity scenarios were developed in consultation with industry. These include:

- Sensitivity studies considering various levels of future interconnection in 2026;
- Sensitivity studies considering the impact of the connection of offshore wind; and
- A sensitivity study for a Future Grid scenario which considers 2030 demand levels and the impact of the network reinforcements identified in the SOEF Roadmap.




Figure 2-2 Study Scenarios: Matrix of Generation and Network Scenarios

| Network | Generation | | | | | |
|-------------|------------|-----|-----|-----|-----------------------|-----------------------|
| | Initial | 33% | 66% | ECP | ECP + 1.7 GW offshore | ECP + 3.9 GW offshore |
| 2024 | X | X | X | X | | |
| 2026.i | X | X | X | X | X | |
| 2026 | | | | X | X | |
| 2026.ii | | | | X | X | |
| Future Grid | | | | X | X | X |

Table 2-1 Overview of Study Scenarios – Core ECP 2.1 Study Scenarios Highlighted

A description of the generation scenarios and study year scenarios are provided below in Section 2.3 and Section 2.4 respectively.

2.3 Renewable Generation Scenarios

The generation study scenarios range from an "Initial" scenario which includes all renewable generation currently connected plus all Gate 3, non-GPA and ECP 1 renewable generation expected to connect by the end of 2023, to an "ECP" scenario which includes all renewable generation currently connected plus all Gate 3, non-GPA, ECP 1 and ECP 2.1 generation.

During consultations with industry in advance of this review, there was an industry request for further sensitivity studies considering the impact of offshore wind connections to be included in the study scope. As a result of this, two further sensitivity scenarios were developed in consultation with industry: the "ECP + 1.7 GW offshore" and "ECP + 3.9 GW offshore" scenarios.

There are four main generation scenarios summarised as follows:

- The "Initial" scenario includes currently connected renewable generation plus all renewable generation expected to be connected by end of 2023.
- The "33%" scenario includes the renewable generation in the initial scenario plus 33% of the difference in renewable generation between the Initial and ECP scenario.
- The "66%" scenario includes the renewable generation in the initial scenario plus 66% of the difference in renewable generation between the Initial and ECP scenario.
- The "ECP" scenario includes all renewable generation up to and including ECP 2.1.

There are two additional sensitivity scenarios summarised as follows:

- The "ECP + 1.7 GW offshore" scenario includes all renewable generation in the ECP scenario plus an additional 1.7 GW of offshore wind.
- The "ECP + 3.9 GW" offshore scenario includes all renewable generation in the ECP scenario plus an additional 3.9 GW of offshore wind.

A variety of renewable generation scenarios are included to take account of the possibility that not all generators will ultimately connect, and to give a view on the Total Dispatch Down seen under various renewable generation build out scenarios.

The results for each generation scenario are presented explicitly for each area in their respective area report. In this report the results for Area K are presented for each renewable generation scenario.

2.4 Study Year Scenarios

| Network | TER (TWh) | | |
|-------------|-----------|------------------|--------------|
| Year | Ireland | Northern Ireland | All - Island |
| 2024 | 35.8 | 8.6 | 44.3 |
| 2026 | 37.5 | 8.6 | 46.1 |
| Future Grid | 46.5 | 9.5 | 56.0 |

Table 2-2 Total Electricity Requirement (TER) (TWh) from All-Island Generation Capacity Statement 2021-2030

The study years are chosen to capture expected progress over the short to medium term with regard to predicted operational limitation improvements, transmission reinforcements and forecast demand increase.

This is achieved by studying the years 2024 and 2026. For the years 2024 and 2026, the median demand forecast from EirGrid and SONI's All-Island Generation Capacity Statement 2021-2030 was used.

In consulting with industry in advance of this review, there was a request for an additional study showing the impact of the Shaping Our Electricity Future (SOEF) roadmap, recently published by EirGrid and SONI. Hence, a Future Grid scenario has also been studied, which has network and operational constraint assumptions that are aligned with the SOEF study. The demand level for the Future Grid study is based on the All-Island Generation Capacity Statement 2021-2030 high demand scenario for the year 2030.

3 Study Input Assumptions

This section provides an overview of the input assumptions for the over-supply, curtailment and constraint modelling.

3.1 Notable Study Assumptions

The following study assumptions are of note.

3.1.1 Valid for these Generation Assumptions

The estimated over-supply, curtailment and constraint levels in this report are valid for the generation assumptions used in these studies.

3.1.2 All Island Model

As ECP 2.1 is an Ireland connection process, this report provides estimates of over-supply, curtailment and constraint levels for Ireland and not for Northern Ireland. However, for this study, the all island system including Ireland and Northern Ireland has been modelled in Plexos. This is necessary in order to provide a more accurate estimate of generation reduction levels, given that both over-supply and curtailment are all island issues.

3.1.3 Data Freeze

The data freeze for the input assumptions for this analysis was July 2021 for 2024 and 2026 study scenarios and November 2021 for the Future Grid sensitivity study. As a result, there may be some recent developments within the electricity network that are not included.

3.1.4 Transmission Network Outage Programme

A basis of the previous ECP 1 constraints analysis was that the existing network was assumed to be available at all times. In reality, a transmission outage programme will be implemented each year, resulting in outages of transmission circuits and other equipment for periods of time. Outages may be due to scheduled maintenance, forced outages, to facilitate new connections or for reinforcement reasons (e.g. circuit/busbar updates).

Transmission outages may increase generation constraints on the system and, as a result of industry feedback following ECP 1, a representative transmission outage schedule has been included for this ECP 2.1 analysis. The outages included in this schedule represent a geographical spread of circuits across the system and are each configured for a three-month period. This allows a representation of outage impact in each geographical area to be included in the studies. Longer duration outages which may be required for certain connections, reinforcement works or forced outages are not considered and may result in higher wind and solar constraints. The representative transmission outage schedule used in the studies is given in Appendix A Table A4.

3.1.5 Network Requirement for Batteries and Conventional generators

For this analysis, batteries are modelled with a two-hour storage capacity. The batteries are given a notional buy and sell price in the model. When the system price goes below €5 per MWh, batteries charge drawing megawatts from the system, up to their modelled maximum storage capacity. When the system price goes

above €40 per MWh, the batteries provide megawatts to the system until they are fully discharged. This modelling approach means that batteries charge during times of high renewable generation, integrating more solar and wind generation on the system. Note that the batteries in the model are reacting to system wide prices and are not responding to local issues. In general, this approach means batteries do not export power to the system during times of high wind and solar generation.

The situation with conventional generation is similar. For conventional generation, the dispatch is primarily economic in nature. As such, the software only runs the relatively expensive conventional generators infrequently in the simulation.

Hence, the model generally does not dispatch batteries and peaking generators at times of high solar and wind generation output. For this analysis, these assumptions are reasonable. However, in the future, if there was a need for concurrent output from batteries at the same time as wind and solar and/or if a future operation of the system was to require prolonged running of peaker generators, or that some network capacity be explicitly reserved for peaker generators, then this analysis would need to be revised.

3.1.6 Priority Dispatch for Renewable Generation Connecting after July 2019

A recent regulation has been issued from the EU in relation to the treatment of priority dispatch for renewable generation which connected after the 4th July 2019.

The relevant clause (Article 12) is as follows:

REGULATION (EU) 2019/943 OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 5 June 2019 on the internal market for electricity²

Article 12 (6)

Without prejudice to contracts concluded before 4 July 2019, power-generating facilities that use renewable energy sources or high-efficiency cogeneration and were commissioned before 4 July 2019 and, when commissioned, were subject to priority dispatch under Article 15(5) of Directive 2012/27/EU or Article 16(2) of Directive 2009/28/EC of the European Parliament and of the Council (20) shall continue to benefit from priority dispatch. Priority dispatch shall no longer apply to such power-generating facilities from the date on which the power-generating facility becomes subject to significant modifications, which shall be deemed to be the case at least where a new connection agreement is required or where the generation capacity of the power-generating facility is increased.

Under Article 12, renewable generation connected before the 4th July 2019 will still hold priority dispatch, while generation connected after this date will not. This will create a new type of generator for consideration in the dispatch process – the non-priority dispatch renewable generator, connected post July 4th 2019. A final decision in respect of the treatment of non-priority dispatch renewable generators is currently under consideration by the SEM Regulatory Authorities (RAs). The latest proposed decision by the RAs has been implemented in this ECP 2.1 constraints analysis and is summarised below.

During generation reduction for over-supply reasons, a distinction is made between the treatment of priority and non-priority renewable generators, with non-priority generators being dispatched down ahead of priority generators. Within, these two categories of generation, over-supply is applied pro-rata across the all-island system for all generators in the category.

During curtailment or constraint of renewable generation, no distinction is made between priority and non-priority generators, and dispatch down is applied pro-rata across either the all-island system (in the case of curtailment), or across the relevant transmission nodes (in the case of constraint).

² <https://eur-lex.europa.eu/legal-content/EN/TXT/PDF/?uri=CELEX:32019R0943&from=EN>

3.2 Network

3.2.1 Transmission Network

This section details the modelling assumptions used in this study for the transmission network.

The transmission system in Ireland is a meshed network with voltage levels at 400 kV, 275 kV, 220 kV and 110 kV. The network is necessary to allow bulk power flows to be transported over long distances from power stations and renewable generation sites to the towns and cities in Ireland. A diagram of the Irish transmission system can be seen in Figure 3-1. In addition to the current transmission network a number of network reinforcements are considered in each network scenario. A list of the network reinforcements used in the study are provided in Appendix A.

Figure 3-1 shows the Ireland transmission network in 2021. Figure 3-2 shows the Future Grid Ireland transmission network, this diagram shows the location of the large network projects that are included in the Future Grid scenario.




Figure 3-1 Ireland Transmission Network 2021

**Planned Transmission System
400 kV, 275 kV, 220 kV and 110 kV
Future Grid**

LEGEND

| | |
|------------------------------|--------------------|
| — 400 kV Lines | ■ Hydro |
| — 275 kV Lines | ■ Thermal |
| — 220 kV Lines | ▲ Pumped Storage |
| — 110 kV Lines | ■ Wind |
| — HVDC Cables | ■ Tidal |
| — 220 kV Cables | ■ Solar |
| — 110 kV Cables | ■ Battery |
| ● 400 kV Stations | *Some may be a mix |
| ● 275 kV Stations | |
| ● 220 kV Stations | |
| ● 110 kV Stations | |
| ⊕ Phase Shifting Transformer | |




Figure 3-2 Ireland Transmission Network Showing Assumed Future Network Reinforcements

3.2.2 Distribution System

For the purposes of the constraints modelling, a simplified representation of the distribution system is used whereby all load and generation is assumed to be aggregated to the nearest transmission node.

Hence, this report does not account for the impact of constraints (if any) on the distribution network.

3.2.3 Ratings and Overload Ratings

The Ireland transmission system is operated to safely accommodate a single transmission asset loss (N-1 contingency). While formulating an optimum dispatch, system operation takes account of potential overloads that could be caused as a result of certain N-1 contingencies on the transmission system. When determining if the post-contingency flows are within limits, the system operator uses the overload rating of the apparatus or plant (for N-1) as well as the normal rating (for N flows). Where available, the overload rating is typically higher than the normal rating, but is only allowed in emergency conditions and for short periods of time. The overload rating is plant specific. The study is modelled to include the N-1 contingency monitoring.

This rating and overload rating are handled in Plexos.

3.2.4 Transmission Reinforcements

For each study year (2024, 2026 and Future Grid) a number of transmission reinforcements are added to the model. These additional transmission reinforcements include overhead line (OHL) and cable uprating as well as new build OHLs, cables and transformers.

A full list of the transmission reinforcements (new build and uprates) assumed in the constraints modelling is included in Appendix A.1 – A.3.

Customers should recognise that the reinforcements listed will be subject to a full analysis and optimisation process under EirGrid’s Framework for Grid Development before a decision is made to proceed with them. Inclusion of transmission reinforcement projects in this report is not confirmation that they will proceed, and other projects may be selected in their place. For the avoidance of doubt, any party making a decision based on this list should recognise that these are modelling assumptions only and should not be considered as a basis in fact. Additional information about reinforcements is available on the EirGrid website.

3.3 Demand

An introduction to the demand used in this report is provided in Section 2.

The demand profile shapes for Ireland and Northern Ireland are based on their 2018 historical demand profiles. The historical profiles are adjusted to reflect a future winter peak and annual energy value based on the All Island Generation Capacity Statement 2021 – 2030 median demand (for 2024 and 2026) and 2030 high demand (for Future Grid). The values used are shown in Table 3-1.

| Year | TER (TWh) | | | Transmission Winter Peak (GW) | | |
|-------------|-----------|------------------|--------------|-------------------------------|------------------|------------|
| | Ireland | Northern Ireland | All - Island | Ireland | Northern Ireland | All-Island |
| 2024 | 35.8 | 8.6 | 44.3 | 5.96 | 1.67 | 7.57 |
| 2026 | 37.5 | 8.6 | 46.1 | 6.14 | 1.69 | 7.77 |
| Future Grid | 46.5 | 9.5 | 56.0 | 7.04 | 1.80 | 8.75 |

Table 3-1 Forecast Demand and Peak for Study Years 2024, 2026 and Future Grid

The nodal distribution of the load used in the constraints modelling is consistent with the “All Island Ten Year Transmission Forecast Statement 2019”.

3.4 Interconnection

Existing Interconnection on the island consists of a tie line between Ireland and Northern Ireland plus two High Voltage Direct Current (HVDC) interconnectors to Great Britain (GB), referred to as the Moyle Interconnector and the East-West Interconnector (EWIC). This section describes the assumptions and modelling methodology used for interconnection in these studies.

3.4.1 North–South Tie Line

The connection of Ireland’s power system to Northern Ireland is achieved via a double circuit 275 kV line running from Louth to Tandragee. In addition to the main 275 kV double circuit, there are two 110 kV connections, one between Letterkenny in Co. Donegal and Strabane in Co. Tyrone, and the other between Corraclassy in Co. Cavan and Enniskillen in Co. Fermanagh.

The purpose of these 110 kV circuits is to provide support to either transmission system for certain conditions or in the event of an unexpected circuit outage. Phase shifting transformers in Strabane and Enniskillen are used to control the power flow under normal conditions.

It is assumed that the Letterkenny-Strabane and Corraclassy-Enniskillen 110 kV connections are not used to transfer power between the two control areas for the purposes of this modelling exercise.

EirGrid and SONI are also currently developing a 400 kV North-South Interconnector between Woodland in Ireland and Turleenan in Northern Ireland. The new North-South Interconnector is assumed to be in place for the 2026 and Future Grid scenarios.

Prior to the 400 kV North-South Interconnector being built, the existing Louth-Tandragee Interconnector is assumed to be limited. The assumption in this study is that flows are limited to 300 MW from South to North and 300 MW from North to South. When the 400 kV North-South Interconnector is in place, this limitation will be effectively removed.

3.4.2 Moyle Interconnector

The Moyle Interconnector, which went into commercial operation in 2002, connects the electricity grids of Northern Ireland and Great Britain between Ballycronan More (Islandmagee) and Auchencrosh (Ayrshire). It technically has a transfer capacity of 500 MW, however due to constraints on the transmission networks at either end this capacity can be reduced.

For the purposes of this study the Moyle Interconnector is assumed to have a 400 MW capacity for the 2024 and 2026 study horizons, this assumption is increased to 500 MW for the Future Grid scenario. An overview of the interconnector capacities can be seen in Table 3-2.

3.4.3 East–West Interconnector (EWIC)

The East-West Interconnector links the electricity grids of Ireland and Great Britain, from converter stations at Portan in Ireland to Shotton in Wales. It began commercial operation in December 2012.

The EWIC Interconnector is modelled for all study years with a maximum capacity of 500 MW.

3.4.4 Additional Interconnection

For 2026 studies, three separate scenarios for additional interconnection were studied. The core 2026 scenario includes a Greenlink interconnector with a capacity of 500 MW connecting Ireland to Great Britain. Two 2026 sensitivity studies were also included: one with no additional interconnectors; and one with the Greenlink interconnector as well as a Celtic interconnector with a capacity of 700 MW connecting Ireland to France.

For the Future Grid scenario, the Celtic interconnector with a capacity of 700 MW and the Greenlink interconnector with a capacity of 500 MW are both modelled.

3.4.5 Interconnector Capacities

The interconnector capacities used in the model are shown in Table 3-2.

| Interconnector Export/Import Capacity (MW) | 2024 | 2026 | 2026.i | 2026.ii | Future Grid |
|--|---------|---------|---------|---------|-------------|
| Moyle | 400/450 | 400/450 | 400/450 | 400/450 | 500/500 |
| EWIC | 500/500 | 500/500 | 500/500 | 500/500 | 500/500 |
| Greenlink | | | 500/500 | 500/500 | 500/500 |
| Celtic | | | | 700/700 | 700/700 |

Table 3-2 Interconnection Capacities

It is a study assumption that interconnectors can be used to export renewable energy, with the provision that, when calculating an annual average behaviour, it would be optimistic to assume that maximum interconnector export will always be available when required.

Based on historical flow analysis, the interconnectors to GB are modelled to have a full export capacity for 65% of the time. As a result of this the Moyle, EWIC and Greenlink interconnectors are modelled with an ability to export at full capacity for 65% of the time.

However, the Celtic interconnector's export capacity is de-rated by 20%, i.e. Celtic has an export rating of 560 MW in the model. This has been assumed as there will be times when the international market schedule will sometimes provide less export than could theoretically be possible. For example, the receiving country may not be in a position to accept large trades, the position of renewable energy in the day ahead market may be impacted by forecast error, etc.

3.5 Priority Dispatch

3.5.1 Priority Dispatch for Wind and Solar Generation

The priority dispatch of renewable generation is only applicable for generators connected before the 4th July 2019.

For this study, when applying generation reduction for over-supply reasons, priority generators are given a negative offer price in the model to ensure their priority in the dispatch. During generation re-dispatch for curtailment and constraint reasons, the renewable generators are all given a zero-offer price without a distinction being made between priority and non-priority generators³. As Plexos seeks to provide the most economical solution while satisfying all system constraints it consequently will run as much wind and solar generation as is possible.

3.6 Generation

An introduction and overview of the generation in this study is provided in Section 2. Additional detail is now provided in this section.

3.6.1 Conventional Generation

The model includes a portfolio of the thermal conventional generation in both Ireland and Northern Ireland.

³ These generator price assumptions have been applied for the purposes of modelling in this study. The final SEMC decision on the implementation of Articles 12 and 13 of the Clean Energy Package has yet to be published and may differ from the implementation used in this study.

The operating characteristics of the existing conventional generation employed in the modelling are principally based on the SEM Generator Dataset. In some instances, minor changes to the dataset are made due to additional information becoming available to the TSOs.

The technical dataset includes the following information:

1. Fuel type (e.g. gas, wind, coal etc.) including emissions rates;
2. Maximum and minimum operating output (MW);
3. Capacity state and heat rates (used to determine how much fuel is burnt to produce 1 MW of output power);
4. Ramp rates (important to determine how quickly a machine can change its power output);
5. Minimum up-time and downtime.

This technical data allows the Plexos software to calculate the cost of generating a megawatt of electrical energy for each generator in the model. Note that each generator has a different cost.

Other factors that influence the generation dispatch over an extended study horizon are:

- Generation commissioning and decommissioning;
- Generation outages;
- Generation emissions restrictions.

3.6.2 Conventional Generation Outages

Scheduled and forced conventional generator outages are modelled in Plexos using Scheduled Outage Durations (SODs) and Forced Outage Probabilities (FOPs).

For this study, the Forced Outage Probabilities are used. The FOPs employed are those used for the Dispatch Balancing Costs (DBC) 2020 – 2021 Forecast. Plexos generates forced outage patterns from the FOP and mean time to repair data, which provides a deterministic outage pattern against which the model dispatches generation against demand.

3.6.3 Renewable Generation

The amount of electrical energy output from renewable generation is generally described in terms of capacity factor. The capacity factor relates to the amount of energy that may be achieved from a renewable technology over the period of one calendar year. One factor in the energy yield difference is that solar PV does not produce electrical energy at night, but the wind can blow at any time of the day or night.

The values used in this study for solar and wind are listed in the following sections.

3.6.3.1 Solar

On average, solar profiles tend to have a fairly predictable shape. Figure 3-3 shows the average hourly energy output from solar PV over a one year period. The capacity factor for solar PV is largely dependent on latitude - the closer to the equator the higher the annual capacity factor. The solar capacity factor for a country like Spain will have a value of around 20%, i.e. double the output of Ireland.

The surface plot of Figure 3-3 highlights the typical Ireland solar profile characteristic. The lowest intensity of solar electrical output is in the four winter months November through to February with hourly values on average not exceeding 20%. As expected the solar electrical energy output is highest in the summer months with average hourly solar electrical output peaking in the 50-60% range.

The main point is that the solar electrical available energy is fairly predictable and is typically there during times of increasing electrical demand i.e. the morning load rise. However, the winter peak demand will not be met by solar.

Solar energy output may be reduced if it is located on a part of the network that has constraint issues.




Figure 3-3 Solar Energy Profile (Monthly Average – Hour of Day)

3.6.3.1.1 Solar Profiles

Solar generation is modelled in the analysis using an hourly solar power series at every transmission node where solar generation is connected.

To provide a representative solar series for Ireland, three solar profiles are used. The groupings used are shown in Figure 3-4. The capacity factors of the different profiles are shown in Table 3-3.

This approach captures the variation in solar energy when comparing solar farms in the south and solar farms in the north. Clearly, this approach does not consider hourly variations in solar power within each group, due to local cloud cover in that individual hour, etc. Since this study is focused on the over-supply, curtailment and constraint on the transmission system, it is reasonable to assume that these solar profiles capture the average behaviour of solar on the island.




Figure 3-4 Groupings Used for Solar Profiles in Model

| Solar | Capacity Factor |
|--------------|-----------------|
| Solar North | 10% |
| Solar Middle | 11% |
| Solar South | 12% |

Table 3-3 Capacity Factor of Solar Profiles

It should be noted that given that the profiles are averaged, the expected reduction in generation levels may be underestimated in this study.

3.6.3.2 Wind

This section details how wind generation on the island of Ireland is modelled in Plexos.

Wind generation is modelled using an hourly wind power series at every transmission node where wind generation is connected. To provide a representative wind series, wind profiles are used. In this study, wind profiles are used for all wind farms in an area, i.e. the same wind profiles are used for wind generators in a single area.

By using historical wind profiles, it is possible to account for the geographical variation of wind power across the island. The wind profiles for the study year for both Ireland and Northern Ireland are created using 2015 wind data (2015 was a comparatively high wind year). The capacity factors of these profiles are shown in Figure 3-5 and in Table 3-4.




Figure 3-5 Capacity Factor by Area for Wind

| Wind Regions | 2015 Capacity Factors for Future Windfarms |
|-------------------------|--|
| Ireland | |
| A | 33% |
| B | 35% |
| C | 36% |
| D | 40% |
| E | 36% |
| F | 36% |
| G | 33% |
| H1 | 34% |
| H2 | 33% |
| I | 36% |
| J | 33% |
| K | 42% |
| Offshore | 45% |
| Northern Ireland | |
| NI | 31% |

Table 3-4 Capacity Factors for Future Wind

Capacity Factor

The average wind generation capacity factor for Ireland using the historical 2015 wind profiles is 36%. This gives a capacity factor that is higher as a system average than has been achieved in recent years. This value is representative of a wind fleet that will include new onshore and offshore wind farms incorporating the latest available technology. Consultation with industry selected 2015 as a suitable wind year to use in this study.

3.6.3.3 Renewable Generation – Installed Capacity

Section 2 describes the renewable generation scenarios that are considered as part of this analysis. Some further detail is provided here.

A variety of renewable generation scenarios are included to take account of the possibility that not all generators will ultimately connect, and to give a view on the Total Dispatch Down seen under various renewable generation build out rates. The levels of installed solar and wind generation included in each scenario are shown in Table 3-5.

The Initial scenario includes currently connected renewable generation plus all renewable generation expected to be connected by end of 2023. The “ECP” scenario includes all renewable generation up to and including ECP 2.1. The 33% and 66% scenarios were created by scaling the outputs of generators assumed to connect post-2023 by 33% and 66% respectively.

| Gen Type (MW) | Initial | 33% | 66% | ECP | ECP + 1.7 GW offshore | ECP + 3.9 GW offshore |
|---------------|--------------|--------------|--------------|--------------|-----------------------|-----------------------|
| Solar | 1,245 | 1,804 | 2,380 | 2,939 | 2,939 | 2,939 |
| Wind | 4,957 | 5,388 | 5,833 | 6,264 | 6,264 | 6,264 |
| Wind Offshore | 0 | 0 | 0 | 0 | 1,720 | 3,932 |
| Totals | 6,202 | 7,192 | 8,212 | 9,202 | 10,922 | 13,134 |

Table 3-5 Connected and Contracted Solar and Wind Quantities in Ireland for Our Study Scenarios

3.6.3.4 Generation Controllability

Historically smaller (and some older) wind farms and solar generators are not controllable. The study methodology takes into account all uncontrollable wind and solar generation and does not include these generators in any output reduction calculations.

Generally, apart from some older windfarms, it is assumed that all wind farms are controllable if their MEC is greater than or equal to 5 MW (for generators which received a connection offer before 2015) or if their MEC is greater than or equal to 1 MW (after 2015). All solar farms with an MEC greater than or equal to 1 MW are assumed to be controllable.

3.6.3.5 Perfect Foresight – Wind Forecast

Building an economic power market model will always require input assumptions. One such assumption is that the climatic year will be from historical data. The use of historical data means that the power market model will create generation commitment and dispatch decisions based on the perfect foresight of wind and solar output. In real-time operation of the power system, this is not the case and there will be forecast errors associated with variable renewables and demand. Perfect foresight may mean that power market models show lower levels of curtailment since it may choose to de-commit units based on what it knows will happen. In reality, wind or demand forecast errors may mean that a different schedule of generators may be required than that modelled with perfect foresight.

3.7 System Operation

3.7.1 Safe Operation (Security Constrained N-1)

The basic principle of N-1 security in network planning states that if a component – e.g. a transformer or circuit – should fail in a network, then the network security must still be guaranteed and the remaining network resources must not be overloaded or must not exceed the short-term overload capability of the equipment. System voltage must also remain within permitted limits although Plexos, as a DC load flow analysis tool, does not monitor system voltage as part of this study.

EirGrid operates the Ireland transmission network to be N-1 secure. This Plexos study also monitors N-1 contingencies to ensure the results are valid for an N-1 secure network.

3.7.2 Operational Constraint Rules

This section presents the all-island operational constraints, which feed into the Plexos economic dispatch tool. The operational constraints cover System Non-Synchronous Penetration (SNSP), inertia, operating reserve requirements and minimum number of synchronous units required.

The purpose of this section is to define the set of operational constraints, and how these constraints may evolve over the proposed study horizons. Operational constraints are important as they define system limits that may require reductions in renewable generation, resulting in curtailment. In general, it is expected that certain operational constraints may be relaxed over time, as the system evolves.

3.7.2.1 System-Wide Operational Constraints

There are a number of system-wide operational constraints which ensure that the system operators can operate the system securely and within stability limits.

This study uses the operational constraints listed in Table 3-6 and Table 3-8. The RoCoF limit was not monitored in the Plexos study but is included in Table 3-6 for information.

| Active System Wide Operational Constraints (SNSP, Inertia & Minimum Sets) | | |
|---|---|---|
| Limit | Operational Constraint Rule | Limit Across the Study Years |
| System Non-Synchronous Penetration (SNSP) | There is a requirement to limit the instantaneous penetration of asynchronous generation connected to the all island system. | 80% - 2024 85% - 2026 95% - Future Grid |
| Operational Limit for Inertia | There is a requirement to have a minimum level of inertia on the all-island system. | 20,000 MWs - 2024 17,500 MWs - 2026 15,000 MWs - Future Grid |
| RoCoF | Maximum acceptable Rate of Change of Frequency on the system for the loss of a large infeed (e.g. trip of an interconnector or generator) | 1 Hz/s - 2024, 2026 & Future Grid |
| Minimum sets | Minimum number of synchronous machines required to be on load in each jurisdiction. | 4 IE & 3 NI - 2024 4 IE & 2 NI - 2026 2 IE & 2 NI - Future Grid |

Table 3-6 Active System Wide Operational Constraints (SNSP, Inertia & Minimum Sets)

3.7.2.2 System Non-Synchronous Penetration (SNSP)

There is a system need to limit the amount of ‘non-synchronous’ generation at any point in time. The limit ensures that the power system operates within a stable zone.

A mathematical expression describing the SNSP rule is as follows:

$$\frac{\text{All Island Asynchronous Generation} + \text{Interconnector Imports}}{\text{All Island Demand} + \text{Interconnector Exports}} \leq \text{SNSP Limit}$$

An increase in the SNSP limit will allow more ‘non-synchronous’ generation to be accepted onto the system.

3.7.2.3 Minimum Number of Synchronous Generators

There is a requirement to have a minimum number of conventional generators synchronised at all times to provide inertia to the power system, ensure voltage stability, dynamic stability and to ensure that network limitations (line loading and system voltages) are respected. The minimum number of units in each study horizon is given in Table 3-6.

Changes to the rules are guided by operational and/or planning assumptions. Table 3-7 provides the current requirements for minimum number of conventional units required on the system.

| Minimum Conventional Generation Assumptions |
|--|
| Ireland |
| A minimum of 2 large units in the Dublin region must be synchronised at all times. |
| A minimum of 5 large units in Ireland must be synchronised at all times. |
| Northern Ireland |
| A minimum of 3 large units in Northern Ireland must be synchronised at all times. |

Table 3-7 Summary of Current Conventional Minimum Generation Assumptions

3.7.2.4 Operating Reserve

Operating reserve is surplus operating capacity that can instantly respond to a sudden increase in load or decrease in generation output. Operating reserve provides a safety margin that helps ensure reliable electricity supply despite variability in the load and generation. To provide reserve, some generators are part-loaded i.e. are operated below their maximum output capacity to provide a fast-acting source of reserve. Reserve can also be provided by non-conventional sources such as batteries, storage, interconnectors and demand response, and the future, it is expected that a greater share of reserve may be maintained by such non-conventional sources.

The system wide operating reserve requirements that are used in these studies are shown in Table 3-8.

| Operating Reserve Requirements | |
|--------------------------------|---|
| Limit | Operational Constraint rule |
| Primary Reserve | All Island primary reserve must be at least 75% of the largest in-feed with jurisdictional limits of: Ireland: 155 MW (daytime) and 150 MW (night time) Northern Ireland: 50 MW |

Table 3-8 Active System Wide Operating Reserve Constraints

4 Study Methodology

4.1 Introduction

This section provides an overview of the modelling methodology employed to determine the likely over-supply, curtailment and constraint levels for renewable generation in this study.

The methodology of production cost modelling is utilised to conduct the studies for this report. This section includes a detailed description of production cost modelling, and an overview of Plexos (the modelling tool employed) is also provided. In addition, there is a description of the over-supply, curtailment and constraint modelling methodology.

4.2 Production Cost Modelling

In general terms, production cost models utilise optimisation algorithms with the objective of minimising the cost of generating power to meet demand in a region while satisfying operational, security and environmental constraints. A production cost model minimises the combined fuel cost, CO₂ cost, and variable operation, maintenance and start-up cost. In the model, wind and solar generation are variable sources with zero production cost. Hydro generation also has zero production cost but is energy limited. Chronological production cost models optimise generator commitment and dispatch scheduling for every hour of a study period (typically one-year duration).

Production cost models require:

- Specification of individual generator capabilities including capacity, start-up energy, annual forced outage rate, annual scheduled outage duration, reserve provision capabilities, emission rates and heat rates (fuel input requirement per unit output generation).
- Specification of the hourly demand profile for the region.
- Specification of the fuel price for each type of fuel.
- Specification of the transmission network (required for studies where transmission constraint information is the desired output).
- Specification of contingencies.
- System security constraints such as the requirement for reserve.
- Generator operational constraints such as maximum and minimum operational levels, ramp rates, minimum runtimes and downtimes etc.
- Environmental considerations such as the cost of CO₂.

The commercially available production cost modelling tool employed in this study is Plexos.

4.3 The Software: Plexos Integrated Energy Model

Plexos is a detailed generation and transmission analysis program that has been widely used in the electricity industry for many years. EirGrid has extensive experience in using this simulation tool to model the Irish power system. It is a production cost modelling simulation program, used to determine power system performance and cost. It is a complex and powerful tool for power system analysis, with separate commitment and dispatch algorithms.

Commitment and Dispatch

The commitment process refers to the selection of a number of generators, from the total generation portfolio, that are available to meet customer demand. The decision as to when these generators should come on or off-line is also part of the commitment process. So, for example, additional generation is committed on Monday mornings in order to meet higher weekday (than weekend) demand.

The dispatch process refers to the decisions taken on the loading of individual generation units. Thus, the contribution from each online, or committed, unit towards meeting customer demand is determined by the dispatch decision.

Generator, Demand and Network

Full technical performance characteristics and operational cost details of each generation unit on the system are specified. An hourly system demand profile is also required. In this study, the transmission system is also modelled.

The program output provides complete details of the operation of each generation unit. These are aggregated into system totals. Flows on transmission lines can be monitored and potential constraints on the system can be identified. A wide range of output reports are available, from system summaries to hour-by-hour information on individual generators.

DC Loadflow

Plexos is a DC loadflow simulation tool. Therefore, it only models real power flows and does not consider voltage. Transmission plant and line ratings are MVA rated and ratings vary with voltage. For the purposes of modelling the DC load flow MW ratings for the circuits, the model assumes a conversion factor of 0.9.

The conversion factor allows the necessary spare capacity for reactive power on the circuits and it allows for post-contingency low voltage. This 0.9 conversion factor gives a good performance for a wide range of pre-contingency and post-contingency conditions.

The Plexos model, as constructed, does not account for losses. However, losses are accounted for within the Total Electricity Requirement (TER) demand figures.

4.4 System Model

For this study, the system is modelled at generator level i.e. each conventional generator is modelled in detail. Characteristics such as heat rates, ramp rates, minimum runtime and downtime, start-up energy, reserve provision capabilities, annual forced outage rate, annual scheduled outage duration and emission rates of each individual generator are specified.

Solar and wind powered generators are modelled at 110 kV node level. In other words, if several windfarms are fed from a 110 kV node, the model represents them as a single windfarm at that node. The same is true for solar farms. These generators use hourly generation profiles series. More detail on the modelling of solar and wind powered generation is provided in Section 3.6.3.

Ireland and Northern Ireland are treated as a single dispatch system in the production cost model for the purposes of producing an optimal minimum cost commitment and dispatch. Generators are dispatched based

on their short-run marginal costs (which include the costs of fuel and CO₂ emissions) and in accordance with the dispatch assumptions outlined below.

4.5 Software Determination of Over-Supply, Curtailment and Constraint

For this report, wind and solar generators are assumed to be Grid Code compliant and it is assumed that controllable wind and solar generators can be instructed to reduce their output if required. It is worth noting that there are a small number of older wind turbine sites that are uncontrollable, as mentioned in Section 3.6.3.4.

The Plexos model is used to calculate over-supply, curtailment and constraint. A number of supplementary studies are also needed to properly apportion each of these three types of reduction in generator output.

In the simulation, generators are committed and dispatched in the most economical manner while satisfying operational and security constraints such as limitations on the instantaneous wind/solar penetration, operating reserve requirements, requirement for a minimum number of synchronised conventional generators, system inertia limits, as well as the limitations of the transmission network.

The simulation is a security constrained N-1 study. This means that the network flows are constantly monitored to be safe against the possible loss of any item of transmission equipment.

The total reduction in energy for each renewable generator is calculated by comparing the renewable energy output from the simulation with the available renewable energy.

4.6 Apportioning of Over-Supply, Curtailment and Constraint

Over-supply

Per Article 12 of the EU's Clean Energy Package, priority dispatch of renewable generation will continue to apply only to generators which connected prior to July 4th 2019.

For this study, during generation reduction for over-supply reasons, a distinction is made between the treatment of priority and non-priority renewable generators, and non-priority generators are dispatched down ahead of priority generators. Within, these two categories of generation, over-supply is applied pro-rata across the all-island system for all generators in the category.

Curtailment

For hours when it is necessary to curtail wind and solar generation output, a decision has to be made as to which generators should have their output reduced. It is assumed in this study that, where possible, all controllable wind and solar generators share the reduction in output energy arising from curtailment in proportion to their available energy in that hour i.e. on a pro-rata basis.

Constraint

When a transmission constraint occurs, Plexos will attempt to alleviate the constraint in the most cost-effective manner.

If a transmission constraint causes wind or solar generation to be constrained down, Plexos' internal dispatch logic may choose one generator to constrain down out of several that have the same flow impact on the constraint (due to the fact that, in the constraints model, all wind and solar generators are modelled with zero cost of production).

This report studies the connection of very large amounts of generation to the transmission network. As such, there are some areas where the levels of transmission constraints are both large and frequent. There are also areas where there are, at times, several overlapping operational and transmission constraints. This makes it more difficult to apportion curtailment and constraints to individual nodes.

Post-processing of the results is required to ensure study results are more representative of the application of a constraint instruction. The process involves sharing the constraint volume proportionally between generators that have a similar impact on a constraint issue.

5 Results Summary for Ireland

This section provides a summary of the Total Dispatch Down levels estimated by this study at a system level for Ireland.

Results are shown for the core study scenarios consisting of:

- Study year scenarios 2024 (with no future interconnection) and 2026i (with one future interconnector – Greenlink);
- Renewable generation scenarios Initial, 33%, 66% and ECP.

Results are also shown for the sensitivity study scenarios that were developed in consultation with industry, and in response to industry feedback, consisting of:

- Two 2026 sensitivity studies considering the impact of varying levels of future interconnection: 2026 (with no future interconnection) and 2026ii (with two future interconnectors – Greenlink and Celtic);
- A Future Grid study based on 2030 demand levels and aligned with the network from the SOEF Roadmap.
- Two offshore wind scenarios: ECP + 1.7 GW offshore (2026 and 2030) and ECP + 3.9 GW offshore (2030);

Figure 5-1, Figure 5-2 and Figure 5-3 provide an overview of:

- System Total Dispatch Down percentage levels; broken down by over-supply, curtailment and constraint.
- System Total Dispatch Down and wind and solar generated energy levels in TWh; broken down by over-supply, curtailment and constraint.
- Total Dispatch Down percentage levels per area; broken down by over-supply, curtailment and constraint.

In general, a reduction in Total Dispatch Down levels is seen in later study years due to the benefits of network reinforcements, future interconnection, relaxation of operational constraints and increased demand levels.

An increase in Total Dispatch Down levels is seen for the offshore sensitivity studies, which is largely driven by over-supply.

More detailed results for Area K can be seen in Section 6.

System Dispatch Down (%)




Figure 5-1 System Total Dispatch Down %

Total Dispatch Down and Generation (Wind and Solar)




Figure 5-2 Total Dispatch Down and Generation (Wind and Solar)

Dispatch Down % per Area




Figure 5-3 Total Dispatch Down % per Area

6 Results for Area K

6.1 Introduction

This section provides the over-supply, curtailment and constraint results for Area K that are estimated by this analysis. There is a total of eight core ECP 2-1 studies and eight sensitivity studies presented in this report. The study scenarios and the associated assumptions can be found in Section 2 and Section 3. An overview and discussion of the results is provided in this Section. The over-supply, curtailment and constraint results for each node are provided in Appendix C.

6.2 Study Notes

A list of the major study assumptions is provided in Section 3. For Area K, it is worth mentioning the following again.

6.2.1 Network Outages

The scenarios in this report are intended to give a view of average long-term levels of over-supply, curtailment and constraint, subject to installed generation, demand, interconnection, operational constraints and reinforcement delivery.

A basis of the previous ECP 1 constraints analysis assumed that the existing network was available at all times. In reality, a transmission outage programme will be implemented each year resulting in outages of transmission circuits and other equipment for periods of time. Outages may be due to scheduled maintenance, forced outages, to facilitate new connections or for reinforcement reasons (e.g. circuit/busbar updates).

Transmission outages may increase generation constraints on the system and as a result of industry feedback following ECP 1, a representative transmission outage schedule has been included for this ECP 2.1 analysis. The outages included in this schedule represent a geographical spread of circuits across the system and are each configured for a three-month period. This allows a representation of outage impact in each geographical area to be included in the studies. Longer duration outages which may be required for certain connections, reinforcement works or forced outages are not considered and may result in higher wind and solar constraints. This representative transmission outage schedule is given in Appendix A – Table A-4.

6.2.2 Benefit of Capacity Factor

In practice a specific windfarm may be located at a site with higher wind speeds or may have a better performing type of wind turbine; the result is a higher capacity factor than neighbouring windfarms. This report doesn't reflect this localised diversity between windfarm sites, however, a windfarm with a higher capacity factor may see lower percentage over-supply, curtailment or constraint levels than an adjacent windfarm with a lower capacity factor. This is because at times of medium or low wind speed, the high capacity factor windfarm can generate power when the low capacity factor windfarm can not.

6.2.3 Notes on Over-supply, Curtailment and Constraint Modelling

Over-supply

During generation reduction for over-supply, a distinction is made between the treatment of priority and non-priority renewable generators, with non-priority generators being dispatched down ahead of priority generators. Within these two categories of generation, over-supply is applied pro-rata across the all-island

system for all renewable generators in the category.

For any hour of the study the over-supply level will depend on system demand and interconnector flows. In general, over-supply is expected to increase with increasing installed renewable capacity.

Curtailment

In this report, for each hour of the study, the curtailment is shared pro-rata on a system wide basis with no distinction made between priority and non-priority generators. This means that both curtailment reductions and curtailment increases are shared system wide.

Solar generation has different reported levels of curtailment compared to wind due to different capacity factors and annual profile shapes.

The applied curtailment is broadly constant across the system. However, due to differences in wind and solar profiles and capacity factors between areas, the percentage average curtailment differs between areas.

Constraints

During the constraint of renewable generation, no distinction is made between priority and non-priority generators, the dispatch down is applied across the relevant transmission nodes.

In general, there is a tendency for renewable bulk power to flow towards the demand in Dublin and the interconnectors. These flow patterns are relevant when seeking to understand constraint apportionment in the simulation.

When presented as percentage values, the constraint results look different for solar and wind, as they have a low correlation due to different profile shapes driven by weather patterns.

6.3 Generation Overview

A detailed system level overview of the renewable generation scenarios used in these studies is given in Section 2. The distribution of generation in each scenario based on technology, area and node is given in Appendix B. The node level installed wind and solar generation for Area K in the “ECP” scenario is given in Table 6-1.

| Node | SO | Status | Solar | Wind |
|----------------|-----|----------------|------------|-----------|
| Butlerstown | DSO | connected | | 2 |
| Butlerstown | DSO | due to connect | 27 | |
| Dungarvan | DSO | connected | | 5 |
| Dungarvan | DSO | due to connect | 74 | |
| Rathnaskilloge | TSO | due to connect | 95 | |
| Woodhouse | TSO | connected | | 20 |
| Woodhouse | TSO | due to connect | | 34 |
| Total | | | 196 | 61 |

Table 6-1 Wind and Solar Generation Summary in Area K for Generation Scenario “ECP”

Installed generation for each generation scenario (Ireland and Area K)

Table 6-2 and Table 6-3 show installed solar and wind generation for Ireland and Area K, and the available solar and wind generation for Area K for each generation scenario.

| Solar | Generation Scenario | | | | | |
|-------------------------------------|---------------------|-------|-------|-------|----------------------|----------------------|
| | Initial | 33% | 66% | ECP | ECP + 1.7GW offshore | ECP + 3.9GW offshore |
| Installed Ireland (MW) | 1,245 | 1,804 | 2,380 | 2,939 | 2,939 | 2,939 |
| Installed Area K (MW) | 122 | 146 | 171 | 196 | 196 | 196 |
| Installed Controllable Area K (MW) | 122 | 146 | 171 | 196 | 196 | 196 |
| Available Controllable Area K (GWh) | 132 | 158 | 185 | 212 | 212 | 212 |

Table 6-2 Installed MW and Available GWh for Area K – Solar

| Wind | Generation Scenario | | | | | |
|-------------------------------------|---------------------|-------|-------|-------|----------------------|----------------------|
| | Initial | 33% | 66% | ECP | ECP + 1.7GW offshore | ECP + 3.9GW offshore |
| Installed Ireland (MW) | 4,957 | 5,388 | 5,833 | 6,264 | 7,984 | 10,196 |
| Installed Area K (MW) | 61 | 61 | 61 | 61 | 61 | 61 |
| Installed Controllable Area K (MW) | 54 | 54 | 54 | 54 | 54 | 54 |
| Available Controllable Area K (GWh) | 197 | 197 | 197 | 197 | 197 | 197 |

Table 6-3 Installed MW and Available GWh for Area K – Wind

6.3.1 Connection Works and Generators

In the ECP generation scenario, 818 MW of contracted generation is identified as having Site Related Connection Equipment (SRCE). This means that those generators will not be permitted to connect until certain system works are complete. These works will not be complete by 2024 and are not included in the 2024 study. Consequently, the generators that are associated with these SRCE works are also not included in the 2024 study. In the connection contract, these are included in the Site Related Connection Equipment.

A per-area distribution of generation associated with SRCE per technology is given in Table 6-4.

| AREA | Solar (MW) | Wind (MW) | Total (MW) |
|--------------|--------------|--------------|--------------|
| B | - | 180.1 | 180.1 |
| F | - | 13.8 | 13.8 |
| G | 20.0 | - | 20.0 |
| H1 | - | 28.8 | 28.8 |
| H2 | 87.9 | 60.0 | 147.9 |
| J | 156.8 | 270.2 | 427.0 |
| Total | 264.7 | 552.9 | 817.6 |

Table 6-4 SRCE Generation not included in 2024 Study

6.4 Network Overview

Area K, in the south of the country, includes a mix of priority wind and non-priority solar and wind generators. A summary of generators is given in Table 6-1.

The transmission network in Area K and the surrounding areas is shown in Figure 6-1. The 400 kV circuits are shown in red, the 220 kV circuits in green and the 110 kV circuits in black. Possible future transmission stations and lines for the connection of new generation are also shown on the map below.



Figure 6-1 Network Map for Area K

For Area K, the dominant power flows tend to be towards the load centres on the east coast and the interconnectors. These flow patterns are relevant when seeking to understand constraint apportionment in the simulation.

Constraints in Area K can be caused both by local and wider system issues. Constraints in the model are optimised on a system-wide basis so, in theory, an increase in the installed generation in another area may increase constraints in Area K.

In addition to the power flows out of Area K, there are also power flows across or through Area K. Renewable power from the south west will flow across the transmission network and at least some of this power will flow through Area K.

The power flowing out of Area K meets and joins with power flows from other areas, as the power flows towards the demand centres and interconnectors. A transmission bottleneck between Area K and the east is shared with power flows coming from other areas.

6.5 Future Grid Sensitivity Scenario

In response to feedback from industry, a Future Grid scenario has been modelled as part of this analysis. All reasonable efforts have been made to align the network assumptions in the Future Grid scenario to the Shaping Our Electricity Future (SOEF) roadmap. The network projects included in the study are given in Appendix A – Table A-4. Note however that the wind and solar generation portfolio in the ECP 2.1 Future Grid scenario necessarily differs from the wind and solar portfolio considered in SOEF, in order to maintain compliance with the ECP 2.1 process. The ECP study includes all wind and solar projects which have applied through connection processes, whereas the SOEF study does not include the full set of wind and solar applicants.

The Future Grid study includes a base renewable generation scenario (ECP), along with two sensitivity generation scenarios (ECP + 1.7 GW offshore and ECP + 3.9 GW offshore). The latter two scenarios with additional offshore wind have been included to show the potential impact of increasing offshore wind on Total Dispatch Down levels.

The demand modelled for the Future Grid scenario is based on the high demand scenario for 2030 as published in the All-Island Generation Capacity Statement 2021-2030.

This study is not intended as an assurance to individual generators that their Total Dispatch Down will change to the estimated levels. Rather, it is a consideration of the potential impact of the SOEF reinforcement portfolio on the dispatch down of wind and solar generators. This study is not intended to be exhaustive and it is not intended to remove all transmission constraints.

6.6 Area K – Average Results

The Total Dispatch Down results for Area K are provided below in Table 6-5 to Table 6-7 and Figure 6-2 to Figure 6-4. These include the breakdown between over-supply, curtailment and constraint. The Total Dispatch Down percentages are based on the total available energy. The Total Dispatch Down is the sum of over-supply, curtailment and constraint. The node level breakdown of over-supply, curtailment and constraint are given in Appendix C.

For each generation type in Area K (solar not priority, wind not priority and wind priority), the total installed capacity in MW and total available generation in GWh are given in Table 6-5, Table 6-6 and Table 6-7. The total generation in GWh, after dispatch down and corresponding percentage Total Dispatch Down are also included in the tables for each scenario. Details on the generation and network scenarios are given in Section 2.

6.6.1 Interconnector and Offshore Wind Sensitivity Studies

Results for the interconnector and offshore wind-based sensitivity studies are also included, along with results for the core scenarios. The general trend with increases in interconnector capacity is a reduction in the Total Dispatch Down, largely due to decreases in over-supply. Increasing levels of offshore wind on the other hand, result in increases in the Total Dispatch Down due to significant increases in the available wind energy, resulting in increased levels of over-supply.

6.6.2 Impact of Article 12

Higher Total Dispatch Down is observed for non-priority generators due to the impact of the implementation of Article 12 in the studies, which results in non-priority generators being reduced ahead of priority generators for over-supply reasons.

6.6.3 Future Grid Sensitivity Study

The results of the Future Grid scenario show a notable reduction in Total Dispatch Down over the core study years (2024 and 2026) due to the impact of the SOEF network reinforcements, increased demand levels in 2030 and the relaxation of operational constraints in 2030. However, increases in installed wind and solar generation, as seen in the offshore wind scenarios, result in rising over-supply levels, resulting in an increase in Total Dispatch Down. A detailed impact on Area K in the Future Grid and associated sensitivity case is given in Table 6-5, Table 6-6 and Table 6-7. Further node level details can be viewed in Appendix C.

6.6.4 Area Subgroups

There is often a post-processing step between the Plexos simulation and this report. This is necessary if a subgroup of nodes within the area has noticeably different constraint levels from another subgroup as a result of the network topology. This step is not required for Area K. Within Area K, all the nodes have similar levels of constraints and there is no need to prepare subgroups.

| SOLAR NOT PRIORITY | | | | | | | |
|-------------------------|-------------------------|---------|-------|-------|-------|----------------------|----------------------|
| AREA K | Year | Initial | 33% | 66% | ECP | ECP + 1.7GW Offshore | ECP + 3.9GW Offshore |
| Installed (MW) | 2024 | 122 | 146 | 171 | 196 | | |
| Installed (MW) | 2026 | | | | 196 | 196 | |
| Installed (MW) | 2026 with GL | 122 | 146 | 171 | 196 | 196 | |
| Installed (MW) | 2026 with GL and Celtic | | | | 196 | 196 | |
| Installed (MW) | Future Grid | | | | 196 | 196 | 196 |
| Available Energy (GWh) | 2024 | 131.8 | 158.1 | 185.3 | 211.7 | | |
| Available Energy (GWh) | 2026 | | | | 211.5 | 211.5 | |
| Available Energy (GWh) | 2026 with GL | 131.7 | 158.0 | 185.1 | 211.5 | 211.5 | |
| Available Energy (GWh) | 2026 with GL and Celtic | | | | 211.5 | 211.5 | |
| Available Energy (GWh) | Future Grid | | | | 211.5 | 211.5 | 211.5 |
| Generation (GWh) | 2024 | 117.2 | 136.7 | 154.5 | 168.8 | | |
| Generation (GWh) | 2026 | | | | 180.6 | 171.7 | |
| Generation (GWh) | 2026 with GL | 121.7 | 141.9 | 161.6 | 177.2 | 170.9 | |
| Generation (GWh) | 2026 with GL and Celtic | | | | 199.8 | 191.9 | |
| Generation (GWh) | Future Grid | | | | 200.9 | 200.0 | 189.0 |
| Over-supply (%) | 2024 | 0% | 1% | 2% | 3% | | |
| Over-supply (%) | 2026 | | | | 3% | 9% | |
| Over-supply (%) | 2026 with GL | 0% | 0% | 1% | 2% | 7% | |
| Over-supply (%) | 2026 with GL and Celtic | | | | 1% | 4% | |
| Over-supply (%) | Future Grid | | | | 0% | 2% | 7% |
| Curtailment (%) | 2024 | 1% | 2% | 2% | 3% | | |
| Curtailment (%) | 2026 | | | | 2% | 4% | |
| Curtailment (%) | 2026 with GL | 0% | 1% | 1% | 2% | 3% | |
| Curtailment (%) | 2026 with GL and Celtic | | | | 1% | 3% | |
| Curtailment (%) | Future Grid | | | | 0% | 1% | 2% |
| Constraint (%) | 2024 | 10% | 11% | 13% | 14% | | |
| Constraint (%) | 2026 | | | | 9% | 6% | |
| Constraint (%) | 2026 with GL | 7% | 10% | 11% | 12% | 9% | |
| Constraint (%) | 2026 with GL and Celtic | | | | 4% | 2% | |
| Constraint (%) | Future Grid | | | | 4% | 2% | 1% |
| Total Dispatch Down (%) | 2024 | 11% | 14% | 17% | 20% | | |
| Total Dispatch Down (%) | 2026 | | | | 15% | 19% | |
| Total Dispatch Down (%) | 2026 with GL | 8% | 10% | 13% | 16% | 19% | |
| Total Dispatch Down (%) | 2026 with GL and Celtic | | | | 6% | 9% | |
| Total Dispatch Down (%) | Future Grid | | | | 5% | 5% | 11% |

Table 6-5 Over-supply, Curtailment and Constraint for Solar Not Priority in Area K

SOLAR NOT PRIORITY AREA K




Figure 6-2 Results Solar Not Priority Area K

| WIND NOT PRIORITY | | | | | | | |
|------------------------|-------------------------|---------|-------|-------|-------|----------------------|----------------------|
| AREA K | Year | Initial | 33% | 66% | ECP | ECP + 1.7GW Offshore | ECP + 3.9GW Offshore |
| Installed (MW) | 2024 | 34.0 | 34.0 | 34.0 | 34.0 | | |
| Installed (MW) | 2026 | | | | 34.0 | 34.0 | |
| Installed (MW) | 2026 with GL | 34.0 | 34.0 | 34.0 | 34.0 | 34.0 | |
| Installed (MW) | 2026 with GL and Celtic | | | | 34.0 | 34.0 | |
| Installed (MW) | Future Grid | | | | 34.0 | 34.0 | 34.0 |
| Available Energy (GWh) | 2024 | 124.5 | 124.5 | 124.5 | 124.5 | | |
| Available Energy (GWh) | 2026 | | | | 124.0 | 124.0 | |
| Available Energy (GWh) | 2026 with GL | 124.0 | 124.0 | 124.0 | 124.0 | 124.0 | |
| Available Energy (GWh) | 2026 with GL and Celtic | | | | 124.0 | 124.0 | |
| Available Energy (GWh) | Future Grid | | | | 124.0 | 124.0 | 124.0 |
| Generation (GWh) | 2024 | 106.0 | 103.2 | 100.4 | 97.1 | | |
| Generation (GWh) | 2026 | | | | 101.7 | 88.2 | |
| Generation (GWh) | 2026 with GL | 112.8 | 109.5 | 107.0 | 103.1 | 89.8 | |
| Generation (GWh) | 2026 with GL and Celtic | | | | 117.3 | 105.4 | |
| Generation (GWh) | Future Grid | | | | 117.8 | 114.9 | 100.8 |
| Over-supply (%) | 2024 | 1% | 3% | 5% | 7% | | |
| Over-supply (%) | 2026 | | | | 6% | 18% | |
| Over-supply (%) | 2026 with GL | 0% | 1% | 2% | 3% | 14% | |
| Over-supply (%) | 2026 with GL and Celtic | | | | 1% | 8% | |
| Over-supply (%) | Future Grid | | | | 0% | 3% | 14% |
| Curtailment (%) | 2024 | 2% | 3% | 4% | 5% | | |
| Curtailment (%) | 2026 | | | | 4% | 6% | |
| Curtailment (%) | 2026 with GL | 1% | 1% | 2% | 3% | 5% | |
| Curtailment (%) | 2026 with GL and Celtic | | | | 2% | 5% | |
| Curtailment (%) | Future Grid | | | | 0% | 2% | 4% |

| | | | | | | | |
|-------------------------|-------------------------|-----|-----|-----|-----|-----|-----|
| Constraint (%) | 2024 | 11% | 11% | 11% | 11% | | |
| Constraint (%) | 2026 | | | | 8% | 5% | |
| Constraint (%) | 2026 with GL | 8% | 10% | 10% | 10% | 8% | |
| Constraint (%) | 2026 with GL and Celtic | | | | 3% | 2% | |
| Constraint (%) | Future Grid | | | | 4% | 1% | 1% |
| Total Dispatch Down (%) | 2024 | 15% | 17% | 19% | 22% | | |
| Total Dispatch Down (%) | 2026 | | | | 18% | 29% | |
| Total Dispatch Down (%) | 2026 with GL | 9% | 12% | 14% | 17% | 28% | |
| Total Dispatch Down (%) | 2026 with GL and Celtic | | | | 5% | 15% | |
| Total Dispatch Down (%) | Future Grid | | | | 5% | 7% | 19% |

Table 6-6 Over-supply, Curtailment and Constraint for Wind Not Priority in Area K

WIND NOT PRIORITY AREA K




Figure 6-3 Results Wind Not Priority Area K

| WIND PRIORITY | | | | | | | |
|------------------------|-------------------------|---------|------|------|------|----------------------|----------------------|
| AREA K | Year | Initial | 33% | 66% | ECP | ECP + 1.7GW Offshore | ECP + 3.9GW Offshore |
| Installed (MW) | 2024 | 20 | 20 | 20 | 20 | | |
| Installed (MW) | 2026 | | | | 20 | 20 | |
| Installed (MW) | 2026 with GL | 20 | 20 | 20 | 20 | 20 | |
| Installed (MW) | 2026 with GL and Celtic | | | | 20 | 20 | |
| Installed (MW) | Future Grid | | | | 20 | 20 | 20 |
| Available Energy (GWh) | 2024 | 73.2 | 73.2 | 73.2 | 73.2 | | |
| Available Energy (GWh) | 2026 | | | | 72.9 | 72.9 | |
| Available Energy (GWh) | 2026 with GL | 72.9 | 72.9 | 72.9 | 72.9 | 72.9 | |
| Available Energy (GWh) | 2026 with GL and Celtic | | | | 72.9 | 72.9 | |
| Available Energy (GWh) | Future Grid | | | | 72.9 | 72.9 | 72.9 |
| Generation (GWh) | 2024 | 63.1 | 62.0 | 61.4 | 60.6 | | |
| Generation (GWh) | 2026 | | | | 62.7 | 61.9 | |

| | | | | | | | |
|-------------------------|-------------------------|------|------|------|------|------|------|
| Generation (GWh) | 2026 with GL | 66.6 | 64.7 | 63.8 | 62.4 | 60.6 | |
| Generation (GWh) | 2026 with GL and Celtic | | | | 69.3 | 67.1 | |
| Generation (GWh) | Future Grid | | | | 69.3 | 69.3 | 68.2 |
| Over-supply (%) | 2024 | | | | | | |
| Over-supply (%) | 2026 | | | | | | |
| Over-supply (%) | 2026 with GL | | | | | | |
| Over-supply (%) | 2026 with GL and Celtic | | | | | | |
| Over-supply (%) | Future Grid | | | | | | |
| Curtailement (%) | 2024 | 3% | 4% | 5% | 6% | | |
| Curtailement (%) | 2026 | | | | 6% | 9% | |
| Curtailement (%) | 2026 with GL | 1% | 1% | 2% | 4% | 7% | |
| Curtailement (%) | 2026 with GL and Celtic | | | | 2% | 6% | |
| Curtailement (%) | Future Grid | | | | 0% | 3% | 5% |
| Constraint (%) | 2024 | 11% | 12% | 11% | 11% | | |
| Constraint (%) | 2026 | | | | 8% | 6% | |
| Constraint (%) | 2026 with GL | 8% | 10% | 10% | 11% | 10% | |
| Constraint (%) | 2026 with GL and Celtic | | | | 3% | 2% | |
| Constraint (%) | Future Grid | | | | 5% | 2% | 1% |
| Total Dispatch Down (%) | 2024 | 14% | 15% | 16% | 17% | | |
| Total Dispatch Down (%) | 2026 | | | | 14% | 15% | |
| Total Dispatch Down (%) | 2026 with GL | 9% | 11% | 12% | 14% | 17% | |
| Total Dispatch Down (%) | 2026 with GL and Celtic | | | | 5% | 8% | |
| Total Dispatch Down (%) | Future Grid | | | | 5% | 5% | 7% |

Table 6-7 Over-supply, Curtailment and Constraint for Wind Priority in Area K




Figure 6-4 Results Wind Priority Area K

6.7 Conclusion – Results for Area K

This section provides an overview of the estimated over-supply, curtailment and constraint values for Area K for a range of scenarios based on a number of installed generation assumptions (generation scenarios) and the study year (network and demand assumptions). The results highly depend on the study assumptions, which are described in this report.

Appendix C contains the detailed results consisting of energy (GWh), percentage over-supply, curtailment and constraint values for each node for both solar and wind in Area K.

Appendix A – Network Reinforcement & Maintenance

A.1 Reinforcements in 2024

The table below lists the reinforcements, additional to the current network, that are included in the 2024 study scenario.

| Project Type | Project | Year |
|--------------------|---|------|
| Station | Aghada 220 kV Station busbar reconfiguration | 2024 |
| Station | Agivey 110/33 kV cluster substation | 2024 |
| Uprate | Arva - Carrick on Shannon 110 kV uprate (circuit 1) | 2024 |
| Uprate | Ballylumford - Eden 110 kV uprate | 2024 |
| Uprate | Ballynahulla - Ballyvouskil 220 kV uprate | 2024 |
| Uprate | Ballynahulla - Knockanure 220 kV uprate | 2024 |
| Static Compensator | Ballynahulla station - statcom | 2024 |
| New Build | Ballyragget - Kilkenny 110 kV line | 2024 |
| Reactive Support | Ballyvouskil Temporary 50 Mvar reactor | 2024 |
| Static Compensator | Ballyvouskill station - statcom | 2024 |
| New Build | Belcamp Shellybanks 220 kV Cable | 2024 |
| SPS | Bellacorick Special Protection Scheme | 2024 |
| Uprate | Binbane - Cathaleen's Fall 110 kV uprate (circuit 1) | 2024 |
| Uprate | Cashla - Salthill 110 kV uprate (circuit 1) | 2024 |
| Uprate | Castlebar - Cloon 110 kV uprate (circuit 1) | 2024 |
| Station | Clashavoon 250 MVA transformer and couple 110 kV | 2024 |
| Uprate | Coolkeeragh - Magherafelt 275 kV uprate (OHL part to Redwood) | 2024 |
| Uprate | Coolnabacky - Portlaoise 110 kV uprate (circuit 1) | 2024 |
| Uprate | Corduff - Ryebrook 110 kV uprate | 2024 |
| New Build | Corduff T2103 - 220 kV Station Deep Reinforcement Works | 2024 |
| Uprate | Drybridge - Oldbridge - Platin 110 kV uprate (Oldbridge Amazon) | 2024 |
| Uprate | Flagford - Louth 220 kV solve derate - restore rating to this circuit | 2024 |
| Uprate | Flagford - Sliabh Bawn 110 kV uprate (circuit 1) | 2024 |
| Uprate | Galway - Knockranny 110 kV uprate (when Galway station redevelops) | 2024 |
| Station | Galway 110 kV station redevelopment project | 2024 |
| Uprate | Gorman - Platin 110 kV uprate | 2024 |
| Uprate | Great Island - Kilkenny 110 kV uprate (circuit 1) | 2024 |
| Station | Kells 110/33 kV cluster substation | 2024 |
| New Build | Kellystown new 220 kV station | 2024 |
| Station | Kilbarry 110 kV GIS Station | 2024 |
| New build | Kilpaddoge - Knockanure 220 kV cable | 2024 |
| New build | Kilpaddoge - Moneypoint 400 kV Project (Cross Shannon) | 2024 |
| Station | Kinnegad 110 kV Station, Derryiron 110 kV Bay Conductor Uprate | 2024 |
| Reactive Support | Knockanure reactor | 2024 |
| Uprate | Knockraha - Raffeen 220 kV line refurbishment and fix derate | 2024 |
| Station | Knockraha 220 kV busbar station & installation of additional couplers | 2024 |
| Uprate | Lanesboro - Mullingar 110 kV uprate (circuit 1) | 2024 |
| Uprate | Lanesboro - Sliabh Bawn 110 kV uprate (circuit 1) | 2024 |
| Station | Lanesboro 110 kV station redevelopment project | 2024 |
| Uprate | Maynooth - Woodland 220 kV uprate | 2024 |
| Transformer | Moneypoint T4202 fix derate | 2024 |
| New Build | North Connacht 110 kV Project & Flagford - Tonroe 110 kV uprate | 2024 |

| | | |
|--------|---|------|
| Uprate | Omagh Main - Dromore 110 kV uprate | 2024 |
| SNSP | SNSP 80% (70% at present - please note that the TSOs on 22nd April 2021 commenced a 75% SNSP trial) | 2024 |

Table A-1 Reinforcements included in the 2024 study

A.2 Reinforcements in 2026

The table below lists the network reinforcements included in the 2026 study scenario, additional to the network in the 2024 study scenario.

| Project Type | Project | Year |
|------------------|---|------|
| Uprate | Bandon - Dunmanway 110 kV uprate (circuit 1) | 2026 |
| Uprate | Cahir - Barrymore 110 kV uprate | 2026 |
| New Build | Celtic Interconnector | 2026 |
| Station | Coolnabacky Station 400 kV - new station and associated lines and station works | 2026 |
| Uprate | Dalton busbar uprate | 2026 |
| Series Capacitor | Dunstown 400 kV Series Capacitor | 2026 |
| New Build | Greenlink Interconnector | 2026 |
| Uprate | Louth - Ratrussan 110 kV uprate | 2026 |
| New Build | Mid Antrim project | 2026 |
| Series Capacitor | Moneypoint 400 kV Series Capacitor | 2026 |
| Uprate | Moy - Glenree 110 kV uprate (circuit 1) | 2026 |
| New Build | North South 400 kV Interconnector | 2026 |
| Series Capacitor | Oldstreet 400 kV Series Capacitor | 2026 |

Table A-2 Reinforcements included in the 2026 study scenario, additional to 2024 study reinforcements

A.3 Reinforcements in Future Grid

The table below lists the reinforcements, additional to the current network, that are included in the Future Grid study scenario.

| Project Type | Project | Year |
|--------------------|---|-------------|
| Station | Aghada Station Busbar Reconfiguration | Future Grid |
| Upvoltage | Arklow - Ballybeg - Carrickmines 220 kV (circuit 1) | Future Grid |
| Uprate | Arva - Carrick On Shannon 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Athlone - Lanesboro 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Athy - Carlow 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Ballylumford - Eden 110 kV uprate | Future Grid |
| Static Compensator | Ballynahulla Station - Statcom | Future Grid |
| Uprate | Ballyvouskill - Ballynahula - Knockanure 220 kV uprate | Future Grid |
| Static Compensator | Ballyvouskill 220/110 kV Station - Statcom | Future Grid |
| Uprate | Bandon - Dunmanway 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Baroda - Monread 110 kV uprate (circuit 1) | Future Grid |
| DLR | Baroda - Newbridge 110 kV (circuit 1) | Future Grid |
| DLR | Bellacorrick - Castlebar 110 kV (circuit 1) | Future Grid |
| Uprate | Binbane - Cathaleen's Fall 110 kV uprate (circuit 1) | Future Grid |
| New Build | Binbane - Clogher - Cathaleen's Fall - 110 kV Clogher tie in | Future Grid |
| DLR | Cashla - Dalton 110 kV (circuit 1) | Future Grid |
| Uprate | Cashla - Salthill 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Castlebar - Cloon 110 kV uprate (circuit 1) | Future Grid |
| Station | Castlebar 110 kV station busbar | Future Grid |
| DLR | Cathaleen's Fall - Coraclassy 110 kV (circuit 1) | Future Grid |
| New Build | Clashavoon - Macroom No. 1 & associated station works & 250 MVA transformer | Future Grid |
| Uprate | Clashavoon - Tarbert 220 kV uprate (circuit 1) | Future Grid |
| New Build | Clogher - Srananagh 220 kV (circuit 1) | Future Grid |
| Uprate | Coleraine - Coolkeeragh 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Coolkeeragh - Killymallaght 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Coolkeeragh - Limavady 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Coolkeeragh - Magherafelt 275 kV Circuits Refurbishment | Future Grid |
| Uprate | Coolkeeragh - Strabane 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Coolnabacky - Portlaoise 110 kV uprate (circuit 1) | Future Grid |
| Station | Coolnabacky Station 400 kV - new station and associated lines and station works | Future Grid |
| Uprate | Corderry - Srananagh 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Crane - Wexford 110 kV uprate (circuit 1) | Future Grid |
| DLR | Cushaling - Newbridge 110 kV (circuit 1) | Future Grid |
| Station | Dalton busbar | Future Grid |
| Uprate | Derryiron - Kinnegad 110 kV uprate (circuit 1) | Future Grid |
| Reactive Support | Distributed Series Reactors Project (Nationwide) | Future Grid |
| Uprate | Drumkeen - Clogher 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Drumnakelly - Tamnamore 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Drumnakelly - Tamnamore 110 kV uprate (circuit 2) | Future Grid |
| Uprate | Drybridge - Louth 110 kV uprate (circuit 1) | Future Grid |
| Series Capacitor | Dunstown Series Capacitor | Future Grid |
| Uprate | Finglas - North Wall 220 kV uprate (circuit 1) | Future Grid |
| Uprate | Flagford - Sliabh Bawn 110 kV uprate (circuit 1) | Future Grid |
| Upvoltage | Flagford - Srananagh 110 kV (circuit 1) | Future Grid |
| Uprate | Galway - Salthill 110 kV uprate (circuit 1) | Future Grid |
| Station | Galway Station Redevelopment Project | Future Grid |
| Transformer | Gort second transformer | Future Grid |
| Uprate | Great Island - Kellis 220 kV uprate (circuit 1) | Future Grid |
| Uprate | Great Island - Kilkenny 110 kV uprate (circuit 1) | Future Grid |

| | | |
|--------------------|---|-------------|
| Transformer | Great Island 220/110 kV transformer No.3 | Future Grid |
| New Build | Inchicore - Carrickmines 220 kV (circuit 1) | Future Grid |
| Station | Kilbarry GIS Station | Future Grid |
| New Build | Kildare - Meath 400 kV Grid Upgrade Project (Capital Project 966) | Future Grid |
| Uprate | Killoteran - Waterford 110 kV uprate (circuit 1) | Future Grid |
| New Build | Kilpaddoge - Knockanure 220 kV cable | Future Grid |
| New Build | Kilpaddoge - Moneypoint 400 kV Project (Cross Shannon) | Future Grid |
| Uprate | Kilteel - Maynooth 110 kV uprate (circuit 1) | Future Grid |
| Reactive Support | Knockanure Reactor | Future Grid |
| Uprate | Knockraha - Cahir 110 kV uprate (circuit 1) | Future Grid |
| Station | Knockraha Short Circuit Rating Mitigation | Future Grid |
| Station | Knockraha station installation of additional couplers | Future Grid |
| Uprate | Lanesboro - Mullingar 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Lanesboro - Sliabh Bawn 110 kV uprate (circuit 1) | Future Grid |
| Station | Lanesboro Station Redevelopment Project | Future Grid |
| Station | Letterkenny busbar | Future Grid |
| Uprate | Louth - Oriel 220 kV uprate (circuit 1) | Future Grid |
| DLR | Magherakeel - Omagh (circuit 1) | Future Grid |
| Uprate | Maynooth - Rinawade 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Maynooth - Timahoe 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Derryiron - Timahoe 110 kV uprate (circuit 1) | Future Grid |
| New Build | Mid Antrim Upgrade | Future Grid |
| New Build | Mid-Tyrone Project | Future Grid |
| Series Capacitor | Moneypoint Series Capacitor | Future Grid |
| Uprate | Moy - Glenree 110 kV uprate (circuit 1) | Future Grid |
| Station | Moy 110 kV Station reconfiguration and busbar uprate | Future Grid |
| New Build | North Connacht 110 kV Reinforcement Project | Future Grid |
| New Build | North South 400 kV Interconnector - NI | Future Grid |
| New Build | North South 400 kV Interconnector - IE | Future Grid |
| Uprate | North Wall - Poolbeg 220 kV uprate (circuit 1) | Future Grid |
| New Build | North West of NI 110 kV reinforcement | Future Grid |
| Series Capacitor | Oldstreet Series Capacitor | Future Grid |
| Uprate | Omagh - Strabane 110 kV uprate (circuit 2) | Future Grid |
| Uprate | Omagh Main - Dromore Uprate | Future Grid |
| Uprate | Poolbeg - Carrickmines 220 kV uprate (circuit 1) | Future Grid |
| Uprate | Poolbeg South - Inchicore 220 kV uprate (circuit 1) | Future Grid |
| Uprate | Poolbeg South - Inchicore 220 kV uprate (circuit 2) | Future Grid |
| Uprate | Rinawade - Dunfirth Tee 110 kV uprate (circuit 1) | Future Grid |
| Uprate | Sligo - Srananagh 110 kV uprate (circuit 3) | Future Grid |
| Static Compensator | Thurles Station - Statcom | Future Grid |
| New Build | Woodland - Finglas 400 kV cable cct | Future Grid |
| Uprate | Woodland - Oriel 220 kV uprate (circuit 1) | Future Grid |

Table A-3 Reinforcements included in the Future Grid study

A.4 Maintenance within the Plexos Modelling

The table below outlines the representative transmission outage schedule applied within the Plexos model for this study.

| Object | Duration in Months (M ⁴) | Category |
|--|--------------------------------------|-------------|
| Ballylumford - Kells 275 kV | M6-8 | NI |
| Coleraine - Coolkeeragh 110 kV | M6-8 | NI |
| Kells 110 kV - 275 kV | M9-11 | Transformer |
| Tandragee 110 kV - 275kV | M6-8 | Transformer |
| Arva - Navan 110 kV (circuit 1) | M3-5 | IE |
| Carrigadrohid - Kilbarry 110 kV (circuit 1) | M9-11 | IE |
| Castlebar - Cloon 110 kV (circuit 1) | M6-8 | IE |
| Corduff - Woodland 220 kV (circuit 1) | M6-8 | IE |
| Cullenagh - Great Island 220 kV (circuit 1) | M3-5 | IE |
| Cushaling - Portlaoise 110 kV (circuit 1) | M3-5 | IE |
| Dunstown - Kellis 220 kV (circuit 1) | M6-8 | IE |
| Dunstown - Maynooth 220 kV (circuit 2) | M9-11 | IE |
| Flagford - Louth 220 kV (circuit 1) | M9-11 | IE |
| Flagford - Sligo 110 kV (circuit 1) | M3-5 | IE |
| Gorman - Maynooth 220 kV (circuit 1) | M6-8 | IE |
| Great Island - Lodgewood 220 kV (circuit 1) | M9-11 | IE |
| Kilpaddoge - Moneypoint 380 kV (circuit 1 new) | M9-11 | IE |
| Kilpaddoge - Tralee 110 kV (circuit 1) | M6-8 | IE |
| Maynooth - Blake-T 110 kV (circuit 1) | M9-11 | IE |
| Maynooth - Shannonbridge 220 kV (circuit 1) | M3-5 | IE |
| Oldstreet - Woodland 380 kV (circuit 1) | M6-8 | IE |
| Thurles - Ikerrin-T 110 kV (circuit 1) | M6-8 | IE |
| Arklow T2102 | M6-8 | Transformer |
| Cashla T2101 | M3-5 | Transformer |
| Cashla T2104 | M6-8 | Transformer |
| Clashavoon T2102 | M3-5 | Transformer |
| Dunstown T4202 | M9-11 | Transformer |
| Killonan T2104 | M9-11 | Transformer |
| Knockraha T2101 | M9-11 | Transformer |
| Moneypoint T4202 | M3-5 | Transformer |

Table A-4 Representative Transmission Outage Schedule

⁴ M1-12 is January to December

Appendix B – Generator

The following generator information is included in this Appendix:

- Generator Type for each Generation Scenario
- Generator Type by Area for each Generation Scenario
- Generator Type by Node for all Generators
- Generation List by Name

Note: the tables in the following section include both Ireland and Northern Ireland generation.

B.1 Generation Type for each Generator Scenario

The table below shows existing and expected wind, wind offshore, solar, wave, battery and other technologies (other technologies include: biomass, biogas, CHP, LFG and Anaerobic Digester (AD) plants) in both Ireland and Northern Ireland, which were included in this analysis.

| | Initial (MW) | 33% (MW) | 66% (MW) | ECP (MW) | ECP + 1.7 GW offshore (MW) | ECP + 3.9 GW offshore (MW) |
|---------------------------|--------------|---------------|---------------|---------------|----------------------------|----------------------------|
| Battery | 1,072 | 1,171 | 1,272 | 1,371 | 1,371 | 1,371 |
| Wave | - | 3 | 7 | 10 | 10 | 10 |
| Solar | 1,431 | 1,990 | 2,566 | 3,125 | 3,125 | 3,125 |
| Other Technologies | 25 | 53 | 82 | 114 | 114 | 114 |
| Wind | 6,320 | 7,056 | 7,815 | 8,552 | 8,552 | 8,552 |
| Wind Offshore | - | - | - | - | 1,720 | 3,932 |
| Totals | 8,848 | 10,274 | 11,743 | 13,172 | 14,892 | 17,104 |

Table B-1 Total Generation per Generation Type

B.2 Generation Type by Area for each Generator Scenario

The table below shows existing and expected wind, wind offshore, solar, wave, battery and other technologies (other technologies include: biomass, biogas, CHP, LFG and AD plants) in both Ireland and Northern Ireland, which were included in this analysis.

| | Initial (MW) | 33% (MW) | 66% (MW) | ECP (MW) | ECP + 1.7 GW offshore (MW) | ECP + 3.9 GW offshore (MW) |
|---------------------------|--------------|--------------|--------------|--------------|----------------------------|----------------------------|
| Battery | 1,072 | 1,171 | 1,272 | 1,371 | 1,371 | 1,371 |
| B | 11 | 15 | 19 | 23 | 23 | 23 |
| C | 263 | 268 | 274 | 279 | 279 | 279 |
| E | 31 | 43 | 56 | 69 | 69 | 69 |
| G | 50 | 70 | 90 | 110 | 110 | 110 |
| H2 | 25 | 45 | 65 | 85 | 85 | 85 |
| I | 178 | 178 | 178 | 178 | 178 | 178 |
| J | 304 | 336 | 369 | 401 | 401 | 401 |
| NI | 210 | 215 | 221 | 226 | 226 | 226 |
| Other Technologies | 25 | 53 | 82 | 114 | 114 | 114 |
| A | - | 0 | 0 | 0 | 0 | 0 |
| B | 2 | 18 | 35 | 51 | 51 | 51 |
| C | - | 0 | 1 | 1 | 1 | 1 |
| D | 0 | 0 | 0 | 0 | 0 | 0 |
| E | 0 | 1 | 1 | 2 | 2 | 2 |
| F | 2 | 2 | 2 | 2 | 2 | 2 |
| G | 13 | 13 | 14 | 14 | 14 | 14 |
| I | 1 | 2 | 3 | 5 | 5 | 5 |
| J | 6 | 9 | 13 | 16 | 16 | 16 |
| K | 0 | 0 | 0 | 0 | 0 | 0 |
| NI | - | 6 | 12 | 22 | 22 | 22 |
| Solar | 1,431 | 1,990 | 2,566 | 3,125 | 3,125 | 3,125 |
| A | - | 13 | 27 | 40 | 40 | 40 |
| B | 43 | 51 | 59 | 67 | 67 | 67 |
| C | 77 | 131 | 187 | 241 | 241 | 241 |
| D | - | 8 | 17 | 26 | 26 | 26 |
| E | 148 | 177 | 207 | 236 | 236 | 236 |
| F | 9 | 17 | 25 | 32 | 32 | 32 |
| G | 212 | 257 | 303 | 347 | 347 | 347 |
| H1 | 26 | 84 | 144 | 202 | 202 | 202 |

| | | | | | | |
|---------------|-------|--------|--------|--------|--------|--------|
| H2 | 211 | 322 | 437 | 548 | 548 | 548 |
| I | 35 | 94 | 156 | 215 | 215 | 215 |
| J | 362 | 502 | 647 | 788 | 788 | 788 |
| K | 122 | 146 | 171 | 196 | 196 | 196 |
| NI | 187 | 187 | 187 | 187 | 187 | 187 |
| Wave | - | 3 | 7 | 10 | 10 | 10 |
| B | - | 3 | 7 | 10 | 10 | 10 |
| Wind | 6,320 | 7,056 | 7,815 | 8,552 | 8,552 | 8,552 |
| A | 814 | 840 | 866 | 891 | 891 | 891 |
| B | 782 | 872 | 964 | 1,055 | 1,055 | 1,055 |
| C | 131 | 193 | 256 | 317 | 317 | 317 |
| D | 310 | 315 | 320 | 324 | 324 | 324 |
| E | 1,461 | 1,494 | 1,528 | 1,561 | 1,561 | 1,561 |
| F | 208 | 216 | 224 | 232 | 232 | 232 |
| G | 230 | 246 | 263 | 279 | 279 | 279 |
| H1 | 541 | 551 | 561 | 571 | 571 | 571 |
| H2 | 332 | 372 | 413 | 453 | 453 | 453 |
| I | 7 | 7 | 8 | 8 | 8 | 8 |
| J | 80 | 222 | 369 | 511 | 511 | 511 |
| K | 61 | 61 | 61 | 61 | 61 | 61 |
| NI | 1,363 | 1,668 | 1,983 | 2,288 | 2,288 | 2,288 |
| Wind Offshore | - | - | - | - | 1,720 | 3,932 |
| B | - | - | - | - | - | 392 |
| G | - | - | - | - | 350 | 370 |
| H2 | - | - | - | - | 520 | 520 |
| J | - | - | - | - | 850 | 2,650 |
| Grand Total | 8,848 | 10,274 | 11,743 | 13,172 | 14,892 | 17,104 |

Table B-2 Generation Type by Area for each Generator Scenario

B.3 Generation Type by Node

The table below shows expected wind, wind offshore, solar, wave, battery and other technologies (other technologies include: biomass, biogas, CHP, LFG and AD plants) in both Ireland and Northern Ireland, which were included in this analysis.

| Area and Node | Battery | Wave | Solar | Other Technologies | Wind | Wind Offshore |
|--------------------|------------|-----------|------------|--------------------|------------|---------------|
| A | 0 | 0 | 40 | 0 | 286 | 0 |
| Binbane | 0 | 0 | 0 | 0 | 30 | 0 |
| Corderry | 0 | 0 | 40 | 0 | 16 | 0 |
| Croaghonagh | 0 | 0 | 0 | 0 | 138 | 0 |
| Gortawee | 0 | 0 | 0 | 0 | 10 | 0 |
| Lenalea | 0 | 0 | 0 | 0 | 31 | 0 |
| Letterkenny | 0 | 0 | 0 | 0 | 31 | 0 |
| Tievebrack | 0 | 0 | 0 | 0 | 30 | 0 |
| B | 23 | 10 | 67 | 49 | 447 | 392 |
| Bellacorick | 0 | 10 | 0 | 0 | 204 | 0 |
| Cashla | 0 | 0 | 0 | 0 | 0 | 392 |
| Cloon | 0 | 0 | 24 | 0 | 5 | 0 |
| Dalton | 12 | 0 | 8 | 0 | 0 | 0 |
| Firlough | 0 | 0 | 0 | 0 | 76 | 0 |
| Knockranny | 0 | 0 | 0 | 0 | 159 | 0 |
| Shantallow | 0 | 0 | 35 | 0 | 0 | 0 |
| Sligo | 0 | 0 | 0 | 0 | 4 | 0 |
| Tawnaghmore | 11 | 0 | 0 | 49 | 0 | 0 |
| C | 179 | 0 | 241 | 1 | 226 | 0 |
| Athlone | 0 | 0 | 8 | 0 | 1 | 0 |
| Carrick on Shannon | 0 | 0 | 4 | 0 | 0 | 0 |
| Derrycarney | 0 | 0 | 0 | 0 | 34 | 0 |
| Lanesboro | 16 | 0 | 61 | 0 | 98 | 0 |
| Mullingar | 0 | 0 | 29 | 1 | 93 | 0 |
| Richmond | 0 | 0 | 12 | 0 | 0 | 0 |
| Shannonbridge | 0 | 0 | 65 | 0 | 0 | 0 |
| Shannonbridge 220 | 163 | 0 | 0 | 0 | 0 | 0 |
| Somerset | 0 | 0 | 4 | 0 | 0 | 0 |
| Shanonagh | 0 | 0 | 59 | 0 | 0 | 0 |
| D | 0 | 0 | 26 | 0 | 29 | 0 |
| Ardnacrusha | 0 | 0 | 14 | 0 | 0 | 0 |
| Booltiagh | 0 | 0 | 0 | 0 | 29 | 0 |
| Drumline | 0 | 0 | 12 | 0 | 0 | 0 |
| E | 38 | 0 | 236 | 2 | 101 | 0 |
| Aughinish | 0 | 0 | 50 | 0 | 0 | 0 |
| Boggeragh | 0 | 0 | 0 | 0 | 3 | 0 |
| Charleville | 0 | 0 | 30 | 2 | 0 | 0 |
| Clahane | 0 | 0 | 34 | 0 | 0 | 0 |
| Coomagearlahy | 0 | 0 | 7 | 0 | 0 | 0 |
| Drombeg | 0 | 0 | 50 | 0 | 0 | 0 |
| Glenlara | 0 | 0 | 10 | 0 | 0 | 0 |
| Kilpaddoge | 30 | 0 | 0 | 0 | 25 | 0 |
| Knockearagh | 0 | 0 | 9 | 0 | 0 | 0 |
| Limerick | 0 | 0 | 9 | 0 | 5 | 0 |
| Mallow | 0 | 0 | 5 | 0 | 0 | 0 |
| Moneypoint | 8 | 0 | 0 | 0 | 0 | 0 |
| Oughtragh | 0 | 0 | 4 | 0 | 0 | 0 |
| Reamore | 0 | 0 | 0 | 0 | 25 | 0 |
| Tralee | 0 | 0 | 7 | 0 | 0 | 0 |

| | | | | | | |
|------------------|------------|----------|------------|-----------|------------|------------|
| Trien | 0 | 0 | 9 | 0 | 0 | 0 |
| Ballyvouskil 220 | 0 | 0 | 13 | 0 | 42 | 0 |
| F | 0 | 0 | 32 | 0 | 31 | 0 |
| Ballylickey | 0 | 0 | 0 | 0 | 6 | 0 |
| Bandon | 0 | 0 | 21 | 0 | 0 | 0 |
| Dunmanway | 0 | 0 | 5 | 0 | 25 | 0 |
| Macroom | 0 | 0 | 6 | 0 | 0 | 0 |
| G | 110 | 0 | 347 | 13 | 105 | 370 |
| Baltrasna | 0 | 0 | 75 | 0 | 0 | 0 |
| Drybridge | 0 | 0 | 17 | 0 | 0 | 0 |
| Dundalk | 0 | 0 | 5 | 0 | 0 | 0 |
| Gaskinstown | 0 | 0 | 85 | 0 | 0 | 0 |
| Gillinstown | 0 | 0 | 95 | 0 | 0 | 0 |
| Gorman | 50 | 0 | 0 | 0 | 0 | 0 |
| Hawkinstown | 0 | 0 | 50 | 0 | 0 | 0 |
| Lisdrum | 60 | 0 | 0 | 0 | 82 | 0 |
| Meath Hill | 0 | 0 | 0 | 0 | 23 | 0 |
| Navan | 0 | 0 | 16 | 13 | 0 | 0 |
| Oriel | 0 | 0 | 0 | 0 | 0 | 370 |
| Shankill | 0 | 0 | 4 | 0 | 0 | 0 |
| H1 | 0 | 0 | 202 | 0 | 123 | 0 |
| Ahane | 0 | 0 | 8 | 0 | 0 | 0 |
| Ballydine | 0 | 0 | 6 | 0 | 0 | 0 |
| Barrymore | 0 | 0 | 15 | 0 | 0 | 0 |
| Cahir | 0 | 0 | 31 | 0 | 0 | 0 |
| Doon | 0 | 0 | 8 | 0 | 0 | 0 |
| Killonan | 0 | 0 | 0 | 0 | 94 | 0 |
| Lisheen | 0 | 0 | 0 | 0 | 29 | 0 |
| Mothel | 0 | 0 | 60 | 0 | 0 | 0 |
| Nenagh | 0 | 0 | 4 | 0 | 0 | 0 |
| Tipperary | 0 | 0 | 4 | 0 | 0 | 0 |
| Timoney | 0 | 0 | 67 | 0 | 0 | 0 |
| H2 | 85 | 0 | 548 | 0 | 121 | 520 |
| Arklow | 30 | 0 | 63 | 0 | 40 | 520 |
| Ballybeg | 0 | 0 | 8 | 0 | 0 | 0 |
| Ballyragget | 0 | 0 | 40 | 0 | 60 | 0 |
| Banoge | 9 | 0 | 9 | 0 | 0 | 0 |
| Carlow | 0 | 0 | 9 | 0 | 21 | 0 |
| Crane | 16 | 0 | 14 | 0 | 0 | 0 |
| Croy | 0 | 0 | 20 | 0 | 0 | 0 |
| Great Island | 30 | 0 | 17 | 0 | 0 | 0 |
| Kilkenny | 0 | 0 | 18 | 0 | 0 | 0 |
| Rosspile | 0 | 0 | 95 | 0 | 0 | 0 |
| Tullabeg | 0 | 0 | 50 | 0 | 0 | 0 |
| Waterford | 0 | 0 | 4 | 0 | 0 | 0 |
| Wexford | 0 | 0 | 201 | 0 | 0 | 0 |
| I | 178 | 0 | 215 | 4 | 1 | 0 |
| Aghada | 178 | 0 | 0 | 0 | 0 | 0 |
| Barnahely | 0 | 0 | 5 | 0 | 1 | 0 |
| Castleview | 0 | 0 | 0 | 4 | 0 | 0 |
| Coolroe | 0 | 0 | 10 | 0 | 0 | 0 |
| Cow Cross | 0 | 0 | 5 | 0 | 0 | 0 |
| Kilbarry | 0 | 0 | 10 | 0 | 0 | 0 |
| Knockraha | 0 | 0 | 26 | 0 | 0 | 0 |
| Midleton | 0 | 0 | 8 | 0 | 0 | 0 |
| Trabeg | 0 | 0 | 10 | 0 | 0 | 0 |
| Raffeen | 0 | 0 | 55 | 0 | 0 | 0 |

| | | | | | | |
|----------------|------------|----------|------------|-----------|--------------|--------------|
| Lysaghtstown | 0 | 0 | 87 | 0 | 0 | 0 |
| J | 393 | 0 | 788 | 10 | 430 | 2,650 |
| Athy | 0 | 0 | 9 | 0 | 0 | 0 |
| Belcamp | 0 | 0 | 0 | 0 | 0 | 500 |
| Blake T | 0 | 0 | 5 | 0 | 0 | 0 |
| Blundelstown | 0 | 0 | 60 | 0 | 0 | 0 |
| Carrickmines | 0 | 0 | 0 | 0 | 0 | 700 |
| Clonfad | 0 | 0 | 100 | 0 | 0 | 0 |
| Coolnabacky | 0 | 0 | 55 | 0 | 0 | 0 |
| Cushaling | 0 | 0 | 0 | 0 | 100 | 0 |
| Derryiron | 38 | 0 | 47 | 0 | 110 | 0 |
| Dunfirth | 0 | 0 | 38 | 0 | 0 | 0 |
| Finglas | 0 | 0 | 8 | 0 | 0 | 0 |
| Glasmore | 0 | 0 | 45 | 0 | 0 | 0 |
| Griffinrath | 0 | 0 | 41 | 0 | 0 | 0 |
| Harristown | 0 | 0 | 42 | 0 | 0 | 0 |
| Huntstown 220 | 10 | 0 | 0 | 0 | 0 | 0 |
| Inchicore | 30 | 0 | 0 | 0 | 0 | 0 |
| Irishtown | 30 | 0 | 0 | 0 | 0 | 0 |
| Kilteel | 90 | 0 | 15 | 0 | 0 | 0 |
| Monread | 0 | 0 | 8 | 0 | 0 | 0 |
| Mount Lucas | 0 | 0 | 0 | 0 | 60 | 0 |
| Newbridge | 0 | 0 | 16 | 0 | 0 | 0 |
| North Wall | 120 | 0 | 0 | 0 | 0 | 0 |
| Poolbeg north | 75 | 0 | 0 | 0 | 0 | 450 |
| Poolbeg south | 0 | 0 | 0 | 0 | 0 | 1,000 |
| Portlaoise | 0 | 0 | 4 | 0 | 45 | 0 |
| Stephenstown | 0 | 0 | 5 | 0 | 0 | 0 |
| Thornsberry | 0 | 0 | 10 | 10 | 5 | 0 |
| Treascon | 0 | 0 | 40 | 0 | 0 | 0 |
| Gallanstown | 0 | 0 | 170 | 0 | 0 | 0 |
| Philipstown | 0 | 0 | 0 | 0 | 50 | 0 |
| Mulgeeth | 0 | 0 | 0 | 0 | 60 | 0 |
| Timahoe North | 0 | 0 | 70 | 0 | 0 | 0 |
| K | 0 | 0 | 196 | 0 | 34 | 0 |
| Butlerstown | 0 | 0 | 27 | 0 | 0 | 0 |
| Dungarvan | 0 | 0 | 74 | 0 | 0 | 0 |
| Rathnaskilloge | 0 | 0 | 95 | 0 | 0 | 0 |
| Woodhouse | 0 | 0 | 0 | 0 | 34 | 0 |
| NI | 116 | 0 | 21 | 22 | 1,055 | 0 |
| Aghyoule | 0 | 0 | 0 | 0 | 24 | 0 |
| Agivey | 0 | 0 | 0 | 0 | 86 | 0 |
| Antrim | 0 | 0 | 0 | 0 | 5 | 0 |
| Ballymena | 0 | 0 | 0 | 0 | 38 | 0 |
| Ballynahinch | 0 | 0 | 0 | 0 | 13 | 0 |
| Banbridge | 0 | 0 | 0 | 0 | 7 | 0 |
| Belfast North | 0 | 0 | 0 | 0 | 2 | 0 |
| Brockaghboy | 0 | 0 | 0 | 0 | 5 | 0 |
| Carnmoney | 0 | 0 | 0 | 0 | 5 | 0 |
| Castlereagh | 50 | 0 | 0 | 0 | 9 | 0 |
| Coleraine | 0 | 0 | 0 | 0 | 49 | 0 |
| Coolkeeragh | 0 | 0 | 0 | 0 | 38 | 0 |
| Creagh | 0 | 0 | 0 | 0 | 5 | 0 |
| Cregagh | 0 | 0 | 0 | 0 | 1 | 0 |
| Curraghmulkin | 0 | 0 | 0 | 0 | 131 | 0 |
| Drumnakelly | 0 | 0 | 0 | 0 | 7 | 0 |
| Dungannon | 0 | 0 | 0 | 0 | 24 | 0 |

| | | | | | | |
|--------------------|--------------|-----------|--------------|------------|--------------|--------------|
| Eden | 0 | 0 | 0 | 0 | 5 | 0 |
| Enniskillen | 0 | 0 | 0 | 0 | 20 | 0 |
| Glengormley | 0 | 0 | 0 | 18 | 17 | 0 |
| Gort | 0 | 0 | 0 | 0 | 23 | 0 |
| Kells | 50 | 0 | 21 | 0 | 48 | 0 |
| Killymallaght | 0 | 0 | 0 | 0 | 50 | 0 |
| Larne | 0 | 0 | 0 | 0 | 50 | 0 |
| Limavady | 0 | 0 | 0 | 0 | 36 | 0 |
| Lisaghmore | 0 | 0 | 0 | 0 | 8 | 0 |
| Lisburn | 0 | 0 | 0 | 0 | 7 | 0 |
| Magherafelt | 0 | 0 | 0 | 0 | 121 | 0 |
| Magherakeel | 0 | 0 | 0 | 0 | 19 | 0 |
| Newry | 16 | 0 | 0 | 4 | 8 | 0 |
| Omagh | 0 | 0 | 0 | 0 | 91 | 0 |
| Strabane | 0 | 0 | 0 | 0 | 35 | 0 |
| Tremoge | 0 | 0 | 0 | 0 | 63 | 0 |
| Waringstown | 0 | 0 | 0 | 0 | 7 | 0 |
| Grand Total | 1,121 | 10 | 2,959 | 100 | 2,989 | 3,932 |

Table B-3 Generation Type by Node

B.4 Generator List by Name

The table below shows existing and expected wind, wind offshore, solar, wave, battery and other technologies (other technologies include: biomass, biogas, CHP, LFG and AD plants) sorted A to Z by name in both Ireland and Northern Ireland, which were included in this analysis.

| Area | Node | Type | Name | SO | Status | MEC |
|------|------------------|--------------------|---|-----|-----------|-----|
| E | Knockearagh | other technologies | Adambridge Manufacturers Ltd | DSO | connected | 3 |
| I | Aghada | battery | Aghada BESS 01 | TSO | offer | 19 |
| I | Aghada | battery | Aghada BESS 02 | TSO | offer | 159 |
| NI | Aghyoule | wind | Aghyoule Main Total Wind | DSO | connected | 3 |
| A | Corderry | wind | Altagowlan (1) | DSO | connected | 8 |
| NI | Limavady | wind | Altahullion - replant extra for 70pc | DSO | offer | 24 |
| NI | Limavady | wind | Altahullion 1 | DSO | connected | 26 |
| NI | Limavady | wind | Altahullion 2 | DSO | connected | 12 |
| NI | Gort | wind | Altamuskin | DSO | connected | 14 |
| NI | Rasharkin | wind | Altaveedan | DSO | connected | 18 |
| K | Butlerstown | solar | Amberhill Solar Farm | DSO | offer | 4 |
| B | Bellacorick | wave | AMETS Belmullet (1) | DSO | offer | 10 |
| H1 | Thurles | wind | An Cnoc | DSO | connected | 12 |
| A | Cathaleen's Fall | wind | Anarget (1) | DSO | connected | 2 |
| NI | Antrim | solar | Antrim Main Total PV | DSO | connected | 4 |
| NI | Antrim | wind | Antrim Main Total Wind | DSO | connected | 1 |
| NI | Antrim | wind | Antrim small scale - extra for 70pc | DSO | offer | 5 |
| B | Knockranny | wind | Ardderoo 2 (Formerly Buffy) | TSO | offer | 64 |
| B | Knockranny | wind | Ardderoo wind extension | TSO | offer | 18 |
| B | Knockranny | wind | Ardderoo Wind Farm | TSO | offer | 27 |
| H2 | Arklow | wind offshore | Arklow 220 offshore new A | TSO | offer | 260 |
| H2 | Arklow | wind offshore | Arklow 220 offshore new B | TSO | offer | 260 |
| H2 | Arklow | wind | Arklow Bank (1) | DSO | connected | 25 |
| E | Trien | solar | Asdee solar | DSO | offer | 5 |
| E | Athea | wind | Athea (1)a | TSO | connected | 34 |
| H2 | Arklow | other technologies | Aughrim Energy (1) | DSO | connected | 1 |
| NI | Coolkeeragh | wind | Aught Wind Farm | TSO | offer | 38 |
| H2 | Crane | battery | Avonbeg ESS | DSO | offer | 16 |
| G | Meath Hill | other technologies | Bailie Foods CHP (1) | DSO | connected | 1 |
| G | Meath Hill | other technologies | Bailieboro CHP II | DSO | connected | 4 |
| E | Trien | wind | Ballagh (1) | DSO | connected | 5 |
| H2 | Crory | wind | Ballaman formerly (Kennystown) (1) | DSO | connected | 4 |
| H1 | Thurles | wind | Ballinacurry WF | DSO | connected | 5 |
| H1 | Tipperary | solar | Ballinalard Solar Farm | DSO | offer | 4 |
| E | Tralee | wind | Ballincollig Hill (1) | DSO | connected | 15 |
| E | Aughinish | solar | Ballinknockane Solar Farm | TSO | offer | 50 |
| H1 | Nenagh | wind | Ballinlough (1) | DSO | connected | 3 |
| I | Raffeen | solar | Ballinrea Solar Park | TSO | offer | 55 |
| H1 | Nenagh | wind | Ballinveny (1) | DSO | connected | 3 |
| F | Ballylickey | wind | Ballybane (Glanta Commons) Wind Farm | DSO | connected | 20 |
| F | Ballylickey | wind | Ballybane 2 (Glanta Commons) Wind Farm | DSO | connected | 8 |
| F | Ballylickey | wind | Ballybane 2A | DSO | connected | 12 |
| F | Ballylickey | wind | Ballybane 2A (Glanta Commons) Wind Farm Extension | DSO | connected | 2 |
| F | Ballylickey | wind | Ballybane 3 (Glanta Commons) Wind Farm | DSO | connected | 4 |
| H1 | Thurles | wind | Ballybay Wind Farm (Tullaroan) | DSO | connected | 14 |
| NI | Newtownards | solar | Ballyboley (Solar Farm) | DSO | connected | 5 |
| H2 | Crory | wind | Ballycadden (1) | DSO | connected | 14 |
| H2 | Crory | wind | Ballycadden (2) | DSO | connected | 10 |

| | | | | | | |
|----|-----------------|--------------------|--|-----|-----------|----|
| C | Somerset | solar | Ballycrissane Solar Farm | DSO | offer | 4 |
| H2 | Great Island | solar | Ballycullane Solar Park | DSO | offer | 5 |
| H2 | Arklow | wind | Ballycumber (1) | DSO | connected | 18 |
| K | Dungarvan | wind | Ballycurreen (1) | DSO | connected | 5 |
| H2 | Crory | wind | Ballyduff (1) | DSO | connected | 4 |
| NI | Ballymena | solar | Ballygarvey Road | DSO | connected | 7 |
| H2 | Great Island | solar | Ballygowny Solar Farm | DSO | offer | 12 |
| J | Glasmore | solar | Ballykea Solar Farm | DSO | offer | 1 |
| NI | Larne | wind | Ballykeel Wind Farm | DSO | offer | 16 |
| E | Kilpaddoge | wind | Ballylongford Windfarm | DSO | offer | 25 |
| K | Dungarvan | solar | Ballymac PV | DSO | offer | 5 |
| H1 | Cahir | solar | Ballymacadam (Monraha) Solar PV Farm | DSO | offer | 19 |
| H2 | Arklow | wind | Ballymanus WindFarm | DSO | offer | 40 |
| H2 | Waterford | wind | Ballymartin (1) | DSO | connected | 6 |
| H2 | Waterford | wind | Ballymartin (2) | DSO | connected | 8 |
| NI | Ballymena | solar | Ballymena Main Total PV | DSO | connected | 4 |
| NI | Ballymena | wind | Ballymena Main Total Wind | DSO | offer | 4 |
| NI | Ballymena | wind | Ballymena Main Total Wind | DSO | connected | 1 |
| NI | Ballymena | wind | Ballymena small scale - extra for 70pc | DSO | offer | 10 |
| I | Cow Cross | solar | Ballynacrusha | DSO | offer | 5 |
| NI | Ballynahinch | wind | Ballynahinch Main Total Wind | DSO | offer | 5 |
| NI | Ballynahinch | wind | Ballynahinch Main Total Wind | DSO | connected | 2 |
| NI | Ballynahinch | wind | Ballynahinch small scale - extra for 70pc | DSO | offer | 8 |
| H2 | Crory | wind | Ballynancoran (1) | DSO | connected | 4 |
| H2 | Kilkenny | solar | Ballytobin Solar PV | DSO | offer | 4 |
| NI | Glengormley | wind | Ballyutoagh Wind Farm | DSO | offer | 12 |
| H2 | Ballywater | wind | Ballywater (1) | TSO | connected | 32 |
| H2 | Ballywater | wind | Ballywater (2) | TSO | connected | 11 |
| NI | Banbridge | wind | Banbridge Main Total Wind | DSO | connected | 4 |
| NI | Banbridge | wind | Banbridge small scale - extra for 70pc | DSO | offer | 7 |
| E | Clahane | solar | Banemore Solar Farm | TSO | offer | 34 |
| NI | Rasharkin | solar | Bann Road PV | DSO | connected | 36 |
| B | Cloon | solar | Barnderg Solar Farm | DSO | offer | 4 |
| H2 | Banoge | solar | Barnland Solar | DSO | offer | 1 |
| H1 | Barrymore | wind | Barranafaddock (1) | DSO | connected | 32 |
| F | Macroom | wind | Bawnmore (1) formerly Burren (Cork) | DSO | connected | 24 |
| E | Trien | wind | Beale Hill (1) | DSO | connected | 2 |
| E | Trien | wind | Beale Hill (2) | DSO | connected | 3 |
| E | Trien | wind | Beale Hill (3) | DSO | connected | 1 |
| K | Butlerstown | wind | Beallough (1) | DSO | connected | 2 |
| A | Trillick | wind | Beam Hill (1) | DSO | connected | 14 |
| F | Dunmanway | solar | Beanhill South | DSO | offer | 5 |
| G | Drybridge | solar | Beaulieu PV | DSO | offer | 4 |
| E | Tralee | wind | Beenageeha (1) | DSO | connected | 4 |
| E | Athea | battery | Beenanaspock and Tobertooreen Wind Farm | TSO | connected | 11 |
| E | Athea | wind | Beenanaspock and Tobertooreen Wind Farm | TSO | connected | 23 |
| NI | Belfast Central | solar | Belfast Central Main Total PV | DSO | connected | 3 |
| NI | Belfast North | wind | Belfast North small scale - extra for 70pc | DSO | offer | 2 |
| B | Bellacorick | wind | Bellacorick (1) | DSO | connected | 6 |
| NI | Omagh | wind | Bessy Bell | DSO | connected | 5 |
| NI | Omagh | wind | Bessy Bell - replant extra for 70pc | DSO | offer | 24 |
| NI | Omagh | wind | Bessy Bell 2 | DSO | connected | 9 |
| H2 | Carlow | wind | Bilboa (1) | DSO | offer | 15 |
| H2 | Carlow | wind | Bilboa (2) | DSO | offer | 6 |
| NI | Strabane | wind | Bin Mountain | DSO | connected | 9 |
| B | Tonroe | other technologies | Biocore Enviromental AD | DSO | connected | 2 |

| | | | | | | |
|----|---------------|--------------------|---|-----|-----------|-----|
| C | Mullingar | other technologies | Bioenergy Facility | DSO | offer | 1 |
| A | Corderry | wind | Black Banks (1) | DSO | connected | 3 |
| A | Corderry | wind | Black Banks (2) | DSO | connected | 7 |
| B | Glenree | wind | Black Lough (1) | DSO | connected | 13 |
| C | Shannonbridge | solar | Blackwater Bog Solar 1 | TSO | offer | 65 |
| J | Blundelstown | solar | Blundelstown | TSO | offer | 60 |
| H2 | Wexford | solar | Blusheens Solar (1) | DSO | offer | 8 |
| H2 | Wexford | solar | Blusheens Solar (2) | DSO | offer | 4 |
| J | Monread | solar | Bodenstown Solar Farm | DSO | offer | 4 |
| E | Boggeragh | wind | Boggeragh (1) | TSO | connected | 57 |
| E | Boggeragh | wind | Boggeragh 2 | TSO | connected | 66 |
| E | Boggeragh | wind | Boggeragh 2 (Killavoy (1)) | TSO | connected | 18 |
| E | Charleville | wind | Boolard Wind Farm (Charleville) | DSO | connected | 4 |
| D | Slievecallan | wind | Boolinrudda (formerly Loughaun North) | TSO | connected | 45 |
| D | Booltiagh | wind | Booltiagh (1) | TSO | connected | 19 |
| D | Booltiagh | wind | Booltiagh (2) | TSO | connected | 3 |
| D | Booltiagh | wind | Booltiagh (3) | TSO | connected | 9 |
| D | Booltiagh | wind | Boolynagleragh (1) | DSO | connected | 37 |
| NI | Ballymena | wind | Brackagh Quarry | DSO | connected | 5 |
| NI | Brockaghboy | wind | Brockaghboy | TSO | connected | 48 |
| NI | Brockaghboy | wind | Brockaghboy extension - extra for 70pc | DSO | offer | 5 |
| H1 | Lisheen | wind | Bruckana (1) | DSO | connected | 40 |
| J | Finglas | solar | Bullstown Solar Farm | DSO | offer | 8 |
| B | Bellacorick | wind | Bunnahowen (1) | DSO | connected | 3 |
| B | Glenree | wind | Bunnyconnellan (1) | DSO | connected | 28 |
| E | Garrow | wind | Caherdowney (1) | DSO | connected | 10 |
| D | Booltiagh | wind | Cahermurphy (1) | DSO | connected | 6 |
| NI | Enniskillen | wind | Callagheen | DSO | connected | 17 |
| F | Bandon | solar | Callatrim South Solar Farm (prev. Kilcawha) | DSO | offer | 6 |
| H1 | Cauteen | wind | Cappagh White (1) | DSO | connected | 13 |
| H1 | Cauteen | wind | Cappawhite A | DSO | connected | 57 |
| F | Dunmanway | other technologies | Carbery Milk Products CHP (1) | DSO | connected | 6 |
| A | Letterkenny | wind | Cark (1) | DSO | connected | 15 |
| NI | Carnmoney | wind | Carn Hill | DSO | connected | 14 |
| NI | Kells | wind | Carnalbanagh | TSO | offer | 25 |
| NI | Carnmoney | wind | Carnmoney small scale - extra for 70pc | DSO | offer | 5 |
| H2 | Wexford | wind | Carnsore (1) | DSO | connected | 12 |
| A | Corderry | wind | Carrane Hill (1) | DSO | connected | 3 |
| A | Corderry | wind | Carrane Hill (2) | DSO | connected | 2 |
| H1 | Ballydine | solar | Carrick Solar | DSO | offer | 6 |
| A | Letterkenny | wind | Carrick Wind Farm (Garrymore) | DSO | offer | 4 |
| G | Shankill | solar | Carrickabane Solar Farm | DSO | offer | 4 |
| G | Shankill | wind | Carrickallen Wind Farm | DSO | connected | 22 |
| NI | Killymallaght | wind | Carrickatane | DSO | connected | 21 |
| B | Sligo | wind | Carrickeeney (1) | DSO | connected | 8 |
| J | Carrickmines | wind offshore | Carrickmines 220 offshore new A | TSO | offer | 350 |
| J | Carrickmines | wind offshore | Carrickmines 220 offshore new B | TSO | offer | 350 |
| C | Dallow | wind | Carrig (1) | DSO | connected | 3 |
| E | Boggeragh | wind | Carrigcannon (1) | DSO | connected | 20 |
| E | Boggeragh | wind | Carrigcannon (2) | DSO | offer | 3 |
| F | Dunmanway | wind | Carrigdangan (formerly Barnadivine) | TSO | connected | 60 |
| F | Dunmanway | wind | Carrigdangan Wind Farm Ext. | TSO | offer | 8 |
| E | Rathkeale | wind | Carrons (1) | DSO | connected | 5 |
| B | Dalton | battery | Carrowbeg Battery Storage (Prev MCB) | DSO | offer | 12 |
| B | Glenree | wind | Carrowleagh (1) | DSO | connected | 34 |
| B | Glenree | wind | Carrowleagh (2) | DSO | connected | 3 |
| D | Tullabrack | wind | Carrownawelaun (1) | DSO | connected | 5 |

| | | | | | | |
|----|----------------|---------------|--|-----|-----------|-----|
| B | Cashla | wind offshore | Cashla 220 offshore new | TSO | offer | 392 |
| NI | Curraghmulkin | wind | Castlecraig | DSO | connected | 25 |
| H2 | Castledockrell | wind | Castledockrell (1) | TSO | connected | 20 |
| H2 | Castledockrell | wind | Castledockrell (2) | TSO | connected | 2 |
| H2 | Castledockrell | wind | Castledockrell (3) | TSO | connected | 3 |
| H2 | Castledockrell | wind | Castledockrell (4) | TSO | connected | 16 |
| NI | Kells | wind | Castlegore | DSO | offer | 23 |
| H2 | Kilkenny | solar | Castlekelly Solar PV Farm | DSO | offer | 4 |
| E | Charleville | wind | Castlepool (1) | DSO | connected | 33 |
| NI | Castlereagh | battery | Castlereagh battery | TSO | offer | 50 |
| NI | Magherakeel | wind | Church Hill | DSO | connected | 18 |
| E | Clahane | wind | Clahane (1) | TSO | connected | 38 |
| E | Clahane | wind | Clahane (2) | TSO | connected | 14 |
| B | Dalton | solar | Claremorris 2 Solar Farm | DSO | offer | 4 |
| K | Butlerstown | solar | Clashganny South Solar Farm | DSO | offer | 10 |
| K | Dungarvan | solar | Clashnagoneen Solar Farm | DSO | offer | 4 |
| E | Coomataggart | wind | Cleanrath (1) | DSO | connected | 43 |
| C | Richmond | solar | Cleggill Solar Park | DSO | offer | 8 |
| C | Derrycarney | wind | Cloghan Wind Farm | TSO | offer | 34 |
| E | Cloghboola | wind | Cloghanaleskirt (1) | DSO | connected | 13 |
| A | Binbane | wind | Clogheravaddy Wind Farm (Phase 1) | DSO | connected | 9 |
| A | Binbane | wind | Clogheravaddy Wind Farm (Phase 2) | DSO | offer | 11 |
| A | Binbane | wind | Clogheravaddy Wind Farm (Phase 3) | DSO | offer | 4 |
| NI | Tremoge | wind | Cloghfin | DSO | offer | 5 |
| J | Cushaling | wind | Cloncreen Wind farm | TSO | offer | 100 |
| C | Shanonagh | solar | Clondardis Solar | TSO | offer | 59 |
| J | Clonfad | solar | Clonfad Solar | TSO | offer | 100 |
| J | Derryiron | solar | Clonin North solar | TSO | offer | 47 |
| D | Drumline | solar | Clonloghan 2 Solar Park | DSO | offer | 8 |
| H1 | Cahir | solar | Clonmel Road Solar | DSO | offer | 4 |
| J | Thornsberry | wind | Clonminch Community Wind Turbine | DSO | offer | 5 |
| B | Cloon | solar | Cloonascragh Solar | DSO | offer | 20 |
| C | Athlone | wind | Clooncon East Single WTG | DSO | offer | 1 |
| B | Cloon | wind | Clooninagh Wind Farm | DSO | offer | 5 |
| B | Cloon | wind | Cloonlusk (1) | DSO | connected | 4 |
| NI | Loguestown | wind | Cloonty | DSO | connected | 9 |
| G | Drybridge | solar | Cluide Solar | DSO | offer | 4 |
| E | Garrow | wind | Clydaghroe (1) | DSO | connected | 5 |
| H1 | Ahane | solar | Clyduff Solar Park | DSO | offer | 4 |
| NI | Coleraine | wind | Coleraine Main Total Wind | DSO | connected | 10 |
| NI | Coleraine | wind | Coleraine small scale - extra for 70pc | DSO | offer | 25 |
| G | Drybridge | wind | Collon Wind Power | DSO | connected | 2 |
| J | Griffinrath | solar | Confey Solar Park | DSO | offer | 10 |
| G | Lisdrum | wind | Coolberrin Wind Farm (formerly Bragan Wind Farm) | DSO | offer | 33 |
| C | Mullingar | wind | Coole wind | TSO | offer | 88 |
| E | Cordal | wind | Coollegrean (1) | DSO | connected | 19 |
| H2 | Arklow | solar | Coolnagloose Community Solar | DSO | offer | 1 |
| K | Dungarvan | solar | Cooltubbrid West Solar | DSO | offer | 4 |
| A | Trillick | wind | Cooly (1) | DSO | connected | 4 |
| I | Kilbarry | solar | Coolyduff | DSO | offer | 5 |
| E | Garrow | wind | Coomacheo (1) | TSO | connected | 41 |
| E | Garrow | wind | Coomacheo (2) | TSO | connected | 18 |
| E | Coomagearlahy | wind | Coomagearlahy (1) | TSO | connected | 43 |
| E | Coomagearlahy | wind | Coomagearlahy (2) | TSO | connected | 9 |
| E | Coomagearlahy | wind | Coomagearlahy (3) | TSO | connected | 30 |
| F | Dunmanway | wind | Coomatallin (1) | DSO | connected | 6 |
| F | Dunmanway | wind | Coomatallin (2) | DSO | offer | 3 |

| | | | | | | |
|----|---------------|--------------------|---|-----|-----------|-----|
| H2 | Carlow | solar | Coppenagh solar | DSO | offer | 5 |
| E | Cordal | wind | Cordal (1) | TSO | connected | 36 |
| E | Cordal | wind | Cordal (2) | TSO | connected | 54 |
| A | Gortawee | wind | Coreen (1) | DSO | connected | 3 |
| F | Macroom | other technologies | Cork Green Energy Biomass CHP Plant | DSO | connected | 1 |
| I | Kilbarry | other technologies | Cork University Hospital CHP (1) | DSO | connected | 1 |
| A | Binbane | wind | Corkermore (1) | DSO | connected | 10 |
| A | Binbane | wind | Corkermore (2) | DSO | offer | 9 |
| NI | Ballymena | wind | Corkey | DSO | connected | 5 |
| NI | Ballymena | wind | Corkey - replant extra for 70pc | DSO | offer | 24 |
| NI | Curraghmulkin | wind | Cornavarrow | DSO | connected | 36 |
| A | Arigna | wind | Corrie Mountain (1) | DSO | connected | 5 |
| A | Sorne Hill | wind | Corvin Wind Turbine | DSO | connected | 2 |
| B | Bellacorick | wind | Corvoderry (was Gortnahurra (1)) | DSO | offer | 34 |
| E | Coomagearlahy | solar | Coumaclovane Solar Extension | TSO | offer | 7 |
| H2 | Banoge | solar | Courtown Solar Farm (previously Coolnastudd) | DSO | offer | 4 |
| NI | Agivey | wind | Craiggoire | DSO | offer | 24 |
| NI | Creagh | wind | Creagh Main Total Wind | DSO | connected | 8 |
| NI | Creagh | wind | Creagh small scale - extra for 70pc | DSO | offer | 5 |
| C | Lanesboro | solar | Creivy Solar | DSO | offer | 4 |
| NI | Cregagh | wind | Cregagh small scale - extra for 70pc | DSO | offer | 1 |
| NI | Tremoge | wind | Cregganconroe | DSO | connected | 14 |
| NI | Magherakeel | wind | Crigshane | DSO | connected | 32 |
| A | Croaghonagh | wind | Croaghonagh 1 Windfarm (Merged with Carrickalangan) | TSO | offer | 138 |
| I | Midleton | wind | Crocane (1) | DSO | connected | 2 |
| NI | Dungannon | wind | Crockagarran | DSO | connected | 18 |
| A | Trillick | wind | Crockahenny (1) | DSO | connected | 5 |
| NI | Tremoge | wind | Crockandun | DSO | connected | 15 |
| NI | Gort | wind | Crockbaravally | DSO | connected | 8 |
| NI | Tremoge | wind | Crockdun | DSO | connected | 13 |
| A | Ardnagappary | wind | Cronalaght (1) | DSO | connected | 5 |
| A | Ardnagappary | wind | Cronalaght (2) | DSO | connected | 18 |
| H2 | Carlow | wind | Cronelea (1) | DSO | connected | 5 |
| H2 | Carlow | wind | Cronelea (2) | DSO | connected | 5 |
| H2 | Carlow | wind | Cronelea Upper (1) | DSO | connected | 3 |
| H2 | Carlow | wind | Cronelea Upper (2) | DSO | connected | 2 |
| E | Mallow | solar | Crossfield | DSO | offer | 5 |
| D | Booltiagh | wind | Crossmore (1) | DSO | offer | 15 |
| D | Booltiagh | wind | Crossmore (2) | DSO | offer | 10 |
| B | Castlebar | wind | Cuillalea (1) | DSO | connected | 3 |
| B | Castlebar | wind | Cuillalea (2) | DSO | connected | 2 |
| A | Letterkenny | wind | Culliagh (1) | DSO | connected | 12 |
| F | Bandon | solar | Currabeha | DSO | offer | 5 |
| F | Dunmanway | wind | Currabwee (1) | DSO | connected | 5 |
| E | Glenlara | solar | Curraduff (previously Southwest Solar) | DSO | offer | 5 |
| NI | Curraghmulkin | wind | Curraghmulkin - extra for 70pc | DSO | offer | 37 |
| E | Trien | wind | Curraghderri (1) | DSO | connected | 5 |
| H1 | Nenagh | wind | Curraghgraique (1) | DSO | connected | 3 |
| H1 | Nenagh | wind | Curraghgraique (2) | DSO | connected | 2 |
| H2 | Waterford | solar | Curraghmartin Solar Park | DSO | offer | 4 |
| NI | Lisaghmore | wind | Curryfree | DSO | connected | 15 |
| J | Philipstown | wind | Cushaling wind (loop into Cushaling - Newbridge) | TSO | offer | 50 |
| E | Mallow | other technologies | Dairygold Mallow (2) | DSO | connected | 4 |
| H1 | Barrymore | other technologies | Dairygold, Mitchelstown, zero | DSO | connected | 9 |
| G | Baltrasna | solar | Darthogue Solar | DSO | offer | 20 |

| | | | | | | |
|----|----------------------|--------------------|--|-----|-----------|-----|
| J | College Park | inertia | Data Electronics Services Ltd | DSO | connected | 4 |
| H2 | Wexford | solar | Davidstown Solar | DSO | offer | 5 |
| H2 | Wexford | solar | Dennistown Extension Solar Park | DSO | offer | 24 |
| I | Barnahely | wind | DePuy | DSO | connected | 3 |
| I | Barnahely | wind | DePuy Synthes Turbine2 | DSO | offer | 1 |
| F | Ballylickey | wind | Derreenacrinnig West (prev Kilvinane 2 WF) | DSO | offer | 6 |
| C | Lanesboro | battery | Derryadd battery | TSO | offer | 16 |
| C | Lanesboro | wind | Derryadd wind | TSO | offer | 90 |
| D | Derrybrien | wind | Derrybrien (1) | TSO | connected | 60 |
| J | Thornsberry | other technologies | Derryclure (1) | DSO | offer | 10 |
| B | Castlebar | wind | Derrynadivva Wind Farm (prev. Raheen Bar 2) | DSO | connected | 9 |
| A | Garvagh | wind | Derrysallagh Wind Farm (Formerly Kilronan 2) | DSO | connected | 34 |
| F | Dunmanway | wind | Derryvacorneen (1) | DSO | connected | 17 |
| NI | Curraghamulkin | wind | Dooish | DSO | offer | 42 |
| B | Bellacorick | wind | Dooleeg More (1) | DSO | offer | 3 |
| B | Bellacorick | wind | Dooleeg More Ext. | DSO | offer | 1 |
| J | Portlaoise | wind | Dooray WF | DSO | offer | 45 |
| NI | Magherafelt | wind | Doraville - extra for 70pc | TSO | offer | 118 |
| J | Mulgeeth | wind | Drehid wind | TSO | offer | 60 |
| E | Dromada | wind | Dromada (1) | TSO | connected | 29 |
| E | Glenlara | solar | Dromalour | DSO | offer | 5 |
| E | Drombeg | solar | Drombeg Solar Park | TSO | offer | 50 |
| E | Glenlara 220 kV side | wind | Dromdeeven (1) | DSO | connected | 11 |
| E | Glenlara 220 kV side | wind | Dromdeeven (2) | DSO | connected | 17 |
| E | Tralee | solar | Dromroe Solar | DSO | offer | 4 |
| E | Tralee | solar | Dromroe Solar 2 | DSO | offer | 3 |
| D | Ardnacrusha | solar | Dromsallagh Solar | DSO | offer | 4 |
| I | Kilbarry | solar | Drumgarriiff South | DSO | offer | 5 |
| G | Lisdrum | wind | Drumlins Park wind | TSO | offer | 49 |
| A | Trillick | wind | Drumlough Hill (1) | DSO | connected | 5 |
| A | Trillick | wind | Drumlough Hill (2) | DSO | connected | 10 |
| NI | Drumnakelly | solar | Drumnakelly Main Total PV | DSO | connected | 2 |
| NI | Drumnakelly | wind | Drumnakelly Main Total Wind | DSO | connected | 8 |
| NI | Drumnakelly | wind | Drumnakelly small scale - extra for 70pc | DSO | offer | 7 |
| K | Dungarvan | solar | Drumroe East Solar 2 Cluster | DSO | offer | 37 |
| K | Dungarvan | solar | Drumroe East Solar Farm | DSO | offer | 15 |
| J | Ringsend | other technologies | Dublin Civic Offices CHP (1) | DSO | connected | 1 |
| NI | Coleraine | wind | Dunbeg | DSO | connected | 42 |
| NI | Dungannon | solar | Dungannon Main Total PV | DSO | connected | 5 |
| NI | Dungannon | wind | Dungannon Main Total Wind | DSO | connected | 9 |
| NI | Dungannon | wind | Dungannon small scale - extra for 70pc | DSO | offer | 24 |
| NI | Coleraine | wind | Dunmore | DSO | connected | 21 |
| G | Drybridge | wind | Dunmore (1) | DSO | connected | 2 |
| G | Drybridge | wind | Dunmore (2) | DSO | connected | 2 |
| J | Newbridge | solar | Dunmurry Springs PV | DSO | offer | 12 |
| NI | Antrim | solar | Dunore Point solar PV Farm | DSO | connected | 5 |
| J | Dunfirth | solar | Dysart PV | DSO | offer | 20 |
| NI | Eden | wind | Eden Main Total Wind | DSO | connected | 4 |
| NI | Eden | wind | Eden small scale - extra for 70pc | DSO | offer | 5 |
| NI | Killymallaght | wind | Eglis | DSO | connected | 15 |
| NI | Ballymena | wind | Elginny Hill | DSO | connected | 23 |
| NI | Larne | wind | Elliot's Hill | DSO | connected | 5 |
| NI | Larne | wind | Elliot's Hill - replant extra for 70pc | DSO | offer | 24 |

| | | | | | | |
|----|--------------|--------------------|---|-----|-----------|-----|
| NI | Enniskillen | wind | Enniskillen Main Total Wind | DSO | connected | 11 |
| NI | Enniskillen | wind | Enniskillen small scale - extra for 70pc | DSO | offer | 20 |
| K | Dungarvan | other technologies | Eras Eco AD (prev Knocknagappagh WF) | DSO | connected | 2 |
| H1 | Timoney | solar | Erkina solar | TSO | offer | 67 |
| NI | Tremoge | wind | Eshmore | DSO | connected | 7 |
| E | Boggeragh | wind | Esk (1) | DSO | connected | 6 |
| E | Boggeragh | wind | Esk Wind Farm (sub metered Gneeves 2 Merge) | DSO | connected | 5 |
| E | Boggeragh | wind | ESK Wind Farm Phase 2 | DSO | connected | 12 |
| E | Charleville | other technologies | Evaporator Upgrade | DSO | offer | 2 |
| NI | Agivey | wind | Evishagarran | DSO | offer | 40 |
| NI | Agivey | wind | Evishagarran Inc MEC | DSO | offer | 7 |
| H1 | Barrymore | solar | Farran South | DSO | offer | 15 |
| F | Bandon | solar | Farrangalway Solar PV Farm | DSO | offer | 5 |
| B | Sligo | wind | Faughary (1) | DSO | connected | 6 |
| J | Glasmore | solar | Featherbed Lane Solar | DSO | offer | 4 |
| E | Charleville | solar | Fiddane Solar | DSO | offer | 30 |
| NI | Rasharkin | solar | Finvoy Road | DSO | connected | 5 |
| D | Drumline | solar | Firgrove Solar Park | DSO | offer | 4 |
| B | Firlough | wind | Firlough TG371 was Carrowleagh-Kilbride DG741 | TSO | offer | 48 |
| B | Firlough | wind | Firlough Wind Farm | TSO | offer | 27 |
| A | Sorne Hill | wind | Flughland (1) | DSO | connected | 9 |
| I | Castleview | other technologies | FMC Gas Turbine | DSO | connected | 2 |
| K | Dungarvan | solar | Foxhall PV | DSO | offer | 4 |
| H1 | Thurles | wind | Foyle Windfarm | DSO | connected | 10 |
| G | Navan | solar | Friarspark (was Glebe Golf Course) | DSO | offer | 4 |
| G | Navan | solar | Friarspark Solar 2 | DSO | offer | 2 |
| B | Knockranny | wind | Fuinneamh Oileáin Árann | DSO | offer | 2 |
| J | Gallanstown | solar | Gallanstown Solar | TSO | offer | 119 |
| J | Stephenstown | battery | Gardnershill FGS | DSO | connected | 9 |
| H1 | Cauteen | wind | Garracummer (1) | DSO | connected | 37 |
| H1 | Cauteen | wind | Garracummer (2) | DSO | connected | 1 |
| F | Bandon | wind | Garranereagh (1) | DSO | connected | 9 |
| I | Coolroe | solar | Garravagh 1 Solar Park | DSO | offer | 10 |
| A | Letterkenny | wind | Garrymore WF | DSO | offer | 4 |
| D | Ardnacrusha | solar | Garrynacurra Solar Farm (Cratloe Community Solar) | DSO | offer | 5 |
| F | Bandon | solar | Garryndruig | DSO | offer | 5 |
| G | Meath Hill | wind | Gartnaneane (1) | DSO | connected | 11 |
| G | Meath Hill | wind | Gartnaneane (2) | DSO | connected | 5 |
| A | Garvagh | wind | Garvagh - Glebe (1a) | TSO | connected | 26 |
| A | Garvagh | wind | Garvagh - Tullynahaw (1c) | TSO | connected | 22 |
| NI | Coleraine | wind | Garves | DSO | connected | 15 |
| G | Gaskinstown | solar | Gaskinstown Solar Farm | TSO | offer | 85 |
| A | Corderry | wind | Geevagh (1) | DSO | connected | 5 |
| H2 | Croy | wind | Gibbet Hill (1) | DSO | connected | 15 |
| G | Gillinstown | solar | Gillinstown Solar | TSO | offer | 95 |
| A | Sorne Hill | wind | Glackmore Hill (2) | DSO | connected | 1 |
| E | Cloghboola | wind | Glanaruddery 1 (formerly Dromadda More Wind Farm) | DSO | connected | 20 |
| E | Cloghboola | wind | Glanaruddery 2 (formerly Dromadda More 2) | DSO | connected | 12 |
| J | Portlaoise | other technologies | Glanbia Ballyraggett CHP (1) | DSO | connected | 8 |
| E | Glanlee | wind | Glanlee (1) | TSO | connected | 30 |
| E | Cloghboola | wind | Glantaunyalkeen Windfarm (Cloghboola (2) Ext) | DSO | connected | 10 |
| A | Corderry | solar | Glen Solar | TSO | offer | 40 |

| | | | | | | |
|----|---------------|--------------------|---|-----|-----------|-----|
| A | Letterkenny | wind | Glenalla (Garrymore) | DSO | offer | 2 |
| NI | Rasharkin | wind | Glenbuck | DSO | connected | 9 |
| H1 | Cauteen | wind | Glencarbry (1) | DSO | connected | 33 |
| E | Kilpaddoge | battery | Glencloosagh Phase 3 | TSO | offer | 30 |
| NI | Glengormley | wind | Glengormley Main Total Wind | DSO | connected | 1 |
| NI | Glengormley | wind | Glengormley small scale - extra for 70pc | DSO | offer | 5 |
| H2 | Arklow | solar | Glenoge Community Solar | DSO | offer | 5 |
| H1 | Cauteen | wind | Glenough (1) | DSO | connected | 33 |
| E | Knockearagh | wind | Gneeves (1) | DSO | connected | 9 |
| A | Golagh | wind | Golagh (1) | TSO | connected | 15 |
| E | Charleville | other technologies | Golden Vale CHP (1) | DSO | connected | 4 |
| H2 | Banoge | battery | Gorey Battery Energy Storage | DSO | offer | 9 |
| H2 | Banoge | solar | Gorey Solar | DSO | offer | 4 |
| G | Gorman | battery | Gorman (Graigs) Energy Storage Station | TSO | offer | 30 |
| G | Gorman | battery | Gorman Energy Storage Station - Extension | TSO | offer | 20 |
| D | Booltiagh | wind | Gortaheera CM2 Windfarm | DSO | offer | 4 |
| H2 | Carlow | wind | Gortahile (1) | DSO | connected | 21 |
| J | Athy | other technologies | Gorteen Lower | DSO | connected | 1 |
| NI | Tremoge | wind | Gortfinbar | DSO | connected | 15 |
| E | Trien | wind | Gortnacloghy Wind Farm | DSO | connected | 4 |
| B | Tonroe | wind | Grady Joinery | DSO | connected | 3 |
| H2 | Wexford | solar | Grahormick solar | TSO | offer | 60 |
| H2 | Crane | solar | Graigue Beg Community Solar Farm | DSO | offer | 5 |
| F | Bandon | other technologies | Graingers Sawmills CHP (1) | DSO | connected | 3 |
| G | Drybridge | solar | Grangegeeth Solar | DSO | offer | 4 |
| H2 | Crane | wind | Greenoge (1) | DSO | connected | 5 |
| NI | Magherakeel | wind | Gronan Wind Farm | DSO | offer | 12 |
| E | Rathkeale | wind | Grouse Lodge (1) | DSO | connected | 15 |
| E | Coomataggart | wind | Grousemount WF | TSO | connected | 114 |
| G | Dundalk | wind | Grove Hill (1) formerly Tullynageer | DSO | connected | 16 |
| NI | Coleraine | wind | Gruig | DSO | connected | 25 |
| J | Inchicore | other technologies | Guinness CHP (1) | DSO | connected | 8 |
| H1 | Thurles | wind | Gurteen (1) | DSO | connected | 2 |
| J | Gallanstown | solar | Harlockstown Solar (Gallanstown Solar Extension) | TSO | offer | 51 |
| J | Harristown | solar | Harristown Solar PV | TSO | offer | 42 |
| G | Hawkinstown | solar | Hawkinstown Solar Park re-submission | TSO | offer | 50 |
| NI | Glengormley | other technologies | Hightown Quarry, Boghill Rd, Mallusk | DSO | offer | 18 |
| G | Baltrasna | solar | Hilltown PV | DSO | offer | 10 |
| I | Castleview | other technologies | Hoffman Renewable Bioenergy Plant | DSO | offer | 4 |
| H1 | Cauteen | wind | Holyford (1) | DSO | connected | 9 |
| H1 | Doon | solar | Horsepasture Solar Farm (Grian PV) | DSO | offer | 8 |
| J | Dunfirth | solar | Hortland PV (from merge Knockanally and Hortland) | DSO | offer | 14 |
| NI | Omagh | wind | Hunters Hill | DSO | connected | 20 |
| J | Huntstown 220 | battery | Huntstown 10 MW battery | TSO | offer | 10 |
| J | Finglas | other technologies | Huntstown Renewable Bioenergy Plant | DSO | connected | 4 |
| J | Inchicore | battery | Inchicore BESS | DSO | offer | 30 |
| NI | Tremoge | wind | Inishative | DSO | connected | 14 |
| B | Knockranny | wind | Inverin (Knock South) (1) | DSO | connected | 3 |
| F | Ballylickey | wind | Kealkil (Curraglass) (1) | DSO | connected | 9 |
| H2 | Kilkenny | solar | Keatingstown Solar Farm | DSO | offer | 6 |
| J | Glasmore | other technologies | Keelings CHP | DSO | connected | 2 |
| K | Butlerstown | solar | Keiloge Solar | DSO | offer | 4 |
| NI | Kells | battery | Kells battery | TSO | offer | 50 |
| E | Kilpaddoge | wind | Kelwin Power Plant | TSO | connected | 42 |
| E | Kilpaddoge | battery | Kelwin Power Plant - Phase 2 | TSO | connected | 20 |

| | | | | | | |
|----|-------------------|--------------------|--|-----|-----------|-----|
| J | Monread | solar | Kerdiffstown PV | DSO | offer | 4 |
| E | Limerick | wind | Kilballyowen Windfarm | DSO | offer | 5 |
| E | Charleville | wind | Kilbereherth (1) | DSO | connected | 5 |
| H2 | Crane | wind | Kilbranish (1) | DSO | connected | 3 |
| G | Baltrasna | solar | Kilbrew Solar Farm | TSO | offer | 35 |
| J | Glasmore | other technologies | Kilbush Nurseries CHP | DSO | connected | 2 |
| K | Dungarvan | solar | Kilcannon | DSO | offer | 5 |
| H2 | Carlow | solar | Kilcarrig Solar PV Farm | DSO | offer | 4 |
| C | Lanesboro | wind | Kilcash Community Wind Turbine | DSO | offer | 3 |
| E | Limerick | solar | Kilcolman Solar Farm | DSO | offer | 4 |
| G | Navan | solar | Kilkeelan Phase 2 Solar Farm | DSO | offer | 1 |
| G | Navan | solar | Kilkeelan Solar Farm | DSO | offer | 4 |
| H1 | Kill Hill | wind | Kill Hill (1) - phase 1 | TSO | connected | 36 |
| B | Tawnaghmore | battery | Killala (phase 2) | DSO | offer | 11 |
| B | Tawnaghmore | wind | Killala Wind Farm (Phase 1) | DSO | connected | 19 |
| F | Dunmanway | wind | Killaveenoge (formerly Barrboy (1)) | DSO | connected | 8 |
| A | Gortawee | wind | Killegar Community Wind Turbine | DSO | offer | 5 |
| A | Binbane | wind | Killin Hill (1) | DSO | connected | 6 |
| A | Binbane | wind | Killybegs (1) | DSO | connected | 3 |
| A | Binbane | wind | Killybegs Community Wind Turbine | DSO | offer | 4 |
| NI | Killymallaght | wind | Killymallaght - extra for 70pc | DSO | offer | 50 |
| H2 | Great Island | battery | Kilmannock Battery Storage Facility | DSO | offer | 30 |
| E | Charleville | wind | Kilmeedy (1) | DSO | connected | 5 |
| A | Arigna | wind | Kilronan (1) | DSO | connected | 5 |
| NI | Kilroot | battery | Kilroot battery | TSO | connected | 10 |
| D | Booltiagh | wind | Kiltumper | DSO | connected | 5 |
| F | Bandon | wind | Kilvinane (1) | DSO | connected | 5 |
| B | Cunghill | wind | Kingsmountain (1) | TSO | connected | 24 |
| B | Cunghill | wind | Kingsmountain (2) | TSO | connected | 11 |
| J | Blake T | solar | Kishavanna Solar Farm | DSO | offer | 5 |
| NI | Castlereagh | wind | Knock small scale - extra for 70pc | DSO | offer | 1 |
| E | Knockacummer | wind | Knockacummer (1) | TSO | connected | 100 |
| H2 | Arklow | solar | Knockadosan Solar (formerly Springfarm Wind Farm) | DSO | offer | 6 |
| D | Slievecallan | wind | Knockalassa (formerly Keelderry) | TSO | connected | 27 |
| B | Knockranny | wind | Knockalough (1) | TSO | connected | 35 |
| E | Oughtragh | wind | Knockaneden (1) | DSO | connected | 9 |
| D | Ardnacrusha | wind | Knockastanna (1) | DSO | connected | 8 |
| E | Trien 220 kV side | wind | Knockawarriga (1) | DSO | connected | 23 |
| E | Trien 220 kV side | wind | Knockawarriga Extension (Glenduff & Caherlevoy) Wi | DSO | connected | 7 |
| F | Dunmanway | wind | Knockeenbui Wind Farm | DSO | offer | 14 |
| F | Macroom | solar | Knockglass Solar extension | DSO | offer | 2 |
| F | Macroom | solar | Knockglass Solar Farm | DSO | offer | 4 |
| E | Cloghboola | wind | Knocknagashel Wind (Cloghboola (1)) | TSO | connected | 46 |
| E | Reamore | wind | Knocknagoum (1) | DSO | connected | 43 |
| E | Reamore | wind | Knocknagoum (2) formerly Muingnatee (3) | DSO | connected | 2 |
| H2 | Crory | wind | Knocknalour (1) | DSO | connected | 5 |
| H2 | Crory | wind | Knocknalour (2) | DSO | connected | 4 |
| K | Woodhouse | wind | Knocknamona Wind Farm (Prev. Crohaun) | TSO | offer | 34 |
| E | Ballyvouskil 220 | solar | Knocknamork solar | TSO | offer | 13 |
| E | Ballyvouskil 220 | wind | Knocknamork wind | TSO | offer | 42 |
| E | Charleville | wind | Knocknatallig | DSO | connected | 18 |

| | | | | | | |
|----|--------------|---------|--|-----|-----------|-----|
| B | Knockranny | wind | Knockranny wind | TSO | offer | 47 |
| H2 | Kilkenny | solar | Knocktopher Solar | DSO | offer | 4 |
| B | Moy | wind | Lackan (1) | DSO | connected | 6 |
| H1 | Ahane | solar | Laghtane Solar Farm | DSO | offer | 4 |
| F | Dunmanway | wind | Lahanaght Hill (1) | DSO | connected | 4 |
| B | Tonroe | wind | Largan Hill (1) | DSO | connected | 6 |
| NI | Larne | wind | Larne Main Total Wind | DSO | connected | 10 |
| NI | Larne | wind | Larne small scale - extra for 70pc | DSO | offer | 10 |
| NI | Waringstown | solar | Laurel Hill Road + Overinstall | DSO | connected | 10 |
| C | Dallow | wind | Leabeg (1) | DSO | connected | 4 |
| I | Barnahely | solar | Leacht Cross Solar | DSO | offer | 5 |
| E | Kilpaddoge | wind | Leanamore (1) (formerly Tarbert (1)) | DSO | connected | 18 |
| J | Thornsberry | solar | Lehinch Solar Farm | DSO | offer | 4 |
| B | Salthill | wind | Leitir Guingaid & Doire Chrith1 & 2 Merge | DSO | connected | 41 |
| A | Lenalea | wind | Lenalea Wind Farm | TSO | offer | 31 |
| B | Castlebar | wind | Lenanavea (Burren) Wind Farm | DSO | connected | 5 |
| NI | Omagh | wind | Lendrum's Bridge | DSO | connected | 13 |
| NI | Omagh | wind | Lendrum's Bridge - replant extra for 70pc | DSO | offer | 26 |
| A | Letterkenny | wind | Lettergull (1) | DSO | offer | 20 |
| G | Shankill | wind | Liffey Autoproduction Project | DSO | connected | 2 |
| G | Shankill | wind | Liffey Autoproduction Project (extension) | DSO | connected | 1 |
| NI | Limavady | wind | Limavady Main Total Wind | DSO | connected | 3 |
| NI | Limavady | wind | Limavady small scale - extra for 70pc | DSO | offer | 12 |
| NI | Lisaghmore | wind | Lisaghmore Main Total Wind | DSO | connected | 4 |
| NI | Lisaghmore | wind | Lisaghmore small scale - extra for 70pc | DSO | offer | 4 |
| H1 | Nenagh | solar | Lisbrien Solar Farm | DSO | offer | 4 |
| NI | Lisburn | solar | Lisburn Main Total PV | DSO | connected | 1 |
| NI | Lisburn | wind | Lisburn Main Total Wind | DSO | connected | 4 |
| NI | Lisburn | solar | Lisburn PV Park (aka Balinderry Road and Moneybroo | DSO | connected | 17 |
| NI | Lisburn | wind | Lisburn small scale - extra for 70pc | DSO | offer | 7 |
| H2 | Ballyragget | wind | Lisdowney (1) | DSO | connected | 9 |
| J | Portlaoise | wind | Lisdowney (1) | DSO | connected | 9 |
| G | Lisdrum | battery | Lisdrumdoagh Energy Storage Facility | TSO | offer | 60 |
| B | Dalton | solar | Lisduff Solar Park (Claremorris) | DSO | offer | 4 |
| NI | Eden | wind | Lisglass | DSO | connected | 2 |
| H1 | Lisheen | wind | Lisheen (1) | TSO | connected | 36 |
| H1 | Lisheen | wind | Lisheen (1a) | TSO | connected | 23 |
| H1 | Lisheen | wind | Lisheen 3 | TSO | offer | 29 |
| C | Richmond | solar | Lisnageeragh Solar Farm | DSO | offer | 4 |
| C | Mullingar | solar | Liss Solar Farm (prev Lands at Liss) | DSO | offer | 4 |
| D | Booltiagh | wind | Lissycasey (1) | DSO | connected | 13 |
| H2 | Ballyragget | solar | Loan PV | DSO | offer | 5 |
| NI | Loguestown | wind | Loguestown Main Total Wind | DSO | connected | 6 |
| NI | Rasharkin | wind | Long Mountain | DSO | connected | 28 |
| NI | Strabane | wind | Lough Hill | DSO | connected | 8 |
| NI | Lisburn | solar | Lough Road Solar | DSO | connected | 25 |
| K | Butlerstown | solar | Loughdenee Solar | DSO | offer | 9 |
| A | Binbane | wind | Loughderryduff (1) | DSO | connected | 8 |
| J | Coolnabacky | solar | Loughteague | TSO | offer | 55 |
| C | Derrycarney | battery | Lumcloon ESS (Derrycarney) | TSO | connected | 100 |
| A | Letterkenny | wind | Lurganboy (1) | DSO | connected | 5 |
| I | Midleton | solar | Lurrig Solar Farm | DSO | offer | 4 |
| I | Lysaghtstown | solar | Lysaghtstown Solar | TSO | offer | 87 |
| H2 | Crane | solar | Macallian Solar | DSO | offer | 9 |
| B | Dalton | wind | Mace Upper (1) | DSO | connected | 3 |

| | | | | | | |
|----|----------------------|--------------------|---|-----|-----------|----|
| H2 | Wexford | solar | Mackmine Solar | DSO | offer | 19 |
| E | Knockearagh | solar | Madam's Hill Solar Park | DSO | offer | 9 |
| NI | Lisburn | solar | Maghaberry Road | DSO | connected | 27 |
| B | Dalton | wind | Magheramore and Cloontooa (1) | DSO | connected | 41 |
| E | Oughtragh | solar | Maine Solar | DSO | offer | 4 |
| J | Glasmore | solar | Mainscourt | DSO | offer | 40 |
| C | Mullingar | solar | Marlinstown Solar Farm (prev Russellstown) | DSO | offer | 4 |
| G | Navan | solar | Martinstown Solar formerly Crowinstown Great wind | DSO | offer | 5 |
| J | Finglas | other technologies | Mater Hospital CHP (1) | DSO | connected | 2 |
| J | Stephenstown | solar | Matt Solar Farm | DSO | offer | 5 |
| E | Glenlara 220 kV side | wind | Mauricetown (Glenduff) Wind Farm | DSO | connected | 14 |
| B | Tawnaghmore | other technologies | Mayo Renewable Power Biomass CHP | DSO | offer | 49 |
| G | Drybridge | other technologies | Meath Waste-to-Energy (2) | DSO | connected | 4 |
| A | Binbane | wind | Meenachullalan (1) | DSO | connected | 12 |
| A | Binbane | wind | Meenachullalan (2) | DSO | offer | 2 |
| A | Cathaleen's Fall | wind | Meenadreen (1) | DSO | connected | 3 |
| A | Letterkenny | wind | Meenanilta (1) | DSO | connected | 3 |
| A | Letterkenny | wind | Meenanilta (2) | DSO | connected | 2 |
| A | Letterkenny | wind | Meenanilta (3) | DSO | connected | 3 |
| A | Trillick | wind | Meenaward | DSO | connected | 7 |
| A | Sorne Hill | wind | Meenkeeragh (1) | DSO | connected | 4 |
| A | Meentycat | wind | Meentycat (1) | TSO | connected | 71 |
| A | Meentycat | wind | Meentycat (2) | TSO | connected | 14 |
| C | Dallow | wind | Meenwaun WF | DSO | connected | 10 |
| NI | Ballymena | wind | Michelin | DSO | connected | 5 |
| C | Lanesboro | solar | Middleton solar (Longford) | TSO | offer | 57 |
| F | Dunmanway | wind | Milane Hill (1) | DSO | connected | 6 |
| NI | Antrim | solar | Millar Farm | DSO | connected | 8 |
| I | Midleton | other technologies | Millipore | DSO | connected | 1 |
| H2 | Ballybeg | solar | Millvale PV | DSO | offer | 8 |
| D | Tullabrack | wind | Moanmore (1) | DSO | connected | 13 |
| J | Mount Lucas | wind | Moanvane wind | TSO | offer | 60 |
| J | Athy | solar | Moatstown Solar | DSO | offer | 4 |
| NI | Aghyoule | wind | Molly Mountain | DSO | connected | 15 |
| H1 | Ikerrin | wind | Monaincha Bog (1) | DSO | connected | 36 |
| I | Knockraha | solar | Monatooreen Solar | TSO | offer | 26 |
| A | Corderry | wind | Moneenatieve (1) | DSO | connected | 4 |
| E | Moneypoint | battery | Moneypoint Battery Storage | TSO | offer | 8 |
| E | Moneypoint | wind | Moneypoint WF | TSO | connected | 17 |
| NI | Coolkeeragh | wind | Monnaboy | DSO | connected | 12 |
| H1 | Cahir | solar | Monroe East solar from merge Ballyfowloo Lawclon | DSO | offer | 8 |
| H1 | Mothel | solar | Mothel PV | TSO | offer | 60 |
| E | Tralee | wind | Mount Eagle (1) | DSO | connected | 5 |
| E | Tralee | wind | Mount Eagle (2) | DSO | connected | 2 |
| J | Mount Lucas | wind | Mount Lucas (1) | TSO | connected | 79 |
| G | Ratrussan | wind | Mountain Lodge (1) | TSO | connected | 25 |
| G | Shankill | wind | Mountain Lodge (2) | DSO | connected | 3 |
| G | Ratrussan | wind | Mountain Lodge (3) | TSO | connected | 6 |
| J | Thornsberry | solar | Muinagh Solar Farm | DSO | offer | 4 |
| J | Thornsberry | solar | Muinagh Solar Phase 2 | DSO | offer | 2 |
| E | Reamore | wind | Muingnaminnane (1) | DSO | connected | 15 |
| G | Meath Hill | wind | Mullananalt (1) | DSO | connected | 8 |
| A | Tievebrack | wind | Mully Graffy Windfarm (Kilgorman) | TSO | offer | 30 |
| A | Mulreavy | wind | Mulreavy (Mulreavy (1)) | TSO | connected | 82 |

| | | | | | | |
|----|--------------------|--------------------|--|-----|-----------|-----|
| A | Mulreavy | wind | Mulreavy Ext (Croaghnameal (1)) | TSO | connected | 4 |
| A | Mulreavy | wind | Mulreavy Ext (Meenadreen South (1)) | TSO | connected | 4 |
| A | Mulreavy | wind | Mulreavy Ext (Meenadreen South (2)) | TSO | connected | 5 |
| E | Limerick | solar | Mungret Solar | DSO | offer | 5 |
| NI | Gort | wind | Murley Mountain | DSO | offer | 23 |
| NI | Newry | battery | Newry battery | TSO | offer | 16 |
| NI | Newry | other technologies | Newry Biomass | DSO | offer | 4 |
| NI | Newry | solar | Newry Main Total PV | DSO | connected | 2 |
| NI | Newry | wind | Newry Main Total Wind | DSO | connected | 3 |
| NI | Newry | wind | Newry small scale - extra for 70pc | DSO | offer | 8 |
| NI | Newtownards | wind | Newtownards Main Total Wind | DSO | connected | 5 |
| NI | Castlereagh | wind | Newtownards small scale - extra for 70pc | DSO | offer | 4 |
| H2 | Arklow | battery | North Arklow battery | TSO | offer | 30 |
| H2 | Arklow | solar | North Arklow Solar | TSO | offer | 47 |
| J | Belcamp | wind offshore | North Irish Sea Array | TSO | offer | 250 |
| J | Belcamp | wind offshore | North Irish Sea Array (1) B | TSO | offer | 250 |
| J | North Wall | battery | North Wall 5 | TSO | offer | 120 |
| NI | Omagh | wind | Omagh Main Total Wind | DSO | connected | 13 |
| NI | Omagh | wind | Omagh small scale - extra for 70pc | DSO | offer | 41 |
| NI | Enniskillen | wind | Ora More | DSO | connected | 15 |
| G | Oriel | wind offshore | Oriel (1) | TSO | offer | 210 |
| G | Oriel | wind offshore | Oriel offshore new A | TSO | offer | 160 |
| K | Butlerstown | other technologies | Ormonde Organics AD | DSO | connected | 1 |
| J | Dunfirth | solar | Ovidstown Solar | DSO | offer | 4 |
| B | Bellacorick | wind | Oweninny 3 (Previously Oweninny 5) | TSO | offer | 50 |
| B | Bellacorick | wind | Oweninny Power (1) | TSO | connected | 93 |
| B | Bellacorick | wind | Oweninny Power (2) | TSO | offer | 83 |
| NI | Strabane | wind | Owenreagh - replant extra for 70pc | DSO | offer | 23 |
| NI | Strabane | wind | Owenreagh 1 | DSO | connected | 6 |
| NI | Strabane | wind | Owenreagh 2 | DSO | connected | 5 |
| G | Baltrasna | solar | Painestown Hill Solar Farm | DSO | offer | 10 |
| H2 | Ballyragget | solar | Parksgrove solar | DSO | offer | 35 |
| I | Trabeg | solar | Piercestown (formerly Jackeens) SPV | DSO | offer | 5 |
| NI | Curraghmulkin | wind | Pigeon Top | DSO | offer | 52 |
| H2 | Ballyragget | wind | Pinewoods wind | TSO | offer | 60 |
| I | Kilbarry | wind | Pluckanes (1) | DSO | connected | 1 |
| J | Newbridge | solar | Pollardstown PV | DSO | offer | 4 |
| J | Poolbeg north | wind offshore | Poolbeg 220 north offshore new A | TSO | offer | 450 |
| J | Poolbeg south | wind offshore | Poolbeg 220 south offshore new B | TSO | offer | 500 |
| J | Poolbeg south | wind offshore | Poolbeg 220 south offshore new C | TSO | offer | 500 |
| J | Poolbeg north | battery | Poolbeg BESS | TSO | offer | 75 |
| J | Kilteel | battery | Porterstown battery | TSO | offer | 60 |
| J | Kilteel | battery | Porterstown Battery Storage Facility | TSO | offer | 30 |
| B | Castlebar | wind | Raheen Barr (1) | DSO | connected | 19 |
| B | Castlebar | wind | Raheen Barr extension (was Derrynadivva extension) | DSO | connected | 7 |
| H2 | Arklow | wind | Raheenleagh (1) | DSO | connected | 35 |
| H2 | Waterford | wind | Rahora (1) | DSO | connected | 4 |
| G | Meath Hill | wind | Raragh (2) | DSO | connected | 12 |
| E | Rathkeale | wind | Rathcahill (1) | DSO | connected | 13 |
| NI | Rathgael | wind | Rathgael Main Total Wind | DSO | connected | 1 |
| NI | Castlereagh | wind | Rathgael small scale - extra for 70pc | DSO | offer | 4 |
| C | Carrick on Shannon | solar | Rathleg Solar Farm | DSO | offer | 4 |
| E | Charleville | wind | Rathnacally (1) | DSO | connected | 4 |
| K | Rathnaskilloge | solar | Rathnaskilloge | TSO | offer | 95 |
| NI | Ballymena | wind | Rathsherry | DSO | connected | 21 |

| | | | | | | |
|----|-------------------|--------------------|--|-----|-----------|-----|
| G | Ratrussan | wind | Ratrussan (1a) | TSO | connected | 48 |
| F | Dunmanway | wind | Reenascreena (1) | DSO | connected | 5 |
| J | Derryiron | battery | Rhode 37.5 MW ESS | DSO | offer | 38 |
| H2 | Wexford | wind | Richfield (1) | DSO | connected | 20 |
| H2 | Wexford | wind | Richfield (2) | DSO | connected | 7 |
| NI | Coleraine | wind | Rigged Hill | DSO | connected | 5 |
| NI | Coleraine | wind | Rigged Hill - replant extra for 70pc | DSO | offer | 24 |
| C | Athlone | solar | Rooaun Solar | DSO | offer | 4 |
| B | Tonroe | wind | Roosky (1) | DSO | connected | 4 |
| NI | Rosebank | wind | Rosebank Main Total Wind | DSO | connected | 3 |
| B | Knockranny | wind | Rossaveel Wind | DSO | connected | 3 |
| H2 | Rosspile | solar | Rosspile Solar Farm | TSO | offer | 95 |
| C | Lanesboro | wind | Roxborough | DSO | offer | 5 |
| E | Cordal | wind | Scartaglen (1) | DSO | connected | 35 |
| E | Cordal | wind | Scartaglen (2) | DSO | connected | 4 |
| NI | Omagh | wind | Screggagh | DSO | connected | 20 |
| B | Uggool | wind | Seecon (1) | TSO | connected | 105 |
| NI | Magherakeel | wind | Seegronan | DSO | connected | 14 |
| NI | Magherakeel | wind | Seegronan Extension Wind farm | DSO | offer | 7 |
| A | Arigna | wind | Seltanaveeny (1) | DSO | connected | 5 |
| G | Navan | other technologies | Shamrock Renewable Fuels formerly Farelly Brothers | DSO | offer | 13 |
| E | Trien | solar | Shanacool (Trienearagh) Solar Park | DSO | offer | 4 |
| I | Trabeg | solar | Shanagraigue | DSO | offer | 5 |
| J | Portlaoise | solar | Shanderry Solar Farm | DSO | offer | 4 |
| A | Binbane | wind | Shannagh (1) previously Kilcar | DSO | connected | 3 |
| C | Athlone | solar | Shannagh Beg Solar Farm | DSO | offer | 4 |
| C | Shannonbridge 220 | battery | Shannonbridge B ESS | TSO | offer | 63 |
| C | Shannonbridge 220 | battery | Shannonbridge ESS | TSO | offer | 100 |
| B | Shantallow | solar | Shantallow Solar | TSO | offer | 35 |
| NI | Gort | wind | Shantavny Scotch | DSO | connected | 16 |
| B | Bellacorick | wind | Sheskin (1) | DSO | offer | 17 |
| B | Bellacorick | wind | Sheskin (2) | DSO | offer | 16 |
| C | Mullingar | solar | Sianmore PV | DSO | offer | 17 |
| C | Dallow | wind | Skehanagh (1) | DSO | connected | 4 |
| C | Lanesboro | wind | Skrine (1) | DSO | connected | 5 |
| C | Sliabh Bawn | wind | Sliabh Bawn (1) | TSO | connected | 58 |
| NI | Omagh | wind | Slieve Divena 1 | DSO | connected | 30 |
| NI | Gort | wind | Slieve Divena 2 | DSO | connected | 20 |
| NI | Killymallaght | wind | Slieve Kirk | TSO | connected | 74 |
| NI | Aghyoule | wind | Slieve Rushen (Mantlin) | DSO | connected | 54 |
| NI | Curraghamulkin | wind | Slieveglass | DSO | connected | 7 |
| NI | Ballymena | wind | Slievehanaghan | DSO | connected | 1 |
| H1 | Tipperary | wind | Slievereagh (1) | DSO | connected | 3 |
| H1 | Tipperary | wind | Slievereagh (1) | DSO | connected | 2 |
| NI | Agivey | wind | Smulgedon | DSO | offer | 16 |
| NI | Aghyoule | wind | Snugborough | DSO | connected | 14 |
| NI | Aghyoule | wind | Snugborough - replant extra for 70pc | DSO | offer | 24 |
| C | Somerset | wind | Sonnagh Old (1) | DSO | connected | 8 |
| A | Sorne Hill | wind | Sorne Hill (1) | DSO | connected | 32 |
| A | Sorne Hill | wind | Sorne Hill (2) | DSO | connected | 7 |
| A | Sorne Hill | wind | Sorne Hill Single Turbine (Enros) | DSO | connected | 2 |
| D | Booltiagh | wind | Sorrell Island (Glenmore) WF Ext | DSO | connected | 8 |
| D | Booltiagh | wind | Sorrell Island (prev Glenmore) (1) | DSO | connected | 24 |
| J | Irishtown | battery | South Wall BESS | TSO | offer | 30 |
| A | Cathaleen's Fall | wind | Spaddan (1) | DSO | connected | 18 |

| | | | | | | |
|----|-------------------|--------------------|---|-----|-----------|----|
| A | Arigna | wind | Spion Kop (1) | DSO | connected | 1 |
| NI | Lisaghmore | wind | Springtown small scale - extra for 70pc | DSO | offer | 4 |
| E | Reamore | wind | Stack's Mountain | DSO | offer | 25 |
| G | Drybridge | solar | Stamullen 2 | DSO | offer | 1 |
| G | Drybridge | solar | Stamullen Solar Park | DSO | offer | 4 |
| NI | Kells | solar | Steeple Road | DSO | offer | 21 |
| NI | Strabane | wind | Strabane Main Total Wind | DSO | connected | 12 |
| NI | Strabane | wind | Strabane small scale - extra for 70pc | DSO | offer | 12 |
| NI | Magherafelt | wind | Straw Mountain Wind Farm | DSO | offer | 3 |
| J | Griffinrath | solar | Taghadoe Solar Farm | DSO | offer | 25 |
| G | Meath Hill | wind | Taghart (1) | DSO | offer | 23 |
| NI | Tamnamore | battery | Tamnamore battery | TSO | connected | 50 |
| NI | Tandragee | battery | Tandragee battery | TSO | connected | 50 |
| NI | Omagh | wind | Tappaghan | DSO | connected | 29 |
| E | Glenlara | wind | Taurbeg (1) | DSO | connected | 26 |
| I | Midleton | solar | Tead More Solar (Meelshane) | DSO | offer | 4 |
| G | Meath Hill | wind | Teevurcher | DSO | connected | 9 |
| NI | Gort | wind | Teiges | DSO | connected | 11 |
| H1 | Nenagh | wind | Templederry (1) | DSO | connected | 4 |
| B | Sligo | wind | Templehouse Community Wind Turbine | DSO | offer | 4 |
| H2 | Arklow | solar | Templerainey East Solar Farm (Ballycooleen) | DSO | offer | 4 |
| H2 | Crory | solar | The Dell Solar | DSO | offer | 20 |
| NI | Magherakeel | wind | Thornog | DSO | connected | 20 |
| A | Sorne Hill | wind | Three Trees (1) | DSO | connected | 4 |
| J | Kilteel | solar | Threecastles Solar Farm | DSO | offer | 15 |
| NI | Magherakeel | wind | Tievenameenta | DSO | connected | 35 |
| J | Timahoe North | solar | Timahoe North solar | TSO | offer | 70 |
| F | Bandon | other technologies | Timoleague Agri Gen | DSO | connected | 1 |
| E | Trien | wind | Tournafulla (1) | DSO | connected | 8 |
| E | Trien 220 kV side | wind | Tournafulla (2) | DSO | connected | 17 |
| J | Griffinrath | solar | Tower Hill Solar Farm | DSO | offer | 6 |
| H2 | Wexford | solar | Tracystown Solar | TSO | offer | 81 |
| J | Treascon | solar | Treascon Solar | TSO | offer | 40 |
| NI | Tremoge | wind | Tremoge - extra for 70pc | DSO | offer | 58 |
| C | Mullingar | wind | Tromra Community WT | DSO | offer | 5 |
| H2 | Tullabeg | solar | Tullabeg Solar Park | TSO | offer | 50 |
| D | Tullabrack | wind | Tullabrack (1) | DSO | connected | 14 |
| A | Gortawee | wind | Tullyhaw Community Wind Turbine | DSO | offer | 5 |
| C | Mullingar | solar | Tullynally Estate | DSO | offer | 4 |
| G | Meath Hill | wind | Tullynamalra (1) | DSO | connected | 3 |
| A | Corderry | wind | Tullynamoyle (1) | DSO | connected | 9 |
| A | Corderry | wind | Tullynamoyle 2 Wind Farm | DSO | connected | 10 |
| A | Corderry | wind | Tullynamoyle 3 | DSO | connected | 12 |
| A | Corderry | wind | Tullynamoyle Wind Farm 5 | DSO | offer | 16 |
| D | Ardnacrusha | solar | Tuogh Solar Park | DSO | offer | 5 |
| E | Tralee | wind | Tursillagh (1) | DSO | connected | 15 |
| E | Tralee | wind | Tursillagh (2) | DSO | connected | 7 |
| B | Uggool | wind | Uggool (1) | TSO | connected | 64 |
| J | Blackrock | other technologies | University College Dublin | DSO | connected | 1 |
| H1 | Killonan | wind | Upperchurch (1) | DSO | offer | 94 |
| NI | Waringstown | wind | Waringstown small scale - extra for 70pc | DSO | offer | 7 |
| E | Knockearagh | wind | WEDcross (1) | DSO | connected | 5 |
| G | Dundalk | solar | Willville Solar Park | DSO | offer | 4 |
| G | Dundalk | solar | Willville Solar Park extension | DSO | offer | 1 |
| I | Barnahely | wind | Wind Energy Project (Janssen) | DSO | connected | 2 |
| NI | Larne | wind | Wolf Bog | DSO | connected | 10 |

| | | | | | | |
|---|-----------|--------------------|----------------------------|-----|-----------|-----|
| K | Woodhouse | wind | Woodhouse (1) | TSO | connected | 20 |
| J | Athy | solar | Woodstock North Solar Farm | DSO | offer | 5 |
| E | Rathkeale | other technologies | Wyeth Askeaton | DSO | connected | 7 |
| J | Derryiron | wind | Yellow River Wind Farm | TSO | offer | 110 |

Table B-4 Generator List by Name

Note that the year of connection is rounded from the build-out rate date or target connection date.

These are in addition to the large generators which are listed in EirGrid and SONI's All Island Generation Capacity Statement 2021 - 2030.

Appendix C Area K Node Results

This appendix presents the results of the modelling analysis for Area K. The levels of over-supply, curtailment and constraint that controllable solar and wind generators in Area K might expect to experience are reported on a nodal basis for the study scenarios. Details on the generation capacity at each node are also provided along with the assumed amount of controllable generation.

This appendix also presents a list for each node of those generators that are included in the study.



Figure C-1 Area K

C.1 Butlerstown

The location of this node is shown in the figure below.



Figure C-2 Location of Node

The generators, which are modelled at this node, are listed as follows.

| Generator | SO | Type | Status | Capacity (MW) |
|-----------------------------|-----|--------------------|----------|---------------|
| Amberhill Solar Farm | DSO | solar not priority | ECP 2.1 | 4.0 |
| Beallough (1) | DSO | wind uncontrolled | Pre-Gate | 1.7 |
| Clashganny South Solar Farm | DSO | solar not priority | ECP 2.1 | 10.0 |
| Keiloge Solar | DSO | solar not priority | ECP 1 | 4.0 |
| Loughdenee Solar | DSO | solar not priority | ECP 2.1 | 9.0 |
| Ormonde Organics AD | DSO | priority | Non GPA | 1.0 |

Table C-1 Generation Included in Study for Node

The solar not priority data is given in the below table.

| BUTLERSTOWN | | | | | | | |
|------------------------|-------------------------|---------|------|------|------|----------------------|----------------------|
| SOLAR NOT PRIORITY | Year | Initial | 33% | 66% | ECP | ECP + 1.7GW Offshore | ECP + 3.9GW Offshore |
| Installed (MW) | 2024 | 4 | 12 | 19 | 27 | | |
| Installed (MW) | 2026 | | | | 27 | 27 | |
| Installed (MW) | 2026 with GL | 4 | 12 | 19 | 27 | 27 | |
| Installed (MW) | 2026 with GL and Celtic | | | | 27 | 27 | |
| Installed (MW) | Future Grid | | | | 27 | 27 | 27 |
| Available Energy (GWh) | 2024 | 4.3 | 12.5 | 20.9 | 29.1 | | |
| Available Energy (GWh) | 2026 | | | | 29.1 | 29.1 | |
| Available Energy (GWh) | 2026 with GL | 4.3 | 12.5 | 20.9 | 29.1 | 29.1 | |
| Available Energy (GWh) | 2026 with GL and Celtic | | | | 29.1 | 29.1 | |
| Available Energy (GWh) | Future Grid | | | | 29.1 | 29.1 | 29.1 |

| | | | | | | | |
|-------------------------|-------------------------|-----|------|------|------|------|------|
| Generation (GWh) | 2024 | 3.8 | 10.8 | 17.4 | 23.2 | | |
| Generation (GWh) | 2026 | | | | 24.8 | 23.6 | |
| Generation (GWh) | 2026 with GL | 3.9 | 11.2 | 18.2 | 24.4 | 23.5 | |
| Generation (GWh) | 2026 with GL and Celtic | | | | 27.5 | 26.4 | |
| Generation (GWh) | Future Grid | | | | 27.6 | 27.5 | 26.0 |
| Over-supply (%) | 2024 | 0% | 1% | 2% | 3% | | |
| Over-supply (%) | 2026 | | | | 3% | 9% | |
| Over-supply (%) | 2026 with GL | | 0% | 1% | 2% | 7% | |
| Over-supply (%) | 2026 with GL and Celtic | | | | 1% | 4% | |
| Over-supply (%) | Future Grid | | | | 0% | 2% | 7% |
| Curtailment (%) | 2024 | 1% | 2% | 2% | 3% | | |
| Curtailment (%) | 2026 | | | | 2% | 4% | |
| Curtailment (%) | 2026 with GL | | 1% | 1% | 2% | 3% | |
| Curtailment (%) | 2026 with GL and Celtic | | | | 1% | 3% | |
| Curtailment (%) | Future Grid | | | | 0% | 1% | 2% |
| Constraint (%) | 2024 | 10% | 11% | 13% | 14% | | |
| Constraint (%) | 2026 | | | | 9% | 6% | |
| Constraint (%) | 2026 with GL | 7% | 10% | 11% | 12% | 9% | |
| Constraint (%) | 2026 with GL and Celtic | | | | 4% | 2% | |
| Constraint (%) | Future Grid | | | | 4% | 2% | 1% |
| Total Dispatch Down (%) | 2024 | 11% | 14% | 17% | 20% | | |
| Total Dispatch Down (%) | 2026 | | | | 15% | 19% | |
| Total Dispatch Down (%) | 2026 with GL | 7% | 10% | 13% | 16% | 19% | |
| Total Dispatch Down (%) | 2026 with GL and Celtic | | | | 6% | 9% | |
| Total Dispatch Down (%) | Future Grid | | | | 5% | 5% | 11% |

Table C-2 Results for Solar Not Priority

BUTLERSTOWN SOLAR NOT PRIORITY




Figure C-3 Total Dispatch Down for Solar Not Priority

C.2 Dungarvan

The location of this node is shown in the figure below.




Figure C-4 Location of Node

The generators, which are modelled at this node, are listed as follows.

| Generator | SO | Type | Status | Capacity (MW) |
|--------------------------------------|-----|--------------------|---------|---------------|
| Ballycurreen (1) | DSO | wind uncontrolled | Gate 3 | 5.0 |
| Ballymac PV | DSO | solar not priority | ECP 2.1 | 5.0 |
| Clashnagoneen Solar Farm | DSO | solar not priority | ECP 1 | 4.0 |
| Cooltubbrid West Solar | DSO | solar not priority | ECP 2.1 | 4.0 |
| Drumroe East Solar 2 Cluster | DSO | solar not priority | ECP 2.1 | 37.0 |
| Drumroe East Solar Farm | DSO | solar not priority | ECP 1 | 15.0 |
| Eras Eco AD (prev Knocknagappagh WF) | DSO | priority | Gate 2 | 1.7 |
| Foxhall PV | DSO | solar not priority | ECP 1 | 4.0 |
| Kilcannon | DSO | solar not priority | ECP 2.1 | 5.0 |

Table C-3 Generation Included in Study for Node

The solar not priority data is given in the below table.

| DUNGARVAN | | | | | | | |
|--------------------|-------------------------|---------|-----|-----|-----|----------------------|----------------------|
| SOLAR NOT PRIORITY | Year | Initial | 33% | 66% | ECP | ECP + 1.7GW Offshore | ECP + 3.9GW Offshore |
| Installed (MW) | 2024 | 23 | 40 | 57 | 74 | | |
| Installed (MW) | 2026 | | | | 74 | 74 | |
| Installed (MW) | 2026 with GL | 23 | 40 | 57 | 74 | 74 | |
| Installed (MW) | 2026 with GL and Celtic | | | | 74 | 74 | |
| Installed (MW) | Future Grid | | | | 74 | 74 | 74 |

| | | | | | | | |
|-------------------------|-------------------------|------|------|------|------|------|------|
| Available Energy (GWh) | 2024 | 24.8 | 43.0 | 61.7 | 79.9 | | |
| Available Energy (GWh) | 2026 | | | | 79.8 | 79.8 | |
| Available Energy (GWh) | 2026 with GL | 24.8 | 43.0 | 61.7 | 79.8 | 79.8 | |
| Available Energy (GWh) | 2026 with GL and Celtic | | | | 79.8 | 79.8 | |
| Available Energy (GWh) | Future Grid | | | | 79.8 | 79.8 | 79.8 |
| | | | | | | | |
| Generation (GWh) | 2024 | 22.1 | 37.2 | 51.5 | 63.7 | | |
| Generation (GWh) | 2026 | | | | 68.2 | 64.8 | |
| Generation (GWh) | 2026 with GL | 22.9 | 38.6 | 53.8 | 66.9 | 64.5 | |
| Generation (GWh) | 2026 with GL and Celtic | | | | 75.4 | 72.4 | |
| Generation (GWh) | Future Grid | | | | 75.8 | 75.5 | 71.3 |
| | | | | | | | |
| Over-supply (%) | 2024 | 0% | 1% | 2% | 3% | | |
| Over-supply (%) | 2026 | | | | 3% | 9% | |
| Over-supply (%) | 2026 with GL | 0% | 0% | 1% | 2% | 7% | |
| Over-supply (%) | 2026 with GL and Celtic | | | | 1% | 4% | |
| Over-supply (%) | Future Grid | | | | 0% | 2% | 7% |
| | | | | | | | |
| Curtailement (%) | 2024 | 1% | 2% | 2% | 3% | | |
| Curtailement (%) | 2026 | | | | 2% | 4% | |
| Curtailement (%) | 2026 with GL | 0% | 1% | 1% | 2% | 3% | |
| Curtailement (%) | 2026 with GL and Celtic | | | | 1% | 3% | |
| Curtailement (%) | Future Grid | | | | 0% | 1% | 2% |
| | | | | | | | |
| Constraint (%) | 2024 | 10% | 11% | 13% | 14% | | |
| Constraint (%) | 2026 | | | | 9% | 6% | |
| Constraint (%) | 2026 with GL | 7% | 10% | 11% | 12% | 9% | |
| Constraint (%) | 2026 with GL and Celtic | | | | 4% | 2% | |
| Constraint (%) | Future Grid | | | | 4% | 2% | 1% |
| | | | | | | | |
| Total Dispatch Down (%) | 2024 | 11% | 14% | 17% | 20% | | |
| Total Dispatch Down (%) | 2026 | | | | 15% | 19% | |
| Total Dispatch Down (%) | 2026 with GL | 8% | 10% | 13% | 16% | 19% | |
| Total Dispatch Down (%) | 2026 with GL and Celtic | | | | 6% | 9% | |
| Total Dispatch Down (%) | Future Grid | | | | 5% | 5% | 11% |

Table C-4 Results for Solar Not Priority

DUNGARVAN SOLAR NOT PRIORITY




Figure C-5 Total Dispatch Down for Solar Not Priority

C.3 Rathnaskilloge

The location of this node is shown in the figure below.



Figure C-6 Location of Node

The generators, which are modelled at this node, are listed as follows.

| Generator | SO | Type | Status | Capacity (MW) |
|----------------|-----|--------------------|--------|---------------|
| Rathnaskilloge | TSO | solar not priority | ECP 1 | 95.0 |

Table C-5 Generation Included in Study for Node

The solar not priority data is given in the below table.

| RATHNASKILLOGE | | | | | | | |
|------------------------|-------------------------|---------|-------|-------|-------|----------------------|----------------------|
| SOLAR NOT PRIORITY | Year | Initial | 33% | 66% | ECP | ECP + 1.7GW Offshore | ECP + 3.9GW Offshore |
| Installed (MW) | 2024 | 95 | 95 | 95 | 95 | | |
| Installed (MW) | 2026 | | | | 95 | 95 | |
| Installed (MW) | 2026 with GL | 95 | 95 | 95 | 95 | 95 | |
| Installed (MW) | 2026 with GL and Celtic | | | | 95 | 95 | |
| Installed (MW) | Future Grid | | | | 95 | 95 | 95 |
| Available Energy (GWh) | 2024 | 102.7 | 102.7 | 102.7 | 102.7 | | |
| Available Energy (GWh) | 2026 | | | | 102.6 | 102.6 | |
| Available Energy (GWh) | 2026 with GL | 102.6 | 102.6 | 102.6 | 102.6 | 102.6 | |
| Available Energy (GWh) | 2026 with GL and Celtic | | | | 102.6 | 102.6 | |
| Available Energy (GWh) | Future Grid | | | | 102.6 | 102.6 | 102.6 |
| Generation (GWh) | 2024 | 91.3 | 88.7 | 85.6 | 81.9 | | |
| Generation (GWh) | 2026 | | | | 87.6 | 83.3 | |
| Generation (GWh) | 2026 with GL | 94.8 | 92.1 | 89.5 | 86.0 | 82.9 | |
| Generation (GWh) | 2026 with GL and Celtic | | | | 96.9 | 93.1 | |
| Generation (GWh) | Future Grid | | | | 97.4 | 97.0 | 91.7 |
| Over-supply (%) | 2024 | 0% | 1% | 2% | 3% | | |
| Over-supply (%) | 2026 | | | | 3% | 9% | |

| | | | | | | | |
|-------------------------|-------------------------|-----|-----|-----|-----|-----|-----|
| Over-supply (%) | 2026 with GL | 0% | 0% | 1% | 2% | 7% | |
| Over-supply (%) | 2026 with GL and Celtic | | | | 1% | 4% | |
| Over-supply (%) | Future Grid | | | | 0% | 2% | 7% |
| | | | | | | | |
| Curtailment (%) | 2024 | 1% | 2% | 2% | 3% | | |
| Curtailment (%) | 2026 | | | | 2% | 4% | |
| Curtailment (%) | 2026 with GL | 0% | 1% | 1% | 2% | 3% | |
| Curtailment (%) | 2026 with GL and Celtic | | | | 1% | 3% | |
| Curtailment (%) | Future Grid | | | | 0% | 1% | 2% |
| | | | | | | | |
| Constraint (%) | 2024 | 10% | 11% | 13% | 14% | | |
| Constraint (%) | 2026 | | | | 9% | 6% | |
| Constraint (%) | 2026 with GL | 7% | 10% | 11% | 12% | 9% | |
| Constraint (%) | 2026 with GL and Celtic | | | | 4% | 2% | |
| Constraint (%) | Future Grid | | | | 4% | 2% | 1% |
| | | | | | | | |
| Total Dispatch Down (%) | 2024 | 11% | 14% | 17% | 20% | | |
| Total Dispatch Down (%) | 2026 | | | | 15% | 19% | |
| Total Dispatch Down (%) | 2026 with GL | 8% | 10% | 13% | 16% | 19% | |
| Total Dispatch Down (%) | 2026 with GL and Celtic | | | | 6% | 9% | |
| Total Dispatch Down (%) | Future Grid | | | | 5% | 5% | 11% |

Table C-6 Results for Solar Not Priority

RATHNASKILLOGE SOLAR NOT PRIORITY




Figure C-7 Total Dispatch Down for Solar Not Priority

C.4 Woodhouse

The location of this node is shown in the figure below.




Figure C-8 Location of Node

The generators, which are modelled at this node, are listed as follows.

| Generator | SO | Type | Status | Capacity (MW) |
|---------------------------------------|-----|-------------------|--------|---------------|
| Knocknamona Wind Farm (Prev. Crohaun) | TSO | wind not priority | Gate 3 | 34.0 |
| Woodhouse (1) | TSO | wind priority | Gate 3 | 20.0 |

Table C-7 Generation Included in Study for Node

The wind not priority data is given in the below table.

| WOODHOUSE | | | | | | | |
|------------------------|-------------------------|---------|-------|-------|-------|----------------------|----------------------|
| WIND NOT PRIORITY | Year | Initial | 33% | 66% | ECP | ECP + 1.7GW Offshore | ECP + 3.9GW Offshore |
| Installed (MW) | 2024 | 34 | 34 | 34 | 34 | | |
| Installed (MW) | 2026 | | | | 34 | 34 | |
| Installed (MW) | 2026 with GL | 34 | 34 | 34 | 34 | 34 | |
| Installed (MW) | 2026 with GL and Celtic | | | | 34 | 34 | |
| Installed (MW) | Future Grid | | | | 34 | 34 | 34 |
| Available Energy (GWh) | 2024 | 124.5 | 124.5 | 124.5 | 124.5 | | |
| Available Energy (GWh) | 2026 | | | | 124.0 | 124.0 | |
| Available Energy (GWh) | 2026 with GL | 124.0 | 124.0 | 124.0 | 124.0 | 124.0 | |
| Available Energy (GWh) | 2026 with GL and Celtic | | | | 124.0 | 124.0 | |
| Available Energy (GWh) | Future Grid | | | | 124.0 | 124.0 | 124.0 |
| Generation (GWh) | 2024 | 106.0 | 103.2 | 100.4 | 97.1 | | |
| Generation (GWh) | 2026 | | | | 101.7 | 88.2 | |

| | | | | | | | |
|-------------------------|-------------------------|-------|-------|-------|-------|-------|-------|
| Generation (GWh) | 2026 with GL | 112.8 | 109.5 | 107.0 | 103.1 | 89.8 | |
| Generation (GWh) | 2026 with GL and Celtic | | | | 117.3 | 105.4 | |
| Generation (GWh) | Future Grid | | | | 117.8 | 114.9 | 100.8 |
| Over-supply (%) | 2024 | 1% | 3% | 5% | 7% | | |
| Over-supply (%) | 2026 | | | | 6% | 18% | |
| Over-supply (%) | 2026 with GL | 0% | 1% | 2% | 3% | 14% | |
| Over-supply (%) | 2026 with GL and Celtic | | | | 1% | 8% | |
| Over-supply (%) | Future Grid | | | | 0% | 3% | 14% |
| Curtailment (%) | 2024 | 2% | 3% | 4% | 5% | | |
| Curtailment (%) | 2026 | | | | 4% | 6% | |
| Curtailment (%) | 2026 with GL | 1% | 1% | 2% | 3% | 5% | |
| Curtailment (%) | 2026 with GL and Celtic | | | | 2% | 5% | |
| Curtailment (%) | Future Grid | | | | 0% | 2% | 4% |
| Constraint (%) | 2024 | 11% | 11% | 11% | 11% | | |
| Constraint (%) | 2026 | | | | 8% | 5% | |
| Constraint (%) | 2026 with GL | 8% | 10% | 10% | 10% | 8% | |
| Constraint (%) | 2026 with GL and Celtic | | | | 3% | 2% | |
| Constraint (%) | Future Grid | | | | 4% | 1% | 1% |
| Total Dispatch Down (%) | 2024 | 15% | 17% | 19% | 22% | | |
| Total Dispatch Down (%) | 2026 | | | | 18% | 29% | |
| Total Dispatch Down (%) | 2026 with GL | 9% | 12% | 14% | 17% | 28% | |
| Total Dispatch Down (%) | 2026 with GL and Celtic | | | | 5% | 15% | |
| Total Dispatch Down (%) | Future Grid | | | | 5% | 7% | 19% |

Table C-8 Results for Wind Not Priority

WOODHOUSE WIND NOT PRIORITY




Figure C-9 Total Dispatch Down for Wind Not Priority

The wind priority data is given in the below table.

| WOODHOUSE | | | | | | | |
|-------------------------|-------------------------|---------|------|------|------|----------------------|----------------------|
| WIND PRIORITY | Year | Initial | 33% | 66% | ECP | ECP + 1.7GW Offshore | ECP + 3.9GW Offshore |
| Installed (MW) | 2024 | 20 | 20 | 20 | 20 | | |
| Installed (MW) | 2026 | | | | 20 | 20 | |
| Installed (MW) | 2026 with GL | 20 | 20 | 20 | 20 | 20 | |
| Installed (MW) | 2026 with GL and Celtic | | | | 20 | 20 | |
| Installed (MW) | Future Grid | | | | 20 | 20 | 20 |
| Available Energy (GWh) | 2024 | 73.2 | 73.2 | 73.2 | 73.2 | | |
| Available Energy (GWh) | 2026 | | | | 72.9 | 72.9 | |
| Available Energy (GWh) | 2026 with GL | 72.9 | 72.9 | 72.9 | 72.9 | 72.9 | |
| Available Energy (GWh) | 2026 with GL and Celtic | | | | 72.9 | 72.9 | |
| Available Energy (GWh) | Future Grid | | | | 72.9 | 72.9 | 72.9 |
| Generation (GWh) | 2024 | 63.1 | 62.0 | 61.4 | 60.6 | | |
| Generation (GWh) | 2026 | | | | 62.7 | 61.9 | |
| Generation (GWh) | 2026 with GL | 66.6 | 64.7 | 63.8 | 62.4 | 60.6 | |
| Generation (GWh) | 2026 with GL and Celtic | | | | 69.3 | 67.1 | |
| Generation (GWh) | Future Grid | | | | 69.3 | 69.3 | 68.2 |
| Over-supply (%) | 2024 | | | | | | |
| Over-supply (%) | 2026 | | | | | | |
| Over-supply (%) | 2026 with GL | | | | | | |
| Over-supply (%) | 2026 with GL and Celtic | | | | | | |
| Over-supply (%) | Future Grid | | | | | | |
| Curtailment (%) | 2024 | 3% | 4% | 5% | 6% | | |
| Curtailment (%) | 2026 | | | | 6% | 9% | |
| Curtailment (%) | 2026 with GL | 1% | 1% | 2% | 4% | 7% | |
| Curtailment (%) | 2026 with GL and Celtic | | | | 2% | 6% | |
| Curtailment (%) | Future Grid | | | | 0% | 3% | 5% |
| Constraint (%) | 2024 | 11% | 12% | 11% | 11% | | |
| Constraint (%) | 2026 | | | | 8% | 6% | |
| Constraint (%) | 2026 with GL | 8% | 10% | 10% | 11% | 10% | |
| Constraint (%) | 2026 with GL and Celtic | | | | 3% | 2% | |
| Constraint (%) | Future Grid | | | | 5% | 2% | 1% |
| Total Dispatch Down (%) | 2024 | 14% | 15% | 16% | 17% | | |
| Total Dispatch Down (%) | 2026 | | | | 14% | 15% | |
| Total Dispatch Down (%) | 2026 with GL | 9% | 11% | 12% | 14% | 17% | |
| Total Dispatch Down (%) | 2026 with GL and Celtic | | | | 5% | 8% | |
| Total Dispatch Down (%) | Future Grid | | | | 5% | 5% | 7% |

Table C-9 Results for Wind Priority

WOODHOUSE WIND PRIORITY




Figure C-10 Total Dispatch Down for Wind Priority

Abbreviation and Terms

Active Power

The product of voltage and the in-phase component of alternating current measured in Megawatts (MW). When compounded with the flow of 'reactive power', measured in Megavolt-Amperes Reactive (Mvar), the resultant is measured in Megavolt-Amperes (MVA).

Busbar

The common connection point of two or more circuits.

Capacity Factor

The capacity factor of a generator is the ratio of the actual electrical energy output over a given period of time to the maximum possible electrical energy output over that period.

$$\text{Capacity Factor} = \frac{\text{Energy Output}}{\text{Hours per year} * \text{Installed Capacity}}$$

Combined Cycle Gas Turbine (CCGT)

This is a type of thermal generator that typically uses natural gas as a fuel source. It is a collection of gas turbines and steam units; where waste heat from the gas turbine(s) is passed through a heat recovery boiler to generate steam for the steam turbines.

Commission for Regulation of Utilities (CRU)

The CRU is the regulator for the electricity, natural gas and public water sectors in Ireland.

Constraint

The reduction in output of a generator due to network limits. Usually, constraints are local to a transmission bottleneck.

Contingency

The unexpected failure or outage of a system component, such as a generation unit, transmission line, transformer or other electrical element. The transmission network is operated safe against the possible failure or outage of any system component. Hence, contingency usually refers to the possible loss of any system component. A contingency may also include multiple components, when these are subject to common cause outages.

Curtailement

Curtailement is when the transmission system operators EirGrid and SONI ask generation to reduce their output to ensure system security is maintained. Usually, curtailement is shared across the whole system.

Demand

The amount of electrical power that customers consume and which is measured in Megawatts (MW). In a general sense, the amount of power that must be transported from transmission network connected generation stations to meet all customers' electricity requirements.

Dispatch Balancing Costs (DBC)

Dispatch Balancing Costs refers to a number of payments related to how generators are instructed. They include Constraint Payments, Uninstructed Imbalance Payments and Generator Testing Charges. The Transmission System Operators (TSOs) are responsible for forecasting and managing Dispatch Balancing Costs.

Enduring Connection Policy (ECP)

The Commission for Regulation of Utilities (CRU) has put in place a revised approach to issuing connection offers to generators. This approach is called the Enduring Connection Policy (ECP). With ECP, it is envisaged

that batches of generator connection offers will issue on a periodic basis.

Enduring Connection Policy - 2 (ECP-2)

ECP-2 is the second stage of the CRU's development of enduring connection policy in Ireland. In June 2020 the CRU published their decision on ECP-2, this decision set policy for at least three batches of connection offers (ECP-2.1, ECP-2.2 and ECP-2.3).

Forced Outage Probability (FOP)

This is the statistical probability that a generation unit will be unable to produce electricity for non-scheduled reasons due to the failure of either the generation plant or supporting systems. Periods, when the unit is on scheduled outage, are not included in the determination of forced outage probability.

Generation Dispatch

This is the configuration of outputs from the connected generation units.

Interconnector

The electrical link, facilities and equipment that connect the transmission network of one power market to another.

Loadflow

Study carried out to simulate the flow of power on the transmission system given a generation dispatch and system load.

A DC loadflow is a study, which uses simplifying assumptions in relation to voltage and reactive power. DC loadflow studies are used as part of an overarching study. For example, Plexos uses DC loadflow because it is performing studies for every hour of every study year and is performing a large optimisation calculation for each of these.

Maximum Export Capacity (MEC)

The maximum export value (MW) provided in accordance with a generator's connection agreement. The MEC is a contract value that the generator chooses as its maximum output.

Megawatt (MW) and Gigawatt (GW)

Unit of power: 1 megawatt = 1,000 kilowatts = 106 joules / second

1 gigawatt = 1,000 megawatts

Megawatt Hour (MWh), Gigawatt Hour (GWh) and Terawatt Hour (TWh)

Unit of energy: 1 megawatt hour = 1,000 kilowatt hours = 3.6×10^9 joules

1 gigawatt hour = 1,000 megawatt hours

1 terawatt hour = 1,000 gigawatt hours

Operational Constraints/Limits

In order to operate a safe, secure and stable electricity system, the TSO must operate the system within certain operational constraints/limits which include; maximum SNSP, maximum RoCoF, minimum level of system inertia, minimum number of conventional units, minimum levels of reserve.

Conventional generator "must run" rules to ensure adequate system voltage and power flow control

Over-supply

Reduction of renewable generation to a level below its availability for over-supply reasons is necessary when the total available generation exceeds system demand plus interconnector export flows. Over-supply is applied through market processes prior to dispatch or balancing actions taken by the transmission system operator such as curtailment and constraint.

Plexos

Plexos is a commercially available power system simulation tool used in this study to evaluate over supply, curtailment and constraint. Plexos is a detailed generation and transmission analysis program that has been widely used in the electricity industry for many years.

Rate of Change of Frequency (RoCoF)

As low inertia non-synchronous generators displace high inertia synchronous generators in system dispatch, then the system gets lighter. Then, for the loss of a large infeed (e.g. trip of an interconnector or generator), the system frequency will change more quickly.

RoCoF is the agreed limit to which the system is agreed to be operated and which generators, demand and system protection schemes are expected to manage. In Ireland, the TSOs are proposing to increase the RoCoF value. This will allow more renewable generation and may require confirmation by participants that they can meet the proposed RoCoF.

Short Run Marginal Cost (SRMC)

The instantaneous variable cost for a power plant to provide an additional unit of electricity, i.e. the cost of each extra MW it could produce excluding its fixed costs. The SRMC reflects the opportunity cost of the electricity produced, which is the economic activity that the generator forgoes to produce electricity. For example, in the case of a generator fuelled by gas, the opportunity cost includes the price of gas on the day that it is bidding in because if the generator is not producing electricity it could sell its gas in the open market.

System Non-Synchronous Penetration (SNSP)

The introduction of large quantities of non-synchronous generators such as solar and wind poses challenges to a synchronous power system. For Ireland, a system non-synchronous penetration (SNSP) ratio is defined to help identify the system operational limits. The present allowable ratio is 75% but future system services arrangements and proposed amendments to system operation are expected to allow SNSP to increase in future years.

Total Dispatch Down

For the purpose of this report Total Dispatch Down is equivalent to the sum of oversupply (generation self reduction due to market position), plus curtailment (re-dispatch due to system operational constraints), plus constraint (re-dispatch due to network limitations).

Total Electricity Requirement (TER)

TER is the total amount of electricity required by a country. It includes all electricity exported by generating units, as well as that consumed on-site by self-consuming electricity producers, e.g. CHP.

Transmission Peak

The peak demand that is transported on the transmission network. The transmission peak includes an estimate of transmission losses.

Transmission System

The transmission system is a meshed network of high-voltage lines and cables (400 kV, 275 kV, 220 kV and 110 kV) for the transmission of bulk electricity supply around Ireland and Northern Ireland.

Transmission System Operator (TSO)

In the electrical power business, a transmission system operator is the licensed entity that is responsible for transmitting electrical power from generation plants to regional or local electricity distribution operators and Large Energy Users connected at the transmission level.

Upgrading

A network reinforcement solution whereby an existing circuit's rating can be increased. This is achieved by increasing ground clearances and/or replacing conductor, together with any changes to terminal equipment, support structures and foundations.

Winter Peak

This is the maximum annual system demand. Historically this occurs in the winter period October to February, inclusive in Ireland and in the period November to February in Northern Ireland.

References

Enduring Connection Policy

<http://www.eirgridgroup.com/customer-and-industry/becoming-a-customer/generator-connections/enduring-connection-polic/>

Generation Capacity Statement

<http://www.eirgridgroup.com/site-files/library/EirGrid/208281-All-Island-Generation-Capacity-Statement-LR13A.pdf>

Reinforcement Projects

<http://www.eirgridgroup.com/the-grid/projects/>

<http://www.soni.ltd.uk/the-grid/projects/>

All Island Ten Year Transmission Forecast Statement 2020

<https://www.eirgridgroup.com/site-files/library/EirGrid/All-Island-Ten-Year-Transmission-Forecast-Statement-2020.pdf>

Tomorrows Energy Scenarios

<http://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid-TES-2019-Report.pdf>

Generator Information

<http://www.eirgridgroup.com/how-the-grid-works/renewables/>

<https://www.esbnetworks.ie/new-connections/generator-connections/generator-connection-statistics>

Shaping Our Electricity Future

<https://www.eirgridgroup.com/site-files/library/EirGrid/Full-Technical-Report-on-Shaping-Our-Electricity-Future.pdf>