

Transmission Development Plan 2023



Disclaimer

While all reasonable care has been taken to prepare this document, we can make no guarantee to the quality, accuracy and completeness of the information herein. We do not accept responsibility for any loss associated with the use of this information. Use of this document and the information it contains is at the user's own risk.

Information in this document does not amount to a recommendation as regards to any possible investment. Before taking a business decision based on the content of this document, we advise that interested parties seek separate and independent opinion in relation to the matters covered by this document.

*Information in this document with reference to completion dates (Estimated Completion Dates, Forecast Completion Dates and Indicative Completion Dates) has been prepared with all reasonable care and diligence. All and any dates have been estimated and are indicative and subject to change. All dates have been estimated in line with the European Union (Internal Market in electricity) (3) Regulations 2022 (S.I. no 227/2022) and all and any dates are subject to revision.

Copyright notice

All rights reserved. This entire publication is subject to the laws of copyright.

This publication may not be reproduced or transmitted in any form or by any means, electronic or manual, including photocopying without the prior written permission of EirGrid and SONI.



The Oval, 160 Shelbourne Road,
Ballsbridge, Dublin 4, D04 FW28,
Ireland

Document structure

The structure of the document is as follows:

The **Abbreviations and Terms** provides a glossary of terms and acronyms used in the document.

The **Executive Summary** gives an overview of the main highlights of the document and presents a summary of the Plan.

Section 1: Introduction – our statutory and legal obligations are introduced. The purpose and context of the Transmission Development Plan (TDP) is outlined.

Section 2: Investment drivers and needs – the drivers of network development are introduced and discussed, as are the needs of the network which result from these drivers. The needs are identified through the application of the grid development approach discussed in Appendix B.

Section 3: Changes to the Plan since 2021 – provides information on the changes to the plan between TDP 2021 and TDP 2023.

Section 4: Planned network developments – summarises the development projects that are currently in progress.

Section 5: Regional view – summarises and categorises the development projects that are currently in progress by region.

Section 6: Projects in early stages of development – projects in early stages of development are outlined.

Section 7: Summary of Environmental Appraisal Report (EAR) – summarises the EAR of TDP 2023.

Appendix A: Irish projects in European Plans

Appendix B: Approach to grid development

Appendix C: References

Abbreviations and terms

Abbreviations

AA	Appropriate Assessment	PA	Project Agreement
ABP	An Bord Pleanála	RegIP	Regional Investment Plan
ATR	Associated Transmission Reinforcement(s)	RES	Renewable Energy Sources
CP No.	Capital Project Identification Number	RES-E	Renewable Energy Sources – Electricity
CPP	Committed Project Parameters	RESS	Renewable Electricity Support Scheme
CRU	Commission for Regulation of Utilities	RGNS	Regional Group North Sea
DSO	Distribution System Operator	RIDP	Renewable Integration Development Project
EAR	Environmental Appraisal Report	SAC	Special Area of Conservation
EC	European Commission	SEA	Strategic Environmental Assessment
ECD	Estimated Completion Date	SI60	Statutory Instrument No. 60 of 2005
EIA	Environmental Impact Assessment	SI147	Statutory Instrument No. 147 of 2011
EIAR	Environmental Impact Assessment Report	SI445	Statutory Instrument No. 445 of 2000
ENTSO-E	European Network of Transmission System Operators for Electricity	SI227	Statutory Instrument No. 227 of 2022
ER	Environmental Report	SONI	System Operator Northern Ireland
ESB	Electricity Supply Board	SPA	Special Protection Areas
EU	European Union	SNSP	System Non-Synchronous Penetration
EWIC	East West Interconnector	TAO	Transmission Asset Owner
GCS	Generation Capacity Statement	TDP	Transmission Development Plan
GIS	Gas Insulated Switchgear	TSO	Transmission System Operator
GW	Gigawatt	TSSPS	Transmission System Security and Planning Standards
HV	High Voltage	TYNDP	Ten Year Network Development Plan
HVDC	High Voltage Direct Current	TYTFS	Ten Year Transmission Forecast Statement
IA	Infrastructure Agreement		
IP	Implementation Programme		
LPA	Local Planning Authority		
MEC	Maximum Export Capacity		
MIC	Maximum Import Capacity		
MW	Megawatt		
NDP	Network Delivery Portfolio		
NIS	Natura Impact Statement		

Terms

Bay

A connection point to a busbar and comprising switchgear and measurement equipment.

Busbar

An electrical conductor located in a station that makes a common connection between several circuits.

Capacitor

An item of plant normally used on the electrical network to supply reactive power to loads (generally locally) and thereby support the local area voltage.

Capital Project Number (CP No.)

Each project has a unique Capital Project Number to help coordination between EirGrid and the TAO, and for reporting purposes.

Circuit

A line or cable, including associated switchgear, which carries electrical power.

Circuit breaker

A device used to open a circuit that is carrying electrical current.

Constraint

A change in the output of generators, scheduled in the market or not, due to transmission network limitations – specifically the overloading of transmission lines, cables and transformers.

Contingency

An unexpected failure or outage of a network component, such as a generation unit, transmission line, transformer or other electrical element.

Coupler

This is a device which can be used to either connect or disconnect sections of busbars. A coupler increases Security of Supply and flexibility under both fault and maintenance conditions. A coupler can also be known as a Sectionalising Circuit Breaker.

Deep reinforcement

Refers to network reinforcement additional to the shallow connection that is required to allow a new generator or demand to operate at maximum export or import capacity respectively.

Demand

The amount of electrical power that is consumed by a customer and is measured in Megawatts (MW). In a general sense, the amount of power that must be transported from transmission network connected generation stations to meet all customers' electricity requirements.

Demand-side management

The modification of normal demand patterns usually through the use of financial incentives.

Deterministic methodology

The deterministic methodology is often referred to as the N-1 criterion. This means that the system must have sufficient capacity so that in the eventuality of a probable system outage, there are no resulting system problems such as overloading, under-voltage, over-voltage or instability.

Distribution system operator

In the electrical power business, a distribution system operator is the licensed entity responsible for:

- Operating and ensuring the maintenance and development of the distribution system in a given area (and its interconnections), if necessary and where applicable; and
- Ensuring the long term ability of the system to meet reasonable demands for electrical power.

EirGrid

The independent statutory electricity Transmission System Operator in Ireland.

Embedded generation

Refers to generation that is connected to the distribution network or at a customer's site.

Estimated Completion Date (ECD)

The estimated completion or forecast energisation date of a project. The estimate is subject to the:

- Planning process where applicable;
- Construction progress; and
- Availability of transmission outages and commissioning.

*ECDs are indicative dates and subject to change.

Gas Insulated Switchgear (GIS)

A compact form of switchgear where the conductors and circuit breakers are insulated by an inert gas (that is, typically SF₆).

Gate

A group processing mechanism to efficiently process large volumes of connection applications from renewable and conventional generators wishing to connect to the transmission or distribution systems. This is a CRU approved and directed approach.

Generation dispatch

The configuration of outputs from the connected generation units.

Grid

A network of high voltage lines and cables (400 kV, 275 kV, 220 kV and 110 kV) used to transmit bulk electricity supplies around Ireland. The terms grid, electricity transmission network, and transmission system are used interchangeably in this Development Plan.

Intact network

The transmission network with no network element removed for maintenance, replacement or repair.

Interconnector

The electrical link, facilities and equipment that connect the transmission network of one jurisdiction to another.

Maintenance trip conditions

This condition occurs when a network component (generation unit, transmission line, transformer or other electrical element) is out of service for maintenance, and there is an unexpected failure or outage of another network component.

Maximum Export Capacity (MEC)

The maximum export value (MW) provided in accordance with a generator's connection agreement. The MEC is a contract value which the generator chooses as its maximum output.

Maximum Import Capacity (MIC)

The maximum import value (MW) provided in accordance with a customer's connection agreement. The MIC is a contract value which a customer chooses to cater for maximum demand at their site.

Network development driver

A factor based on national and European energy policy objectives that influences or 'drives' the investment in the transmission network.

Network development need

A deficiency or problem on the network which arises as a result of one or a number of network development drivers. Network reinforcement is required to solve a network development need.

Power flow

The physical flow of electrical power. It is typically measured in Megavolt-Amperes (MVA) which is the complex combination of both 'active' and 'reactive' electrical power. The flow of 'active' power is measured in Megawatts (MW); the flow of 'reactive power' is measured in Megavars (Mvar).

Phase Shifting Transformer (PST)

A type of device employed on the electrical network to control the flow of active power.

Reactive compensation

The process of supplying reactive power to the network to compensate for reactive power usage at a point in time.

Reactive power

The portion of electricity that establishes and sustains the electric and magnetic fields of alternating current equipment. Reactive power is measured in Megavars (Mvar).

Reactor

An item of plant comprising a coil of electrical wire. It is typically employed on the electrical network to either:

- Limit short circuit levels; or
- Prevent voltage rise,

depending on its installation and configuration.

Series compensation

A technology that boosts flows on very long transmission lines. There have been recent advances in this technology and its control systems. This allows for greater flexibility and more benefits when using series compensation.

Shallow connection

The local connection assets required to connect a customer, or customers, to the transmission network. These types of connections are typically for the specific benefit of that particular customer or group of customers.

Single contingency conditions

This condition occurs when the transmission network is intact and there is an unexpected failure or outage of one network component (generation unit, transmission line, transformer or other electrical elements).

Summer valley

The annual minimum electrical demand that usually occurs in August.

Summer peak

The week-day peak electrical demand value between March and September, inclusive, which is typically 80 % of the winter peak.

Switchgear

A combination of electrical equipment such as disconnects and/or circuit breakers used to isolate equipment in or near an electrical station.

Transformer

An item of electrical equipment that allows electrical power to flow between typically two different voltage levels in an alternating current (AC) power system.

Transmission Losses

A small proportion of energy is lost as heat or light whilst transporting electricity on the transmission network. These losses are known as transmission losses.

Transmission peak

The peak demand that is transported on the transmission network. The transmission peak includes an estimate of transmission losses.

Transmission system security and planning standards

The set of standards that the transmission system is designed to meet. The criteria are deterministic as is the norm throughout the world. They set out objective standards which have been found to deliver an acceptable compromise between the cost of development and the transmission service provided. The Transmission System Security and Planning Standards were previously referred to as the Transmission Planning Criteria.

Transmission system operator

In the electrical power business, a transmission system operator is the licensed entity that is responsible for:

- Operating and ensuring the maintenance and development of the transmission system in a given area (and its interconnections), if necessary and where applicable; and
- Ensuring the long term ability of the system to transmit electrical power from generation plants to transmission connected demand and regional or local electricity distribution operators.

Uprate

To increase the capacity or rating of electrical equipment.

Winter peak

This is the maximum annual system demand. It occurs in the period October to February of the following year, inclusive. Thus, for transmission planning purposes the winter peak 2022 – 2023, the first year of this Plan, may occur in late 2022 or early 2023. The winter peak figures take account of the impact of projected Demand-Side Management initiatives.

Contents

Document structure	3
Abbreviations and terms	4
Executive summary	14
1. Introduction	20
1.1 Statutory and licence requirements	21
1.2 Transmission Development Plan 2023	21
1.3 Process for developing the Transmission Development Plan	24
1.4 Context of the Plan	24
1.5 Network design	28
1.6 Regional view	32
2. Investment drivers and needs	34
2.1 Strategic context of transmission network investment	35
2.2 National and European energy policy	36
2.3 Policy drivers of transmission network investment	37
2.4 Technical drivers for transmission network investment	39
2.5 Network development needs	41
3. Changes to the Plan since 2021 and 2022	42
3.1 Projects completed in 2021 and 2022	43
3.2 Projects removed in 2021 and 2022	47
3.3 Projects added in 2021 and 2022	47
3.4 Projects on hold	52
3.5 Candidates solutions progressing the framework for grid development	53

4. Planned network developments	56
4.1 Overview of the Plan	57
4.2 Summary of projects in steps 4 to 6	58
4.3 Project delivery	60
4.4 Completion dates	61
5. Regional view	62
5.1 Overview	63
5.2 The Border, Midlands and West	64
5.3 The South-West and Mid-West	88
5.4 The South-East, Mid-East and Dublin	104
5.5 Projects at multiple locations	138
6. Projects in early stages of development	142
6.1 Overview	143
6.2 The Border, Midlands and West	144
6.3 The South-West and Mid-West	145
6.4 The South-East, Mid-East and Dublin	146
7. Summary of environmental appraisal	148
Appendix A: Irish projects in European Plans	152
Appendix B: Approach to grid development	158
Appendix C: References	168



Executive summary





The Transmission Development Plan (TDP) 2023 – 2032 lists the committed projects and projects under development for the enhancement of the Irish transmission network over the coming ten years.

Committed projects are those that have received EirGrid capital approval and are in Steps 4-6 of our six-step process for developing the grid. Indicative completion dates have been included for these projects. These projects are detailed in Chapter 5.

The projects which are in the development stages are those which have not yet received capital approval and are in Steps 2-3. These projects are detailed in Chapter 6.

Introduction

The TDP 2023 – 2032 succeeds the TDP 2021 – 2030. The plan has been prepared in accordance with our statutory and licence obligations.

Additional projects will be included in future TDPs as the needs identified in the Tomorrow's Energy Scenarios System Needs Assessment and candidate reinforcements presented in the latest version of Shaping Our Electricity Future¹ are brought through our six-step process for developing the grid. Inherent in this is the Government target to achieve 80% electricity from renewable energy sources (RES-E) by 2030.

Changes to the Plan since TDP 2021

There were 145 active projects in TDP 2021. Since then:

- 47 projects that were active in TDP 2021 have been completed;
- Three new projects added in the period covered by this TDP have been completed;
- One project that was active in TDP 2021 has been removed;
- Two projects that were active in TDP 2021 have been put on hold; and
- 110 projects have been added to the Development Plan. Thus, there are 202 active projects in this version of the TDP. The changes since TDP 2021 are described in greater detail in Chapter 3.

It is important to mention that from this version of the TDP onwards, the main input to the list of reported projects in this document is obtained from the Network Delivery Portfolio, NDP.

The NDP publication provides a quarterly status update on three key milestones, EirGrid Capital Approval, Project Agreement with ESB and a forecast energisation date. Dates shown in the NDP are based on an unconstrained scenario and are, therefore, indicative and subject to change due to operational requirements and emergent equipment conditions. Associated Transmission Reinforcement (ATR) system reinforcement updates are contained in EirGrid's NDP. If necessary, Generator customers will continue to receive direct ATR related communications from their System Operator.

The NDP is the most ambitious programme of works ever undertaken on the transmission system in Ireland. To place the NDP in context, EirGrid has anticipated that over 350 projects need to be completed to reinforce the system, connect Industry and meet the target by 2030. Of the 350 projects listed in the NDP, the TDP reports the projects that received capital approval as of the data freeze date.

Project dates and timelines provided in the NDP are based on an unconstrained scenario and are, therefore, indicative in nature and subject to change for a variety of reasons.

1 https://www.eirgridgroup.com/site-files/library/EirGrid/Shaping-Our-Electricity-Future_Version-1.1-Plain-English-Summary_07.23.pdf

Transmission network development

The development of the Irish electricity sector is guided by several national and European Union (EU) policy and strategic objectives. These objectives guide investment in the Irish transmission network and are summarised as follows:

- Ensuring the security of electricity supply;
- Ensuring the competitiveness of the national economy;
- Ensuring the long-term sustainability of electricity supply in the country; and
- Ensuring that the targets of the Climate Action Plan are met.

In order to achieve these strategic objectives, we must invest in the development and maintenance of the electricity transmission network. Drivers of investment include:

- Securing transmission network supplies;
- Supporting market integration; and
- Supporting the integration of Renewable Energy Sources, interconnectors development, thermal generation and system services providers.

As demand for electricity and/or the mix and location of generation changes, or the transmission network becomes more interconnected with neighbouring transmission networks², the flow of electrical energy throughout the transmission network changes. To accommodate these changes in power flows, it is often necessary to modify or strengthen the transmission network to maintain a secure, reliable high performing system, to meet the needs of the energy citizen, businesses and the all users of the transmission network.

In addition, the timely maintenance and/or replacement of transmission assets is required to provide the necessary continuity of service, to facilitate the transport of electricity from where it is generated to where it is used.

² The European electric power transmission networks are interconnected, so as to be able to transmit energy from one country to the other.

Shaping Our Electricity Future

The Government's first Climate Action Plan was published in 2019³ setting out an ambitious plan for decarbonising Ireland's economy. Specifically, for the electricity sector, it set a target that at least 70% of our electricity will come from renewable energy sources (RES) by 2030.

In response to this, EirGrid initiated a programme of work called Shaping Our Electricity Future⁴ with a core objective of establishing a roadmap for delivery of the 70% RES-E target. In March 2021, EirGrid launched a 14-week stakeholder consultation providing four options for how the target could be achieved. A number of reports were published in support of this consultation, including a technical report, outlining our views on the many network, operational and market requirements that need to be put in place by 2030. EirGrid received approximately 430 responses to the consultation from a wide range of stakeholders. This feedback was used to prepare the Shaping Our Electricity Future v1.0 roadmap which was published in November 2021.

The SOEF v1.0 roadmap identifies activities required across four separate workstreams; networks, operations, markets and stakeholder engagement. Network planning studies carried out for the networks workstream identified 40 candidate reinforcements that are required in addition to already committed network projects. Our commitment to maximising the use of the existing grid is demonstrated by the study results; 35 of the 40 reinforcements involve the use of existing assets, replacement of existing assets or the use of non-network technologies such as power flow controllers or dynamic line ratings.

The studies show that the additional projects assist in achieving RES-E levels in excess of 70%, establishing a strong platform to achieve the long-term ambition of net zero emissions by 2050. The proposed reinforcements will be studied in more detail before progressing through the six-step grid development framework and potentially appearing in future versions of the transmission development plan.

³ <https://www.gov.ie/en/publication/ccb2e0-the-climate-action-plan-2019/>

⁴ <https://www.eirgridgroup.com/the-grid/shaping-our-electricity-f/>

The Shaping Our Electricity Future roadmap is a dynamic plan that has been updated and published in July 2023. This new version, Shaping Our Electricity Future v1.1⁵, reflects the best available information, including changes in climate and energy policy, and reports on progress against specific actions within the roadmap, including the necessary changes for achieving the government's target of up to 80% RES-E by 2030 as detailed in the Climate Action plan of 2021⁶, and the electricity sector carbon dioxide emissions limits and budgets as detailed in the latest version of the Climate Action Plan published in December 2022⁷.

SOEF v1.1 has reported a selection of transmission network reinforcements that satisfy the needs of the transmission system. Twenty candidate reinforcements have been identified to meet the increased renewable ambition in both jurisdictions. These candidate reinforcements are required in addition to other committed projects that are already progressing through the framework for grid development and are also additional reinforcement to those identified in SOEF v1.0. The candidate reinforcements for Ireland are indicated in section 3.5.1.

In Ireland, sixteen new candidate reinforcements projects have been identified to address new renewable generation connections and demand growth across the country. All these sixteen reinforcements involve the use of existing assets or the use of non-network technologies such as power flow controller or dynamic line ratings, demonstrating EirGrid's commitment to maximising the use of the existing grid.

The main objective of SOEF Roadmaps is to outline how we can make the grid ready to meet the government targets of up to 80% RES-E and low carbon emission by 2030. SOEF uses the data in the latest TDP to determine the base reinforcements for future years and proposes candidate solutions that have the potential to progress the framework for grid development.

The candidate solutions identified in SOEF v1.0 and v1.1, in addition to other identified projects, will require detailed assessment using the framework for grid development to determine the optimum path forward. The projects resulting from this process will be reported in future TDPs.

5 https://www.eirgridgroup.com/site-files/library/EirGrid/Shaping-Our-Electricity-Future-Roadmap_Version-1.1_07.23.pdf

6 <https://www.gov.ie/en/publication/6223e-climate-action-plan-2021/>

7 <https://www.gov.ie/en/publication/7bd8c-climate-action-plan-2023/>

1. Introduction

The transmission network is a series of high voltage, 400 kV, 275 kV, 220 kV and 110 kV stations, lines and cables. It is the backbone of the power system, efficiently transporting large amounts of power from where it is generated to where it is needed, safely and reliably.

Electricity supply is essential, and a reliable transmission network is the means by which we move electricity around the country. The development of transmission network infrastructure is, therefore, of national strategic importance.

The primary objective of the Transmission Development Plan (TDP) is to describe the transmission network reinforcements which are currently approved for delivery within the next ten years. This is a point in time list that until now has been updated annually. The TDP outlines:

- The drivers of network development;
- The network investment needs; and
- The planned network developments required to address these needs.

This TDP covers Ireland only as it is not an all-island plan. SONI, the electricity System Operator for Northern Ireland, produces the TDP for Northern Ireland⁸.

1.1 Statutory and licence requirements

EirGrid is responsible for the operation and development of the transmission network in Ireland. We have both statutory and licence obligations to produce a TDP, these are:

- Regulation 8(6) of Statutory Instrument (SI) No. 445 of 2000⁹ as amended;
- Regulation 8(6) of Statutory Instrument (SI) No. 227 of 2022¹⁰ as amended;
- Condition 8 of EirGrid's Transmission System Operator (TSO) Licence; and
- Article 51 of Directive 2019/944/EC.

1.2 Transmission Development Plan 2023

TDP 2023 is our plan to develop the network through specific projects over the next ten years.

It is possible that changes will occur in the scope and timing of the listed developments. Similarly, given the continuously changing nature of electricity requirements, new developments will emerge. These changes will be accommodated in future TDPs. As such, the long-term development of the network is constantly under review.

⁸ <https://www.soni.ltd.uk/media/documents/SONI-Transmission-Development-Plan-Northern-Ireland-2020-2029.pdf>

⁹ <https://www.irishstatutebook.ie/eli/2000/si/445/made/en/print>

¹⁰ <https://www.irishstatutebook.ie/eli/2022/si/227/made/en/print>

To help the comparison of network development projects year-on-year and in the interest of routine reporting, data is represented at a fixed point in time – the data freeze date. The freeze date for project inclusion for this TDP is 21 December 2022. The previous TDP, TDP 2021, had a freeze date of 01 January 2021.

In this TDP, we report on projects according to our six-step process for developing the grid and engaging with stakeholders. The six-step process is set out in Appendix B and in our Have Your Say brochure¹¹.

Our annual stakeholder engagement activities and plans, including project consultations and engagements, are detailed on our website¹².



Figure 1-1: Our framework for grid development

This TDP describes all committed projects that are in steps 4 to 6 of our six-step process on the freeze date of 21 December 2022.

Committed projects have received EirGrid capital approval which occurs at the end of step 3. Indicative completion dates are included for these projects. These projects are detailed in Chapter 5.

¹¹ https://www.eirgridgroup.com/__uuid/7d658280-91a2-4dbb-b438-ef005a857761/EirGrid-Have-Your-Say_May-2017.pdf

¹² <https://www.eirgridgroup.com/the-grid/stakeholder-engagement/>

This TDP also includes information in Chapter 6 on projects that are in the early stages of development, that is in steps 2 and 3. As these projects progress and get EirGrid capital approval they will move through steps 4 to 6.

EirGrid is required to publish quarterly updates on the progress of all its transmission infrastructure projects as set out in CRU/20/154¹³, the CRU's PR5 Regulatory Framework, Incentives and Reporting Decision Paper. Since October 2022, our Network Delivery Portfolio (NDP) status reports has been published on our website¹⁴. It is important to mention that from this version of TDP onwards, the main input to the list of reported projects in this document is obtained is the NDP.

The NDP publication provides a quarterly status update on three key milestones, EirGrid Capital Approval, Project Agreement with ESB and a forecast energisation date. Dates shown in the NDP are based on an unconstrained scenario and are, therefore, indicative and subject to change due to operational requirements and emergent equipment conditions. Associated Transmission Reinforcement (ATR) system reinforcement updates are contained in EirGrid's NDP.

If necessary, Generator customers will continue to receive direct ATR related communications from their System Operator.

The NDP is the most ambitious programme of works ever undertaken on the transmission system in Ireland. To place the NDP in context, EirGrid has anticipated that over 350 projects need to be completed to reinforce the system, connect Industry and meet the target by 2030. Of the 350 projects listed in the NDP, the TDP reports the projects that received capital approval as of the data freeze date.

Project dates and timelines provided in the NDP are based on an unconstrained scenario and are, therefore, indicative in nature and subject to change for a variety of reasons.

EirGrid and ESB Networks, in their respective capacity as TSO and TAO, publish an Annual Electricity Transmission Performance Report and an Investment Planning and Delivery Report.

The Commission for Regulation of Utilities (CRU), as part of its decision paper CRU/20/154 PR5 Regulatory Framework, Incentives and Reporting, requires the TSO and the TAO to produce these joint reports setting out their annual performance in regard to the operation and development of the transmission system. The reports are intended to provide customers, industry participants and other interested parties with a clear, accessible, comprehensive, quantified but non-technical report on performance in the previous calendar year. The 2019, 2020 and 2021 reports can be found on our website¹⁵.

¹³ <https://cruie-live-96ca64acab2247eca8a850a7e54b-5b34f62.divio-media.com/documents/CRU20154-PR5-Regulatory-Framework-Incentives-and-Reporting-1.pdf>

¹⁴ <https://www.eirgridgroup.com/customer-and-industry/general-customer-information/network-delivery-portfolio/index.xml>

¹⁵ <https://www.eirgridgroup.com/how-the-grid-works/tso-regulatory-publicatio/>

1.3 Process for developing the Transmission Development Plan

This TDP covers a period of ten years. As part of the preparation of the TDP, we consult with SONI to ensure that the information is accurate. A public consultation on the draft TDP is held by the CRU. Following feedback received from the public consultation we update the TDP, as required, and provide a report to the CRU on feedback received. We prepare the final version of the TDP and submit it to the CRU for approval.

1.4 Context of the Plan

The TDP takes account of a wide range of contexts. This section highlights the fields covered by the document.

1.4.1 All-Island and European context

Our TSO license obliges us to carry out transmission planning on a coordinated all-island basis with SONI. This requirement is met by the System Operator Agreement in place between EirGrid and SONI.

Each year EirGrid and SONI jointly prepare the All-Island Generation Capacity Statement (GCS)¹⁶. The GCS outlines demand forecasts and assesses the generation adequacy of the island of Ireland over the ten-year period covered by the GCS.

EirGrid and SONI also jointly prepare the annual All-Island Ten Year Transmission Forecast Statement (TYTFS)¹⁷. The TYTFS provides detailed data and models of the transmission system.

The TYTFS is designed to assist users and potential users of the transmission system to identify opportunities to connect to and make use of the transmission system. The demand forecast in the TYTFS is based on the demand forecast in the GCS.

SONI publishes the Transmission Development Plan for Northern Ireland. The TDPs for Ireland and Northern Ireland provide details of the transmission system developments expected to be progressed in Ireland and Northern Ireland in the coming 10 years. These transmission system developments are also included in the data, assumptions and analyses in the TYTFS.

European legislation requires all European TSOs to cooperate through the European Network of Transmission System Operators for Electricity (ENTSO-E). ENTSO-E has six regional groups that co-ordinate network planning and development at regional level. We are members of the Regional Group North Sea (RGNS). ENTSO-E publishes a Ten Year Network Development Plan (TYNDP) every two years. The TYNDP outlines projects of European significance. Irish projects in European plans are detailed in Appendix A.

It is important that readers of this TDP are aware of the all-island and European context. Readers should consider these other documents, our approach to scenario planning, detailed in the next section, and also our Shaping Electricity Future Roadmap. Figure 1-2 below shows the links between the various documents.

¹⁶ https://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid_SONI_Ireland_Capacity_Outlook_2022-2031.pdf

¹⁷ <https://www.eirgridgroup.com/site-files/library/EirGrid/All-Island-Ten-Year-Transmission-Forecast-Statement-TYTFS-2021.pdf>

Readers, in particular users or potential users of the transmission system, may also find it beneficial to consult specific sections in the TYTFS. The specific sections 'How to Use the Information for Generation' and 'How to Use the Information for Demand' are in Sections 7 and 8 of the TYTFS respectively. The sections outline how generation and demand customers can use the 'opportunities to connect' information in the TYTFS.

1.4.2 Grid development strategy

We published our grid development strategy in January 2017¹⁸. In it we outline our three strategy statements:

- Inclusive consultation with local communities and stakeholders will be central to our approach;
- We will consider all practical technology options; and
- We will optimise the existing grid to minimise the need for new infrastructure.

Our strategy statements guide and influence how we develop the grid.

1.4.3 Offshore grid development

Due to its peripheral location at the edge of the Atlantic, with a sea area of 490,000 square kilometre that is approximately seven times its landmass, Ireland has considerable offshore renewable energy potential.

In addition to onshore renewable energy development, meeting the government targets for 2030 will require development of significant offshore renewable energy infrastructure over the coming years. Harnessing our offshore renewable energy resources will play a key role in the transition towards a sustainable, secure and competitive energy system.

EirGrid will plan, develop and own the offshore transmission system, which will ultimately be managed according to a centralised model. Ownership of the offshore transmission system assets will be vested in EirGrid at all phases of offshore renewable energy development as provided for in legislation under the Maritime Area Planning (MAP) Bill 2021¹⁹.

Offshore grid development will be underpinned by a framework that provides for a phased transition from the current decentralised model towards an enduring centralised offshore grid model, to take place in line with three scheduled offshore Renewable Electricity Support Scheme (RESS) auctions.

The Framework will progress in three phases, which will start with a decentralised plan involving offshore development carried out by EirGrid and developers, (Phases One and Two), and end with a centralised development where EirGrid will plan and build out transmission infrastructure, with the potential, where possible, to optimise the connections of multiple projects to the offshore transmission system from areas deemed suitable for offshore renewable energy development.

¹⁸ <https://www.eirgridgroup.com/the-grid/irelands-strategy/>

¹⁹ <https://MaritimeAreaPlanning>

1.4.4 Climate Action Plan

In December 2022, the Irish Government launched its Climate Action Plan 2023, CAP 2023. The revised plan reflects increased ambitions for the decarbonisation of Ireland's economy, including a revised target of renewable sources (RES-E). Among the most important measures in the CAP 2023 is to increase the proportion of renewable electricity to up to 80% by 2030 and a target of 9 GW from onshore wind, 8 GW from solar, and at least 5 GW of offshore wind energy plus 2 GW for green hydrogen production.

The new targets for the electricity sector will allow us to operate at higher system non-synchronous penetration (SNSP) levels more often reducing emission by using RES. At the same time, it will allow us to electrify other sector such as transport and heat reducing emissions in these sectors too.

EirGrid will continue to monitor changes in climate and energy policy and update our development plans accordingly. We are focused not only on 2030 targets but also on the long-term ambition of net zero greenhouse gas emissions in Ireland by 2050 which is a legal requirement as set out in the Climate Action and Low Carbon Development (Amendment) Act 2021.

In order to meet decarbonisation targets in the electricity sector, investment will be needed in new renewable generation capacity, system service infrastructure and electricity networks. The transition to low-carbon and renewable energy will have widespread consequences, indeed it will require a significant transformation of the electricity system.

In September 2019, we launched our Strategy 2020-2025²⁰ which is shaped by two factors: climate change and the impending transformation of the electricity sector. We are committed to leading the change toward net zero carbon emissions from the electricity system and achieving renewable energy targets.

The TDP contains a list of the committed projects as at data freeze day of 21 December 2022. Additional projects will be included in future TDPs as a result of our ongoing assessment of the impact of evolving climate and energy policies including revisions to the Government's Climate Action Plan.

20 <https://www.eirgridgroup.com/about/strategy-2025/>

1.4.5 Capital expenditure

This plan includes 202 active projects that are underway. Funding for transmission projects is approved by the CRU through the price review process. The CRU approved allowable capital expenditure of €1.2 billion for network projects in the current five-year price review period 2021–2025, CRU/20/152²¹.

The CRU and EirGrid have a framework in place for monitoring transmission capital expenditure. This framework provides flexibility to respond to the identified needs which are influenced by external factors; including changes in generation and demand, amongst others. Expenditure beyond 2025 will be considered and approved in future price reviews.

1.4.6 United Kingdom's referendum on EU membership

The transition period of the UK's exit from the European Union ended on 31 December 2020. The Protocol on Ireland and Northern Ireland²² provides for the continued operation of the Single Electricity Market (SEM) and maintains the applicability of relevant EU energy law in Northern Ireland. However, since the UK has now decoupled from the EU internal energy market, since 01 January 2021, the SEM has in place less efficient cross-border trading arrangements with the GB electricity market.

The EU-UK Trade and Cooperation Agreement²³ calls for the EU and the UK to cooperate to support the delivery of cost efficient, clean and secure supplies of electricity and gas, based on competitive markets and non-discriminatory access to networks as part of their future partnership. As such, new trading arrangements are to be agreed, for operation in coming years and a new co-operation agreement is to be put in place between UK and EU TSOs.

Regardless of the UK leaving the EU, there will always be many shared benefits of working closely with our nearest neighbours. We aim to maintain a strong relationship between Ireland, Northern Ireland and Great Britain on electricity matters.

²¹ <https://www.cru.ie/publications/26864/>

²² <https://www.gov.ie/en/publication/060fdf-northern-ireland/#the-protocol-and-the-all-island-economy>

²³ https://commission.europa.eu/strategy-and-policy/relations-non-eu-countries/relations-united-kingdom/eu-uk-trade-and-cooperation-agreement_en

1.5 Network design

The development of the transmission network involves forecasting future needs. Solutions to address these needs must strike a balance between network reliability, costs, and environmental impacts. The process is flexible to enable the long-term development of the network.

Considerations that shape the medium and long-term development of the transmission network are outlined below. Tomorrow's Energy Scenarios looks further into the future to 2035, 2040 and 2050 based on changes to the electricity portfolio, such as electricity generation, demand, interconnection and storage. Shaping Our Electricity Future provides an outline of the key developments from a networks, engagement, operations and markets perspective needed to support a secure transition up to 80% RES-E on the electricity grid by 2030. Potential projects identified in Tomorrows Energy Scenarios and Shaping Our Electricity Future are brought through the grid development process and any projects identified will be included in future TDP's.

1.5.1 Tomorrow's Energy Scenarios

Scenario Planning was introduced into our grid development process in 2017 to cater for the increased level of uncertainty over the future usage of the grid. We call our scenario planning Tomorrow's Energy Scenarios²⁴ (TES).

Our scenarios detail a range of potential futures for the electricity sector in Ireland, with specific focus on what this means for the electricity transmission system over the next twenty years and beyond. The underlying assumptions in the scenarios are validated using feedback received from policy makers, industry and the general public as part of an open consultation. This includes feedback from Gas Networks Ireland on projections for gas usage for electricity generation in Ireland.

When the scenarios are finalised, we use them to test the performance of the electricity transmission grid and publish the results in the TES System Needs Assessment (SNA)²⁵.

Additional projects will be included in future TDPs as the needs identified in the TES SNA are brought through our six-step process for developing the grid. Inherent in this is the requirement to achieve up to 80% RES-E target by 2030.

²⁴ <https://www.eirgridgroup.com/customer-and-industry/tes/>

²⁵ TES 2017 System Needs Assessment Report: <https://www.eirgridgroup.com/site-files/library/EirGrid/TES-2017-System-Needs-Assessment-Final.pdf>

TES 2019 System Needs Assessment Report: https://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid-TES-2019-System-Needs-Assessment-Report_Final.pdf




Figure 1-2: Links between the various planning documents

The need and requirement for transmission capacity is continuously evolving. In addition to needs identified in TES SNA, further system needs may be identified in the period between iterations of the Tomorrow's Energy Scenarios. Examples of changes that may arise include plant closures, changes to the condition of network assets and new connections that emerge through the connection offer process.

The needs identified in the TES process are brought through our six-step process for developing the grid. As needs and projects progress through the six-step process, they are included in the TDP.

EirGrid and SONI are in the process of developing revised TES scenarios for Ireland and Northern Ireland out to 2050 – we plan to publish these scenarios for consultation over the summer months with a view to final launch thereafter.

1.5.2 Shaping Our Electricity Future

The Government's first iteration of the Climate Action Plan was published in 2019 setting out an ambitious action plan for decarbonising Ireland's economy. Specifically, for the electricity sector, it set a target of at least 70% RES-E by 2030.

In response to this, EirGrid initiated a program of work called Shaping Our Electricity Future with a core objective of establishing a roadmap for delivery of the 70% RES-E target. In March 2021, EirGrid launched a 14 week stakeholder consultation providing a range of options for how the target could be achieved. A number of reports were published in support of this consultation including a technical report²⁶, outlining our views on the many network, operational and market requirements that need to be put in place by 2030. EirGrid received approximately 430 responses to the consultation from a wide range of stakeholders.

This feedback was used to prepare the final Shaping Our Electricity Future 2030 roadmap²⁷ which was published in November 2021.

The SOEF v1.0 roadmap articulates activities required across four separate workstreams; networks, operations, markets, and stakeholder engagement. Network planning studies carried out for the networks workstream identified 40 candidate reinforcements that are required in addition to already committed network projects.

²⁶ <https://www.eirgridgroup.com/site-files/library/EirGrid/Full-Technical-Report-on-Shaping-Our-Electricity-Future.pdf>

²⁷ https://www.eirgridgroup.com/site-files/library/EirGrid/Shaping_Our_Electricity_Future_Roadmap.pdf

Our commitment to maximising the use of the existing grid is demonstrated by the study results; 35 of the 40 reinforcements involve the use of existing assets, replacement of existing assets or the use of non-network technologies such as power flow controllers or dynamic line ratings.

The studies show that the additional projects assist in achieving RES-E levels in excess of 70% establishing a strong platform to achieve the long-term ambition of net zero emissions by 2050. The proposed reinforcements will be studied in more detail before progressing through the six-step grid development framework and potentially appearing in future versions of the transmission development plan.

The Shaping Our Electricity Future roadmap is a dynamic plan that has been updated and published in July 2023. This new version, Shaping Our Electricity Future v1.1, reports on progress against specific actions within the roadmap, including the necessary changes for achieving the government's target of up to 80% RES-E by 2030, and the electricity sector's carbon dioxide emissions limits and budgets, as detailed in the Climate Action plan of 2022.

Shaping Our Electricity Future v1.1 has reported a selection of transmission network reinforcements that satisfy the needs of the transmission system. Twenty candidate reinforcements have been identified to meet the increased renewable ambition in both jurisdictions.

These candidate reinforcements are required in addition to other committed project that are already progressing through the framework for grid development and are also additional reinforcement to those identified in SOEF v1.0. The candidate reinforcements for Ireland are indicated in section 3.5.1.

In Ireland, sixteen new candidate reinforcements projects have been identified to address new renewable generation connections and demand growth across the country. All these sixteen reinforcements involve the use of existing assets or the use of non-network technologies such as power flow controller or dynamic line ratings, demonstrating EirGrid's commitment to maximising the use of the existing grid.

The main objective of SOEF Roadmaps is to outline how we can make the grid ready to meet the government targets of up to 80% RES-E and low carbon emission by 2030. SOEF uses the data in the latest TDP to determine the base reinforcements for future years and proposes candidate solutions that have the potential to progress through the framework for grid development.

The candidate solutions identified in SOEF v1.0 and v1.1, in addition to other identified projects, will require detailed assessment using the framework for grid development to determine the optimum path forward. The projects resulting from this process will be reported in future TDPs.

1.6 Regional view

Power flows on the transmission network are not contained within specific counties. To help project reporting and give a regional view to our TDP we group counties together to create regions. In the TDP we use three regions to help communicate the development of the transmission system in Ireland:

1. The Border, Midlands and West;
2. The Mid-West and South-West; and
3. The South-East, Mid-East and Dublin.

These three regions are made up of eight underlying statutory regions and associated counties as follows:

1. Border: Donegal, Sligo, Leitrim, Cavan and Monaghan;
2. Midlands: Longford, Westmeath, Offaly and Laois;
3. West: Mayo, Galway and Roscommon;
4. South-West: Kerry and Cork;
5. Mid-West: Clare, Limerick and Tipperary²⁸;
6. South-East: Waterford, Wexford, Kilkenny and Carlow;
7. Mid-East: Wicklow, Kildare, Meath and Louth²⁹;
8. Dublin.

These eight regions are Ireland's regions as per the Nomenclature of Territorial Units for Statistics (NUTS) 3 classification. These regions are also used by government agencies in Ireland, including IDA Ireland and the Central Statistics Office.

The eight statutory regions are illustrated in Figure 1-3 below.

Projects are described by region in Chapter 5 'Regional view'.

²⁸ Formerly Tipperary was split into North Tipperary, which was in the Mid-West region, and South Tipperary which was in the South-East region.

²⁹ Formerly Louth was in the Border region.




Figure 1-3: Illustration of Ireland's regions as per the Nomenclature of Territorial Units for Statistics (NUTS) 3 classification

2. Investment drivers and needs

The Irish Government's Energy White Paper³⁰ released in December 2015 set out Ireland's energy future and continues to be valid. The Climate Action Plan published in December 2022 reflects more recent national and European policy developments. A legally binding target up to 80% RES-E is detailed in Ireland's National Energy and Climate Plan 2023³¹, which is Ireland's contribution to the European Union's effort-sharing approach of the Clean Energy Package.

Investment in the transmission system is necessary to enable Ireland's transition to a low carbon energy future. In this regard, the TDP is developed to support Government objectives and enable this energy transition.

2.1 Strategic context of transmission network investment

The ability to provide all customers with a secure, efficient, reliable and stable electricity supply is essential for Irish society and to enable economic activity and economic growth.

The Irish electricity industry and its development take direction from a number of broad national and European³² strategic objectives.

These objectives guide investment in the Irish transmission network and are summarised as follows:

- Ensuring the security of electricity supply;
- Ensuring the competitiveness of the national economy; and
- Ensuring the long-term sustainability of electricity supply in the country.

To ensure these objectives are met we must provide ongoing and timely reinforcement of the Irish transmission network.

³⁰ <https://www.gov.ie/en/publication/550df-the-white-paper-irelands-transition-to-a-low-carbon-energy-future-2015-2030/>

³¹ <https://www.gov.ie/pdf/?file=https://assets.gov.ie/94442/f3e50986-9fde-4d34-aa35-319af3bfac0c.pdf#page=null>

³² https://ec.europa.eu/energy/topics/energy-strategy/clean-energy-all-europeans_en

As the TSO for Ireland, EirGrid has a statutory duty to support the development of the Irish economy and society by ensuring the transmission network is able to support all reasonable demands for electricity. In addition, we are required to enter into agreement for connection with parties seeking to connect to the network under terms approved by the CRU.

Changes to demand, generation, or to interconnection with neighbouring transmission networks may alter the flow of electrical power throughout the Irish transmission network. To accommodate these changes in power flows it is often necessary to reinforce the transmission network to ensure adequate performance and reliability levels are maintained.

2.2 National and European energy policy

2.2.1 Security of supply

Security of supply deals with generation adequacy and the availability of generation to meet the fluctuating demand needs over time. Hence, electricity policy seeks to promote broadening the country's access to generation and promotes further interconnections with neighbouring countries.

Security of supply is also concerned with the reliability and security of the transmission network. Policy therefore also seeks to promote the timely development of the transmission network to maintain an acceptable level of performance and reliability.

2.2.2 Competitiveness

Low or competitively priced electricity is viewed as the product of a competitive electricity market. As a result, electricity policy generally seeks to promote increased competition. This is achieved through further market integration, by removing network constraints and broadening the market by interconnecting with neighbouring electricity markets.

2.2.3 Sustainability

Ireland is heavily reliant on imported fossil fuels for the generation of electricity. The long-term development of the Irish economy is impacted by the sustainability of the fossil fuels upon which it relies. Furthermore, burning fossil fuels produces greenhouse gases. Electricity policy therefore attempts to address these issues through the integration of energy produced from renewable energy sources.

In December 2022, the Irish Government launched its Climate Action Plan 2023. The revised plan reflects increased ambitions for the decarbonisation of Ireland's economy including a revised target of up to 80% RES-E by 2030. EirGrid is focused not only on 2030 targets but also on the long-term ambition of net zero greenhouse gas emissions in Ireland by 2050 which is a legal requirement as set out in the Climate Action and Low Carbon Development (Amendment) Act 2021.

In order to meet decarbonisation targets in the electricity sector, investment will be needed in new renewable generation capacity, system service infrastructure and electricity networks. The transition to low-carbon and renewable energy will have widespread consequences, indeed it will require a significant transformation of the electricity system.

In September 2019 EirGrid launched our Strategy 2020-2025 which is shaped by climate change and the impending transformation of the electricity sector. We are committed to leading the change towards a carbon-free electricity system and achieving renewable energy targets by 2030.

2.3 Policy drivers of transmission network investment

In order to achieve the identified strategic objectives laid out by national and EU policies, we must continue to invest in the development and maintenance of the electricity transmission network. Specific drivers of investment in transmission network infrastructure are identified and described in the following sections.

2.3.1 Security of transmission network

Security of supply generally addresses two separate issues:

- The availability of primary energy resources to generate sufficient electricity to meet demand; and
- The ability of the transmission network to reliably transport electrical energy from the generators to the demand centres where it is consumed.

The TDP is aimed at addressing the Security of Supply issues that relate to the transmission network.

Therefore, for this document, Security of Supply means the ability of the transmission network to reliably and securely transport electrical energy from where it is generated to the demand centres where it is consumed.

2.3.2 Market integration

With increased market integration, electrical power can flow from areas where it is cheap to produce to areas where it is more highly valued. Therefore, the aim is to make the EU electricity markets more integrated.

The integration of RES and other forms of low carbon generation significantly increases the power exchange opportunities across the region. Differences in national targets combined with varying availabilities of renewable sources across Europe will lead to greater penetration of RES in certain areas compared to others. Therefore, there is a need to reinforce the transmission networks between and within EU countries.

2.3.3 Renewable Energy Sources integration

Developing renewable energy is an integral part of Ireland's sustainable energy objectives and climate change strategy. In comparison to fossil fuels, RES have lower or no net emissions. RES contribute to the decarbonisation of the energy supply and reduction in greenhouse gases emissions. They also contribute to energy security, being, for the most part, an indigenous energy source. At the moment, onshore wind farms and hydro stations are the main sources of renewable electricity generation in Ireland. However, as Ireland moves to fully decarbonise its energy system, it is expected that additional renewable energy technologies will be further developed.

This is reflected in the Climate Action Plan 2023 which sets ambitious targets for deployment of renewables including 9 GW from onshore wind, 8 GW from solar, and at least 5 GW of offshore wind energy by 2030. It is also expected that energy storage facilities will be a necessary part of the future energy system, helping to ensure the safe and secure operation of a power system with high levels of variable RES generation.

In order to fulfil both European and national renewable targets, many RES-related projects are expected to be initiated throughout the period of this TDP. Many of these projects are located in rural areas where the transmission network is less developed. This places pressure on the electricity transmission network in these rural areas. Significant challenges will arise in extending and reinforcing the network to connect new RES.

2.4 Technical drivers for transmission network investment

Technical drivers of transmission network investment include changes in demand, generation and interconnection, inter-regional power flows and changes in asset conditions.

2.4.1 Changes in demand, generation and interconnection

Demand growth, the connection of new demand or interconnectors during periods when power is exported can give rise to higher power flows which may trigger the need to reinforce the network as a result. Closure or reduction in the size of demand facilities can reduce the power flows on lines feeding the load. However, in certain cases where the demand is absorbing local generation and reducing the amount of generation exported from the area, the closure can lead to increased power flows.

Because of the relative size of individual generators, changes in generation installations, whether new additions or closures can have a more significant impact on power flows than demand. This is equally so in the case of interconnectors which are treated as generators during periods when power is imported.

The addition of new generation capacity requires network development to connect the new generator to the network. This provides a path for electric power flow between the new generator and the transmission network. This is commonly known as the shallow connection. The new generation capacity will inevitably alter the power flows across the network, which has the potential to create overload problems deep into the network. To resolve these overloads we need further reinforcements, known as deep reinforcements, to allow full network access.

The connection of large synchronous generators, or groups of generators, combined with the increasingly meshed nature of the transmission network results in lower network impedance, which is the measure of resistance to the flow of electric current, and consequently increased short circuit levels. This can be a safety issue, as under fault conditions, high short circuit currents may cause damage, or in rare cases, catastrophic failure of high voltage equipment. We monitor fault levels on the network and take measures to prevent such conditions occurring.

National and EU policy recognises the economic and technical benefits associated with increased interconnection and therefore seeks to promote interconnection between European transmission systems. Increased interconnection between transmission networks results in a larger energy market.

With increased market integration there is greater competition and the potential for prices to be reduced. With increased interconnection there is also access to a broader generation base, which enhances the networks' Security of Supply. This can potentially defer the need for additional generation to be constructed to meet Security of Supply standards or requirements.

Our annual All-Island Generation Capacity Statement (GCS) 2022-2031, which is available on the EirGrid website, details expected changes in demand, generation and interconnection. The changes are summarised at the system-level.

Our annual All-Island Ten Year Transmission Forecast Statement (TYTFS) 2021 – 2030 describes the expected changes in demand, generation and interconnection at the individual station level. It is important to mention that this document refers to committed generation and demand or customers that have signed a Connection Agreement and not future pipeline projects that are not committed.

To cater for the increased level of uncertainty over the future usage of the grid, we introduced scenario planning into our grid development process. We call our scenarios Tomorrow's Energy Scenarios (TES).

2.4.2 Changes in inter-regional power flows

The following factors have the potential to significantly change the flow of electrical power throughout the transmission network:

- Changes in demand;
- Further internal integration of the All-Island Single Electricity Market;
- Further integration with neighbouring countries; and
- Integration of significant levels of new generation (both conventional and renewable).

These factors drive the need for network reinforcements over the next ten years and beyond.

2.4.3 Changes in asset condition

Impacted by a number of factors:

- The age of the asset;
- The type of technology used;
- The level of maintenance;
- The environment in which it operates; and
- Utilisation.

In order to ensure appropriate levels of network safety and that Security of Supply is not compromised, routine condition assessments are carried out. These assess the condition of the assets and estimate remaining useful life.

Typically, where asset condition is poor, assets are:

- Refurbished;
- Replaced on a like-for-like basis; or
- Replaced with higher rated equipment to cater for future needs.

2.5 Network development needs

The technical drivers of transmission network investment listed above result in network development needs. To address these needs, we must provide ongoing and timely reinforcement of the Irish electricity transmission network.

The primary measure of network development needs is assessed by comparing transmission network performance with the required performance levels set out in the Transmission System Security and Planning Standards (TSSPS).

Our TSO licence, granted by the CRU, specifically requires us to ensure the maintenance of and, if necessary, develop the transmission network in accordance with the TSSPS.

It is possible to categorise the resulting reinforcement needs:

- Reinforcements required to support changes in, or connection of, new demand and generation;
- Reinforcements related to interconnection;
- Reinforcements to facilitate inter-regional power flows; and
- Reinforcements to address the condition of existing assets.

3. Changes to the Plan since 2021 and 2022

TDP 2023 – 2032 has a data freeze date of 21 December 2022 while TDP 2021 had a freeze date of 01 January 2021.

There were 145 active projects in TDP 2021³³. Since then:

- 110 new projects have been added as they received capital approval.
- 47 active projects in TDP 2021 have been completed.
- Three new projects added in the period covered by this TDP have been completed, CP1176, CP1179 and CP1180.
- One project, CP0837, was on hold and has been reactivated.
- One project that was active in TDP 2021 has been removed.
- Two projects that were active in TDP 2021 have been put on hold.

Thus, there are 202 active projects in this Development Plan. These are identified by region in Chapter 5.

3.1 Projects completed in 2021 and 2022

Fifty projects were energised and/or completed in 2021 and 2022:

- Sixteen new assets have been built:
 - Thirty-two kilometres of new transmission circuits, 26 km of UGC and 6 km of OHL.
 - Connection of 557 MW RES, 172 MW of Wind Farms, 275 MW of Solar Farms and 110 MW of BESS.
 - Four new power transformers, two of them are connected at 220 kV to accommodate large customer demands, and the other two connected to the distribution system at 110 kV.
 - Two new reactors connected to the transmission system. One of them is connected to prevent over voltages arising from the amount of underground cable in its area and the other one is a temporary connection while a STATCOM project is completed.
- Twenty uprates were completed, three of them in circuits totalling 152 km of transmission lines uprated. The other uprates were modifications to stations either to facilitate the flow of energy through them or to accommodate RES integration.
- Twelve refurbishment projects were completed, five of them in circuits totalling 188 km of transmission lines refurbishments.
- One composite project was completed, and a voltage uprate project trial was also completed.

³³ <https://www.eirgridgroup.com/site-files/library/EirGrid/Transmission-Development-Plan-2021-2030.pdf>

The completed projects are listed in Table 3-1.

Table 3-1: Projects completed in 2021 and 2022		
No.	CP No.	Project title
1	CP0486	Wexford 110 kV Station Transformer Bay
2	CP0647	Kilpaddoge 220-110 kV station
3	CP0724	Thornsberry 110 kV Busbar Uprate ATR ³⁴
4	CP0726	Kilpaddoge – Knockanure 220 kV cable
5	CP0740	Letterkenny 110 kV Station – Relocation of 110 kV Bay & 2 New Couplers
6	CP0763	Clashavoon – Tarbert 220 kV line uprate
7	CP0771	Castlebar 110 kV station busbar uprate
8	CP0794	Aghada 220 kV Station Busbar Reconfiguration
9	CP0829	Clashavoon Macrooom No1 110 kV circuit & associated station works & 250 MVA transformer
10	CP0833	Mayo Renewable Power Biomass
11	CP0864	Tarbert – Tralee No 1 Line Refurbishment
12	CP0868	Knockraha – Raffeen 220 kV line refurbishment
13	CP0883	Ballyvouskill Knockanure 220 kV Line Uprate
14	CP0894	Great Island 110-38 kV trafo DSO and bay works
15	CP0903	Cloon – Lanesboro 110 kV No 1 Line Refurbishment
16	CP0913	Flagford – Sligo 110 kV Line Conflict
17	CP0936	Knockanure Reactor
18	CP0945	Great Island Kilkenny 110 kV Uprate
19	CP0972	Wexford 110 kV Busbar Uprate
20	CP1009	Cruiserath (Amazon) 220 kV Permanent Connection
21	CP1011	Carrickalangan 110 kV station
22	CP1014	Gemini (Snugborough) Phase 2
23	CP1016	220 kV Composite Poles Type Testing

³⁴ Majority of the work, ATR-related, has been completed. Minor work remaining.

Table 3-1: Projects completed in 2021 and 2022

No.	CP No.	Project title
24	CP1017	400 kV Voltage Uprate Trial
25	CP1019	Cashla Tynagh 220 kV Line Fibre Wrap
26	CP1025	Corduff 110 kV Station Development Project
27	CP1036	Transformer Protection Upgrades
28	CP1037	Kilbarry Line Conflicts
29	CP1040	Rosspile 110 kV station
30	CP1047	Oweninny Power 2 ³⁵
31	CP1049	Bracetown 220 kV Station (Clonee Phase 3)
32	CP1051	Gallanstown Solar 110 kV Station
33	CP1053	220 kV Cable Sealing End Replacement at three transmission stations
34	CP1058	Shannonbridge A – New 220 kV transformer bay
35	CP1077	Temporary 50 Mvar reactor in Ballyvouskil
36	CP1083	Gorman Energy Storage
37	CP1084	Lisdrumdoagh 110 kV Battery Storage ³⁴
38	CP1085	Aghada Battery Storage
39	CP1087	Porterstown Battery Storage ³⁴
40	CP1091	New 400 220 kV Transformer for Moneypoint Sub-Station
41	CP1093	Barnageeragh 110 kV Station (Equinix) ³⁴
42	CP1099	Lisheen 3 Windfarm ³⁴
43	CP1101	Mullagharlin 110 kV Station – 2 New DSO Transformer Bays ^{37 34}
44	CP1120	Cloncreen 110 kV Station ³⁴
45	CP1130	Cloghan Wind Farm – New 110 kV transformer bay ³⁴
46	CP1131	Gillinstown Solar (Garballagh 110 kV Station) ³⁴
47	CP1135	Golagh Windfarm Modification ³⁴

35 CP1047, CP1084, CP1087, CP1093, CP1099, CP1101, CP1120, CP1130, CP 1131 and CP1135 were added in the previous Development Plan and completed in the period covered by this Development Plan.

Table 3-1: Projects completed in 2021 and 2022

No.	CP No.	Project title
48	CP1176	Huntstown T2002 Customer Transformer connection ³⁶
49	CP1179	Cloghran Phase 2 Transformer Replacement ³⁵
50	CP1180	Moneypoint Synchronous Condenser ³⁵

More information on the completed projects is detailed in our Investment Planning and Delivery Report³⁷ and Annual Electricity Transmission Performance Report³⁸.

The reports are in line with the CRU Reporting and Incentives decisions for Price Review 4 (2016-2020), CER/18/087⁴⁰, and Price Review 5 (2021-2025), CRU/20/154⁴¹.

For a full evaluation of delivery and performance of the annual Transmission Capital programme, readers are directed to our website³⁹ for the 2022, 2021 and 2020 reports.

³⁶ CP1176, CP1179 and CP1180 were added and completed during the time covered by this Transmission Development Plan. The projects will be reported as new project as well.

³⁷ https://www.esbnetworks.ie/docs/default-source/publications/draft-investment-planning-and-delivery-report-2021.pdf?sfvrsn=7cdab9bb_6

³⁸ https://www.esbnetworks.ie/docs/default-source/publications/annual-electricity-transmission-performance-report-2020.pdf?sfvrsn=1547347_41

³⁹ <https://www.eirgridgroup.com/how-the-grid-works/tso-regulatory-publicatio/>

⁴⁰ <https://cruie-live-96ca64acab2247eca8a850a7e54b-5b34f62.divio-media.com/documents/CRU18087-Reporting-and-Incentives-under-Price-Review-4-Decision-Paper.pdf>

⁴¹ <https://cruie-live-96ca64acab2247eca8a850a7e54b-5b34f62.divio-media.com/documents/CRU20154-PR5-Regulatory-Framework-Incentives-and-Reporting-1.pdf>

3.2 Projects removed in 2021 and 2022

One project has been removed: Ballyadam 110 kV Station Development (CP1151).

As TSO, EirGrid has decided to put the project on hold. EirGrid is exploring other options in the area which may result in a brand new project scope to be reported in future TDPs.

Table 3-2: Project removed in 2021 and 2022

No.	CP No.	Project title
1	CP1151	Ballyadam 110 kV Station Development

3.3 Projects added in 2021 and 2022

One hundred and ten new projects have received capital approval and were added to ongoing projects in 2021 and 2022, these include 46 New Build Connections, 5 New Build Capacity, 21 Replacements, 31 modifications to the system and 7 other projects with other classifications, such as line conflicts.

One project that was on hold in TDP 2021, CP0837, has been re-activated. The project is identified in the table below using footnotes.

Table 3-3: Projects added in 2021 and 2022

No.	CP No.	Project title
1	CP0817	Flagford – Sliabh Bawn 110 kV circuit uprate
2	CP0837	Bellacorick 110 kV Station Uprate ⁴²
3	CP0907	Dalton 110 kV Busbar
4	CP0917	Prospect Tarbert Cable Replacement
5	CP0966	Kildare – Meath Grid Upgrade
6	CP1000	Lanesboro – Mullingar 110 kV line Uprate
7	CP1001	Corduff – Finglas 1 & 2 220 kV line refurbishment
8	CP1021	East Meath – North Dublin Reinforcement
9	CP1023	Letterkenny Busbar Ratings Needs

⁴² CP0837 Bellacorick 110 kV Station Uprate was On Hold in previous version of TDP.

Table 3-3: Projects added in 2021 and 2022

No.	CP No.	Project title
10	CP1045	Finglas Land Acquisition
11	CP1059	Shannonbridge B ESS – 220 kV transformer bay
12	CP1078	Lanesboro – Sliabh Bawn 110 kV circuit thermal capacity
13	CP1079	Binbane – Cathaleen’s Fall 110 kV circuit thermal capacity
14	CP1100	Finglas – North Wall Cable Replacement
15	CP1119	Cashla Flagford 220 kV Line Refurbishment
16	CP1122	Physical Security of Transmission Stations – Dublin Region
17	CP1123	Physical Security of Transmission Stations – South Region
18	CP1124	Physical Security of Transmission Stations – North Region
19	CP1125	Physical Security of Transmission Stations – Central Region
20	CP1128	Monatoreen Solar
21	CP1142	Firlough WF (Carrownaglogh 110 kV Station)
22	CP1143	Blackwater Bog Solar 1
23	CP1144	Kinnegad 110 kV station, Derryiron 110 kV bay conductor uprate
24	CP1145	Rathnaskilloge Solar Farm
25	CP1146	Carrickmines – Poolbeg 220 kV Cable Replacement
26	CP1149	Newbridge – Cushaling 110 kV line, Stations bay conductors and lead-in conductor uprate
27	CP1150	Inchicore – Poolbeg #2 220 kV Cable Replacement
28	CP1155	Glenree – Moy 110 kV Line Uprate
29	CP1156	Sligo 110 kV Station – Srananagh 1 & 2 Bay uprates
30	CP1157	Inchicore – Poolbeg #1 220 kV Cable Replacement
31	CP1158	Clonfad Solar
32	CP1162	Irishtown, Shellybanks and connected stations 220 kV protection upgrade
33	CP1163	Butlerstown, Killoteran and Waterford 110 kV protection upgrade
34	CP1164	West Cork 110 kV Protection Upgrade
35	CP1166	Gorman – Platin 110 kV line uprate

Table 3-3: Projects added in 2021 and 2022

No.	CP No.	Project title
36	CP1167	Drybridge – Oldbridge – Platin 110 kV line uprate
37	CP1168	Cashla-Salthill 110 kV Thermal Uprate
38	CP1170	Bracklone – Portlaoise 110 kV Circuit Thermal Capacity
39	CP1172	Crane – Wexford 110 kV Circuit Thermal Capacity
40	CP1173	Glencloosagh Phase 1 – Rotating Stabiliser
41	CP1174	Aghaleague 110 kV Station
42	CP1175	Kishoge 110 kV Station
43	CP1176	Huntstown T2002 Customer Transformer connection
44	CP1179	Cloghran Phase 2 Transformer Replacement
45	CP1180	Moneypoint Synchronous Condenser
46	CP1181	Corduff Platin 110 kV Line Conflict
47	CP1183	Mooretown 220 kV Station
48	CP1186	Agannygal, Ennis and connected stations 110 kV Protection Upgrade
49	CP1188	Kilcarbery
50	CP1190	Poolbeg 220 kV Station
51	CP1191	Cashla – Galway 110 kV circuit 1 Line Uprate
52	CP1194	Woodland 400 kV Station Redevelopment
53	CP1197	Dunstown Asset Replacements
54	CP1199	Derryiron – Thornsberry 110 kV Circuit Uprate
55	CP1200	Carrickmines Area 220 kV Cable Ducting
56	CP1201	Bogtown 110 kV Station
57	CP1207	Lisheen – Thurles 110 kV Protection Upgrade
58	CP1209	Brown Boveri Circuit Breaker Replacements
59	CP1211	Bandon Dunmanway 110 kV circuit thermal capacity
60	CP1212	Bandon Raffeen 110 kV circuit thermal capacity
61	CP1213	Belcamp 220 kV Busbar Extension

Table 3-3: Projects added in 2021 and 2022

No.	CP No.	Project title
62	CP1215	Knockraha station Celtic IC
63	CP1216	Poolbeg – North Wall 220 kV Cable Replacement
64	CP1217	Philipstown 110 kV Station (Cushaling Wind Farm)
65	CP1219	Coole Wind Farm
66	CP1220	Garrintaggart 110 kV Station – Pinewoods Wind Farm
67	CP1222	Knockraha 220 kV Transformer Replacement
68	CP1224	Lysaghtstown 110 kV Station
69	CP1225	Finglas Corduff 220 kV Protection Upgrade
70	CP1227	Cashla and Connected Stations 220 kV & 110 kV Protection Upgrade
71	CP1228	Shannonbridge and connected stations 220 kV & 110 kV Protection Upgrade
72	CP1229	Lislea 110 kV Station – Drumlins WF
73	CP1230	Darndale Phase 2 – 3 110 kV customer connections in Darndale 110 kV station
74	CP1231	Knockdrin 110 kV Station (Yellow River Wind Farm)
75	CP1232	Derryiron 110 kV Busbar Rating Needs
76	CP1234	Laurencetown 110 kV Station
77	CP1235	Louth – Woodland 220 kV Uprate
78	CP1236	Timoney 110 kV Station
79	CP1237	Ferry View 110 kV Stn
80	CP1240	Coumaclovane Solar Extension
81	CP1241	Belcamp BSP Transfer
82	CP1242	Great Island 220-110 kV transformer upgrades
83	CP1243	Blundelstown 110 kV Station – 2 New DSO Transformer Bays
84	CP1244	North Arklow Solar Plus Storage Facility
85	CP1245	Castletreasure 110 kV Station
86	CP1246	Coomnaclohy 110 kV Station (Knocknamork Wind and Solar Park)
87	CP1247	New Ballyvouskill 220/110 kV Transformer

Table 3-3: Projects added in 2021 and 2022

No.	CP No.	Project title
88	CP1248	Harlockstown Solar (Gallanstown Ext)
89	CP1249	Porterstown Battery Phase2
90	CP1255	Castlelost FlexGen
91	CP1256	Greener Ideas Profile Park
92	CP1259	Cuilleen Power
93	CP1260	Tracystown Solar
94	CP1261	Grahormick Solar
95	CP1262	Shanonagh 110 kV Station
96	CP1264	Rhode ESS
97	CP1265	Corkagh 110 kV Station Phase 2
98	CP1267	Arklow 220 kV – DSO Ballymanus WF
99	CP1268	Dunfirth 110 kV – DSO Dysart PV
100	CP1269	Lodgewood 220 kV – DSO The Dell SF
101	CP1272	Derryiron Temporary Bypass Project
102	CP1275	Cashla – Galway 110 kV circuit 2 Line Uprate (Part of CP1191)
103	CP1276	Cashla – Galway 110 kV circuit 3 Line Uprate (Part of CP1191)
104	CP1277	Intel 110 kV Line Diversion
105	CP1320	Barrymore Cahir Knockraha 110 kV Line Uprate
106	CP1393	Offshore Phase 1 Project 1
107	CP1394	Codling Wind Park
108	CP1396	Arklow Bank Wind Park
109	CP1397	North Irish Sea Array
110	CP1398	Dublin Array

3.4 Projects on hold

As of 21 December 2022, there were four projects on hold. They are listed in Table 3-4 below.

There are various reasons for placing a project on hold, such as:

- Uncertainty regarding customer plans;
- Reassessment of the need for the project;
- Change in the timing of the need for the project; and
- Reassessment of whether the project is the appropriate solution to address the identified need given the latest information available.

Table 3-4: Projects on hold

No.	CP No.	Project title
1	CP0977	Glanagow Raffeen 220 kV Cable Diversion
2	CP1035	N6 Line Diversions
3	CP1107	North Wall 4 & 5
4	CP1046	Banemore Solar Farm

3.5 Candidates solutions progressing the framework for grid development

Shaping Our Electricity Future v1.0 identified candidate solutions, and these are becoming committed projects as they work their way through EirGrid's Framework for Grid Development process.

The candidate solutions progressing through the framework for grid development are given in the Table 3-5.

Table 3-5: Candidate solutions progressing the framework for grid development

No.	Candidate solution	CP No.	Region	Status
1	Drybridge – Louth 110 kV circuit	CP0808	Mid-East	Committed
2	Flagford – Srananagh 110 kV circuit	CP0982	North-West	Early stage ⁴³
3	Sligo – Srananagh 110 kV circuit 3	CP0982	North-West	Early stage ⁴⁴
4	Woodland – Finglas 400 kV cable cct	CP1021	Dublin	Committed
5	Finglas – North Wall 220 kV circuit	CP1100	Dublin	Committed
6	Poolbeg – Carrickmines 220 kV circuit	CP1146	Dublin	Committed
7	Poolbeg South – Inchicore 220 kV circuit 2	CP1150	Dublin	Committed
8	Poolbeg South – Inchicore 220 kV circuit 1	CP1157	Dublin	Committed
9	Galway – Salthill 110 kV circuit	CP1191	West	Committed
10	Arklow – Ballybeg – Carrickmines 220 kV circuit	CP1196	South-East	Early stage
11	Bandon – Dunmanway 110 kV circuit	CP1211	South-West	Committed
12	North Wall – Poolbeg 220 kV circuit	CP1216	Dublin	Committed

⁴³ A committed project is a development that received capital approval to be constructed. Reported in chapter 5.

⁴⁴ A project in early stages is a development that has not yet received capital approval. Reported in chapter 6.

Table 3-5: Candidate solutions progressing the framework for grid development

No.	Candidate solution	CP No.	Region	Status
13	Inchicore – Carrickmines 220 kV circuit	CP1226	Dublin	Early stage
14	Binbane – Clogher – Cathaleen’s Fall 110 kV	CP1233	North-West	Early stage
15	Clogher – Srananagh 220 kV circuit	CP1233	North-West	Early stage
16	Louth – Oriel 220 kV circuit	CP1235	Mid-East	Committed
17	Woodland – Oriel 220 kV circuit	CP1235	Mid-East	Committed
18	Great Island 220/110 transformer No.3	CP1242	South-East	Committed
19	Cashla – Dalton 110 kV circuit 1	CP1321	West	Early stage
20	Maynooth – Rinawade 110 kV circuit	CP1390	Mid-East	Early stage
21	Maynooth – Timahoe 110 kV circuit	CP1391	West	Early stage
22	Rinawade – Dunfirth 0 kV circuit	CP1403	Mid-East	Early stage

3.5.1 SOEF v1.1

The candidate reinforcements identified as part of the latest Shaping Our Electricity Future Roadmap v1.1 are in addition to the committed projects and solutions in Shaping Our Electricity Future v1.0, and the solution progressing through the framework for grid development will be reported in future TDPs.

All candidate reinforcements identified as part of Shaping Our Electricity Future v1.1 will need to enter EirGrid's Framework for Grid Development process and they will be reported in future TDPs as they receive capital approval.

A list of those candidate reinforcements can be found on the Appendix 4 of the Shaping Our Electricity Future v1.1 roadmap report.

Table 3-6: Candidate solutions identified in SOEF v1.1

No.	Candidate solution	Path	Domain	Region
1	Deenes – Drybridge 110 kV	New	Static device (DLR)	North-East
2	Gorman – Maynooth 220 kV	Uprate	Circuit	North-East
3	Meath Hill – Louth 110 kV	New	Static device (DLR)	North-East
4	Lisdrum – Louth 110 kV	New	Static device (DLR)	North-East
5	Ratrussan – Shankill 110 kV	New	Static device (DLR)	North-East
6	Baltrasna – Corduff 110 kV	New	Static device (DLR)	Mid-East
7	Corduff – Blundelstown – Mullingar 110 kV	Uprate	Circuit	Mid-East
8	Maynooth – Castlelost 220 kV	Uprate	Circuit	Mid-East
9	Crane – Wexford 110 kV	New	Static device (DLR)	South-East
10	Cullenagh – Waterford 110 kV	New	Static device (PFC)	South-East
11	Great Island – Waterford 1 110 kV	New	Static device (DLR)	South-East
12	Drumline – Ennis 110 kV	New	Static device (DLR)	South-West
13	Letterkenny – Golagh T 110 kV	Uprate	Circuit	North-West
14	Cashla – Dalton 110 kV	Uprate	Circuit	North-West
15	Castlebar – Dalton 110 kV	Uprate	Circuit	North-West
16	Srananagh – Cathaleen's Fall 2 110 kV	New	Static device (DLR)	North-West

4. Planned network developments

This chapter summarises the network development projects arising from the transmission network development planning process (outlined in Appendix B). Projects are described in greater detail in Chapter 5.

4.1 Overview of the Plan

The TDP includes 202 projects that are active and in progress. These projects are categorised as one of the following: New Build; Uprate/Modify; Refurbish/Replace; or Other.

New Build projects: are projects that involve the construction of new stations or new circuits. This category also includes projects that involve the installation of new equipment in existing stations.

An example of a new build project is the installation of new transformers or new reactive support devices within existing stations.

New Build projects are segregated in two categories:

- New Build Connection: New connection projects; and
- New Build Capacity: Projects that deliver additional grid capacity.

Uprate/Modify projects: are projects that involve the uprating of existing assets. An example of an uprate project is changing equipment to increase the capacity rating of circuits or busbars.

This category also includes projects that involve the modification of existing assets.

An example of a modification project is the installation of new couplers or new bays in existing stations. Reconfiguration of existing stations is also included in this category.

Refurbish/Replace projects: are projects that involve the refurbishment of existing stations or existing circuits. This category also includes projects that involve the replacement of existing assets. For example, the replacement of stations at or close to the end of their useful life or replacement and upgrading of protection in existing stations.

Other: are projects that do not fall naturally into any of the three categories above.

Table 4-1 below summarises the active projects into their respective categories and regions.

However, the descriptions of these projects have been included in chapter 5 as well as in the tables of this chapter.

Table 4-1: Summary of projects by category and region

Project category	Border, Midlands, West	South-West, Mid-West	South-East, Mid-East, Dublin	Projects at multiple locations	Total
New Build	28	16	49		93
Uprate/Modify	23	7	18	1	49
Refurbish/Replace	8	15	24	5	52
Other			5	3	8
Total	59	38	96	9	202

4.2 Summary of projects in steps 4 to 6

Figure 4-1 shows all projects in Step 4 – Step 6. All new developments shown in figure 4-1 are subject to environmental assessment as appropriate in accordance with the relevant planning requirements. For those projects not yet in the planning process, the location of the reinforcements shown on the map are indicative only and do not represent preferred routes/locations. A full list of projects and their corresponding steps of development is given in Chapter 5.


An online version of the map shown in Figure 4-1 can be found on this link⁴⁵. The locations of the new assets are for reference only.

4.2.1 Works outside scope of this Plan

In addition to the projects summarised in this chapter, we also coordinate capital projects which are classified as minor capital works with the TAO, such as minor station alterations. These projects are numerous and generally deal with the day-to-day operation and maintenance of the network. These are not included in the TDP.

45 <https://eirgrid-ie.maps.arcgis.com/apps/webappviewer/index.html?id=db3b1fce078d493a9fd67d6b5ce4ef8d>

Figure 4-1: Planned network developments in steps 4 to 6 of our six-step process



4.3 Project delivery

The development of the transmission network is subject to delivery risk. We use risk management plans and processes to identify, analyse, monitor and manage project and programme risks. These plans and processes facilitate the management of project dependencies and critical path issues within the context of a changing environment.

Dates related to project completion are provided by EirGrid's Network Delivery Portfolio (NDP) quarterly publication which includes 3 major milestones, EirGrid Capital Approval (GW3), Project Agreement with ESB Networks (GW6) and the forecast energisation date (EI). The dates indicated in the NDP are based on an unconstrained scenario and are, therefore, indicative and subject to change. These dates are reported in the tables in Chapter 5 using the Q4-22 NDP milestone data.

The project schedule is developed initially using standard lead times for generic project types. As a project moves forward through the six steps, a detailed schedule is developed and maintained, milestones are achieved and there is increasing certainty regarding the completion date. The following points need to be taken into account when considering project progression and risk:

- Current level of project maturity;
- Outage availability;
- Land access, planning and consent risks; and
- Project complexity.

We differentiate between moderate and high-risk projects based on project type and project step. Projects that are due for completion in the near-term generally carry less risk than those due for completion in later years. Line and station projects which are due to be completed in the near-term are considered to be within the moderate risk category. Large-scale linear developments scheduled to be completed in later years tend to have a higher level of risk associated with them. When inter-dependent projects take place at the same time, care has to be taken scheduling the required outages. Therefore, the region or location of a project also has an impact on its risk profile. Transmission outage planning is an iterative and ongoing process which is a core aspect of project delivery.

EirGrid's Shaping Our Electricity Future Roadmap identifies network projects as a strategic enabler to achieving 2030 RES-E targets. The programme of network investment needed in advance of 2030 is significant and requires both EirGrid and ESB Networks to streamline how grid infrastructure is delivered. EirGrid and ESB Networks will develop and implement an end-to-end TSO/TAO joint approach to optimise delivery of grid infrastructure projects.

As mentioned, in the project tables in Chapter 5 expected and indicative delivery dates are reported. Some of the more common reasons for changes in Project Agreement or Energisation dates are as follows:

- Difficulty in achieving outages particularly for brown field station projects and projects in the North West;
- Changes in customer's plans;
- Difficulties gaining access to land;
- Changes in project scope;
- Increasing planning consent and environmental requirements; and
- Issues with the quality of contestable builds.

EirGrid publishes the NDP on a quarterly basis to communicate updates and changes to the portfolio to stakeholders. In such cases we endeavour to communicate with and mitigate impacts on customers.

4.4 Completion dates

Information in this document with reference to completion dates (Estimated Completion Dates, Forecast Completion Dates and Indicative Completion Dates) has been prepared with all reasonable care and diligence. All and any dates have been estimated and are indicative and subject to change. All dates have been estimated in line with the European Union (Internal Market in electricity) (3) Regulations 2022 (S.I. no 227/2022) and all and any dates are subject to revision.

5. Regional view

This chapter details the committed projects as of the data freeze date, 21 December 2022. Committed projects are those projects that are in Steps 4-6 of our six-step process for developing the grid. Committed projects have received EirGrid capital approval which occurs at the end of Step 3. Indicative completion dates are included for these projects*.

5.1 Overview

This chapter describes the projects including their drivers, needs, location, EirGrid Capital Approval dates (GW3), Project Agreement with ESB dates (GW6), forecast energisation date (EI), capital project number (CP No.) and step in the six-step process for developing the grid.

Projects are categorised by region, as per Figure 1-3 in Chapter 1.

Table 5-1 below summarises the number of active projects by region.

Table 5-1: Summary of active projects by region	
Active TDP projects by region	
Region	No. of active projects
Border, Midlands and West	59
South-West and Mid-West	38
South-East, Mid-East and Dublin	96
Projects at multiple locations ⁴⁶	9
Total	202

⁴⁶ These involve multiple individual projects at various locations around the country.

5.2 The Border, Midlands and West

Summary of projects	
New Build	28
Uprate/Modify	23
Refurbish/Replace	8
Total	59



Active TDP projects by region

The Border, Midlands and West has a wide variety of generation sources. These are dispersed around the region and include wind, solar, storage, hydro, diesel, gas, and a co-fired peat/biomass-burning power station. Note that two peat-powered generating plants at Shannonbridge in Offaly and Lanesboro in Longford closed at the end of December 2020.

The existing transmission network is predominantly 110 kV and 220 kV. There is limited high capacity 400 kV infrastructure in the southern part of the region. It is important to note that the North-West area is relatively isolated from the 220 kV network and comprises of a network of 110 kV circuits, many of which are long lines, and is characterised by a strong wind resource and a low electricity demand.

Development of this network is mainly required to connect a high level of renewable generation.

The existing transmission network allows limited power flows between Northern Ireland and Ireland via the existing 275 kV Tandragee-Louth interconnector.

While the eastern part of the country has seen significant increases in new large industry demand, the West and North-West have seen a large amount of renewable generation connections with many requests for further connection. This level of generation is greater than the capacity of the network resulting in local constraints related to power-transfer needs. These large transfers of power create voltage support needs, which are exacerbated by the decommissioning of the peat plants in the Midlands.

To cater for high levels of renewable generation, network reinforcement is necessary. This will enable the efficient export of generation from this area towards areas with high load, such as the eastern seaboard.

One of the main challenges involved in the grid development of the North-West is the fact that there are limited opportunities for outages, and multiple simultaneous circuit outages for maintenance, uprating, new connections or substation works, are often not possible. As part of Shaping Our Electricity Future, EirGrid has launched an initiative to review and transform how outages of the transmission system are planned and granted. This initiative will include a review of outage requirements and durations during construction as well as consideration of outages during project initiation and decision making. This process will seek to minimize the requirement for outages during construction where possible. EirGrid and ESNB will continue to work closely to deliver the outage programme and in turn the grid delivery programme as effectively and efficiently as possible in all areas of the network requiring reinforcement including the Border, Midlands and West.

In summary there are reinforcement needs due to:

- Local constraints related to power-transfer capacity and voltage support needs;
- Asset condition; and
- Further market integration with Northern Ireland.

The projects described in this section will enable the transmission network to accommodate more diverse power flows. They will also provide benefits to existing and future users of the transmission network and facilitate future regional load growth.

The TDP contains a list of the committed projects as at 21 December 2022. Indicative completion dates are included for these projects*.


We will continue to assess reinforcement needs in the North-West and to identify candidate solutions as part of the Shaping Our Electricity Future update, aiming to find new projects required in the area beyond those already progressing through the grid development process.

As needs and projects progress through the six-step process they will be included in the TDP.

The projects in the Border, Midlands and West are discussed in more detail below.

Figure 5-1 shows the location of projects in Steps 4 to 6 in the Border, Midlands and West.

Figure 5-1: Planned network developments in Steps 4 to 6 in the Border, Midlands and West



Reinforcement of the transmission network between Ireland and Northern Ireland Project

- North South Interconnection Development (CP0466) – 400 kV Circuit from Woodland Transmission Station in Co. Meath to Turleenan Transmission Station in Northern Ireland⁴⁷

Description

The drivers for this project are market integration, Security of Supply and RES integration. There is a requirement for increased power to flow between Ireland and Northern Ireland. This is mainly driven by changes to the all-island generation portfolio, plant retirements and the relative operational costs of generation plants in each jurisdiction.

The capacity for power flows between Ireland and Northern Ireland is limited by the existing infrastructure. In particular, there is a risk that a single event could take the existing 275 kV interconnector out of service. This would lead to a system separation of Ireland and Northern Ireland, requiring each system to instantly adjust to achieve a new demand-supply balance.

The North South Interconnection Development will remove this risk of system separation and significantly increase cross-border transmission capacity.

The North South Interconnection Development will offer significant economic benefits, by:

- Improving Security of Supply, by:
 - allowing sharing of generation across the island; and
 - removing the scenario where a single event could lead to system separation of Ireland and Northern Ireland;
- Improving competition and economic operation by removing operational constraints;
- Providing the required flexibility for renewable generation; and
- Ensuring Security of Supply for the North East of Ireland.

This is a joint EirGrid and SONI project.

⁴⁷ <https://www.eirgridgroup.com/the-grid/projects/north-south/the-project/>

Reinforcement of the transmission and distribution network in Donegal

Projects

- Cathaleen's Fall and Connected Stations 110 kV Protection Upgrade (CP1161)
- Binbane – Cathaleen's Fall 110 kV Thermal Uprate (CP1079)
- Letterkenny 110 kV station Uprate (CP1023)
- Power Flow Control Scheme (CP1048)

Description

The driver for this project is Security of Supply.

Cathaleen's Fall, Cliff, Corraclassy and Gortawee 110 kV stations, require replacement of aged protection relays and teleprotection interfaces in order to mitigate against suboptimal protection system performance.

Protection system enhancement works are also required to ensure compliance with best practice in transmission system protection. A new busbar protection scheme in Corraclassy 110 kV station and a new combined Current/Voltage transformer will also be installed.

The thermal uprate of Binbane – Cathaleen's Fall 110 kV circuit has been identified as an Associated Transmission Reinforcement (ATR) and will support the need for power-transfer capacity arising due to new RES generation in the North West, as this region does not have the capacity to accommodate the expected future generation.

The Letterkenny 110 kV station upgrade is essential to ensure a more secure supply of electricity for County Donegal and to enable the further integration of renewable energy in line with Government Policy targets. It will also be a key enabler in creating electricity demand opportunities in Donegal. The scope of this project involves a new 110 kV station with a busbar rating of 2500 Amp.

Initially, the Power Flow Control Scheme was defined as an interim project to help manage constraints until Lanesboro redevelopment was completed. However, the Lanesboro station redevelopment has moved forward more quickly than expected, while the process for deploying the new technology proposed for Richmond station was not established quickly enough. Therefore, deployment of the technology that was to be installed at Richmond station to help manage constraints is no longer required at this location.

The project has been rescoped and alternative circuits on which to deploy the Power Flow Controllers have been considered. The project consists of the installation of a power flow control device connected in series at Binbane station on Tievebrack – Binbane 110 kV.

This deployment of power flow control devices will have an important role to play from a network and operational perspective in helping to reduce constraints by balancing flows on the network between parallel paths.

Reinforcement of the transmission network within and out of Mayo

Projects

- North Connacht 110 kV Project (CP0816), comprising:
 - A new Moy – Tonroe 110 kV circuit;
 - Uprate of the existing Flagford – Tonroe 110 kV circuit; and
 - Redevelopment of the existing Tonroe 110 kV station
- Castlebar – Cloon 110 kV Thermal Uprate (CP0848)
- Bellacorick 110 kV Station (CP0837)

Description

The driver for North Connacht 110 kV project is RES integration. The need for reinforcement arises due to the requirement to connect new RES generation. The level of generation is greater than the capacity of the local 110 kV network, even when uprated. The generation contracted to connect in the area could result in overloads on the existing infrastructure, under both intact network and single contingency conditions.

We are progressing this project through our six-step process for developing the grid. We are continuing to engage with landowners, communities and stakeholders in the region. The best performing option, that is currently being progressed, is an underground cable for the North Connacht project.

For the most up to date information on the project please visit the project pages on the EirGrid website⁴⁸.

The drivers for Castlebar – Cloon 110 kV Thermal Uprate are Security of Supply and RES Integration. The Castlebar – Cloon 110 kV circuit is one of the few transmission circuits in County Mayo and provides an important pathway for power supply into the area but also for transferring renewable generation out from the area to where it is needed. This reinforcement is planned to support the need for increased power-transfer capacity arising due to new RES generation. This project is part of a suite of uprates being progressed in the North-West to aid in the delivery of future renewable generation and alleviate some of the constraints in the transmission network.

The Bellacorick station projects involve the installation of a new 110 kV transformer bay that will facilitate the connection of the distribution connected wind farms via an up-rated distribution transformer at Bellacorick.

⁴⁸ <https://www.eirgridgroup.com/the-grid/projects/north-connacht/the-project/>

Reinforcement of the transmission network in Mayo

Projects

- Moy 110 kV Station – Busbar Uprate, New Coupler and Refurbishment Works (CP0839)
- Dalton 110 kV Busbar Uprate (CP0907)
- Glenree – Moy 110 kV Thermal Uprate (CP1155)

Description

The drivers for these projects are RES integration and Security of Supply.

The need for these reinforcements arises due to a shortage of transmission capacity. The existing infrastructure could overload under single contingency and maintenance-trip conditions arising due to new RES generation.

In addition, the projects also involve refurbishment works due to the condition of the assets, these refurbishments will be carried out at the same time as the uprating works.

New couplers will be installed in Castlebar and Moy 110 kV stations. These works will improve Security of Supply and increase operational flexibility. This is of particular relevance during the outage season to facilitate maintenance and construction works.

The need of a busbar uprate at Dalton 110 kV station is primarily driven by the connection of renewable generation in county Mayo.

This 110 kV busbar is the limiting component of the station today as it places a restriction on the power that can flow on the two 110 kV circuits (Dalton – Cashla 110 kV and Dalton – Castlebar 110 kV) connected to it and limits generation in the area. Therefore, the uprate is planned to cope with the future transfer of power through this station, as the busbar is at risk of transferring power flows in excess of its thermal rating.

The existing Glenree – Moy 110 kV circuit is a key component in the transmission system located in county Mayo. The planned uprate is part of a suite of uprates being progressed in the North West to aid in the delivery of future renewable generation and alleviate some of the constraints on current connected generation. Therefore, this circuit uprate will increase the future transfer of power through this circuit for intact network or following the loss of nearby circuits.

New generation and battery connections in the Border, Midlands and West Projects

- Shantallow 110 kV New Station and loop-in to Cashla – Shannonbridge – Somerset Tee 110 kV circuit – Solar farm connection (CP1061)
- Buffy 110 kV Station – New single bay 110 kV AIS station, connected into the existing Knockranny – (CP1094)
- Oweninny Power 3 Windfarm – New single bay 110 kV AIS station, known as Croagh West 110 kV station, to be tailed into the existing Bellacorick 110 kV station – (CP1073)
- Mullu Graffy Windfarm – New line bay in the existing Tievebrack AIS 110 kV station connected by 6.1 km UGC to a new single bay 110 kV line/transformer bay AIS station – (CP1126)
- Lenalea Windfarm – New 4 bay 110 kV C-type AIS station looping into the existing Letterkenny – Tievebrack 110 kV OHL – (CP1127)
- Loughteague 110 kV Solar Farm – Direct connection ('Under the fence') to a designated bay of the proposed Coolnabacky 440/110 kV – (CP1060)
- Clonfad Solar Farm – New 4 bay C-type 110 kV AIS station looping into the existing Kinnegad – Mullingar 110 kV OHL, connected by OHL – (CP1158)
- Firlough Windfarm – New 4 bay C-type 110 kV AIS station looping into the existing Glenree – Moy 110 kV, connected by UGC via Line Cable Interface Masts (LCIMs) – (CP1142)
- Blackwater Bog solar farm – New single bay 110 kV AIS station tailed into a new line bay at Shannonbridge 220/110 kV station via circa 3.5 km of UGC – (CP1143)
- Shannonbridge B, battery connection – Tail fed single bay 220 kV AIS station connecting to Shannonbridge 220 kV station via approx. 250m of underground cable – (CP1059)
- Coole Windfarm – New single bay AIS station, Lickny 110 kV Station, tailed into the existing Mullingar 110 kV Station via a 26km UGC – (CP1219)
- Pinewoods Windfarm – New AIS 110 kV 4-Bay C-Type station, called Garrintaggart, looped into the future Ballyragget – Coolnabacky 110 kV OHL via 2no. OHL's of approx. length 0.05km – (CP1220)
- Cushaling Windfarm – New AIS 110 kV 4-Bay C-Type station, called Philipstown, looped into the existing Cushaling – Portlaoise 110 kV OHL via 2no. UGC's approx. 1km long each – (CP1217)
- Aghaleague Solar farm – New Aghaleague 110 kV AIS single bay station to be tailed into the existing Garvagh 110 kV Station – (CP1174)
- Drumlins Park Windfarm – New AIS 110 kV 4-bay C-type station, Lislea 110 kV Station, looping into the existing Lisdrum – Shankill 110 kV circuit via two underground cables (0.7km in length) – (CP1229)
- Rhode ESS – Energy storage system to be connected via the distribution network to Derryiron 110 kV station – (CP1264)
- Knockranny Windfarm – New 110 kV single bay AIS station, Ferry View, tailed into the existing Knockranny 110 kV Station via UGC of approx. length 2km – (CP1237)
- Knockdrin Windfarm – New single bay AIS station, Knockdrin 110 kV Station, tailed into the existing Derryiron 110 kV Station via approximately 0.3 km of underground cable – (CP1231)

- Clonin North Solar Farm – New single bay AIS station, Laurencetown 110 kV station, tailed into the existing Derryiron 110 kV station via a 0.1 km of UGC – (CP1234)
- Clondardis Solar Farm – New AIS 110 kV 4-Bay C-Type station looping into the existing Mullingar – Lanesboro 110 kV OHL – (CP1262)

Description

The driver for these projects is the integration of RES. These projects are needed to connect new generation and battery connections.

Storage projects are also driven by Security of Supply by:

- Improving competition and economic operation by removing operational constraints; and
- Providing the required flexibility for increased renewable generation.

Reinforcement of the transmission and distribution networks in the Border, Midlands and West

Projects

- Bracklone 110 kV New Station and Loop-in to Newbridge – Portlaoise 110 kV Circuit – New DSO demand connection (CP0644)
- Cashla – Flagford 220 kV Line Refurbishment (CP1119)
- Flagford – Sliabh Bawn 110 kV Thermal Uprate (0817)
- Lanesboro – Mullingar 110 kV Thermal Uprate (CP1000)
- Lanesboro – Sliabh Bawn 110 kV Thermal Uprate (CP1078)

Description

The driver for these projects is Security of Supply and RES integration.

The DSO has requested the connection of a new 110 kV station close to Portarlinton in Co. Laois. This project was previously on hold.

A Line Condition Assessment (LCA) and a Line Project Assessment Report (LPAR) have confirmed that Cashla – Flagford 220 kV needs to be refurbished. The main elements of refurbishment include tower painting, insulator and hardware replacement.

The continued operation of Cashla – Flagford 220 kV is essential for the system security and it is believed that this refurbishment should be carried out as per the scope of the LPAR to extend the assets life by 20 years.

The existing Flagford – Sliabh Bawn 110 kV, Lanesboro – Mullingar 110 kV and Lanesboro – Sliabh Bawn 110 kV circuits form part of the transmission network in the North West area which does not have the capacity to accommodate the expected future generation and therefore forms part of a heavily used and important area of the network. Thermal uprates of these circuits are planned to support the need for power-transfer capacity arising due to new RES generation.

Reinforcement and Upgrade of the transmission network in Galway Projects

- Oldstreet, Tynagh and Cashla 400 kV and 220 kV Protection Upgrade (CP1153)
- Galway 110 kV Station Redevelopment (CP0871)
- Cashla – Salthill 110 kV Thermal Upgrade (CP1168)
- Cashla – Galway 110 kV circuit 1 Thermal Upgrade (CP1191)
- Cashla – Galway 110 kV circuit 2 Thermal Upgrade (CP1275)
- Cashla – Galway 110 kV circuit 3 Thermal Upgrade (CP1276)

Description

The drivers for these projects are RES integration and Security of Supply.

Aged protection relays and teleprotection interfaces in Oldstreet 400 kV station and Cashla and Tynagh 220 kV stations have to be replaced. Standardisation of approach is included in the protection scheme for the Oldstreet transformer and an inclusion of dedicated auto-reclose supervision relays on both ends of Cashla – Tynagh 220 kV circuit. This is part of a new standard approach in auto-reclose supervision when overhead lines are combined with cabled sections. Those works will be covered under CP1153.

A significant amount of new renewable generation has been connected or is in the process of being connected to the transmission and distribution system along the western seaboard in Connacht, and specifically around the Galway area. This power needs to be transported to where it is needed.

Galway 110 kV station needs to be redeveloped to cater for power flows in excess of the rating of the busbar which are driven by the connection of new generation in the area.

A needs assessment of the transmission network in the Galway area confirmed that increased thermal capacity between Cashla and Galway stations is required to cater for an unplanned loss (single contingency) of one of the Cashla – Galway 110 kV circuits. The solution for the area is to upgrade Cashla – Galway 110 kV circuits 1, 2 and 3 and Cashla – Salthill 110 kV circuit.

Offshore project in Galway Project

- Skerd Rocks (CP1393)

Description

The driver for this project is RES Integration.

In line with the CRU decision on Offshore Connection Policy (CRU2022/968⁴⁹), applicable to Offshore Phase 1 projects, Offshore projects received capital approval in advance of the connection offers in order to prioritise and expedite the design review process through the use of Advanced Works Packages (AWP) to ensure the target Project Agreement dates of December 2024 is achieved. These AWP's will allow EirGrid to review the Phase 1 projects concepts designs in advance of the ORESS-1 auction.

Skerd Rocks Wind Farm is an offshore wind farm located off the coast of County Galway and is one of the six projects included in Phase 1 of the Offshore Delivery Programme.

The new customer station tailed to existing station in the network and their connections from the offshore platforms to the onshore stations will be reported in future TDPs when the connection offer process is completed.

Reinforcement of the transmission network in Cavan

Projects

- Arva and Connected Stations 110 kV Protection Upgrade (CP1152)
- Arva – Carrick-on-Shannon 110 kV line uprate (CP0841)

Description

The driver for these projects is Security of Supply.

Arva, Gortawee, Navan, Rattrassan and Shankill 110 kV stations require replacement of aged protection relays and teleprotection interfaces in order to mitigate against suboptimal protection system performance. Protection system enhancement works are also required to ensure compliance with best practice in transmission system protection. Installation of a new busbar protection scheme in Gortawee station and the installation of new combined Current/Voltage transformers (CT/VT), on Shankill transformers, are also included in this project.

A study carried out in early 2019 to identify thermal constraints confirmed the need to uprate Arva – Carrick-on-Shannon 110 kV. This project is part of a suite of uprates being progressed in the North-West to aid in the delivery of future renewable generation and alleviate some of the constraints on existing connected generation.

The uprate of the Arva – Carrick-on-Shannon 110 kV circuit has been identified as an Associated Transmission Reinforcement (ATR) and is expected to release an important amount of Firm Access Quantity (FAQ) when completed.

49 <https://www.cru.ie/publications/27340/>

Reinforcement of the transmission network in Sligo

Projects

- Sligo, Srananagh 220-110 kV Protection Upgrade (CP1139)
- Sligo 110 kV Station – Srananagh 1 & 2 Bay Upgrades (CP1156)

Description

The driver for these projects is Security of Supply.

This project involves replacement of aged protection relays and teleprotection interfaces in Sligo 110 kV and Srananagh 220 kV stations to mitigate against suboptimal protection system performance.

The Sligo – Srananagh 1 & 2 110 kV circuits are currently limited by the bay conductors on the Srananagh 1 & 2 110 kV at Sligo 110 kV substation. It has been decided that the best solution to overcome this limitation is to progress with an uprate of these bays at Sligo 110 kV station. Overcoming this limitation will help to accommodate the expected future generation in the area and maintain compliance with the Transmission System Security and Planning Standards (TSSPS).

Reinforcement of the transmission network in Offaly

Projects

- Derryiron – Thornsby 110 kV Thermal uprate (CP1199)
- Derryiron Busbar Uprate (CP1232)
- Derryiron Temporary Arrangement (CP1272)

Description

The drivers for these projects are Security of Supply and RES Integration.

Planning studies indicate that the connection of new generation and the building of new infrastructure will increase the power flowing through the area. The Derryiron – Thornsby 110 kV circuit is expected to accommodate a considerable amount of power flow, either in times of future high wind power, in the event of unforeseen loss of the 110 kV Cushaling – Mount Lucas circuit or due the connection of Moanvane windfarm into Mount Lucas 110 kV station. Therefore, the circuits Derryiron – Thornsby needs to be uprated.

Derryiron busbar uprate is also driven by RES Integration. An increase in power transfer through the 110 kV busbar at the Derryiron station is expected due to some planned connections to this station that are driving the need for this project. The project involves a busbar uprate and extension to the busbar at Derryiron and installing a sectionaliser circuit breaker.

The temporary arrangement at Derryiron 110 kV station is driven by Security of Supply, as it is required to reduce the impact of severe outages at Derryiron to keep critical circuits in operation during the planned works to uprate and extend the existing busbar of this station. The arrangement consists in a bypass that will work by temporarily tying the Rhode and Kinnegad circuits together so that they can electrically feed each other while disconnected from the main busbar. The connection, known as flyover, will consist of a conductor spanning the length of the busbar, supported by two steel-frame structures (approx. 11.7m tall) at each end and one intermediate wooden pole.

Both circuits will be connected to this temporary flyover conductor and disconnected from the existing busbar. The arrangement will be a pre-requisite for the connection of 3 customer renewable projects (CP1234, CP1231 and CP1236) and a station upgrade project (CP1232).

Reinforcement of the transmission network in Laois

Projects

- Coolnabacky – Portlaoise 110 kV Line Uprate (CP0835)
- Newbridge – Portlaoise 110 kV Partial Thermal Uprate (CP1170)

Description

The drivers for project CP0835 are Security of Supply and RES integration. This project is related to the Laois – Kilkenny Reinforcement Project (CP0585) which is required to address quality of supply and provide Security of Supply in the area. Please note that CP0585 is further described in the South-East, Mid-East and Dublin section below.

The need for reinforcement arises due to a shortage of transmission capacity. Studies have indicated overloading for an intact network, single contingency and maintenance trip conditions.

In addition, refurbishment works due to the condition of the circuit will be undertaken at the same time as the uprating works.

CP1170 is driven by Security of Supply, as the level of demand are expected to increase in the East while at the same time significant levels of new renewable generation are expected to connect in the Southwest and Midlands.

The Bracklone – Portlaoise and Bracklone – Newbridge 110 kV circuits will be created following completion of a separate capital project (CP0644) to loop the planned new Bracklone 110 kV DSO station into the existing Newbridge – Portlaoise 110 kV circuit. These circuits form an important part of the transmission network in the Midlands supplying local transmission stations, facilitating cross country power flows from the West to the East, and facilitating the connection of renewable generation in the Midlands.

Reinforcement of the transmission network in Longford

Project

- Lanesboro 110 kV Station Redevelopment (CP0919)

Description

The drivers for these projects are RES integration and Security of Supply.

The need for these projects arises due to a shortage of transmission capacity. Lanesboro 110 kV station needs to be redeveloped to cater for increased power flows in excess of the rating of the existing busbar due to the planned connection of new generation.

The redevelopment of Lanesboro 110 kV station will also improve Security of Supply and increase operational flexibility as it will allow existing restrictions in outage planning to be removed. This is of particular relevance during the outage season.

New OCGT generation connections in Border, Midlands and West

Projects

- Castlelost FlexGen (CP1255)
- Cuilleen Power (CP1259)

Description

The drivers for these projects are Security of Supply.

Castlelost FlexGen is a 275 MW generation facility at Rochfortbridge, Co. Westmeath which will be 5 x 55 MW OCGT units connecting via a new 4 Bay C-Type 220 kV GIS Station looped into the Maynooth – Shannonbridge 220 kV circuit.

Greener Ideas Limited is for a 100 MW generation facility at Monksland, Athlone, Co. Roscommon which will be gas fired reciprocating engines connecting via a new single bay 110 kV AIS Station tailed to Athlone 110 kV Station via 1.5 km of UGC.

Other approved projects

In addition to the network reinforcement projects described above, there are also other projects in the Border, Midlands and West, namely:

- Flagford – Louth 220 kV Line Refurbishment (CP0867);
- Louth – Rattrassan 110 kV No. 1 Line Uprate (CP0905);
- Flagford 220/110 kV Station – Circuit Breaker Replacement (CP1031);
- Cashla 220/110 kV Station – Circuit Breaker Replacement (CP1032); and
- N6 Line Diversions (CP1035).

5.2.1 Summary of projects in the Border, Midlands and West

There are 40 projects in the Border, Midlands and West region. These projects are listed in Table 5-2 below.

Table 5-2: Projects in the Border, Midlands and West

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
1	CP0816	North Connacht 110 kV Project	New build capacity	–		■	
2	CP0466	North South 400 kV Interconnector	New build capacity	137 ⁵⁰	■	■	■
3	CP0835	Coolnabacky – Portlaoise 110 kV Line Uprate	Uprate/ modify	8	■	■	
4	CP0839	Moy 110 kV Station – Reconfiguration and Busbar Uprate ⁵²	Uprate/ modify	–	■	■	
5	CP0867	Flagford – Louth 220 kV Line Refurbishment	Refurbish/ replace	110	■		
6	CP0905	Louth – Ratrussan 110 kV No. 1 Line Uprate	Uprate/ modify	39	■		
7	CP0871	Galway 110 kV Station Redevelopment Project	Uprate/ modify	–	■	■	
8	CP0919	Lanesboro 110 kV Station Redevelopment Project	Uprate/ modify	–		■	
9	CP1031	Flagford 220 kV Station Sprecher & Schuh CB Replacement	Refurbish/ replace	–	■		
10	CP1032	Cashla 220 kV Station Sprecher & Schuh CB Replacement	Refurbish/ replace	–	■		
11	CP1048	Power Flow Control Scheme	New build capacity	–		■	

50 The total length is 137 km, 103 km in Ireland and 34 km in Northern Ireland.

51 According to the latest publication of the NDP, the energization date of CP0466 is now 2027. This Clarification is made in order to align with TDP NI.

52 ATR completed.

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
	■				Mayo, Roscommon	5	■	TSO	12/09/2018	15/03/2023	30/06/2026
■	■		■		Meath, Cavan, Monaghan, Armagh, Tyrone	5		TSO	21/09/2016	28/03/2023	22/12/2025 ⁵¹
	■			■	Laois, Laois	5		TSO	30/05/2018	30/03/2024	30/11/2025
	■			■	Mayo	6	■	TSO	30/09/2014	07/10/2015	30/11/2023
				■	Roscommon, Leitrim, Longford, Cavan, Meath, Louth	6		TSO	20/04/2015	30/04/2020	30/11/2025
				■	Louth, Monaghan, Cavan	6		TSO	25/05/2016	29/08/2022	30/09/2024
	■			■	Galway	6	■	TSO	21/06/2017	21/12/2018	30/11/2024
	■				Longford	6	■	TSO	28/12/2017	30/06/2020	30/11/2029
				■	Roscommon	6		TSO	30/06/2018	11/07/2019	20/11/2026
				■	Galway	6		TSO	30/06/2018	11/07/2019	30/11/2026
	■	■			Longford	4		TSO	04/02/2021	29/09/2023	18/12/2024

Table 5-2: Projects in the Border, Midlands and West

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
12	CP1061	Shantallow 110 kV Station – Shantallow Solar Farm	New build connection	–		■	
13	CP0644	Bracklone 110 kV Station – DSO	New build connection	–	■		
14	CP0841	Arva-Carrick on Shannon 110 kV Line Uprate – Refurb	Uprate/modify	43	■	■	
15	CP0848	Castlebar – Cloon 110 kV Line Uprate-Refurb	Uprate/modify	57.3	■	■	
16	CP1094	Buffy 110 kV Station	New build connection	–		■	
17	CP1060	Loughteague 110 kV Solar Farm	New build connection	–		■	
18	CP1073	Oweninny 3	New build connection	–		■	
19	CP1126	Mully Graffy Windfarm	New build connection	–		■	
20	CP1127	Lenalea Windfarm	New build connection	–		■	
21	CP1139	Sligo & Srananagh 220 & 110 kV Protection Upgrade	Refurbish/replace	–	■		
22	CP1152	Arva and connected stations 110 kV Protection Upgrade	Refurbish/replace	–	■		
23	CP1153	Oldstreet, Tynagh and Cashla 400 kV & 220 kV Protection Upgrade	Refurbish/replace	–	■		
24	CP1161	Cathaleen's Fall and Connected Stations 110 kV Protection Upgrade	Refurbish/replace	–	■		
25	CP1158	Clonfad Solar	New build connection	–		■	

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
		■			Galway	6		DEV	11/07/2019	17/12/2021	12/08/2024
		■			Laois	6		DSO	19/03/2020	01/06/2022	01/04/2025
■	■				Cavan, Longford, Leitrim, Roscommon	6	■	TSO	21/05/2020	15/12/2021	30/11/2024
	■				Mayo, Galway	5	■	TSO	16/09/2020	29/12/2023	30/11/2025
		■			Galway	6		DEV	10/02/2020	19/11/2020	30/03/2023
		■			Laois	6		DEV	03/06/2020	05/11/2021	31/03/2025
		■			Mayo	3		DEV	02/07/2020	30/04/2024	30/06/2026
		■			Donegal	4		DEV	06/08/2020	10/02/2023	28/06/2024
		■			Donegal	4		DEV	01/10/2020	05/10/2021	28/04/2023
				■	Sligo	6		TSO	01/10/2020	16/07/2021	30/11/2025
				■	Cavan	6		TSO	12/11/2020	01/09/2021	01/12/2025
				■	Galway	6		TSO	12/11/2020	05/08/2021	30/11/2024
				■	Donegal	6		TSO	04/12/2020	01/12/2021	30/11/2025
		■			Westmeath	3		DEV	19/01/2021	22/12/2022	30/06/2024

Table 5-2: Projects in the Border, Midlands and West

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
26	CP1119	Cashla Flagford 220 kV Line Refurbishment	Refurbish/ replace	88	■		
27	CP1142	Firlough 110 kV Station (Firlough WF)	New build connection	–		■	
28	CP1156	Sligo 110 kV Station – Srananagh 1 & 2 Bay uprates	Uprate/ modify	–	■	■	
29	CP1199	Derryiron – Thornsberry 110 kV Circuit Uprate	Uprate/ modify	19.67		■	
30	CP1143	Blackwater Bog Solar 1	New build connection	–		■	
31	CP1000	Lanesboro – Mullingar 110 kV line LCA	Uprate/ modify	46	■		
32	CP1079	Binbane – Cathaleen’s Fall 110 kV circuit thermal capacity	Uprate/ modify	34.3	■	■	
33	CP1078	Lanesboro – Sliabh Bawn Thermal Uprate	Uprate/ modify	9.4	■		
34	CP0817	Flagford – Sliabh Bawn 110 kV circuit uprate	Uprate/ modify	21.2	■	■	
35	CP0907	Dalton 110 kV Busbar	Uprate/ modify	–	■	■	
36	CP1155	Glenree – Moy 110 kV Line Uprate	Uprate/ modify	13.86	■	■	
37	CP1023	Letterkenny Busbar Ratings Needs	New build capacity	–	■	■	
38	CP1170	Newbridge – Portlaoise 110 kV Partial Thermal Uprate	Uprate/ modify	19.8+2	■		
39	CP1168	Cashla-Salthill 110 kV Thermal Uprate	Uprate/ modify	9.4	■	■	
40	CP1059	Shannonbridge BESS – New 220 kV transformer bay	New build connection	–	■	■	

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
				■	Galway, Roscommon	5		TSO	26/02/2021	30/09/2023	30/11/2025
		■			Mayo	3		DEV	04/02/2021	30/04/2024	30/06/2026
	■				Sligo	4		TSO	18/06/2021	04/04/2022	30/11/2025
	■	■			Offaly	5		TSO	19/11/2021	30/09/2023	30/11/2025
		■			Offaly	3		DEV	06/05/2021	31/12/2023	28/03/2025
	■				Longford, Westmeath	5	■	TSO	29/01/2021	29/12/2023	30/11/2024
	■	■			Donegal	5	■	TSO	29/01/2021	30/03/2023	30/11/2023
	■				Longford, Roscommon	5	■	TSO	18/02/2021	29/12/2023	30/11/2024
	■				Roscommon	6	■	TSO	18/02/2021	02/06/2022	31/10/2024
	■				Mayo	4	■	TSO	01/10/2021	30/06/2023	24/11/2026
	■				Sligo, Mayo	5		TSO	15/04/2021	30/09/2023	30/06/2025
	■				Donegal	4		TSO	17/06/2021	10/09/2024	30/10/2029
■	■				Newbridge, Portlaoise	5		TSO	05/08/2021	30/12/2023	30/11/2025
■	■				Galway	5		TSO	18/03/2021	29/12/2023	30/11/2025
		■			Offaly	6		DEV	28/05/2021	12/10/2022	01/07/2024

Table 5-2: Projects in the Border, Midlands and West

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
41	CP1219	Coole Wind Farm	New build connection	–		■	
42	CP1220	Garrintaggart 110 kV Station – Pinewoods Wind Farm	New build connection	–		■	
43	CP1217	Philipstown 110 kV Station (Cushaling Wind Farm)	New build connection	–		■	
44	CP1174	Aghaleague 110 kV Station	New build connection	–		■	
45	CP1231	Knockdrin 110 kV Station (Yellow River Wind Farm)	New build connection	–		■	
46	CP1229	Lislea 110 kV Station – Drumlins WF	New build connection	–		■	
47	CP1255	Castlelost FlexGen	New build connection	–	■		
48	CP1259	Cuilleen Power	New build connection	–	■		
49	CP1264	Rhode ESS	New build connection	–	■	■	
50	CP1191	Galway Area Transmission Network Needs	Uprate/modify	13.8	■	■	
51	CP1232	Derryiron 110 kV Busbar Rating Needs	Uprate/modify	–	■	■	
52	CP1237	Ferry View 110 kV Station	New build connection	–		■	
53	CP1275	Cashla – Galway 110 kV circuit 2 Uprating (Part of CP1191)	Uprate/modify	11.3	■	■	
54	CP1276	Cashla – Galway 110 kV circuit 3 Uprating (Part of CP1191)	Uprate/modify	11.3	■	■	
55	CP1234	Laurencetown 110 kV Station	New build connection	–		■	

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
		■			Westmeath	4		DEV	01/02/2022	01/11/2024	01/04/2025
		■			Laois	4		DEV	01/02/2022	01/09/2023	01/04/2025
		■			Offaly	3		DEV	03/02/2022	01/10/2023	01/07/2024
		■			Roscommon	3		DEV	02/03/2022	30/03/2024	31/10/2025
		■			Offaly	3		DEV	07/04/2022	30/09/2023	29/11/2024
		■			Monaghan	3		DEV	29/04/2022	22/12/2022	01/10/2024
		■			Westmeath	3		DEV	04/05/2022	03/10/2023	01/07/2024
		■			Roscommon	3		DEV	05/05/2022	03/10/2023	01/07/2024
		■			Offaly	3		DEV	23/06/2022	31/10/2023	31/01/2025
■	■				Galway	3		TSO	21/11/2022	30/12/2025	30/11/2029
■					Galway	3		TSO	29/04/2022	29/09/2023	31/12/2025
			■		Offaly	3		DEV	07/07/2022	01/01/2024	02/12/2024
■	■				Westmeath	3		TSO	21/11/2022	31/12/2024	31/12/2029
■	■				Laois	3		TSO	21/11/2022	31/12/2024	31/12/2029
			■		Offaly	3		DEV	07/04/2022	31/10/2023	01/12/2024

Table 5-2: Projects in the Border, Midlands and West

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
56	CP1262	Shanonagh 110 kV Station	New build connection	–		■	
57	CP1272	Derryiron Temporary Bypass Project	Uprate/Modify	–	■	■	
58	CP1393	Offshore Phase 1 Project 1	New build connection	–		■	
59	CP0837	Bellacorrick 110 kV Station T141 Uprate	Uprate/Modify	–	■	■	

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
			■		Roscommon	3		DEV	10/11/2022	29/02/2024	25/04/2025
■					Offaly	3		TSO	12/10/2022	31/03/2023	30/06/2023
		■			Monaghan	3		TSO	15/12/2022	31/12/2024	30/06/2027
		■			Westmeath	3		TSO	10/12/2014	07/12/2018	01/06/2023

5.3 The South-West and Mid-West

Summary of projects	
New Build	16
Uprate/Modify	7
Refurbish/Replace	15
Total	38



Active TDP projects by region

The South-West and Mid-West have a wide variety of generation sources dispersed around the region. These include wind, storage, hydro, gas, fuel oil, diesel, and coal burning power stations.

The existing transmission network is composed of 110 kV, 220 kV and 400 kV infrastructure. The high capacity 220 kV and 400 kV circuits facilitate high inter-regional power flows from the region.

The development of the transmission network in the area is characterised by the connection of high levels of wind generation in Co. Cork and Co. Kerry. These high levels of generation result in transmission network constraints as power is exported out of the area towards Moneypoint and Knockraha transmission stations. Generation levels in the area are set to increase in the coming years.

The level of generation is greater than the capacity of the network resulting in local constraints related to power-transfer needs. These large transfers of power create voltage support needs.

To cater for the high levels of generation, network reinforcement is needed to enable the efficient export of generation from the area.

In summary there are reinforcement needs due to:

- Local constraints related to power-transfer capacity and voltage support needs; and
- Asset condition.

The projects described in this section will enable the transmission network to accommodate more diverse power flows. They will also provide benefits to existing and future users of the transmission network and facilitate future regional load growth.

The TDP contains a list of the committed projects as at 21 December 2022. Indicative completion dates are included for these projects*.

We will continue to assess reinforcement needs in the South-West and Mid-West and to identify candidate solutions as part of the Shaping Our Electricity Future update, aiming to find new projects required in the area beyond those already progressing through the grid development process.

EirGrid is currently working on a joint project with the French TSO Réseau de Transport d'Électricité (RTE) called the Celtic Interconnector, that would land on the southern coast of Ireland with a connection point in Cork. This interconnector is deemed a Project of Common Interest (PCI) by the European Commission. PCIs are intended to help the EU achieve its energy policy and climate objectives: affordable, secure and sustainable energy for all citizens. See Appendix A, Irish Projects in European Plans, for more information.

The projects in the South-West and Mid-West are discussed in more detail below.

Figure 5-2 shows the location of projects in Steps 4 to 6 in the South-West and Mid-West.

100





Figure 5-2 (b): Planned network developments in Steps 4 to 6 in Cork



Reinforcement of the transmission network in North Kerry

Project

- Tarbert 220/110 kV Station Refurbishment (CP0622)

Description

The driver for this project is Security of Supply.

The need for reinforcement arises due to local constraints on the transmission network.

The existing Tarbert transmission station is being retained. However, due to the age and condition of the assets in Tarbert station, a project involving the refurbishment of the 220 kV assets is progressing.

Reinforcement of the transmission network in Tipperary

Projects

- Cahir and Connected Stations 110 kV Protection Upgrade (CP1111)
- Tipperary, Cahir and Connected Stations 110 kV Protection Upgrade (CP1116)
- Lisheen – Thurles 110 kV protection Upgrade (CP1207)

Description

The driver for these projects is Security of Supply.

The three projects involve replacement of aged protection relays and teleprotection interfaces in Cahir, Ballydine and Doon 110 kV stations (CP1111), Cahir, Cauteen and Tipperary 110 kV stations (CP1116), and in Lisheen and Thurles 110 kV stations (CP1207).

At the Ballydine and Doon 110 kV stations, the installation of a bus zone protection system and the extension of the buildings is planned to make room for the new protection relay panels.

Installation of a new combined Current transformer/Voltage transformer (CT/VT) in Tipperary 110 kV station is the only significant deviation from relay installation and commissioning type work contained in CP1116.

Installation of new duplicate protection relays are included for both Lisheen and Thurles 110 kV stations. This is a particularly vulnerable circuit as there is no redundancy in the protection systems and one end has an end-of-life device. Failure of a single protection element at either end of this line will result in the circuit being forced out of service until urgent repair or replacement can be completed.

Reinforcement of the transmission network between Tipperary and Cork

Project

- Barrymore – Cahir – Knockraha 110 kV Line Upgrade (CP1320)

Description

The drivers for this project are Security of Supply and RES Integration.

The circuit under consideration is the Barrymore – Cahir – Knockraha 110 kV. With the planned development of two new interconnectors in the South of Ireland this circuit requires upgrading to increase its capacity.

Reinforcement of the transmission network in West Cork

Projects

- Coolroe, Inniscarra and connected stations Protection Upgrade (CP1160)
- West Cork Protection Upgrade (CP1164)
- Bandon – Dunmanway 110 kV Line Uprate (CP1211)
- Bandon – Raffeen 110 kV Line Uprate (CP1212)
- Brown Boveri circuit breaker replacements (CP1209)
- New Ballyvouskill 220/110 kV Transformer (CP1247)

Description

The drivers for these projects are Security of Supply and RES integration.

The Coolroe, Inniscarra and Macroom, and West Cork Protection Upgrades involve replacement of aged protection relays and teleprotection interfaces in order to mitigate against sub optimal protection system performance and the need for the grid to have its assets in a good condition.

The existing fibre optic network between Macroom and Inniscarra is planned to be utilised for differential protection and teleprotection. Installation of a new 110 kV busbar protection schemes in Inniscarra and Coolroe 110 kV stations are included in this project.

West Cork Protection upgrade also includes the installation of a new busbar protection scheme in Carrigadrohid station. Building extension works has also been included for Carrigadrohid as new protection cabinet may require more space than is available in the existing control room.

Due to the integration of significant levels of new renewable generation to the transmission and distribution system in the South-West and integration of interconnections, an increase in power flow is expected through Bandon – Dunmanway 110 kV and Bandon – Raffeen 110 kV circuits. These thermal uprates are necessary because in times of high wind power dispatches in the future, an unplanned loss of the Clashavoon – Knockraha 220 kV circuit could result in excessive power flows on the circuit Bandon – Dunmanway – Raffeen 110 kV exceeding its thermal rating, putting Security of Supply at risk.

Brown Boveri circuit breaker replacements project includes changes of circuit breaker in Aghada, Louth, Moneteen, Prospect and Raffeen stations. The circuit breakers are approximately 40 years old and while they have not reached their expected lifespan, due to poor reliability issues, the high costs with refurbishment and the criticality of these assets to the network, the changes are recommended. This project will also include the replacement and refurbishment of other equipment associated with each bay to ensure reliable performance of these critical assets for the future.

The need of the new Ballyvouskill 220/110 kV Transformer project is primarily driven by the planned connection of the RES. The transformers at Ballyvouskill station are at risk of overloading, as it has been identified that one of them will be overloaded beyond its emergency thermal rating due to an unplanned loss of the other one. The installation of a third 220/110 kV transformer at Ballyvouskill station will address the issue described above, ensuring Security of Supply and allowing the connection of renewables sources in the area.

Reinforcement of the transmission network in the Cork City area

Projects

- Knockraha 220 kV Station Upgrade (CP0796)
- Trabeg 110 kV Station (CP0741)
- Knockraha Short Circuit Rating Mitigation (CP0973)
- Cow Cross 110 kV Station (CP1132)
- Kilbarry 110 kV GIS Station (CP0949)
- Kilbarry – Knockraha 110 kV No.2 Line Refurbishment (CP0901)
- Knockraha 220 kV Transformer Replacement (CP1222)

Description

The driver for these projects is Security of Supply. Together they will create and maintain the requisite levels of reliability and flexibility in the transmission network.

The need for the Knockraha 220/110 kV station upgrade project arises due to a number of local constraints on the transmission network. Studies have indicated the potential unacceptable loss of generation and voltage violations without this project.

Trabeg 110 kV station project considers an uprate of 2 x 110 kV AIS load transformers to accommodate an increased distribution demand in the area.

Knockraha Short Circuit Rating Mitigation project addresses safety and Security of Supply. It will strengthen the capability of the support structures for strung busbar and bay conductor equipment to withstand the mechanical forces created by short circuit currents flowing through busbar and bay conductor.

To improve the Security of Supply, the installation of a new distribution transformer at Cow Cross 110 kV is required to facilitate the additional load driven by the retirement of the Cobh 38 kV Station and to facilitate new demand connections.

A new 110 kV station near Kilbarry is being progressed to accommodate increased demand in the area and to improve the Security of Supply. This new station, in combination with the existing Kilbarry 110 kV station, will divide the load between them and improve Security of Supply for Cork city and the vicinity of North Cork.

The proposed refurbishment of the Kilbarry – Knockraha 110 kV focusses on operational and maintenance issues for existing equipment. The refurbishment works include replacement of insulators and hardware, reinforcement of shear blocks, replacement of wooden polesets, corrosion treatment of steel towers, and ancillary site works.

Knockraha 220 kV Transformer Replacement project will replace one of the two oldest transformers with a new modern design transformer. This replacement is due to noise complaints from resident living in close proximity to the station and to improve asset resilience at this critical 220 kV transmission station.

Reinforcement of the transmission network between Ireland and France

Project

- Knockraha Station Celtic Interconnector (CP1215)

Description

The drivers for this project are Market Integration, Security of Supply and RES integration.

As part of the preparation of the connection of the Celtic Interconnector, works will be carried out at Knockraha station.

The Celtic Interconnector is a planned subsea HVDC link to allow the exchange of electricity between Ireland and France. Since 2011, EirGrid has been working with its French equivalent Réseau de Transport d'Électricité (RTE) to find the best way to develop the interconnector to benefit electricity customers and markets in Ireland, France and the EU.

The scope of this project involves three new 400/220 kV single phase transformers, a new 220 kV transformer bay, a new 400 kV transformer bay and the terminations within the Celtic Interconnector AC cable sealing end compound, adjacent to Knockraha 220 kV station.

There is no capital project number associated with the Interconnector itself. This is because the project is being delivered by Celtic Interconnector Designated Activity Company, CIDAC, which is a joint venture between EirGrid and RTE.

The project is jointly funded by both TSOs through cost sharing agreements with the supporting national regulatory authorities with additional EU grant funding.

Reinforcement of the transmission network in Limerick

Projects

- Killonan 220/110 kV Station Redevelopment (CP0624)
- Limerick and Connected Station 110 kV Protection Upgrade (CP1112)

Description

The driver for these projects is Security of Supply.

The Killonan station is an important node on the network, as it is the main bulk supply point for the Mid-West region.

The project involves the replacement of the AIS station with a GIS station on an adjacent site. This is required because of the condition and age of the transmission equipment in the station.

Limerick, Moneteen and Rathkeale stations protection upgrades are required due to aged protection relays. Project works include 110 kV bus zone protection scheme installations at Rathkeale station, installation of measurement devices (CT/VT) at Limerick and Rathkeale and a new fibre connection between Limerick and Moneteen.

New generation and battery connections in the South-West and Mid-West Projects

- Drombeg 110 kV New Station and loop-in to Kilpaddoge – Tralee 110 kV circuit – Solar farm connection – (CP1062)
- Ballinknockane 110 kV New Station and loop-in to Aughinish – Kilpaddoge 110 kV circuit – Solar farm connection – (CP1069)
- Aghada BESS 02 – Connection of a battery storage to a bay in the existing Aghada 220 kV station via 220 kV underground cable – (CP1129)
- Moonatooreen solar farm – New single Bay AIS 110 kV station, Ballynabrannagh, to be tailed into the existing Knockraha 220/110 kV station by approximately 2.8 km of underground cable – (CP1128)
- Lysaghstown solar farm – New 110 kV AIS 4-Bay C-Type station, Lysaghstown, looped into the existing Midleton – Knockraha 110 kV OHL via 2no. UGC of approx. length 0.13km – (CP1224)
- Erkina Solar farm – New 4-bay C-type AIS 110 kV station, looped into the Shannonbridge – Ikerrin Tee – Thurles 110 kV circuit, via two underground cables (approximately 1.1km) – (CP1236)
- Knocknamork Wind and Solar Park – New single bay AIS station, Coomnaclohy 110 kV Station, tailed into the existing Ballyvouskill 220/110 kV Station via approximately 3.5 km of underground cable – (CP1246)
- Ballinrea Solar farm – New single bay AIS station, called Castletreasure 110 kV Station, tailed into the existing Raffeen 220/110 kV Station via approximately 4km of underground cable – (CP1245)
- Coumaclovane Solar Extension – Extension of the existing Glanlee Wind Farm making the existing connection a hybrid plant – (CP1240)

Description

The driver for these projects is the integration of RES. These projects are needed to connect new Windfarm, solar farm and battery connections.

Storage projects are also driven by Security of Supply, by:

- Improving competition and economic operation by removing operational constraints; and
- Providing the required flexibility for increased renewable generation

Reinforcement of the transmission network in the South-West and Mid-West for reactive power support Projects

- Ballynahulla 220/110 kV Station – New Statcom (CP0934)
- Ballyvouskill 220/110 kV Station – New Statcom (CP0935)
- Thurles 110 kV Station – New Statcom (CP0933)

Description

The drivers for these projects are RES integration and Security of Supply.

The need for reinforcement arises from changing generation patterns resulting in a need for additional voltage support in the south west region and around the Thurles area.

Both capacitive and inductive reactive support is required in the south west across two separate 220 kV stations; Ballynahulla and Ballyvouskill. The planned reactive support at Ballyvouskill and Ballynahulla makes up an overall solution for the South-West and the works at the two stations are required for the solution to perform adequately.

The need for additional reactive support in the Thurles area is due to the connection of distributed windfarms in the area and heavily loaded transmission lines during contingencies.

Cable replacement in the South-West and Mid-West

Project

- Prospect – Tarbert Cable replacement (CP0917)

Description

The driver for this project is Security of Supply.

Prospect – Tarbert 220 kV circuit is partially overhead line and partially underground/ submarine cable. The cable has now reached end-of-life and requires replacement in the short term. The need to replace the existing Prospect Tarbert Fluid Filled 220 kV Cable is due to asset condition and age. It is also a requirement of EirGrid's cable maintenance policy to replace all Fluid Filled Cables from the system to remove the environmental risk of leaks.

Other approved projects

In addition to the network reinforcement projects described above, there are also other projects in the South-West and Mid-West, namely:

- Moneypoint – Oldstreet 400 kV Line Refurbishment (CP0824);
- Dunstown – Moneypoint 400 kV Line Refurbishment (CP0873);
- Tarbert – Trien 110 kV No. 1 Line Refurbishment (CP0902); and
- Glanagow 220 kV Station – Point on Wave Controller (CP0983);

5.3.1 Summary of projects in the South-West and Mid-West

There are 37 projects in the South-West and Mid-West region. These are listed in Table 5-3 below.

Table 5-3: Projects in the South-West and Mid-West

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
1	CP0622	Tarbert 220 kV Station Upgrade	Refurbish/ replace	–	■		
2	CP0824	Moneypoint – Oldstreet 400 kV Line Refurbishment	Refurbish/ replace	104	■		
3	CP0796	Knockraha Station & installation of additional couplers	Uprate/ modify	–	■		
4	CP0624	Killonan 220 kV Station Refurbishment – Kilonan Station Works	Refurbish/ replace	–	■		
5	CP0933	Thurles 110 kV Station – Statcom	New build capacity	–	■	■	
6	CP0934	Ballynahulla 220-110 kV Station – Statcom	New build capacity	–	■	■	
7	CP0935	Ballyvouskill 220-110 kV Station – Statcom	New build capacity	–	■	■	
8	CP0873	Dunstown – Moneypoint 400 kV Refurbishment	Refurbish/ replace	209	■		
9	CP0902	Tarbert – Trien 110 kV No. 1 Line Refurbishment	Refurbish/ replace	21	■		
10	CP0973	Knockraha Short Circuit Rating Mitigation	Uprate/ modify	–	■		
11	CP0983	Point on Wave Controller for Glanagow 220 kV Station	Uprate/ modify	–	■		
12	CP0949	Kilbarry 110 kV GIS Station	New build connection	–	■		
13	CP1069	Ballinknockane Solar farm	New build connection	–		■	
14	CP1062	Drombeg Solar 110 kV Station	New build connection	–		■	

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
				■	Kerry	6		DSO	29/05/2012	16/12/2014	30/11/2023
				■	Clare, Galway	6		TSO	17/09/2014	20/06/2018	30/11/2024
	■				Cork	6	■	TSO	21/09/2016	30/09/2016	30/11/2025
				■	Limerick	6		TSO	30/09/2011	01/04/2019	16/11/2027
	■				Tipperary	6	■	TSO	22/10/2015	19/10/2020	30/11/2023
	■				Kerry	6		TSO	22/10/2015	04/07/2019	29/09/2023
	■				Cork	6	■	TSO	22/10/2015	04/07/2019	31/08/2023
				■	Kildare, Laois, Tipperary, Clare	6		TSO	20/06/2014	05/12/2019	30/11/2025
				■	Kerry	6		TSO	15/03/2016	27/09/2017	30/11/2024
				■	Cork	6		TSO	03/11/2016	21/06/2019	03/11/2025
	■				Cork	6		TSO	04/08/2016	23/05/2017	30/11/2023
		■			Cork	6		DSO	14/02/2017	04/03/2021	30/11/2024
		■			Limerick	6		DEV	16/05/2019	24/12/2020	01/10/2024
		■			Kerry	6		DEV	28/06/2019	17/12/2020	31/07/2024

Table 5-3: Projects in the South-West and Mid-West

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
15	CP0901	Kilbarry-Knockraha 110 kV No.2 Line Refurbishment	Refurbish/ replace	12.5	■		
16	CP1116	Tipperary, Cahir and Connected Stations 110 kV Protection Upgrade	Refurbish/ replace	–	■		
17	CP0741	Trabeg 110 kV Station – uprate 2x110 kV transformer bays and control room extension DSO	Uprate/ modify	–	■		
18	CP1111	Ballydine, Cahir and Connected Stations 110 kV Protection Upgrade	Refurbish/ replace	–	■		
19	CP1112	Limerick and Connected Stations 110 kV Protection Upgrade	Refurbish/ replace	–	■		
20	CP1129	Aghada BESS 02	New build connection	–	■	■	
21	CP1132	Cow Cross New 110 kV Transformer	New build capacity	–	■		
22	CP1160	Coolroe, Inniscarra & connected stations Protection Upgrade	Refurbish/ replace	–	■		
23	CP1164	West Cork 110 kV Protection Upgrade	Refurbish/ replace	–	■		
24	CP1207	Lisheen – Thurles 110 kV Protection Upgrade	Refurbish/ replace	–	■		
25	CP1128	Ballynabrannagh 100 kV Station (Moonatooreen Solar)	New build connection	–		■	
26	CP0917	Prospect – Tarbert 220 kV Cable Replacement Project	Refurbish/ replace	2.48	■		
27	CP1211	Bandon Dunmanway 110 kV circuit thermal capacity	Uprate/ modify	25.9	■	■	■
28	CP1212	Bandon Raffeen 110 kV circuit thermal capacity	Uprate/ modify	27.2	■	■	■
29	CP1224	Lysaghtstown 110 kV Station	New build connection	–		■	

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
				■	Cork, Cork	5		TSO	13/05/2020	03/10/2022	30/11/2024
				■	Tipperary	6		TSO	13/05/2020	14/07/2021	30/05/2024
		■			Cork	3		DSO	03/06/2020	29/04/2021	01/05/2025
				■	Tipperary	6		TSO	21/05/2020	18/07/2021	30/11/2024
				■	Limerick	4		TSO	21/05/2020	29/09/2023	31/12/2025
		■			Cork	6		DEV	05/11/2020	17/12/2021	31/08/2023
■		■			Cork	6		DSO	02/09/2020	07/10/2021	28/08/2023
				■	Cork	6		TSO	04/12/2020	04/11/2021	30/11/2024
				■	Cork	6		TSO	04/02/2021	03/02/2022	30/11/2024
				■	Tipperary	5		TSO	04/11/2021	25/10/2022	30/11/2023
		■			Cork	2		DEV	04/11/2021	30/04/2024	30/06/2025
				■	Kerry	4		TSO	16/06/2021	29/09/2023	28/11/2025
■					Cork	3		TSO	21/01/2022	30/09/2024	31/12/2026
■					Cork	3		TSO	28/01/2022	31/12/2024	31/12/2027
		■			Cork	3		TSO	03/02/2022	30/01/2023	30/11/2023

Table 5-3: Projects in the South-West and Mid-West

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
30	CP1215	Knockraha station Celtic IC Non contested works	New build connection	–	■	■	■
31	CP1209	Brown Boveri Circuit Breaker Replacements	Refurbish/replace	–	■		
32	CP1236	Timoney 110 kV Station	New build connection	–		■	
33	CP1246	Coomnaclohy 110 kV Station (Knocknamork Wind and Solar Park)	New build connection	–		■	
34	CP1320	Barrymore Cahir Knockraha 110 kV Line Uprate	Uprate/modify	63.5	■		
35	CP1245	Castletreasure 110 kV Station	New build connection	–		■	
36	CP1222	Knockraha 220 kV Transformer Replacement	Refurbish/replace	–	■		
37	CP1247	New Ballyvouskill 220-110 kV Transformer	New build capacity	–	■	■	
38	CP1240	Coumaclovane Solar Extension	New build connection	–		■	

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
		■	■		Cork	3		TSO	23/02/2022	04/07/2023	31/12/2026
				■	Cork	3		TSO	31/03/2022	22/12/2023	01/12/2028
		■			Tipperary	3		DEV	07/07/2022	23/11/2023	19/11/2024
		■			Cork	3		DEV	07/07/2022	28/02/2024	01/12/2024
■	■		■		Cork/ Tipperary	3		TSO	31/07/2022	31/12/2024	01/11/2028
		■			Cork	3		DEV	09/09/2022	29/03/2024	28/11/2025
				■	Cork	3		TSO	19/01/2022	15/12/2022	10/10/2025
■		■			Cork	3		TSO	10/05/2022	24/07/2023	01/12/2025
		■			Kerry	3		DEV	31/08/2022	31/05/2023	31/10/2023

5.4 The South-East, Mid-East and Dublin

Summary of projects	
New Build	49
Uprate/Modify	18
Refurbish/Replace	24
Other	5
Total	96



Active TDP projects by region

The South-East, Mid-East and Dublin has a wide variety of generation sources dispersed around the region including pumped storage, gas burning power stations, hydro, solar, waste to energy, and the 500 MW East West Interconnector (EWIC).

The greater Dublin area is the major load centre on the Irish transmission network.

As demand grows in Dublin, there are transmission capacity constraints getting power into and around Dublin. To address potential issues, the SEM Committee oversees the Single Electricity Market provisions locational capacity through the Capacity Market Auctions report⁵³.

The existing regional transmission network is comprised of 110 kV, 220 kV and 400 kV infrastructure. The transmission network has to meet a number of diverse power flows that can vary depending on:

- The generation dispatch;
- Network demand;
- Interconnector flows; and
- Network topology.

The network must accommodate high density demand in the area, and local generation exports. Additionally, the network can be subject to high inter-regional power transfers from both north to south and south to north.

⁵³ <https://www.sem-o.com/documents/general-publications/T-4-2024-2025-Final-Capacity-Auction-Results-Report.pdf>

The development of the transmission network in the area is characterised by the displacement of thermal generation in Dublin for wind generation resulting in power-transfer capacity and voltage support needs due to an increase in power flows in the region. This reason being is, in order to integrate higher RES, the energy that was supplied by the thermal plants in the Dublin area will be supplied by the onshore generation, coming from the West and South-West, and from the planned offshore wind generation connections in the Irish sea. The installation of offshore wind generation will at times reduce the impact of large transfers of power into the region from the West but creates other power-transfer capacity needs in Greater Dublin.

A third party is undertaking the development of an additional HVDC interconnector between Ireland and Great Britain, known as the Greenlink Interconnector. The connection point for the interconnector is in the south-east, by a new 220 kV GIS tailed station, Loughtown, which will connect into an existing bay in Great Island station. This interconnector is deemed a PCI by the European Commission. PCIs are intended to help the EU achieve its energy policy and climate objectives: affordable, secure and sustainable energy for all citizens. See Appendix A Irish Projects in European Plans for more information.

Network reinforcement will be required to cater for the power flows resulting from additional demand, generation and interconnection. This will enable the efficient transfer of power to the load centres of the eastern seaboard and the Dublin area.

In summary, there are reinforcement needs due to:

- Local constraints related to power-transfer capacity and voltage support needs;
- Asset condition; and
- Increase in RES connections, wind and solar farms.

The projects described in this section will enable the transmission network to accommodate more diverse power flows. They will also provide benefits to existing and future users of the transmission network and facilitate future regional load growth.

The TDP contains a list of the committed projects as at 21 December 2022. Indicative completion dates are included for these projects*.

We will continue to assess reinforcement needs in the South-East, Mid-East and Dublin and to identify candidate solutions as part of the Shaping Our Electricity Future update, aiming to find new projects required in the area beyond those already progressing through the grid development process.

The projects in the South-East, Mid-East and Dublin are discussed in more detail below.

Figure 5-3 shows the location of projects in Steps 4 to 6 in the South-East, Mid-East and Dublin.

Figure 5-3 (a): Planned network developments in Steps 4 to 6 in the South-East, Mid-East and Dublin





Figure 5-3 (b): Planned network developments in Steps 4 to 6 in Dublin



Reinforcement of the transmission network between Ireland and Wales

Project

- Greenlink Interconnector (CP1088)

Description

The drivers for this project are market integration, Security of Supply and RES integration.

Greenlink Interconnector is a proposed subsea and underground electricity interconnector cable between the electricity grids in Ireland and Great Britain, with a nominal capacity of 500 MW. This committed project brings significant benefits on both sides of the Irish Sea, Ireland and Wales, for integration of low carbon energy sources. In Ireland, it provides a link to EU and Nordic electricity market via Great Britain.

In Ireland, the project will consist of construction of a new 220 kV GIS tailed station, Loughtown, which will connect via approx. 400m of underground cable into an existing bay at Great Island 220 kV GIS Station. The converter hall will be built beside the new Loughtown station.

The Greenlink Interconnection Development will offer significant economic benefits, by:

- Improving Security of Supply, by:
 - diversifying energy sources; and
 - providing additional import and export capacity in both countries;
- Supporting the integration of additional renewable energy;
- Supporting EirGrid in meeting the targets set in the Climate Action Plan;
- Enabling an integrated European grid through Great Britain, by:
 - doubling the interconnection capacity between Ireland and Great Britain; and
 - contributing to each country's interconnection targets;
- Promoting energy price competition; and
- Supporting regional investment and jobs.

Reinforcement of the transmission network between Munster and Leinster

Project

- Grid Link Option 3 Regional Option Solution, comprising:
 - Series Compensation on the existing 400 kV overhead lines that cross the country from Moneypoint in County Clare to Dunstown in County Kildare and Woodland in County Meath. The series compensation devices are planned for:
 - Moneypoint 400 kV Station Series Compensation (CP0967)⁵⁴
 - Oldstreet 400 kV Station Series Compensation (CP0969)⁵⁵
 - Dunstown 400 kV Stations Series Compensation (CP0968)
 - Cross-Shannon 400 kV Cable (CP0970)⁵⁶

⁵⁴ This project is located in the South-West and Mid-West. It is included here as it is part of the Regional Solution.

⁵⁵ This project is located in the Border, Midlands and Mid-West. It is included here as it is part of the Regional Solution.

⁵⁶ This project is located in the South-West and Mid-West. It is included here as it is part of the Regional Solution.

Description

Facilitation of new generation together with existing generation and/or potential future interconnection in the south east introduces large regional electricity flows from the south towards the east coast of Ireland. These electricity flows cause three physical phenomena which must be addressed by the Grid Link project:

- Voltage collapse.
- Large phase angles.
- Thermal overloads.

For more information on the Regional Solution and the need for it please see the report prepared for the Government appointed Independent Expert Panel⁵⁷.

Reinforcement of the transmission network in the Midlands and South-East including Kildare Project

- Laois – Kilkenny Reinforcement Project (CP0585), comprising:
 - A new 400/110 kV station at Coolnabacky near Portlaoise (looped into the existing Dunstown – Moneypoint 400 kV and Athy – Portlaoise 110 kV lines);
 - A new 110 kV circuit from this station to a new 110 kV station at Ballyragget, Co. Kilkenny; and
 - A 110 kV uprate to the existing Ballyragget – Kilkenny line which is currently operated at 38 kV⁵⁸

Description

This project is required to address quality of supply issues and provide Security of Supply in Kilkenny, Carlow, Kildare and Laois.

The need for reinforcement arises due to a shortage of transmission capacity and voltage support across the region. The studies indicated potential violations of voltage limits throughout the area under single contingency conditions and loss of load violations in Kilkenny under maintenance-trip conditions.

The installation of a capacitor in Kilkenny 110 kV station was a short-term measure to maintain supply standards to the area. The Laois – Kilkenny reinforcement addresses the medium to long term quality and Security of Supply concerns.

⁵⁷ <https://www.eirgridgroup.com/site-files/library/EirGrid/Grid-Link-Report-to-IEP.pdf>

⁵⁸ <https://www.eirgridgroup.com/the-grid/projects/laois-kilkenny/the-project/>

Reinforcement of the transmission and distribution networks in the Greater Dublin Area

Projects

- Carrickmines 220/110 kV Station GIS Development (CP0580)
- Finglas 110 kV Station Redevelopment (CP0646)
- Inchicore 220 kV Station Upgrade (CP0692)
- Finglas 220 kV Station Upgrade (CP0792)
- Castlebagot New 220/110 kV Station (CP0872)⁵⁹
- Belcamp – Shellybanks New 220 kV Cable (CP0984)⁶⁰
- Irishtown, Shellybanks & connected stations 220 kV Protection Upgrade (CP1162)
- Poolbeg 220 kV Station project (CP1190)
- Belcamp 220 kV Busbar extension (CP1213)
- Darndale 110 kV Station Phase 2 (CP1230)

Description

The driver for these projects is Security of Supply.

The need for reinforcement arises due to local constraints on the transmission and distribution networks. There is a requirement for additional capacity at a number of locations in the Greater Dublin Area due to load growth. This is primarily at:

- The new Belcamp 220/110 kV station to the east of the existing Finglas 220/110 kV station; and
- The new Castlebagot (formerly West Dublin) 220/110 kV station between Inchicore and Maynooth 220/110 kV stations.

These needs were identified through co-ordinated TSO and DSO network studies. These studies indicated the overloading of a number of existing circuits and transformers under single contingency conditions.

Replacement of substation equipment works are progressing in Inchicore and Carrickmines 220/110 kV stations to address the condition and age of the assets. These stations are major bulk supply points in Dublin.

Inchicore and Finglas 220 kV stations also have their own specific needs. The need for these stations' upgrade projects arises due to a number of local constraints on the transmission network.

In the case of Inchicore, network studies have indicated that the capacity of some of the existing switchgear is close to being exceeded. While in Finglas 220 kV station, studies have indicated the potential for loss of load without this project.

The Belcamp – Shellybanks new 220 kV cable will provide a second 220 kV connection to the new Belcamp 220 kV station which lies to the east of Finglas 220/110 kV station.

Irishtown, Shellybank and connected 220 kV stations upgrade involves replacement of aged protection relays and/or teleprotection interfaces in Carrickmines, Irishtown, Poolbeg and Shellybanks 220 kV stations. This project does not include any additional protection scheme enhancement, as the teleprotection is over fibre and the circuits have already differential protection.

⁵⁹ <https://www.eirgridgroup.com/the-grid/projects/west-dublin/the-project/>

⁶⁰ This project also includes the fit-out of the 220 kV GIS station building built as part of CP0437.

Due to the specific needs that have been identified for Poolbeg 220 kV station which include refurbishment of the station from an asset age and condition perspective and the need to have connectivity for planned offshore, it has been concluded that to ensure continued safe and secure operation of the station, a new 220 kV GIS station should be built offline, and the circuits transferred over to the new station. Once the final circuit has been transferred to the new GIS building the existing AIS and GIS buildings can be fully decommissioned and demolished which will create space for future development.

The busbar construction at Belcamp and the planned use of the station has been changed, as it has been identified that Belcamp station will need to be expanded to accommodate all the expected future bay connections. This extension of the busbar will result in Belcamp 220 kV station having 18 line or transformer bays in an enhanced ring busbar configuration.

Darndale 110 kV Station phase 2 project is driven by Security of Supply. The project consists of three additional customer transformers connected to the spare bays at Darndale station. These new transformers are part of a connection offer of a large demand customer.

Reinforcement of the transmission network in the Greater Dublin Area Projects

- Corduff – Ryebrook 110 kV Line Uprate and Ryebrook 110 kV Station Busbar Uprate (CP0668)
- Maynooth 220 kV Station Reconfiguration (CP0808)
- Corduff 220 kV Station Deep Works (CP1113)
- Corduff – Finglas N0. 1 & 2 220 kV Line Refurbishment (1001)
- Corduff – Finglas 220 kV Protection Upgrade (CP1225)
- Carrickmines area 220 kV Ducts (CP1200)

Description

The driver for these projects is Security of Supply.

The need for Corduff – Ryebrook 110 kV line uprate and Ryebrook 110 kV busbar uprate projects arises due to local constraints on the transmission network. There is a requirement for additional capacity.

The capacity needs were identified by network studies which indicated overloading of the circuit under single contingency conditions.

The need for the Maynooth station project arises due to the condition and age of the assets, and local constraints. The project involves construction of new 220 kV and 110 kV busbars in a new GIS station. The new 220 kV and 110 kV busbars will be built in an enhanced ring configuration, and the short circuit rating of both busbars will be built to the current standard.

The need for deep reinforcements at Corduff 220 kV has been identified as a requirement of the connection of a new data centre facility. The current network in the area does not have the capacity to accommodate this new demand, as well as to allow planned maintenance of the 220/110 kV transformer at Corduff. The works at this station involves installation of new 220 kV coupler bay and its associated protection, new 220 kV transformer bay and its associated protection and a new 110 kV coupler bay with its associated protection.

Corduff – Finglas 220 kV line requires refurbishment to extend the life of the asset while ensuring Security of Supply. The main elements of refurbishment include tower painting, insulators and hardware replacement, labels and danger notices and repair/civil works to existing foundation shear blocks.

Corduff – Finglas 220 kV protection upgrade project is also driven by Security of Supply and involves replacement of aged protection relays and teleprotection interfaces in Finglas 220 kV station and Corduff 220 kV station.

In the course of discussions on offshore wind generation 220 kV cable connections to Carrickmines 220 kV station, EirGrid has been informed of the planned Glenamuck Distributor Road Scheme south of the existing Carrickmines 220 kV station. This new road scheme was identified as an opportunity to create underground access for cable circuits from the south to the nearby Carrickmines 220 kV station.

The installation of conduits for the 220 kV cables in the new road layout would avoid the future need to interfere with the new road scheme, thereby avoiding disruption and additional civil works costs. The new 220 kV underground cable opportunities provided by the ducts placed in the new road scheme will allow for future new transmission circuits that need to connect the Carrickmines substation to other parts of the network, or could be used for the connection of customers such as demand or generation, or new bulk supply points for distribution demand.

New and modified demand connections in the South-East, Mid-East and Dublin Projects

- Kellystown 220 kV New Station and loop-in to Maynooth – Woodland 220 kV circuit – Demand customer connection – (CP1029)
- Baroda 110 kV Station – Two new 110 kV DSO transformer bays – (CP0693)
- Oldbridge 110 kV Station AWP – New Enhanced Ring 110 kV GIS substation and loop-in to the existing Drybridge Platin 110 kV overhead line – (CP1090)
- Grangecastle South – new 110 kV enhanced ring GIS Station, Aungierstown, connected to the Castlebaggot 220/110 kV station via two separate underground cables (CP1102)
- Kishoge – New Kishoge 110 kV C-Type GIS station, looping into the Aungierstown – Castlebaggot 110 kV circuit via two underground cable circuits each approximately 1.7 km – (CP1175)
- Kilcarbery – New Kilcarbery 110 kV C-Type GIS station, looping into the Castlebaggot – Barnakyle 110 kV circuit via two underground cable circuits of approximately 0.25km (CP1188)
- Corduff – Platin 110 kV Line Conflict – Alteration of the circuit to facilitate construction of a large new demand on lands between Huntstown power station and Finglas 220 kV station in North Dublin – (CP1181)

- Corkagh 110 kV station – Transfer of load of a large demand customer from Kilmahud to Corkagh. The project includes 3 new 60 MVA transformers to be installed at customer facility and connected to the existing 3 spare bays at Corkagh 110 kV station – (CP1265)
- Belcamp BSP Transfer – Transfer the Newbury 110 kV station, currently supplied from Finglas station, to be fed from the new Belcamp 220/110 kV station – (CP1241)

Description

The driver for these projects is Security of Supply.

The need for reinforcement arises due to the requirement for new and modified demand connections. These are the shallow connections for a number of DSO connections and directly connected large scale transmission demand customers.

Reinforcement of the transmission network in South-East, Mid-East and Dublin Project

- East Meath – North Dublin Reinforcement (CP1021)
- Kildare – Meath Grid Upgrade (CP0966)
- Louth – Woodland 220 kV Line Uprate (CP1235)
- Replacement Woodland and Dunstown Station (CP1197)

Description

The drivers for these projects are Security of Supply, Market Integration and RES Integration.

The East Meath North Dublin Grid Upgrade project is a proposed electricity transmission development that will help transfer electricity from the Woodland 400 kV to a new 400 kV GIS busbar at Belcamp. That new 400 kV GIS busbar at Belcamp will be connected to the planned 220 kV GIS busbar extension being progressed under CP1213.

Kildare – Meath Grid Upgrade is also driven by Market Integration. The project consists of a suite of transmission network reinforcements centred on strengthening the network between the existing Dunstown 400 kV substation in County Kildare and the Woodland 400 kV substation in County Meath via a high voltage 400 kV underground cable. The project is essential to enable further development of renewable energy generation in line with Government policy to meet the 2030 targets. The project requires the installation of shunt reactors at each end of cable, one dynamic reactive support device and bays to be constructed on the 400 kV busbars in Woodland and Dunstown stations.

The need for Louth – Woodland 220 kV line uprate, involves an increase in network capacity between the existing Louth and Woodland 220 kV stations to facilitate power flows between Ireland and Northern Ireland and to integrate offshore renewable generation off the east coast.

Interconnection to other jurisdictions is essential to meet the Government's renewable energy target of 80% of electricity demand from renewable generation by 2030. This project is important for the integration of offshore renewable energy, as significant levels of new offshore wind generation off the east coast plan to connect to the transmission system in the coming years.

The circuit breakers to be replaced at Woodland and Dunstown have known reliability issues and two major failures in the past decade. Based on a 45-year life expectancy, they have reached the end of their life. Due to the criticality of these assets to the network, it is recommended by both TAO and TSO that these circuit breakers be removed from the system and replaced with new assets. This project will also include the replacement and refurbishment of assets associated with each bay to ensure reliable performance of these critical assets for the future.

Reinforcement of the transmission network in Louth

Projects

- Louth 275/220/110 kV Station Refurbishment – 110 kV Busbar Re-configuration and New Couplers (CP0799)
- Drybridge and Connected Stations 220-110 kV Protection Upgrade (CP1115)

Description

The driver for these projects is Security of Supply.

There are two areas of need for the project:

- The need for network reinforcement; and
- The need for refurbishment works due to the condition of the 220 kV and 110 kV assets.

The need for reinforcement arises due to:

- A shortage of transmission capacity; and
- Possible overload of the 110 kV busbar and some circuit breakers.

In addition, the station works also involve refurbishment works due to the condition of the assets and replacement of strung bay conductors with tubular conductor to accommodate mechanical forces from short circuit currents. These works will be undertaken at the same time as the uprating works.

The Baltrasna, Drybridge and Gorman 110 kV stations project includes the replacement of older protection relays and teleprotection interfaces, as well as protection system upgrade work to ensure compliance with transmission system protection best practice.

The project also caters for connection of two new solar PV connections at Deenes and Garballagh. Critical components of the project scope include the installation of the 110 kV bus zone protection scheme at Baltrasna station and the installation of new current and voltage transformers at Drybridge bays T141 and T142.

Reinforcement of the transmission network in Meath

Projects

- Gorman and Connected Station 220-110 kV Protection Upgrade (CP1109)
- Woodland Station 400-220 kV Protection Upgrade (CP1110)
- Platin and Connected Stations 220-110 kV Protection Upgrade (CP1114)
- Woodland 400 kV Station Redevelopment (CP1194)
- Gorman – Platin 110 kV Line Uprate (CP1166)
- Drybridge – Platin 110 kV Line Uprate (CP1167)
- Kinnegad 110 kV station, Derryiron 110 kV bay conductor uprate (CP1144)
- Blundelstown DSO Project (CP1243)

Description

The driver for the protection upgrade projects is Security of Supply and involve replacement of aged protection relays and teleprotection interfaces in order to mitigate sub-optimal performance of the protection system. These protection system upgrade works are also necessary to ensure compliance with transmission system protection best practices.

Gorman 220 kV, Navan and Meath Hill 110 kV stations project includes the installation of CT/VT units at Navan station.

Woodland station project includes the replacement of protection relays at Woodland 400 kV station.

The Platin and Gorman 110 kV protection upgrade project includes the installation of the Platin 110 kV busbar area protection scheme and extension work to its building, to make room for the new protection relay panels.

The redevelopment of Woodland station is driven by Security of Supply. Woodland is one of the most important stations on the transmission system. It has several major 400 kV and 220 kV circuits connected and several grid infrastructure developments are planned to connect in the coming years.

At times of high-power flow through Woodland 400 kV station, there is potential for a significant Security of Supply issue to arise from single contingencies, such as unexpected loss of a single circuit or piece of equipment, resulting in voltage collapse of the transmission system. To address these issues, this project has received approval for an in-situ reconfiguration of the existing 400 kV AIS double busbar to ring busbar configuration.

Gorman – Platin 110 kV line uprate is necessary as the circuit will not be adequate for the connection of the large new demand. The uprate will also help to accommodate large power flows along the Gorman – Platin 110 kV circuit in the event of an unexpected loss of the Corduff – Platin 110 kV line while the Drybridge – Oldbridge 110 kV line is on outage or vice versa.

The uprate of Drybridge – Platin 110 kV will help to accommodate increased power flows that can occur with the maintenance and trip combination of the Corduff – Platin 110 kV line along with either the Gorman – Platin 110 kV circuit or the Gorman 220/110 kV transformer.

Kinnegad 110 kV station uprate is driven by Security of Supply and RES integration. This uprate was part of wider site related connection equipment work being carried out to allow for the connection a new windfarm at Cloncreen, Co. Offaly. The uprate of the bay conductor equipment at Kinnegad, in the Derryiron 110 kV bay, will allow the connection of the windfarm and the circulation of large power flow along Derryiron – Kinnegad 110 kV circuit in case the loss of the Derryiron – Timahoe North 110 kV circuit.

Blundelstown DSO Project is driven by Security of Supply. This project involves the connection of two new transformers to the transmission system at the new Blundelstown 110 kV station. The new transformers will facilitate a demand increase for an existing DSO large customer. The scope of this project also includes a busbar extension and space provision to an 8-bay enhanced ring station at Blundelstown 110 kV station.

Reinforcement and Line Diversion of the transmission network in Kildare Projects

- New 400 kV Strategic Spare Transformer (CP1092)
- Dunstown Station 400-220 kV Protection Upgrade (CP1108)
- Customer 110 kV Line Diversion (CP1277)

Description

The driver for these projects is Security of Supply.

During 2019, problems arose with the two existing 400 kV/220 kV transformers at Moneypoint 400 kV Station, these included a major failure of transformer T4201 and the placing of an operational restriction on transformer T4202. These incidents coincided with a significant number of scheduled outages at Moneypoint which were required to facilitate transfer to the new GIS Station. The financial impact on Dispatch Balancing Costs (DBC) and Wind Constraints as result of these outages and restrictions has been significant due the increase in cost of running more expensive generation, predominantly Tarbert Power Station. The new 400 kV transformer will be custom built, capable of being transported and installed, if required, in any of the 400 kV/220 kV stations in Ireland.

The needs for a protection relay replacement at Dunstown station are based on the age profile of existing devices, to mitigate against sub optimal protection system performance and to support the anticipated high power-transfer capacity of onshore windfarms in the western region of the island. This project involves replacement of 8 x protection relays in Dunstown 400 kV station.

A large customer has requested a significant alteration to the existing Maynooth – Ryebrook and Dunfirth – Rinawade 110 kV double circuit lines to facilitate future developments at their facilities. A Circuit Alteration Request (CAR) was submitted by ESB Networks to EirGrid. As TSO, EirGrid has assessed the impact of this CAR and will progress the project forward thorough its six-step grid development framework.

Reinforcement of the transmission network in Carlow Projects

- Carlow, Kellis 110 kV Protection Upgrade (CP1137)
- Athy, Carlow and Connected 110 kV Stations Protection Upgrade (CP1140)
- Kellis Station 220-110 kV Protection Upgrade (CP1141)

Description

The driver for these projects is Security of Supply.

The three projects mentioned involve replacement of aged protection relays and teleprotection interfaces. Kellis station is part of the 220 kV circuit from Great Island to Dunstown, and the refurbishment of the stations in the Carlow network will support increased power flows from Great Island due to the connection of the Greenlink Interconnector in Co. Wexford.

The Protection Upgrade at Carlow and Kellis stations includes the installation of a new 110 kV bus bar protection scheme and a new combined Current transformer/Voltage transformer (CT/VT) at Carlow 110 kV stations. It is also possible that the control room at Carlow 110 kV station may not have adequate space for new relay cabinets, so provision has been made to extend the control room if required. This project also includes wrapping of optical fibre on the Carlow – Kellis 110 kV No. 1 circuit to allow teleprotection and differential protection on both Carlow – Kellis 110 kV circuits.

The second project in the list shown above, CP1140, involves replacement of aged protection relays in Athy, Carlow, Pollaphuca and Stratford 110 kV stations. This project includes the installation of a new duplicate distance relay in Athy, new Current and Voltage transformers in Carlow station on the Pollaphuca/Stratford bay and also in Pollaphuca station on the Carlow/Stratford bay.

The protection upgrade at Kellis 220/110 kV station is driven by the age profile of the existing devices.

Reinforcement of the transmission network in Wexford

Projects

- Crane – Wexford 110 kV Thermal Uprate (CP1172)
- Great Island 220/110 kV Transformer Uprates (CP1242)

Description

The drivers for this project are Security of Supply and RES Integration.

The existing Crane – Wexford 110 kV circuit is a key component in the transmission of this power, supplying local transmission stations, facilitating power flows through the South-East in either direction, i.e. towards the East/Dublin or South/Cork, and also facilitating the connection of renewable generation in County Wexford.

Increased RES generation introduces large power flows at times of high renewable generation output. Under contingency conditions, system analysis indicates that power flows along the Crane – Wexford 110 kV circuit exceeding the thermal rating of the circuit can occur due to an unplanned loss of either Great Island – Lodgewood 220 kV circuit or Great Island – Rosspile 110 kV circuit, which is in breach of the TSSPS. Increasing the capacity of Crane – Wexford 110 kV will help to cater for the expected increase in power flow for this area.

The transformer uprates at Great Island project involves the replacement of two transformers. Additionally, an asset condition need has been identified regarding both transformers which are near the end of their service lives and show deteriorating condition.

The two 220/110 kV transformers at Great Island station have a rating of 125 MVA and they have a low 30-minute overload capability of 110% and 130% respectively. The network capacity need concerns the transfer of power between the 220 kV and 110 kV busbars at Great Island station. The unplanned loss of the Cullenagh – Great Island 220 kV circuit in scenarios when interconnectors are exporting power in high renewables cases or importing power in low renewables cases can cause power flows on each of the 220/110 kV transformers at Great Island in excess of their respective overload capabilities.

Reinforcement of the transmission network in Waterford

Projects

- Cullenagh and Connected stations Protection Upgrade (CP1159)
- Butlerstown, Killoteran and Waterford 110 kV Protection Upgrade (CP1163)

Description

The driver for these projects is Security of Supply.

This project involves replacement of aged protection relays and teleprotection interface in: Cullenagh 220 kV station and Ballydine, Butlerstown and Dungarvan 110 kV stations for CP1159; and replacement in Cullenagh 220 kV station, Butlertown, Killoteran and Waterford 110 kV stations.

Protection system enhancement works are also required in both projects to ensure compliance with best practice in transmission system protection.

The existing power line carrier teleprotection on the Cullenagh – Dungarvan 110 kV line will be transferred to fibre based teleprotection interfaces utilising the existing fibre network between these stations.

Installation of a new bus-bar protection scheme in Killoteran station is also included in CP1163.

Reinforcement of the transmission network in Kerry

Project

- Glencloosagh Phase 1 – Rotating Stabiliser (CP1173)

Description

The driver for this project is Security of Supply.

Glencloosagh Phase 1 – Rotating stabiliser project is driven by Security of Supply; this will allow the customer to connect their 8 MVA stabiliser to the transmission system in Co. Kerry. The method of connection will be a new single bay 220 kV AIS station at the Customer's Facility with a tailed connection into Kilpaddoge 220/110 kV Station via UGC.

New generation and battery connections in the South-East, Mid-East and Dublin Projects

- Oriel Offshore Windfarm – New 220 kV GIS Station looping into the existing Louth – Woodland 220 kV (CP0749)
- Tullabeg 110 kV New Station and loop-in to Banoge – Crane 110 kV circuit – Solar farm connection – (CP1068)
- Timahoe North 110 kV New Station and loop-in to Derryiron – Maynooth 110 kV circuit – Solar Farm Connection – (CP1041)
- Woodhouse 110 kV Station – New 110 kV transformer bay – Knocknamona Windfarm Connection – (CP1052)
- Harristown 110 kV New Station and loop-in to Kinnegad – Dunfirth Tee – Rinawade 110 kV circuit – Solar Farm Connection – (CP1055)
- Blundelstown 110 kV New Station and loop-in to Corduff – Mullingar 110 kV circuit – Solar Farm Connection – (CP1020)
- Poolbeg BESS & FlexGen – Direct connection, under-the-fence, via a ganged transformer arrangement cabled into an existing AIS bay in Poolbeg 220 kV Station – (CP1105)
- Gaskinstown Solar Farm – New 4 Bay C-Type 110 kV AIS Station, Deenes, connected by UGC and looped into the existing Baltrasna – Drybridge 110 kV – (CP1136)
- Rathnaskilloge Solar Farm – New 110 kV GIS station, Rathnaskilloge, to be looped into the existing Cullenagh – Dungarvan 110 kV circuit – (CP1145)
- Moanvane Windfarm – New single bay 110 kV AIS station called Bogtown, to be connected into a new bay in Mount Lucas 110 kV Station via approximately 10 km of UGC – (CP1201)
- Harlockstown Solar Farm – To be connected to the new Gallanstown 110 kV station. Gallanstown station is looped into the Corduff – Platin 110 kV circuit – (CP1248)
- Porterstown Battery Storage Phase 2 – To be connected via an over the fence into an existing transformer at Killeel 110 kV – (CP1249)
- North Arklow Solar plus storage facility – new AIS single bay 110 kV station with a tailed connection to Arklow 220/110 kV Station via UGC – (CP1244)
- Tracystown Solar Park – New C-type bay AIS station, Dennistown 110 kV station, tailed into the existing Wexford 110 kV station via approximately 9.8 km of UGC – (CP1260)
- Grahormick Solar Facility – New single bay AIS station, Grahormick 110 kV station, tailed via a new 8.5 km UGC into the new Dennistown 110 kV station, which in turn is tailed into the existing Wexford 110 kV station – (CP1261)
- The Dell Solar – New build connection via the DSO Crory 20 kV network from the Lodgewood 110 kV busbar. A new 110 kV 31.5 MVA transformer is required to facilitate this connection – (CP1269)
- Ballymanus Wind Farm – Connection via DSO Network into the existing Arklow 220 kV GIS station via a terminal remote unit and a 110 kV DSO transformer bay – (CP1267)
- Dysart Solar Farm – Connection via DSO Network into the existing Dunfirth 110 kV via 1.3 km UGC. Dunfirth transformers will be uprated and there will be associated protection upgrades – (CP1268)

Description

The driver for these projects is the integration of RES. These projects are needed to connect new wind farm, solar farm and battery connections.

Storage projects are also driven by Security of Supply, by:

- Improving competition and economic operation by removing operational constraints; and
- Providing the required flexibility for increased renewable generation.

Offshore projects in Wicklow and Dublin Projects

- Codling Wind Park (CP1394)
- Arklow Bank Wind Park (CP1396)
- North Irish Sea Array (CP1397)
- Dublin Array (CP1398)

Description

The driver for these projects is RES Integration.

In line with the CRU decision on Offshore Connection Policy (CRU2022/968⁶¹), applicable to Offshore Phase 1 projects, Offshore projects received capital approval in advance of the connection offers in order to prioritise and expedite the design review process through the use of Advanced Work Packages (AWP) to ensure the target Project Agreement dates of December 2024 are achieved. These AWP's will allow EirGrid to review the Phase 1 projects concepts designs in advance of the ORESS-1 auction.

Codling Wind Park and Arklow Bank are proposed developments of offshore wind farms located off the coast of County Wicklow. North Irish Sea Array and Dublin Array are proposed developments of offshore wind farms located off the coast of County Dublin.

The new customer stations tailed to existing station in the network and their connections from the offshore platforms to the onshore stations will be reported in future TDPs when connection offers are completed.

Cable replacement in Dublin Projects

- Carrickmines – Poolbeg 220 kV Cable Replacement (CP1146)
- Inchicore – Poolbeg #1 220 kV Cable Replacement (CP1157)
- Inchicore – Poolbeg #2 220 kV Cable Replacement (CP1150)
- North Wall – Poolbeg 220 kV Cable Replacement (CP1216)
- Finglas – North Wall 220 kV Cable Replacement (CP1100)

Description

The driver for these projects is Security of Supply.

Carrickmines – Poolbeg 220 kV, Inchicore – Poolbeg 220 kV Circuit No. 1 and Inchicore – Poolbeg 220 kV Circuit No. 2 have approximately 14.5 km, 12.5 km and 11.3 km long lines, respectively, and are low pressure Self-Contained Fluid (SCFF) cable circuit. The need to replace the existing cables of these circuits is due to their condition and age, and also a requirement of EirGrid's Cable Maintenance Policy to replace all Fluid Filled cables on the transmission system.

61 <https://www.cru.ie/publications/27340/>

This strategy has been communicated to the regulator within PR4 and PR5 submissions. The uprating of these circuits to 570 MVA summer is required in the context of Shaping our Electricity Future.

North Wall – Poolbeg 220 kV and Finglas – North Wall 220 kV circuits are approximately 4.6 km and 11.9 km in length respectively and they are High Pressure Fluid Filled (HPFF) cable circuits in their entirety which means that the cables are contained within a steel pipe and surrounded by insulating fluid. As is the case with other cable replacements described above, the need to replace the existing cables of these circuits it is due to their condition and age, but it is also a requirement of EirGrid's Cable Maintenance Policy to replace all Fluid Filled cables on the network.

New generation connections in Dublin Projects

- Corduff FlexGen – Connection of a generation facility into Corduff 220/110 kV station – (CP1103)
- Irishtown FlexGen-BESS – Connection of two facilities; one OCGT and one BESS, via an under the fence connection to a new bay in the existing Irishtown 220 kV GIS station (CP1117)
- Mooretown 220 kV Station – Increase the MIC at the Huntstown site. Connection Method would be via a new GIS 220 kV 8-bay enhanced ring station, Mooretown 220 kV Station, looped into the existing Finglas–Huntstown B 220 kV Circuit and Corduff–Huntstown A 220 kV Circuit, while also forming two new 220 kV circuits Huntstown A – Mooretown and Huntstown B – Mooretown (CP1183)
- P481 Greener Ideas Profile Park – Generation facilities to be connected via a new single bay 110 kV AIS Station tailed to Barnakyle 110 kV via approx. 0.5km of UGC Circuit (CP1256)

Other approved projects

In addition to the network reinforcement projects described above, there are also other projects in the South-East, Mid-East and Dublin, namely:

- Finglas 220/110 kV Station – Pantograph replacement (CP1064);
- Oldstreet – Woodland 400 kV Line Refurbishment (CP0825);
- Maynooth – Woodland 220 kV Line Uprate (CP0869);
- Maynooth – Turlough Hill 220 kV Line Refurbishment (CP0823);
- Great Island – Kellis 220 kV Line Refurbishment (CP0866);
- Maynooth – Turlough Hill 220 kV Circuit Power Line Carrier (PLC) Replacement (CP1022);
- Belcamp Land Acquisition – requirement to accommodate potential future grid development (CP1154)
- Kilshane Land Acquisition – requirement to accommodate a thermal generation plan or other network assets adjacent or proximate to Fingal station (CP1185);

- Physical security of transmission stations, Dublin region (CP1122) – Design and installation of lighting system, video surveillance at entrances gates in Carrickmines, Dunstown and Woodland; and anti-climb features at Dunstown station entrance; and
- Finglas Land Acquisition – requirement to accommodate a thermal generation plan or other network assets adjacent or proximate to Fingal station (CP1045)

5.4.1 Summary of projects in the South-East, Mid-East and Dublin

There are 62 projects in the South-East, Mid-East and Dublin region. These are listed in Table 5-4 below.

Table 5-4: Projects in the South-East, Mid-East and Dublin

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
1	CP0668	Corduff – Ryebrook 110 kV Line Uprate	Uprate/ modify	14	■		
2	CP0646	Finglas 110 kV Station Redevelopment	Refurbish/ replace	–	■		
3	CP0580	Carrickmines 220 kV GIS Development	New build capacity	–	■		
4	CP0792	Finglas 220 kV Reconfiguration Project	Uprate/ modify	–	■		
5	CP0585	Laois-Kilkenny (Coolnabacky) 400 kV Station – New Station & Associated Lines & Station Works	New build capacity	30+ 22 ⁶²	■		
6	CP0825	Oldstreet – Woodland 400 kV Line Refurbishment	Refurbish/ replace	126	■		
7	CP0692	Inchicore 220 kV GIS Station Upgrade	Uprate/ modify	–	■		
8	CP0869	Maynooth – Woodland 220 kV Line Uprate	Uprate/ modify	22	■		
9	CP0872	West Dublin New 220-220 kV Station (Castlebagot 220 kV Station)	New build connection	–	■		
10	CP0808	Maynooth 220 kV Station Reconfiguration	Uprate/ modify	–	■		
11	CP0984	Belcamp – Shellybanks 220 kV New Cable	New build capacity	10	■		
12	CP0968	Dunstown 400 kV Series Capacitor	New build capacity	–	■	■	
13	CP0823	Maynooth – Turlough Hill 220 kV Line Refurbishment	Refurbish/ replace	53	■		

62 30 km is the length of the proposed new 110 kV circuit between the proposed new Coolnabacky 400/110 kV station near Portlaoise and the proposed new 110 kV station at Ballyragget. 22 km is the length of the proposed 110 kV uprate to the existing Ballyragget – Kilkenny line which is currently operated at 38 kV.

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
	■				Dublin, Kildare	6		TSO	29/04/2011	10/05/2013	30/11/2023
	■			■	Dublin	6		TSO	28/08/2009	24/08/2012	01/12/2023
	■			■	Dublin	6		TSO	22/03/2012	14/02/2012	01/12/2023
	■			■	Dublin	6		TSO	22/04/2015	11/03/2018	17/11/2023
	■				Laois, Kilkenny	6		TSO	16/04/2008	17/06/2016	30/06/2025
				■	Galway, Tipperary, Offaly, Kildare, Meath	6		TSO	25/03/2013	19/03/2015	29/12/2023
	■			■	Dublin	6		TSO	21/09/2016	20/03/2019	30/11/2026
	■			■	Kildare, Dublin	6		TSO	15/08/2019	17/12/2020	30/11/2024
	■	■			Dublin	6		TSO	07/07/2014	17/05/2017	31/10/2023
	■			■	Kildare	5		TSO	16/03/2021	29/12/2023	30/11/2027
	■				Dublin	6		TSO	01/07/2016	15/07/2020	31/07/2024
■	■				Kildare	5	■	TSO	15/06/2016	13/06/2023	31/12/2025
				■	Kildare, Wicklow	5		TSO	30/06/2017	29/12/2023	01/11/2026

Table 5-4: Projects in the South-East, Mid-East and Dublin

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
14	CP0866	Great Island – Kellis 220 kV Line Refurbishment	Refurbish/ replace	70	■		
15	CP0967	Moneypoint 400 kV Series Capacitor ⁶³	New build capacity	–	■	■	
16	CP0970	Cross-Shannon 400 kV Cable ⁶⁴	New build capacity	6	■	■	
17	CP0969	Oldstreet-Woodland 400 kV Series Compensation ⁶⁵	New build capacity	–	■	■	
18	CP1020	Blundelstown 110 kV Station (South Meath Solar Farm)	New build connection	–		■	
19	CP1022	Maynooth – Turlough Hill PLC Replacement	Refurbish/ replace	53	■		
20	CP1041	Timahoe North Solar Farm	New build connection	–		■	
21	CP1052	Knocknamona Wind Farm	New build connection	–		■	
22	CP1055	Harristown Solar Farm	New build connection	–		■	
23	CP0799	Louth 220 kV Station Refurbishment	Uprate/ modify	–	■		
24	CP1029	Capital Project 1029	New build connection	–	■		
25	CP0693	Baroda 110 kV Station – 2 x 110 kV transformer bays DSO	Uprate/ modify	–	■		
26	CP1068	Tullabeg Solar 110 kV Station	New build connection	–		■	

⁶³ This project is located in the South-West and Mid-West. It is included here as it is part of the Regional Solution.

⁶⁴ This project is located in the South-West and Mid-West. It is included here as it is part of the Regional Solution.

⁶⁵ This project is located in the Border, Midlands and West. It is included here as it is part of the Regional Solution.

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
				■	Wexford, Carlow	5		TSO	16/11/2022	30/06/2025	30/11/2029
■	■				Clare	4	■	TSO	31/08/2015	01/12/2023	31/12/2025
■	■				Clare, Kerry	4	■	TSO	21/09/2016	28/02/2023	30/11/2025
■	■				Galway	4	■	TSO	15/06/2016	01/12/2023	31/12/2025
		■			Meath	6		DEV	26/01/2018	11/09/2020	04/05/2023
				■	Kildare, Wicklow	6		TSO	22/06/2018	06/12/2019	29/12/2023
		■			Kildare	3		DEV	06/11/2018	21/10/2021	24/04/2024
		■			Waterford	3		DEV	22/10/2018	17/12/2020	18/12/2023
		■			Meath	6		DEV	20/12/2018	19/11/2020	01/12/2025
	■			■	Louth	6		TSO	25/09/2013	12/03/2020	28/02/2029
		■			Kildare	6		DEV	15/05/2019	31/10/2019	27/01/2023
		■			Kildare	4		DSO	14/06/2019	10/01/2020	30/03/2025
		■			Wexford	6		DEV	05/09/2019	01/04/2021	23/10/2023

Table 5-4: Projects in the South-East, Mid-East and Dublin

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
27	CP1064	Finglas Pantograph Replacement Project	Refurbish/ replace	–	■		
28	CP1090	Rathmullan 110 kV Station	New build connection	–	■		
29	CP1088	Greenlink Interconnector	New build connection	–	■	■	■
30	CP1117	Irishtown FlexGen – BESS	New build connection	–	■		
31	CP1115	Drybridge and Connected Stations 110 kV Protection Upgrade	Refurbish/ replace	–	■		
32	CP1108	Dunstown Station 400 – 220 kV Protection Upgrade	Refurbish/ replace	–	■		
33	CP1105	Poolbeg BESS	New build connection	–	■	■	
34	CP1110	Woodland Station 400 – 220 kV Protection Upgrade	Uprate/ modify	–	■		
35	CP1103	Corduff FlexGen	New build connection	–	■		
36	CP1113	Corduff 220 kV Station Deep Works	New build capacity	–	■		
37	CP0749	Oriel Offshore Windfarm	New build connection	–		■	
38	CP1092	New 400 kV Strategic Spare Transformer	New build capacity	–	■		
39	CP1102	Grangecastle South	New build connection	–	■		
40	CP1109	Gorman and Connected Stations 220 – 110 kV Protection Upgrade	Refurbish/ replace	–	■		
41	CP1114	Platin and Connected Stations 220 – 110 kV Protection Upgrade	Refurbish/ replace	–	■		

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
				■	Dublin	6		TSO	20/12/2019	12/11/2020	02/02/2024
		■			Meath	6		DEV	27/11/2020	18/06/2021	02/07/2023
■		■	■		Wexford	6		DEV	20/02/2020	22/06/2022	09/04/2024
		■			Dublin	6		DEV	25/06/2020	22/04/2022	31/08/2023
				■	Louth	6		TSO	13/05/2020	16/04/2021	30/11/2023
				■	Kildare	6		TSO	18/05/2020	19/03/2021	30/11/2023
		■			Dublin	3		DEV	16/04/2020	22/04/2022	29/06/2023
				■	Meath	6		TSO	18/05/2020	19/03/2021	30/11/2023
		■			Dublin	3		DEV	02/04/2020	26/07/2022	31/10/2023
	■	■			Dublin	6		TSO	17/08/2020	02/06/2021	30/04/2024
		■			Louth	4		DEV	27/03/2020	31/12/2024	30/06/2027
■	■	■			Kildare	6		TSO	29/01/2020	15/12/2022	27/06/2025
		■			Dublin	3		DEV	13/05/2020	08/10/2021	24/02/2023
				■	Meath	6		TSO	13/05/2020	25/06/2021	30/11/2023
				■	Meath	6		TSO	13/05/2020	18/08/2021	30/11/2023

Table 5-4: Projects in the South-East, Mid-East and Dublin

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
42	CP1136	Deenes 110 kV Station – Gaskinstown Solar Farm	New build connection	–	■		
43	CP1137	Carlow, Kellis 110 kV Protection Upgrade	Refurbish/replace	–	■		
44	CP1140	Athy, Carlow and connected stations 110 kV Protection Upgrade	Refurbish/replace	–	■		
45	CP1141	Kellis Station 220 & 110 kV Protection Upgrade	Refurbish/replace	–	■		
46	CP1154	Belcamp Land Acquisition	Other	–	■		
47	CP1159	Cullenagh and Connected stations Protection Upgrade	Refurbish/replace	–	■		
48	CP1145	Rathnaskilloge Solar Farm	New build connection	–	■		
49	CP1162	Irishtown, Shellybanks and connected stations 220 kV protection upgrade	Refurbish/replace	–			
50	CP1173	Glencloosagh Phase 1 – Rotating Stabiliser	Uprate/modify	–			
51	CP1190	Poolbeg 220 kV Station	New build connection	–			
52	CP1175	Kishoge 110 kV Station	New build connection	–			
53	CP1188	Kilcarbery	New build connection	–			
54	CP1201	Bogtown 110 kV Station	New build connection	–	■		
55	CP1163	Butlerstown, Killoferan and Waterford 110 kV protection upgrade	Refurbish/replace	–			
56	CP1194	Woodland 400 kV Station Redevelopment	Uprate/modify	–			

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
		■			Meath	4		DEV	19/11/2020	14/12/2022	07/05/2024
				■	Carlow	6		TSO	01/10/2020	01/09/2021	30/11/2023
				■	Carlow	6		TSO	01/10/2020	16/07/2021	30/11/2023
				■	Carlow	6		TSO	01/10/2020	01/09/2021	30/11/2024
					Dublin	4		TSO	19/11/2020	29/09/2023	
				■	Waterford	6		TSO	04/12/2020	04/11/2021	30/11/2025
	■			■	Waterford	3		DEV	07/01/2021	28/11/2022	29/09/2023
			■		Dublin	6		TAO	04/02/2021	04/11/2021	30/11/2026
					Kerry	3		TAO	06/05/2021	31/10/2023	30/07/2025
	■				Dublin	3		TSO	16/12/2021	27/09/2024	20/07/2027
	■				Dublin	6		DEV	09/08/2021	08/05/2023	26/06/2024
	■				Dublin	6		DEV	08/07/2021	15/02/2023	01/10/2024
	■			■	Offaly	3		DEV	07/10/2021	10/11/2022	11/10/2023
			■		Waterford	6		TSO	04/02/2021	04/11/2021	30/11/2024
					Meath	3		TSO	21/03/2022	04/12/2023	30/11/2028

Table 5-4: Projects in the South-East, Mid-East and Dublin

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
57	CP1122	Physical Security of Transmission Stations – Dublin Region	Other	–			
58	CP0966	Kildare Meath Grid Upgrade	New build capacity	50	■	■	
59	CP1146	Carrickmines – Poolbeg 220 kV Cable Replacement	Refurbish/replace	20			
60	CP1157	Inchicore – Poolbeg #1 220 kV Cable Replacement	Refurbish/replace	18			
61	CP1150	Inchicore – Poolbeg #2 220 kV Cable Replacement	Refurbish/replace	16			
62	CP1045	Finglas Land Acquisition	Other	–			
63	CP1213	Belcamp 220 kV Busbar Extension	Uprate/modify	–			
64	CP1172	Crane – Wexford 110 kV Circuit Thermal Capacity	Uprate/modify	22.8	■		■
65	CP1166	Gorman – Platin 110 kV line uprate	Uprate/modify	19.4			■
66	CP1167	Drybridge – Oldbridge – Platin 110 kV line uprate	Uprate/modify	5.3			
67	CP1181	Corduff Platin 110 kV Line Conflict	Other	–			
68	CP1144	Kinnegad 110 kV station, Derryiron 110 kV bay conductor uprate	Uprate/modify	–			
69	CP1216	Poolbeg – North Wall 220 kV Cable Replacement	Refurbish/replace	4.6			
70	CP1183	Mooretown 220 kV Station	New build connection	–			
71	CP1235	Louth – Woodland 220 kV Uprate	Uprate/modify	61.2	■		■

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
					Dublin	5		TSO	01/09/2020	29/12/2023	30/12/2025
■				■	Meath, Kildare, Dublin	4		TSO	24/03/2021	26/04/2024	24/09/2028
			■		Dublin	3		TSO	16/12/2021	18/12/2025	20/06/2029
			■		Dublin	3		TSO	20/12/2021	18/12/2025	31/12/2029
			■		Dublin	3		TSO	16/12/2021	18/12/2025	28/09/2029
					Finglas	3		TSO	30/06/2021		
	■				Belcamp	3		TSO	15/12/2021	07/12/2023	17/09/2027
■				■	Wexford	5		TSO	17/06/2021	30/09/2023	30/11/2025
■					Rathmullan, Donore Road Drogheda	5		TSO	18/03/2021	30/09/2023	29/11/2024
	■				Louth	5		TSO	18/03/2021	30/09/2023	29/11/2024
					Dublin, Meath	6		TSO	30/08/2021	06/05/2022	30/06/2023
					Meath	6		TSO	22/01/2021	04/11/2021	29/11/2025
			■		Dublin	3		TSO	31/05/2022	19/09/2024	01/12/2028
	■				Dublin	3		DEV	06/04/2022	28/04/2023	01/12/2025
		■		■	Louth, Meath	3		TSO	28/04/2022	02/06/2025	01/12/2029

Table 5-4: Projects in the South-East, Mid-East and Dublin

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
72	CP1256	Greener Ideas Profile Park	New build connection	–			
73	CP1248	Harlockstown Solar (Gallanstown Ext)	New build connection	–	■		
74	CP1249	Porterstown Battery Phase2	New build connection	–	■	■	
75	CP1021	East Meath – North Dublin Reinforcement	New build capacity	45		■	■
76	CP1230	Darndale Phase 2 – 3 110 kV customer connections in Darndale 110 kV station	New build connection	–			
77	CP1100	Finglas – North Wall Cable Replacement	Refurbish/replace	11.9			
78	CP1265	Corkagh 110 kV Station Phase 2	New build connection	–			
79	CP1243	Blundelstown 110 kV Station – 2 New DSO Transformer Bays	New build connection	–			
80	CP1001	Corduff – Finglas 1 & 2 220 kV line refurbishment	Refurbish/replace	3.7			
81	CP1225	Finglas Corduff 220 kV Protection Upgrade	Refurbish/replace	–			
82	CP1244	North Arklow Solar Plus Storage	New build connection	–	■	■	
83	CP1200	Carrickmines Area 220 kV Cable Ducting	New build capacity	2.5	■		■
84	CP1241	Belcamp BSP Transfer	Other	–			
85	CP1260	Tracystown Solar	New build connection	–	■		
86	CP1261	Grahormick Solar	New build connection	–	■		

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
	■				Dublin	3		DEV	05/05/2022	03/10/2023	01/07/2024
	■			■	Meath	3		DEV	01/06/2022	24/02/2023	28/07/2023
	■			■	Kildare	3		DEV	01/06/2022	03/07/2023	24/03/2025
					Meath, Dublin	3		TSO	07/06/2022	30/06/2025	31/12/2029
	■				Dublin	6		TSO	17/06/2022	19/12/2022	22/12/2023
■			■		Dublin	3		TSO	28/06/2022	19/12/2024	30/06/2029
	■				Dublin	3		TSO	26/07/2022	31/10/2023	04/06/2024
	■				Meath	3		DSO	14/09/2022	03/07/2023	30/09/2025
■					Dublin	3		TSO	10/11/2022	28/06/2024	01/12/2027
			■		Dublin	3		TSO	03/02/2022	13/12/2022	30/11/2026
	■			■	Wicklow	3		DEV	06/10/2022	11/09/2023	30/09/2024
	■			■	Dublin	6		TSO	30/09/2021	20/12/2022	31/03/2025
	■				Dublin	3		DSO	01/09/2022	20/03/2023	01/04/2025
	■			■	Wexford	3		DEV	30/05/2022	28/02/2024	30/06/2025
	■			■	Wexford	3		DEV	30/05/2022	01/02/2024	30/07/2025

Table 5-4: Projects in the South-East, Mid-East and Dublin

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
87	CP1267	Arklow 220 kV – DSO Ballymanus WF	New build connection	–	■		
88	CP1268	Dunfirth 110 kV – DSO Dysart PV	New build connection	–	■		
89	CP1269	Lodgewood 220 kV – DSO The Dell SF	New build connection	–	■		
90	CP1197	Dunstown Asset Replacements	Refurbish/ replace	–	■		
91	CP1242	Great Island 220-110 kV Transformer Upgrades	Uprate/ modify	–	■	■	
92	CP1277	Customer 110 kV Line Diversion	Uprate/ modify	10			■
93	CP1394	Codling Wind Park	New build connection	–		■	
94	CP1396	Arklow Bank Wind Park	New build connection	–		■	
95	CP1397	North Irish Sea Array	New build connection	–		■	
96	CP1398	Dublin Array	New build connection	–		■	

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
	■			■	Wicklow	3		DSO	30/09/2022	30/10/2023	01/04/2025
	■			■	Kildare	3		DEV	30/09/2022	30/10/2023	01/07/2024
	■			■	Wexford	3		DEV	01/09/2022	30/10/2023	31/10/2024
				■	Meath, Kildare	3		TSO	31/12/2021	31/10/2023	01/12/2028
				■	Wexford	3		TSO	07/12/2022	31/03/2024	01/11/2028
		■			Kildare	3		TAO	30/11/2022	29/03/2024	28/11/2025
		■			Wicklow	3		TSO	15/12/2022	31/12/2024	30/06/2027
		■			Wicklow	3		TSO	15/12/2022	31/12/2024	30/06/2027
		■			Dublin	3		TSO	15/12/2022	31/12/2024	30/06/2027
		■			Wicklow, Dublin	3		TSO	15/12/2022	31/12/2024	30/06/2027

5.5 Projects at multiple locations

Previous to the data freeze date, there were six projects with elements at multiple locations around the country. Four of these projects have been completed and seven new multiple location projects have been added in this development plan. Indicative completion dates are included for these projects. They are listed in Table 5-5 below.

Projects

- Paint Towers Nationwide (CP0857)
- Transformer Protection Upgrade (CP1096)
- Agannnygal, Ennis and connected stations 110 kV Protection Upgrade (CP1186)
- Cashla and connected stations 220 kV & 110 kV Protection Upgrade (CP1227)
- Shannonbridge and connected stations 220 kV & 110 kV Protection Upgrade (CP1228)
- Newbridge – Cushaling 110 kV line, Stations bay conductors and lead-in conductor uprate (CP1149)
- Physical Security of Transmission Stations – South Region (CP1123)
- Physical Security of Transmission Stations – North Region (CP1124)
- Physical Security of Transmission Stations – Central Region (CP1125)

Description

In recent years, the amount of renewable generation connected to medium voltage networks has increased significantly, resulting in 110 kV transformers at Sligo, Corderry, Dalton, Macroom, Ikerrin and Somerset becoming net exporter transformers. As a result, the existing protection schemes in these stations are no longer suitable. Therefore, refurbishments of these stations are progressing through our six-step process for developing the grid and to support the needs for power-transfer capacity.

Protection upgrades are driven by Security of Supply. There are three more protection upgrades projects that involve the installation/ replacement of protection equipment based on the age profile of the devices and to mitigate against sub optimal protection system performance. Protection system enhancement works are also included in all of them to ensure compliance with the best practice in transmission system protection.

The works of Newbridge – Cushaling 110 kV are part of wider site related connection equipment works being carried out to allow for the connection of a new wind farm at Cloncreen, Co. Offaly, which would see the development of a new Kilcumber 110 kV substation connected to Cushaling 110 kV station. This project involves the uprating of the Newbridge 110 kV bay conductor, in Cushaling 110 kV station, the Cushaling 110 kV bay conductor, in Newbridge 110 kV station and the Cushaling 110 kV lead-in conductor, in Newbridge 110 kV station to achieve a better rating.

The physical security of transmission stations in the south, central and north regions are driven by Security of Supply. These projects are necessary to address a significant number of copper earth conductor thefts. Those thefts of earth conductors impose a risk to intruders of injury or death, TSO and TAO staff as well as safety and operational risks to the transmission system.

Table 5-5 Planned projects at multiple locations

	CP No.	Project title	Type	Km	Drivers		
					Security of Supply	RES Integration	Market Integration
1	CP0857	Paint towers nationwide	Refurbish/ replace	–	■		
2	CP1096	Transformer protection upgrade, 6 stations	Refurbish/ replace	–	■		
3	CP1186	Agannygal, Ennis and connected stations 110 kV protection upgrade	Refurbish/ replace		■		
4	CP1227	Cashla and connected stations 220 kV & 110 kV protection upgrade	Refurbish/ replace		■		
5	CP1228	Shannonbridge and connected stations 220 kV & 110 kV protection upgrade	Refurbish/ replace		■		
6	CP1149	Newbridge – Cushaling 110 kV line, stations bay conductors and lead-in conductor uprate	Uprate/ modify		■	■	
7	CP1123	Physical security of transmission stations – South Region	Other		■		
8	CP1124	Physical security of transmission stations – North Region	Other		■		
9	CP1125	Physical security of transmission stations – Central Region	Other		■		

Needs					Location	Step	ATR	LED	GW3 (CA)	GW6 (PA)	Energisation
Inter-Regional PF	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties						
				■	Dublin, Wicklow, Louth, Cork, Kildare, Meath, Kilkenny, Offaly, Carlow	6		TSO	17/02/2014	24/11/2014	31/10/2026
				■	Sligo, Mayo, Leitrim, Tipperary, Galway	6		TSO	10/02/2020	02/10/2020	30/11/2023
				■	Offaly, Galway, Clare	5		TSO	05/08/2021	08/09/2022	31/12/2025
				■	Galway, Clare	3		TSO	02/02/2022	21/09/2022	30/11/2026
				■	Offaly, Roscommon, Tipperary	3		TSO	03/02/2022	26/09/2022	30/11/2026
	■	■			Kildare, Offaly	6		TSO	22/01/2021	04/11/2021	30/11/2023
					Wicklow, Wexford, Cork, Tipperary, Waterford	5		TSO	07/05/2021	29/12/2023	30/12/2025
					Louth, Meath, Cavan, Roscommon, Monaghan	5		TSO	03/02/2022	29/12/2023	30/12/2025
					Kildare, Carlow, Cork, Kilkenny, Limerick, Wicklow	5		TSO	14/07/2021	29/12/2023	30/12/2025

6. Projects in early stages of development

In Chapter 5 we outlined the committed projects as at the data freeze date, 21 December 2022. Committed projects are those projects that are in Steps 4-6 of our six-step process for developing the grid. Committed projects have received EirGrid capital approval which occurs at the end of Step 3.

6.1 Overview

In this chapter we outline the projects that are in the early stages of development, that is, in Steps 2-3 at the time of the data freeze date. As these projects progress and get EirGrid capital approval they will move into Steps 4-6.

The tables below show drivers, needs and locations. Although it is not usual for drivers and needs to change once established, in certain circumstances they may change as projects progress through the early stages of the framework and therefore the information in this chapter should not be considered definitive.

Additional projects will be included in future TDPs as the needs identified in the Tomorrow's Energy Scenarios System Needs Assessment and candidate reinforcements identified in Shaping Our Electricity Future are brought through our six-step process for developing the grid.

Network studies performed as part of Shaping Our Electricity Future have identified a number of additional reinforcements that are required to meet a target of 80% RES-E by 2030, including connection of 5 GW of offshore wind capacity. A total of 40 additional reinforcements were identified; some of these reinforcements are required to address the needs associated with offshore wind connections along the east coast and increased demand growth in Dublin. Subject to engagement and further detailed technical analysis, these reinforcements will be included as appropriate in future TDPs as they are brought through our six-step process.

6.2 The Border, Midlands and West

We have confirmed the need for further investment in this region. Table 6-2 shows the projects progressing the following investments through our six-step process for developing the grid:

Table 6-1: Projects in early stages in Border, Midlands and West

	CP No.	Project title	km	Drivers			Needs					Location
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties
1	CP0982	Flagford – Sligo 110 kV circuit thermal capacity	50.5		■			■				Sligo
2	CP1002	Cushaling – Newbridge 110 kV Line Refurbishment	24.6	■							■	Offaly, Kildare
3	CP1003	Cushaling – Portlaoise 110 kV Line Refurbishment	42.1	■							■	Offaly, Kildare, Laois
4	CP1233	Donegal – Srananagh Corridor ⁶⁶		■	■							Donegal, Sligo

⁶⁶ CP1233 scope relates to the original scope of the removed North West Project.

6.3 The South-West and Mid-West

We have confirmed the need for further investment in this region. Table 6-3 shows the project progressing the following investment through our six-step process for developing the grid.

Table 6-2: Project in early stages in South-West and Mid-West

	CP No.	Project title	km	Drivers			Needs					Location
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties
1	CP1177	Whitegate 110 kV Station Refurbishment	–	■							■	Cork
2	CP1223	Bandon 110 kV Busbar Rating Needs	–	■								Cork

6.4 The South-East, Mid-East and Dublin

We have confirmed the need for further investment in this region. We are progressing the following investments through our six-step process for developing the grid:

Table 6-3: Projects in early stages in South-West and Mid-West

	CP No.	Project title	km	Drivers			Needs					Location
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition	County/ counties
1	CP1390	Maynooth – Rinawade 110V uprate	7.1	■								Kildare
2	CP1196	Arklow – Ballybeg – Carrickmines 110 kV capacity needs	21.9	■								Wicklow, Dublin
3	CP1238	Arklow 220 kV Station Refurbishment	–	■								Wicklow
4	CP1391	Maynooth – Timahoe 110 kV uprate	19	■								Kildare

Table 6-3: Projects in early stages in South-West and Mid-West

[illegible]

7. Summary of environmental appraisal

This TDP which will form part of a Grid Implementation (IP) Plan will be subject to Strategic Environmental Assessment (SEA) including Appropriate Assessment (AA). EU Directive (2001/42/EC) on the assessment of the effects of certain plans and programmes on the environment, herein referred to as the 'SEA Directive', established the statutory requirement for SEA as part of the development of certain plans and programmes.

The enabling legislation is the European Communities (Environmental Assessment of Certain Plans and Programmes) Regulations 2004 (SI 435/2004), as amended in 2011 by SI 200/2011, and the Planning and Development (Strategic Environmental Assessment) Regulations 2004 as amended in 2011 (Irish SI 436/2004 and SI 201/2011).

It is EirGrid and SONI's commitment to provide for a high level of protection to the environment and to contribute to the integration of environmental considerations into the preparation and adoption of plans and programmes with a view to promoting sustainable development.

The purpose of the SEA is to ensure the Grid Implementation Programme (IP) and accompanying TDP 2023 – 2032 is in line with committed Strategic Environmental Objectives (SEOs). These objectives will be set out in the Strategic Environmental Assessment (SEA) prepared for the Grid IP and integrated into the overall approach to grid development. A series of environmental, planning, social and technical policies and objectives also form a core element of the Grid IP and guide sustainable grid development.

The additional projects reported in this Transmission Development Plan, which consist of 51 new build projects, 21 refurbishment/ replacement projects, 31 uprate/modification projects and 7 classified as other types will be examined in the SEA and evaluated against the SEOs. Following the implementation of mitigation measures (where necessary) the SEOs will be achieved.

Each annual TDP subsequent to this TDP will include a formal Environmental Appraisal Report (EAR), which considers whether the subsequent TDP is in accordance with the SEA of the Grid IP. In short, the TDP is subject to appraisal to ensure its conformance with the provisions of the adopted SEA.

EirGrid has developed a Draft SEA Scoping Report and invited comments and observations on it from interested stakeholders in January 2023.




Figure 7-1 Five year lifecycle of SEA and subsequent annual environmental appraisals



Appendix A: Irish projects in European Plans

The TYNDP process consists of four main stages, for which reports are drafted and consultations are managed by ENTSO-E. The TYNDP process is shown in Figure A-1 and further information can be found on the ENTSO-E website⁶⁷.

How are Irish transmission projects included in ENTSO-E's TYNDP?

Scenarios are developed to describe how the future energy landscape is to function within the transmission system, defining potential future developments of the energy system that are used to gain insight on how these projects will benefit the transmission system.

During the Collection Projects stage, ENTSO-E invites operators and project promoters to propose projects requesting to be considered as PCI and included in ENTSO-E's TYNDP. The Identification of System Needs assesses the impact of the Scenarios on the transmission system, identifying network bottlenecks and additional investment needs through the outcomes provided by network power-flow, stability, and market analyses studies. In the Cost-Benefit Analysis, ENTSO-E reviews the benefits and costs of electricity transmission and storage projects from a pan-European perspective, before the European Commission includes them as PCI.




Figure A-1: Overview of the assessment process inside the TYNDP and for identifying PCIs

67 <https://www.entsoe.eu/>

The needs for reinforcement of the transmission network are first identified. Solutions to satisfy these needs are then identified and then assessed relative to each other, taking into consideration their respective costs and benefits to the system throughout the lifecycle of the project. When a solution has been chosen, it is included in the National Development Plan (NDP), which describes planned investments in the national transmission network. This includes construction of new infrastructure and replacement of existing infrastructure.

Projects that integrate at least two EU countries may come under European PCI status. These projects are intended to help the EU achieve climate and energy objectives.

Following the preliminary design, a technical project definition is created. This includes deciding a route and considering environmental and social constraints. Administrative permits are also required before a project can commence. Public consultation is required before a permit can be granted. Funding for transmission projects can come from public or private investors. Projects with PCI status are eligible for EU funding under the Connecting Europe Facility.

Following construction, a testing phase is required before the project can be commissioned. If any equipment is unavailable during construction or maintenance of a project, a planned outage must be coordinated with the relevant TOS(s). The final step in a transmission project is analysis of its impact on system operations and markets once operational. This can tell whether the benefits anticipated during planning have been realised.

Context of TYNDP 2022

Considering the feedback received on the 2020 edition, for the first time in TYNDP 2022, ENTSO-E is collecting feedback from stakeholders on key proposed improvements in the draft Cost-Benefit Analysis Implementation Guidelines, including the inclusion of the Interlinked Model, a new methodology to assess hybrid interconnectors and the assessment of projects' commissioning years.

In October 2021, ENTSO-E invited promoters of transmission and storage infrastructure projects to submit their projects to the TYNDP 2022, ENTSO-E's pan-European network development plan. ENTSO-E performed a cost-benefit analysis on selected projects and released the draft TYNDP 2022 for public consultation between July and September 2022.

Last December ENTSO-E launched a consultation on its 4th ENTSO-E Guideline for the Cost Benefit Analysis of Grid Development Projects. The consultation was open to all interested stakeholders from 16 December 2022 until 1 February 2023.

The final TYNDP 2022 report is expected to be published in the first quarter of 2023.

EirGrid projects in TYNDP 2022

Table A-1 below lists the projects we proposed to be in ENTSO-E's 2022.

Table A-1: EirGrid projects in European TYNDP 2022		
TYNDP No.	CP No.	Project title
107	n/a ⁶⁸	Ireland – France Interconnector (Celtic Interconnector)

Third party projects in TYNDP 2022

Table A-2 below lists the Irish projects proposed by third parties to be in ENTSO-E's TYNDP 2022.

Table A-2: Third party projects in European TYNDP 2020	
TYNDP No.	Project title
1025	Silvermines Hydroelectric Power Station

⁶⁸ There is no capital project number associated with the Interconnector itself because the project is a joint venture between EirGrid and RTE (French operator).

Irish Projects of Common Interest (PCIs)

The European Commission (EC) oversees the designation of Projects of Common Interest⁶⁹ (PCI). The PCI selection is a process separate from the TYNDP process. However, to be eligible for PCI status, inclusion in the last available TYNDP is an explicit condition. Table A-3 below lists the Irish PCIs on the fifth PCI list. The fifth list was published by the European Commission in November 2021⁷⁰. The fifth list will be included in the next version of the TYNDP, TYNDP 2022. Three projects previously included as PCI have been removed from the list.

The TEN-E Regulation is currently being amended. The draft text includes provisions for Projects of Mutual Interest (PMIs) between EU member states and third countries. Three PCIs were removed in the published 5th list. These projects will be re-evaluated after the updated Regulation takes effect and may qualify as PMIs.

Table A-3: Irish Projects of Common Interest in TYNDP 2022

PCI No.	TYNDP No.	Project title
1.6	107	Ireland – France Interconnector (Celtic Interconnector)
2.29	1025	Silvermines Hydroelectric Power Station

Irish e-Highway 2050 project

The e-Highway2050 project⁷¹ is a study project funded by the EC aimed at building a Development Plan for the European transmission network from 2020 to 2050. The Development Plan supports the EU's overall policy objectives with regard to energy and decarbonising the European economy.

Table A-4 below lists the Irish project included in the e-Highway 2050 Plan. This e-Highway project is also identified as such in the fourth PCI list referred to above.

Table A-4: Irish Projects in e-Highway 2050 Plan

PCI No.	TYNDP No.	Project title
1.6	107	Ireland – France Interconnector (Celtic Interconnector)

69 https://energy.ec.europa.eu/topics/infrastructure/projects-common-interest_en

70 https://energy.ec.europa.eu/system/files/2021-11/fifth_pci_list_19_november_2021_annex.pdf

71 <https://docstore.entsoe.eu/major-projects/the-e-highway2050-project/Pages/default.aspx>

How are Irish and European Plans related?

It is worth highlighting how the Irish TDP and the European plans and designations are related. Figure A-1 below illustrates the relationship. All our capital projects, irrespective of size, are described in the TDP.

Only high voltage projects that involve a large increase in transmission capacity are included in European plans. Of those only a small number of large cross border projects which increase the import and/or export capability of ENTSO-E countries are designated Projects of Common Interest.




Figure A-2: [Title]

Appendix B: Approach to grid development

As TSO, we are obliged to develop a safe, secure, reliable, economical, and efficient transmission network to meet all reasonable demands for electricity, in accordance with legal obligations.

Development objectives and strategies

We plan the development of the transmission network taking account of the needs of the transmission system. The need for development is determined by assessing long-term future network performance against technical standards. These technical standards are embodied in the Transmission System Security and Planning Standards^{72,73} (TSSPS). When it is established that changes on the network cannot be accommodated without violating the performance criteria outlined in the TSSPS, a range of issues are considered when selecting a transmission reinforcement strategy.

When assessing development options to address future potential network needs, we use our six-step process for developing the grid. Within our six-step process, we consider the impacts of each possible option on other potential development needs. Sometimes by making more effective use of the existing network, we can delay large investment or avoid the need for additional circuits.

In some cases, a proposed project may meet more than one development requirement, prove more economic and have less impact on the environment than multiple projects. Where possible, we seek to find single development projects to meet multiple network requirements.

Public planning and environmental considerations assist in the development of transmission infrastructure projects. An overview of the public planning and environmental considerations, as well as the TSSPS can be found below.

The Transmission System Security and Planning Standards (TSSPS)

The requirement for network development is identified when the simulation of future conditions indicates that the TSSPS would be breached. These standards are in line with international standards.

The standards are deterministic⁷⁴ – as are those generally used throughout the world in transmission planning. They set out an objective standard which delivers an acceptable compromise between the cost of development and service delivered. Rather than conducting subjective benefit analysis in each case, it is preferable to plan to meet an objective standard and carry out analysis of the options available to meet the standard.

72 <https://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid-Transmission-System-Security-and-Planning-Standards-TSSPS-Final-May-2016.pdf>

73 Previously referred to as the Transmission Planning Criteria.

74 The deterministic methodology is often referred to as the N-1 criterion. The system must have sufficient capacity so that in the event of a probable system outage, there are no resulting system problems such as overloading, under-voltage, over-voltage or instability.

Public planning and environmental considerations

Overview

We have a team of experienced, professional planning and ecological consultants embedded in our Infrastructure Directorate. These consultants assist in the development of transmission infrastructure projects and in other aspects of network development from a planning and environmental perspective. This section provides an overview of the approach taken on individual projects, taking into account best practice and legal requirements. In addition, Section B.3.4 outlines our approach to Strategic Environmental Assessment (SEA) for Grid Implementation Plans. These plans are based on broader strategy approaches to grid development but include aspects of any relevant Transmission Development Plans. A Strategic Environmental Assessment will accompany this TDP to ensure that it is in accordance with the provisions of the Strategic Environmental Objectives detailed in the SEA for the Grid Implementation Plan.

Public planning considerations

Statutory consent for transmission projects is sought on a project-by-project basis, as required under the Planning and Development Acts. At the outset, our public planning specialists determine whether permission is needed for a proposed development, or whether, under the current planning and development legislation, such works may comprise exempted development – that which does not require a prior grant of approval or permission.

These in particular might include line uprate projects, whereby the capacity or rating of electrical equipment is increased, refurbishment and maintenance works.

We undertake a process to confirm our consideration of the exempted status of such works. This process also involves Screening for Appropriate Assessment (AA), which is a statutory obligation under Article 42 of the European Communities⁷⁵ Regulations 2011-15. Where it is determined that planning permission is required, we engage with An Bord Pleanála (ABP) which determines if a proposed development falls within the scope of Section 182A of the Planning and Development Acts 2000 to 2014, which relates to Strategic Infrastructure Development (SID). If it does fall within Section 182A, an application for approval is made directly to the Strategic Infrastructure Division of ABP. If ABP determines that the proposal does not fall within Section 182A, it directs us to make an application for permission to the relevant Local Planning Authority (LPA).

⁷⁵ Birds and Natural Habitats.

The decision-making authority (ABP or LPA) will determine whether the application for development is in accordance with the principles of proper planning and sustainable development. Considerations in this regard include:

- EU directives and governing statutory and strategic policy;
- Conformity with the provisions of key documents such as relevant development plans and Regional Planning Guidelines;
- Input from Prescribed Bodies, such as the:
 - Relevant LPA (if the decision-maker is ABP);
 - Department of Communications, Climate Action and Environment;
 - Department of Housing, Planning, Local Government; and
 - National Parks and Wildlife Service of the Department of Culture, Heritage and the Gaeltacht.
- Requirements to protect designated areas on account of their ecological, cultural, archaeological, visual, or other sensitivity and/or significance.

Environmental considerations

The requirements for Environmental Impact Assessment (EIA) and Appropriate Assessment (AA) are transposed into Irish law in the Planning and Development Acts and associated regulations.

Where necessary, applications for statutory consent are accompanied by an Environmental Impact Assessment Report (EIAR) – the need for a statutory EIAR is informed by way of an EIA Screening report.

Similarly, screening for the need for AA for impacts on European sites, designated Special Conservations Areas (SAC) or Special Protection Areas (SPA), is routinely undertaken for all our grid projects.

Environmental Impact Assessment (EIA)

Projects where EIA is mandatory are identified on Annex I of the EIA Directive (2014) and in Irish legislation under the Planning and Development Acts and relevant regulations. For transmission infrastructure, this includes transmission of electricity by overhead lines where:

- The voltage is 220 kV or more: and
- The circuit length is more than 15 km.

An EIAR may be required for sub-threshold development where likely significant impacts on the environment are identified by the relevant LPA or ABP.

The content and scope of the EIAR is defined by the EIA Directive (2014). However, detail varies between projects depending on local environmental sensitivities.

Appropriate Assessment (AA)

In accordance with the provisions of Article 6 (3) of the EU Habitats Directive, any plan or project not directly connected to a Natura 2000 site (Special Area of Conservation (SAC) or Special Protection Area (SPA)), that is likely to have a significant effect on the site is subject to Appropriate Assessment (AA) of its implications on the site.

The requirements for AA are set out in:

- Article 6 (3) of the EU Habitats Directive (92/43/EEC);
- The European Communities (Birds and Natural Habitats) Regulations 2011-2015; and
- Part XAB of the Planning and Development Act.

Both the habitats and birds' directives have been fully transposed into Irish law. The provisions of Part XAB of the Planning and Development Act require, among other things, that an AA 'shall include a determination by the competent authority under Article 6.3 of the Habitats Directive as to whether or not a proposed development would adversely affect the integrity of a European site.'

The overall AA process is different from EIA as it is only focused on the conservation objectives of European sites. The process is made up of separate stages of assessment, the results of each stage determining the need for the next.

It should be noted that EirGrid has responsibility for screening projects that we wish to undertake. In accordance with Regulation 42(1) of the European Communities (Birds and Natural Habitats) Regulations 2011 as amended, EirGrid is required to screen for the need for AA of plans and projects it wishes to undertake or adopt to assess in view of best scientific knowledge and the conservation objectives of the site(s), if individually or in combination with other plans or projects is likely to have a significant effect on a European site(s).

Strategic Environmental Assessment

Strategic Environmental Assessment (SEA) is a systematic process of predicting and evaluating the environmental effects of a proposed plan or programme in order to ensure that these effects are adequately addressed at the earliest stage. The EU Directive (2001/42/EC) on the Assessment of Effects of Certain Plans and Programmes on the Environment (more usually referred to as the SEA Directive) sets out the types of plans (such as sectoral plans, including energy) that may require formal SEA. To date EirGrid has prepared two SEAs for Grid Implementation Plans which set out the manner in which grid projects will be developed in line with the overarching Grid Development Strategy.

The purpose of the SEA is to ensure that environmental considerations form part of the preparation of plans and programmes before their completion. It aims to provide a high level of protection for the environment and to promote sustainable development.

The Grid Implementation Plans and associated SEA have a nominal five-year lifespan.

Shortly, EirGrid will approve the 2023-2028 Grid IP and SEA statement. This Grid IP updates the environmental objectives set out in the previous Grid 25 IP 2017-2022 and 2011-2016 and sets out the manner in which grid projects will be developed over the next five years.

The documents can be found on our website⁷⁶.

⁷⁶ <https://www.eirgridgroup.com/about/in-the-community/environment/>

Six-step process for developing the grid

The TDP is a snapshot of the development of the transmission network at a particular point in time. These needs are presented in a manner consistent with our approach to developing the grid.

Our approach has six steps and helps to determine whether and how we develop the grid. The six steps are illustrated in the figure below.



Figure B-1: Six-step process for our grid projects

At each step in this process we make decisions that narrow our focus for the choices required in the next step.

Step 1: How do we identify the future needs of the electricity grid?

We start to identify the future needs of the electricity grid by considering potential changes in the demand for electricity.

These changes are influenced by factors such as how and where electricity is generated and changes in demand for electricity.

We consider these changes by developing a set of scenarios, known as Tomorrow's Energy Scenarios⁷⁷, that explore the future of electricity.

Considering these scenarios helps us to plan and identify grid improvements that may be necessary. This in turn helps us to identify projects to meet potential future needs.

The scenarios respond to many factors including Government policy, stakeholder feedback, the economy and expected growth in electricity demand.

We review the scenarios to consider new trends, changes in the industry, and other factors.

The outcome of this work may propose a potential need to reinforce the grid, or a need for an asset refurbishment.

When we have identified and confirmed a need, we start a formal process of project development. At this point, the only decision that has been made is to confirm that there is a need for a grid development project.

Step 2: What technologies can meet these needs?

In Step 2, we look at a range of technical options that can meet the need or needs we confirmed in Step 1.

As part of this process, we seek feedback from the public and stakeholders on a list of potential technical solutions, to understand which options are considered suitable.

From this feedback we produce a shortlist of options to consider in more detail.

In Step 2, options are assessed based on:

- Which technologies are available for use?
- Which option would be preferable – overhead lines or underground cables?
- What related upgrades will the existing network need as a result of new infrastructure?
- Which substations may need an upgrade?
- What does this mean for the lines connecting these substations?

At this point, we publish the options we think should go forward, and the ones we have ruled out. We ask the public for their views on these options, which are considered along with other factors.

We will then make a decision on the most appropriate technical solutions to bring forward to the next step.

⁷⁷ <https://www.eirgridgroup.com/customer-and-industry/tes/>

Step3:**What's the best option and what area may be affected?**

During this step, we study the potential benefits and impacts of the different options we could build, and where we could build them.

For our largest projects, we are likely to spend over a year at this step.

When we are considering where we may build a project, we start by looking at a study area. This is a broad area within a region, rather than a specific, detailed route.

During Step 3, we will ask for the public's views on a specific technology option and on the study area where we want to locate the project.

We may consider more than one technical option, such as developing a new or upgraded line, or upgrading or extending a substation.

Where there are choices like this, we will consult with the public. These issues could include environmental concerns, questions about land use, or other topics that could affect the technology options.

As part of this process, we will publish information about all the technologies and areas and give our opinion on their suitability. We will identify the best performing solution.

At the end of Step 3, we will base our decision on a detailed analysis of feedback and on economic, technical, social, deliverability and environmental factors.

Step 4:**Where exactly should we build?**

Following consultation and engagement in Steps 1, 2 and 3, we have made some key decisions on the technology we will use, and roughly where the project will be built.

We will continue to examine and consider both an overhead line option and an underground cable option if a new line is needed.

In Step 4, we will assess the most appropriate place to build the project.

At this step, the public can significantly influence exactly where we build the project. During this step we work closely with local people – especially landowners who will be directly affected by a project.

We will engage with landowners and the wider community to understand which locations for new infrastructure are preferred by local people.

At this stage, our aim is to collaborate on an agreed route or site, once it is possible and practical.

We will consider all the information gathered in this step, including local knowledge. We will then decide on a preferred route or site to include in our planning application.

Step 5: The planning process

Where a project requires planning permission, we will submit an application to the planning authority – either An Bord Pleanála or the Local Planning Authority.

We will publish a notice in the newspapers when we lodge this application. We will also continue to provide regular project updates.

Once we make an application to An Bord Pleanála, it may decide to hold an oral hearing. This will give those who submitted a written opinion a chance to share their views about the project.

Where possible, we will respond to submissions from those who are directly affected by our plans.

When the planning process ends, the planning authority will do one of the following:

- Grant permission;
- Grant permission on the basis that EirGrid makes some changes to its application; or
- Refuse permission.

Step 6: Construction, energisation and benefit sharing

We continue to engage with the public and stakeholders throughout the construction phase of the project.

Though EirGrid plans the future of the electricity grid, it is ESB Networks that builds new grid infrastructure.

EirGrid and ESB Networks will work together to minimise any impact during construction.

EirGrid will continue to engage with the public on issues such as road access or planning the schedule of works.

We will also inform the wider community of the progress of the project, up to the final process of testing, energisation and completion.

When we build new transmission infrastructure in an area, we set up a Community Fund and establish Proximity Payments for the project. We make Proximity Payments when new transmission infrastructure is built within 200 m of homes in a rural location.

The Community Fund awards grants to local organisations and other good causes in a project area.

Appendix C: References

Our published documents

EirGrid's Strategy 2020-2025

September 2019

Shaping Our Electricity Future

November 2021

Shaping Our Electricity Future

July 2023

Transmission Development Plan (TDP) 2021-2030

August 2022

Transmission System Security and Planning Standards (TSSPS)

May 2016

Ireland's Grid Development Strategy – Your Grid Your Tomorrow

January 2017

All-Island Ten Year Transmission Forecast Statement (TYTFS) 2020-2029

October 2021

All-Island Generation Capacity Statement (GCS) 2021-2030

August 2020

Grid Implementation Plan 2017-2022

April 2019

Grid Implementation Plan 2017-2022 – Strategic Environmental Assessment Statement

April 2019

ENTSO-E published documents

Ten Year Network Development Plan (TYNDP) 2020

July 2022

Regional Investment Plan North Sea 2017

January 2018

National legislation

Electricity Regulation Act

1999

Planning and Development Act

2000 (as amended)

Strategic Infrastructure Act

2006

Statutory Instrument No. 445 of 2000, European Communities (Internal Market in Electricity) Regulations

Statutory Instrument No. 60 of 2005, European Communities (Internal Market in Electricity) Regulations

Statutory Instrument No. 147 of 2011, European Communities (Renewable Energy) Regulations

European legislation

Birds and Natural Habitats Regulations
2011

Cross-border Exchanges in Electricity Regulation (EC) No 714/2009

Environmental Impact Assessment Directive

Habitats Directive

Internal Market for Electricity Directive 2009/72/EC

Internal Market for Electricity Directive 2019/944/EC

Promotion of the Use of Energy from Renewable Resources Directive 2009/28/EC

Energy Efficiency Directive 2012/27/EC

CRU published documents

TSO Licence granted to EirGrid

CER/15/296; Decision on TSO and TAO Transmission Revenue for 2016 to 2020
December 2015

Government published documents

Climate Action Plan 2022
December 2022

Climate Action Plan 2021
November 2021

Climate Action Plan 2019
June 2019

Project Ireland 2040
February 2018

Energy White Paper
2015

Government Policy Statement on the Strategic Importance of Transmission and Other Energy Infrastructure
July 2012





The Oval, 160 Shelbourne Road,
Ballsbridge, Dublin 4, D04 FW28, Ireland
+353 (0) 1 627 1700 | eirgrid.ie

