

Performance Monitoring Workshop

6th June 2013 - Belfast

11th June 2013 - Dublin



Opening Remarks – Anne Trotter

#	Topic	Time	Presenter
	Registration	10:00	-
1	Opening Remarks	10:15	Anne Trotter (Chair)
2	A Day in the Life of Performance Monitoring 2013	10:20	Amanda Kelly / Norman Watson
3	Performance Monitoring from a Generators Perspective (Part 1) AES Bord Gáis	10:40 11:00	Brian Mongan Ed Long
	Tea/Coffee Break	11:20	-
4	Performance Monitoring from a Generators Perspective (Part 2) ESB Generation & Wholesale Markets SSE Renewables	11:35 11:55	Ruairí Costello Jane McArdle
5	Round Up of Current Approach & Questions	12:15	Anne Trotter (Chair)
	Lunch	12:45	-
6	A Day in the Life of Performance Monitoring 2015 (Part 1) Overview of proposal Functional/Non-Functional Requirements Active Power Performance	13:30 13:35 13:50	David Carroll & Norman Watson
	Break	14:30	-
7	A Day in the Life of Performance Monitoring 2015 (Part 2) Available Active Power Performance Frequency Response Performance Reactive Power Performance	14:40 15:00 15:15	David Carroll & Norman Watson
8	Round Up of Proposed Enhanced Approach	15:30	Anne Trotter (Chair)
9	Next Steps	15:45	David Carroll
	Finish	16:00	-



A Day in the Life of Performance Monitoring 2013

Amanda Kelly (EirGrid) /
Norman Watson (SONI)



Performance Monitoring Context

- The TSOs have an obligation to carry it out under the Grid Codes
- The TSOs in both jurisdictions have always monitored the performance of the plant they dispatch
- The basis of secure and economic system operation relies on the expected plant performance to match actual performance

Now, tomorrow and beyond....

- The challenges ahead with a changing plant portfolio, such as increased non-synchronous penetration and different types of technologies, requires a greater degree of plant performance from all units.



Current Conventional Performance Monitoring Process

Daily

- Failure to synchronise (not SONI)
- Trips
- Failure to follow dispatch instructions
- Failure to make correct declarations
- Operating reserve
- Fault Ride Through

Quarterly

- Active power duration
- Reactive power range
- Operating reserve
- Technical Offer Data:
 - Min generation
 - Ramp up/down rates
 - Min up/down time
 - Loading/deloading times
- Secondary fuel capability



Current Wind Farm Performance Monitoring Process (10 Day Notification)

Daily

- Failure to follow dispatch instructions
- Failure of available active power signal

Monthly

- Available active power accuracy
- Active power control accuracy

Other Monitoring

- If a wind farm fails to perform as expected during an event, for instance low voltage ride through.



Benefits of Current Approach

Feeds into Operational Policy

- Improve all island Operating Reserve (OR) policy:
 - Actual reserve performance supports overall OR requirement (holding less reserve compare to previous practices);
 - Provide confidence and assurance to all.



Benefits of Current Approach example

- Generator Performance Incentive (GPI) provide improvement to the overall system
- For example importance of minimum generation in night valley.
- Fairness and consistent approach to all units



Processing of Performance Non-Compliances

- Managed by the TSOs performance monitoring team
 - Operational Services and Performance (EirGrid)
 - Near Time (SONI)
- Mixture of Manual / automatic processing of performance monitoring data

Communication to Generator

- Communication via performance monitoring team email to generator
- Information to generator includes notification, details of non-compliance and any other relevant information.



System Services DS3

Enhanced performance monitoring

- DS3 system Services Project
- Efficient communication of performance monitoring data to all providers
- Consistent approach in line with DS3 program



Questions?



Performance Monitoring from a Generator's Perspective (1)

Denis McBride / Brian Mongan
AES



Performance Monitoring from a Generator's Perspective (2)

Ed Long
Bord Gáis



Tea/Coffee Break



Performance Monitoring from a Generator's Perspective (3)

Ruairí Costello
ESB International



Performance Monitoring from a Generator's Perspective (4)

Jane McArdle
SSE Renewables



Round Up of Current Approach & Questions

Anne Trotter



Lunch



A Day in the Life of Performance Monitoring 2015

Dave Carroll (EirGrid) /
Norman Watson (SONI)



Overview of Presentation

1. Scope of Project
2. Functional Requirements
3. Non Functional Requirements
4. Active Power
5. Available Active Power
6. Frequency Response
7. Reactive Power
8. Operational Process
9. Next Steps



Objective

- Increase certainty and understanding of how plant is performing
- Use information to improve modelling of system
- Facilitate appropriate regulation and incentivisation of necessary products to ensure necessary performance is delivered

Utilise performance capability to efficiently and securely manage power system with up to 75% non synchronous generation



Delivering a Secure Sustainable Electricity System (DS3)

System Services
Performance Monitoring
Grid Code
Demand Side Management



Frequency Control
Voltage Control
Renewable data
System inertia

Models Development
Control Centre Tools
AI Wind Security Assessment Tool



Scope of Enhanced Monitoring Project

- Standardised and harmonised on all-island basis
- Automated monitoring
- Transparent and improved communications
- Monitoring of proposed new System Service products
- Investigate use of improved data i.e. high speed recorders
- Industry Involvement
- Operational Readiness



Progress to date

- Internal project approval granted
- High level Requirements for Enhanced Performance Monitoring developed in Q4 2012
 - Data
 - Analysis
 - Reporting
 - Functional Spec
- Detailed business requirements specification being developed at present



High Level Requirements - Intro

- A 'wish list' has been developed through a number of internal workshops on what the enhanced process should include – inputs from today will be added to this 'wish list'
- These high level requirements will be translated into detailed business rules so that a detailed cost benefit analysis can be undertaken and ultimately so that an IT system can be developed
- This workshop focuses on the requirements and not on the business processes i.e. the follow up



High Level Requirements - Numbers

- Currently 193 individual units bound by Grid Code for which enhanced performance monitoring needs to be carried out for
- Huge volume of data and complexity of business rules
- Number of units expected to increase to ~300 by 2020

	Conventional		Interconnectors		TSO Wind		DSO Wind		Total	
	IRE	NI	IRE	NI	IRE	NI	IRE	NI	IRE	NI
Current No. units	55	23	1	1	19	3	69	22	144	49



Functional Requirements – (1) Customer Facing

- Secure web based portal
- Summary of main issues to clearly show main issues (assigned Priority order)
- Customer can view, download and upload content
- Investigating whether correspondence tracking system can be added
- Aim is to reduce need for emails




Functional Requirements – (2) Data

- Business case being developed to roll out GPS time stamped, high speed data recording (kV, MW, MVA_r)
- If progressed this will require installation on LV side of generator transformer (reactive power)
- EDIL, SEM TOD, SCADA will be used
- Data will be made available to customers



Functional Requirements – (3) Reporting

- Reporting will focus on trends of non-compliance removing follow up for individual events for most part
- Non-compliance items will have a priority
 - Need to develop priority order for each trend (at a later date)
- Detailed standardised reports will be developed
- Calculation steps and raw data would be available in .xls, etc



Functional Requirements – (4) System Services

- Enhanced system will be utilised for new System Services if approved by SEM Committee
- Output will feed into settlement system
- Customers will know whether they achieved the required level of product delivery



Non- Functional Requirements – (1)

- Security of commercially sensitive data
- Access to online portal – what should e.g. OEMs see?
- Archiving of data – trends will be available, however detailed reports will be archived
- Availability - Proposal to have (most) data available as close to real time once quality controlled (e.g. D + 3). A real-time system would be too onerous from a cost and quality control perspective
- Usability – User guides will be developed and training will be provided



DISCUSSION




Active Power

WHY? - Frequency Control

1. Synchronising
2. Block Load
3. Loading/De-Loading
4. Ramping
5. Compliance with Dispatch Instructions
6. Unexpected Load Drops/Trips
7. Secondary Fuel
8. Max Starts per 24 hours




(1) Synchronising



ACTIVE POWER

(1) Synchronising



ACTIVE POWER

(1) Synchronising - DATA

- EDIL – Sync instruction (send time, effective time)
- TOD – Notification time, hot/warm cooling boundary
- Generator CB close time
- Frequency data
- MW output



ACTIVE POWER

(1) Synchronising - ANALYSIS

- Is TOD Grid Code compliant
- Determine heat state
- Determine actual sync performance:
 - Actual Sync Time vs. Expected Sync Time
 - If fail to sync how long did it take to sync after original instruction
 - Notice time given by control centres
- Determine system frequency at time of sync'ing



ACTIVE POWER

(1) Synchronising - REPORTING

Detailed Report for each event:

- Actual SYNC Time vs. Expected SYNC Time
- If *Failsyn* what was system frequency
- Was unit requested to sync again? What was performance?


Summary Report:

- Trend in compliance - % Fail / % Syncs
- Average time taken to SYNC following FAILSYN
- Plot of time taken to SYNC against notification time
- Last time unit synchronised
- Grid Code compliance




ACTIVE POWER

(2) Block Load



(2) Block Load




(2) Block Load

- Use SCADA to determine initial MW output
- Is this Grid Code compliant
- Does this align with the TOD for various heat states




ACTIVE POWER

(3) Loading/De-Loading



ACTIVE POWER

(3) Loading/De-Loading



(3) Loading/De-Loading - DATA

- EDIL – Minimum generation, dispatched MW setpoint, target frequency
- TOD – Loading/De-Loading rates, break points, soak times
- 5 second MW SCADA



ACTIVE POWER

(3) Loading/De-Loading - ANALYSIS

- Is TOD Grid Code compliant
- Determine heat state
- Determine actual loading/de-loading performance
 - The actual MW per minute rate for each loading rate
 - Does unit provide frequency regulation



ACTIVE POWER

(3) Loading/De-Loading - REPORTING

Detailed Report for each event:

- Actual loading/de-loading rate
- Broken down into various break points and heat state


Summary Report:

- Trend in compliance
- Grid Code compliance




ACTIVE POWER

(4) Ramping



(4) Ramping



(4) Ramping - DATA

- EDIL – Minimum generation, dispatched MW setpoint, target frequency, registered capacity, governor droop
- Contracts - TOR2, RRA, ramping under DS3
- TOD – Ramp up/down rates, break points, forbidden zones
- 5 second MW, Hz SCADA



ACTIVE POWER

(4) Ramping - ANALYSIS

- Is TOD Grid Code compliant
- Determine actual ramp up/down performance:
 - The actual MW per minute rate for each ramp rate
 - Does unit provide frequency regulation
- Does unit provide contracted/declared TOR2 & RRA
- Does unit provide contracted DS3 System Services



ACTIVE POWER

(4) Ramping - REPORTING

Detailed Report for each event:

- Actual ramp up/down rate
- Broken down into various break points and heat state
- Whether contracted values delivered


Summary Report:

- Trend in compliance
- Grid Code compliance




ACTIVE POWER


(5) Compliance with Dispatch Instructions



(5) Compliance with Dispatch Instructions



(5) Compliance with Dispatch Instructions



(5) Compliance with Dispatch Instructions - DATA

- EDIL – Minimum generation, dispatched MW setpoint, target frequency, registered capacity, governor droop, declared availability
- Windfarms – Available Active Power signal, active power setpoints/feedback, active power control ON/OFF, frequency response ON/OFF, frequency response curve, DMOL
- DSU - Submitted energy profiles
- 5 second MW, Hz SCADA
- 15 min metered MW output
- Governor deadbands



ACTIVE POWER

(5) Compliance with Dispatch Instructions - ANALYSIS

- Is governor droop Grid Code compliant
- Actual Performance:
 - Last time unit was dispatched to min and max generation
 - Its frequency adjusted MW setpoint reached
 - Does unit respond correctly for changes in frequency
 - According to contracted governor droop
 - According to windfarm frequency response curve



ACTIVE POWER

(5) Compliance with Dispatch Instructions - REPORTING

Detailed Report for each event:

- Whether declared min gen achieved
- Whether declared max gen achieved
- Whether unit went to dispatched MW setpoint
- Whether unit provided frequency regulation
- Wind – whether curtailment or constraint
- Wind – power curve for each windfarm


Summary Report:

- Min/Max gen performance
- Last time dispatched to min and max gen
- Average governor droop




ACTIVE POWER

(6) Unexpected Load changes/Trips



(6) Unexpected Load changes/Trips



(6) Unexpected Load changes/Trips - DATA

- EDIL – Dispatched MW setpoint, declared availability (incl. reason Code), Trip DI, Failmin DI
- Windfarms – Available active power signal, active power setpoints/feedback, active power control ON/OFF, frequency response ON/OFF, frequency response curve
- 1 second MW, Hz SCADA
- Generator wind-down alarm, CB position indication



ACTIVE POWER

(6) Unexpected Load changes/Trips - ANALYSIS

- If output changes over a defined rate (MW/s) and range (MW) then calculate:
 - MW change
 - Rate of MW change (MW/s)
 - Pre-event frequency (Hz)
 - Frequency nadir/zenith (Hz)
 - Type of trip
 - Whether the unit recovers to dispatched setpoint and the time taken



ACTIVE POWER

(6) Unexpected Load changes/Trips - REPORTING

Detailed Report for each event:

- MW change
- Rate of MW change (MW/s)
- Pre-event frequency (Hz)
- Frequency nadir/zenith (Hz)
- Type of trip
- Whether the unit recovers to dispatched setpoint and the time taken


Summary Report:

- Numbers and type of load drops



ACTIVE POWER

(7) Secondary Fuel



(7) Secondary Fuel - DATA

- EDIL – FUCHP/FUCHS instruction, dispatch MW setpoint, declared availability
- Fuel indication
- Submitted fuel changeover curve
- 1 second MW, MVAR, Hz SCADA values
- Fuel stock levels



ACTIVE POWER

(7) Secondary Fuel - ANALYSIS

- Frequency adjust expected output
- Compare actual performance to expected performance



ACTIVE POWER

(7) Secondary Fuel - REPORTING

Detailed Report for each event:

- Instruction time to change fuel
- Actual performance compared to expected performance
- Fuel used
- Whether declared availability on secondary fuel is within limits
- Any oscillations during fuel changeover

Summary Report:

- Dates and result of testing
- Fuel stock levels



ACTIVE POWER

(8) Max Starts per 24 hours - DATA


- EDIL – Declared max starts in 24 hrs (MXST)
- TOD – Time to synchronise (hot), loading rates (hot), de-loading rates, minimum on time, minimum off time



ACTIVE POWER

(8) Max Starts per 24 hours - ANALYSIS

Note : Declarations for MXST made by Market Participants must be calculated based on the relevant unit in a hot state, as indicated in the following diagram. The declaration should take no account of the current warmth status of the unit.



(8) Max Starts per 24 hours - REPORTING

- EDIL – Declared max starts in 24 hrs (MXST)
- TOD – Time to synchronise (hot), loading rates (hot), de-loading rates, minimum on time, minimum off time



ACTIVE POWER

DISCUSSION



Break




Available Active Power

WHY? - Ensure capacity available

1. Minimum & Maximum Generation/Load
2. Wind Available Active Performance
3. DSU Energy Profile



(1) Minimum & Maximum Generation/Load



AVAILABLE ACTIVE POWER

(1) Minimum & Maximum Generation/Load - DATA

- EDIL – Declared min gen, contracted min load, declared maximum availability, registered capacity
- Ambient correction curves & degradation submitted as part of commissioning
- Ambient temperature, pressure, humidity



AVAILABLE ACTIVE POWER

(1) Minimum & Maximum Generation/Load - ANALYSIS

- Is Min Gen & Load Grid Code compliant
- Is unit declaring in line with ambient capability curve



AVAILABLE ACTIVE POWER

(1) Minimum & Maximum Generation/Load - REPORTING

Detailed Report

- Expected minimum generation availability
- Expected maximum generation availability


Summary Report

- Trends in declarations



AVAILABLE ACTIVE POWER

(2) Wind Available Active Power



(2) Wind Available Active Power - DATA

- Active power setpoints, active power setpoint feedback, active power control ON/OFF, high/low wind speed shutdown, % availability, frequency response ON/OFF, frequency response curve select, DMOL, wind speed
- 1 minute available active power (MW), active power output (MW), frequency (Hz), CB position indication
- Windfarm controllability category



AVAILABLE ACTIVE POWER

(2) Wind Available Active Power - ANALYSIS

- Normalised Root Mean Squared Deviation (NRMSE) analysis to ensure available active power tracks MW output when not curtailed/constrained
- If curtailed/constrained then is the available active power correct – base this on wind power curve
- Was there a wind speed shutdown event and was the expected response achieved



AVAILABLE ACTIVE POWER

(2) Wind Available Active Power - REPORTING

Detailed Report:

- 14 day rolling NRMSD analysis
- High/low wind speed shutdown event analysis

Summary Report:

- Average NRMSD



AVAILABLE ACTIVE POWER

(3) DSU Energy Profile - DATA

- DSU will upload their estimated energy profile up to 15 minutes before a trading period
- 15 minute meter readings



AVAILABLE ACTIVE POWER

(3) DSU Energy Profile – ANALYSIS & REPORTING

- Is the estimated energy profile within the required standard
- The actual variance between DSU energy profile and the actual metered energy



AVAILABLE ACTIVE POWER

DISCUSSION




Frequency Response

WHY? - Restore frequency to nominal during events

1. Conventional
2. Wind
3. Frequency Relay Setting Activation
 - Interconnectors
 - Short Term Active Response (STAR) scheme
 - Special Protection Schemes



(1) Conventional



FREQUENCY RESPONSE

(1) Conventional – DATA

- EDIL – Declared POR – RRA, contracted POR – RRA, declared MW availability, declared fuel, active power setpoint, governor droop, target frequency
- 100 ms active power output, 100 ms frequency, actual POR – TOR1, required POR – TOR1, system demand, inertia, System Non-Synchronous Penetration (SNSP)



FREQUENCY RESPONSE

(1) Conventional – ANALYSIS

- Are contracted & declared values Grid Code compliant
- Carried out once frequency less than 49.8 Hz or greater than 50.2 Hz
- Pre-event output based on frequency adjusted dispatch instruction
- Maximum Rate of Change of Frequency (RoCoF)



FREQUENCY RESPONSE

(1) Conventional – REPORTING

Detailed Report:

- Actual vs. expected performance
- Maximum RoCoF

Summary Report:

- Maximum, Minimum, Average, 95th percentile performance
- Scatter plot of performance vs. pre-event output



FREQUENCY RESPONSE

(2) Wind – DATA

- Active power setpoints, active power setpoint feedback, active power control ON/OFF, frequency response ON/OFF, frequency response curve select, DMOL
- 1 minute available active power
- 100 ms active power output, 100 ms frequency, actual POR – TOR1, required POR – TOR1, system demand, inertia, SNSP
- Windfarm controllability category



FREQUENCY RESPONSE

(2) Wind – ANALYSIS

- Are contracted & declared values Grid Code compliant
- Primary frequency response of WFPS to under/over frequency event will be analysed
- Maximum Rate of Change of Frequency (RoCoF)
- Simulated inertia provided



FREQUENCY RESPONSE

(2) Wind – REPORTING

Detailed Report:

- Actual vs. expected performance
- Maximum RoCoF

Summary Report:

- Maximum, Minimum, Average, 95th percentile performance
- Scatter plot of performance vs. pre-event output



FREQUENCY RESPONSE

(3) Frequency Relay Setting Activation – DATA

- EDIL – Declared POR – RRA, contracted POR – RRA, Declared MW availability, declared fuel, active power setpoint, governor droop, target frequency
- 100 ms active power output, 100 ms frequency, 100 ms reactive power output, actual POR – TOR1, required POR – TOR1, system demand, inertia, SNSP
- Frequency trigger points



FREQUENCY RESPONSE

(3) Frequency Relay Setting Activation – ANALYSIS

- Are contracted & declared values Grid Code compliant
- Carried out once frequency settings are triggered
- Pre-event output based on frequency adjusted dispatch instruction
- Maximum Rate of Change of Frequency (RoCoF)



FREQUENCY RESPONSE

(3) Frequency Relay Setting Activation – REPORTING

Detailed Report:

- Actual vs. expected performance
- Maximum RoCoF

Summary Report:

- Maximum, Minimum, Average, 95th percentile performance
- Scatter plot of performance vs. pre-event output



FREQUENCY RESPONSE


Reactive Power

WHY? - Voltage control

1. Conventional/Interconnector
2. Wind



(1) Conventional/Interconnector



(1) Conventional/Interconnector – DATA

- EDIL – Declared MVA_r leading/lagging, contracted MVA_r leading/lagging, declared AVR ON/OFF, MVA_r setpoints
- 100 ms active power output, 100 ms frequency, 100 ms reactive power output, 100 ms HV voltage
- Fault Ride Through Requirements
- CB position indication



REACTIVE POWER

(1) Conventional/Interconnector – ANALYSIS

- Are contracted & declared values Grid Code compliant
- Determine last time unit dispatched to and achieves max leading and lagging at maximum active power output
- Determine whether the AVR responds correctly to changes in system voltage by adjusting the MVA_r output
- For an under voltage event determine if the unit correctly rides through the fault



REACTIVE POWER

(1) Conventional/Interconnector – REPORTING

Detailed Report

- Are values Grid Code compliant
- Actual performance during under voltage event
- Is AVR responding correctly

Summary Report

- Scatter plot of reactive power vs. active power output
- Date unit last dispatch to max leading and lagging at full output



REACTIVE POWER

(2) Wind – DATA

- Active power setpoints, active power setpoint feedback, active power control ON/OFF, available active power, kV/MVAr/pf setpoint, kV/MVAr/pf setpoint feedback
- 100 ms active power output, 100 ms frequency, 100 ms reactive power output, 100 ms HV voltage
- Fault Ride Through Requirements
- CB position indication



REACTIVE POWER

(2) Wind – ANALYSIS

- Are contracted & declared values Grid Code compliant
- Determine last time unit dispatched to and achieves max leading and lagging at maximum active power output
- Determine whether the AVR responds correctly to changes in system voltage by adjusting the MVA_r output
- For an under voltage event determine if the unit correctly rides through the fault



REACTIVE POWER

(2) Wind – REPORTING

Detailed Report

- Are values Grid Code compliant
- Actual performance during under voltage event
- Is AVR responding correctly

Summary Report

- Scatter plot of reactive power vs. active power output
- Date unit last dispatch to max leading and lagging at full output



REACTIVE POWER

Signals

- List of all signals required under Grid Code
- Traffic light display of signals with issues
- Would be automated as much as possible



SIGNALS

DISCUSSION



Round Up of Proposed Enhanced Approach

Anne Trotter



Next Steps (1)

- Email any comments before end June to:
DS3@EirGrid.com
DS3@SONI.ltd.co.uk
- TSOs to summarise feedback and publish to industry by end July
- TSOs to consider proposals from Users when developing detailed Business Requirements Specification (BRS)
- BRS expected to be completed by Q4 2013



Next Steps (2)

- EirGrid will publish updated timelines for implementation of IT system in Q4 2013
- EirGrid to develop business processes for enhanced process and will present these in industry in late 2013/early 2014
- EirGrid are looking for expressions of interest from Users to test trial system: DS3@EirGrid.com; DS3@SONI.ltd.co.uk
- EirGrid to document and publish User guides and training to be provided



Next Steps - Operational Process

- Need to develop trigger for when trends become non-compliance issues
- Each trend would have an associated priority order
- Each priority order would have a required action and timeline in which the user must remedy the non-compliance
- If a required action is not completed by the user within the timeframe then this would result in the TSOs taking an action e.g. changing contract values, change in controllability category



DISCUSSION



THANK YOU FOR YOUR ATTENDANCE TODAY

