

MODIFICATION PROPOSAL FORM



THE OVAL, 160 SHELBOURNE
ROAD
BALLSBRIDGE
DUBLIN 4
PH: +353-1-677 1700
FAX: +353-1-6615375
EMAIL: GRIDCODE@EIRGRID.COM

FORM GC1, PROPOSAL OF MODIFICATION TO GRID CODE.

MODIFICATION PROPOSAL ORIGINATOR:	EirGrid		
MODIFICATION PROPOSAL ORIGINATOR (CONTACT NAME)	William Johnston	MODIFICATION PROPOSAL ORIGINATOR FAX NUMBER:	01 6615375
MODIFICATION PROPOSAL ORIGINATOR TELEPHONE NUMBER:	01 2370393	DATE:	10/05/2012
MODIFICATION PROPOSAL ORIGINATOR E-MAIL ADDRESS:	William.johnston@eirgrid.com	MODIFICATION PROPOSAL NUMBER (EIRGRID USE ONLY)	MPID 225
GRID CODE SECTION(S) AFFECTED BY PROPOSAL:	OC11.5.4		
GRID CODE VERSION :	4		
MODIFICATION PROPOSAL DESCRIPTION (MUST CLEARLY STATE THE DESIRED AMENDMENT, ALL TEXT/FORMULA CHANGES TO THE GRID CODE. THE REQUIRED REASON FOR THE MODIFICATION MUST STATED. ATTACH ANY FURTHER INFORMATION IF NECESSARY.)	<p>The TSO is not responsible for site safety on a User's site, this is the sole responsibility of the organisation "in control" of the workplace. For this reason EirGrid propose to remove the last line from the Grid Code clause OC11.5.4:</p> <p>OC11.5.4 In the event of a Modification or a change in operational practices, which may have an Operational Effect on a User Site, the TSO and the User shall review the adequacy of overall Site safety. In any event, the TSO and each User shall review the adequacy of overall Site safety once every 5 years.</p>		
IMPLICATION OF NOT IMPLEMENTING THE MODIFICATION	There is no specific requirement under safety legislation to review Site safety, by the TSO and the User , once every 5 years. If we do not remove this sentence from the Grid Code there will be an ongoing mismatch between the Grid Code and safety legislation.		
<i>Please submit the Modification Proposal by fax, post or electronically, using the information supplied above</i>			
EIRGRID REVIEWER			

EIRGRID ASSESSMENT

--	--