

MODIFICATION PROPOSAL FORM**POWER QUALITY MODIFICATION***FORM GC1, PROPOSAL OF MODIFICATION TO GRID CODE.*

160 SHELBOURNE ROAD
 BALLSBRIDGE
 DUBLIN 4
 PH: +353-1-677 1700
 FAX: +353-1-6615375
 EMAIL: GRIDCODE@EIRGRID.COM

MODIFICATION PROPOSAL ORIGINATOR:	EIRGRID		
MODIFICATION PROPOSAL ORIGINATOR (CONTACT NAME)	JOHN GING	MODIFICATION PROPOSAL ORIGINATOR FAX NUMBER:	+353-1-6615375
MODIFICATION PROPOSAL ORIGINATOR TELEPHONE NUMBER:	: +353-1-23 70391	DATE:	10/10/2104
MODIFICATION PROPOSAL ORIGINATOR E-MAIL ADDRESS:	JOHN.GING@EIRGRID.COM	MODIFICATION PROPOSAL NUMBER (EIRGRID USE ONLY)	MPID 264
GRID CODE SECTION(S) AFFECTED BY PROPOSAL:	CC.10.13 (CC.10.13.1 – CC.10.13.4) OC. 10.2.2 WFPS.1.6.2.2 and WFPS.1.6.4 Definitions		
GRID CODE VERSION :	5		

FORM GC1

<p>MODIFICATION PROPOSAL DESCRIPTION</p> <p>(MUST CLEARLY STATE THE DESIRED AMENDMENT, ALL TEXT/FORMULA CHANGES TO THE GRID CODE. THE REQUIRED REASON FOR THE MODIFICATION MUST STATED. ATTACH ANY FURTHER INFORMATION IF NECESSARY.)</p>	<p>The current clause CC.10.13 on Power Quality requires clarification to identify the roles, responsibilities and requirements expected of Users and the TSO. A complete rewording of the current clause (and associated clauses) is required. All Users, including Interconnectors, will now be treated equally regarding meeting their Power Quality obligations at the Connection Point. The new text clarifies to whom and under what conditions the specified limits apply.</p> <p>The Harmonics Working Group agreed that limits will not be applied to existing connections unless they were previously advised or they are subject to a material modification. This material modification may include but not be limited to the installation of additional or alternative Plant and/or Apparatus or modifications to the control systems which are capable of altering the Harmonic Voltage Distortion Level at the Connection Point. (See Minutes of Harmonics Working Group at: http://www.eirgrid.com/operations/gridcode/meetingsworkinggroups/).</p> <p>New connections to the Transmission System energising after 1st January 2015 will be issued with incremental Harmonics limits as defined in CC.10.13.1 (a). All Users, including the DSO, generators and demand, intending to connect or modify their connection to the transmission system after that date will be informed as appropriate. However, it may be difficult for the DSO to communicate any implications to parties connecting at lower voltages.</p> <p>See detailed text attached.</p>
<p>IMPLICATION OF NOT IMPLEMENTING THE MODIFICATION</p>	<p>The TSO will have to issue Power Quality limits to all Users, even where it is impractical to do so, without sufficient data detailing the network conditions at the point and time of connection. A number of ambiguities will persist, which may result in a less than adequate power quality available to Users at their Connection Point. Interconnectors will continue to have duplicate requirements. Furthermore, there is an implied requirement to count the number of switching events on the system when assessing the resultant Voltage Fluctuations which is impractical.</p>
<p align="center"><i>Please submit the Modification Proposal by fax, post or electronically, using the information supplied above</i></p>	
<p>EIRGRID REVIEWER</p>	
<p>EIRGRID ASSESSMENT</p>	

CC.10.13 Power Quality

~~Users shall ensure that their connection to the **Transmission System** does not result in the level of distortion or fluctuation of the supply **Voltage** on the **Transmission System**, at the **Connection Point**, exceeding that allocated to them following consultation with the **TSO**. Distortion and fluctuation limits are outlined in IEC/TR3 61000 3-6 (Harmonics) and IEC/TR3 61000 3-7 (**Voltage** fluctuation). Users shall also operate their **Plant** in a manner which will not cause the requirements contained in CENELEC Standard EN 50160 to be breached.~~

CC.10.13.1

(a) **Harmonic Voltage Distortion**

Users shall ensure that their connection to the **Transmission System** does not result in an increase in the level of harmonic distortion of the supply **Voltage** on the **Transmission System**, at the **Connection Point**, exceeding that allocated to them. These incremental limits will be determined by the **TSO** for each **User's** connection, to ensure compliance with IEC/TR 61000-3-6 and by default, CENELEC Standard EN 50160, on the **Transmission System**.

The necessary data will be exchanged between both parties and the exchange of data shall not be unreasonably withheld. This data may consist of but is not limited to; **Impedance Loci** at the **Connection Point**, background distortion levels and **Allocated Harmonic Distortion Limits (AHDL)**.

(b) **Voltage Fluctuations**

Users shall ensure that their connection to the **Transmission System** does not result in the level of fluctuation of the supply **Voltage** on the **Transmission System** at the **Connection Point** exceeding limits set out below. Any necessary data will be exchanged between both parties and the exchange of data shall not be unreasonably withheld.

i. **Voltage Flicker**

Users shall take responsibility for limiting **Voltage Flicker** caused by their **Plant** to remain within the maximum permissible **Voltage Flicker** limits at the **Connection Point** as allocated to them by the **TSO** or, as a minimum, those defined in Table 5 of IEC/TR 61000-3-7.

ii. **Rapid Voltage Change**

Type of rapid Voltage change	$\frac{\Delta U}{U_N}$ Limit (%)	Timeframe
Temporary Voltage Depression	5	Must recover to nominal Voltage in 3 seconds
Step Change	3	One cycle

Users shall ensure that the disturbance levels introduced by their **Plant** and/or **Apparatus** do not promote rapid **Voltage** changes exceeding those specified in the above table or alternative limit allocated to them by the **TSO** during normal system operation.

The **User** can be connected to the **Transmission System** provided that the required studies have been completed by the **User** to show compliance with the limits outlined in CC.10.13.1 (a) and CC.10.13.1 (b) and have been reviewed by the **TSO**. Following consultation with the **TSO**, a conditional connection may be allowed to **Users** where modelling of the connection shows a breach of the limits to be marginal or only occurring during contingencies as defined by the **TSO**. This may allow the **User** to verify that the installation is compliant by monitoring, or to implement a mitigation solution.

The **User's Allocated Harmonic Distortion Limits** and any special conditions pertaining to power quality will be referenced in the **Connection Agreement**. These are subject to verification of compliance by the **TSO** and through an on-going monitoring programme as described in OC10.2.2 (c).

In the event that a **User** causes any such limits in CC.10.13.1 (a) and CC.10.13.1 (b) to be breached, the **TSO** shall be entitled to require the **User** to take such steps as the **TSO** reasonably considers to be necessary in order to prevent such breach from continuing and the **User** shall comply with the **TSO's** instructions without delay.

~~CC.10.13.1~~

CC.10.13.2 The aggregate power factor for a **Demand Customer** is calculated in accordance with the following formula:

FORM GC1

$$APF = \frac{Sum P}{((Sum P)^2 + (Sum Q)^2)^{0.5}}$$

where:

APF is the Aggregate Power Factor for the **Demand Customer**

Sum P is the Energy exchanged with the **Demand Customer** at the **Connection Point** for any half-hour period; and

Sum Q is the Reactive Energy exchanged with the **Demand Customer** at the **Connection Point** for the same half-hour period.

CC.10.13.2

CC.10.13.3 A **Demand Customer** shall ensure that at any load above 50% of **Maximum Import Capacity** the aggregate power factor as determined at the **Connection Point** in any half-hour period shall be within the range 0.90 lagging to unity.

CC.10.13.3

~~Interconnector Operators shall ensure that their connection to the Transmission System does not result in the level of distortion or fluctuation of the supply Voltage on the Transmission System, at the Connection Point, exceeding that allocated to them. These limits will be determined by the TSO during discussions with the Interconnector, where the necessary data will be exchanged between both parties, the exchange of data shall not be unreasonably withheld. This data may consist of impedance loci at the Connection Point and the Interconnector harmonic current emissions. Distortion and fluctuation limits are outlined in IEC/TR3 61000 3 6 (Harmonics) and IEC/TR3 61000 3 7 (Voltage fluctuation). Interconnectors shall also operate their Plant in a manner which will not cause the requirements in CENELEC Standard EN 50160 to be breached.~~

~~The Interconnector cannot be connected to the Transmission System until:~~

- ~~i. the required harmonic studies have been completed by the Interconnector Owner and/or Interconnector Operator to show compliance with the standards outlined above and reviewed by the TSO;~~
- ~~ii. any appropriate remedies to enable the Interconnector to operate with harmonic distortion levels within agreed limits have been identified and implemented with the TSO.~~

CC.10.13.4

~~For Interconnectors the harmonic Voltage distortion emission limits and any special conditions pertaining to the quality of supply must be included in the Connection Agreement, and are subject to verification of compliance by the TSO through an ongoing approved monitoring programme to be implemented by the Interconnector Operator, or as agreed with the TSO.~~

OC10.2.2

In order to achieve the primary objective set out in OC10.2.1, OC10 establishes procedures for **Monitoring, Testing and Investigation**. In particular, this facilitates adequate assessment of each of the following:

- c) whether **Power Quality** of Users conforms with CC.10.13.1; ~~International Electro technical Commission Standards: 'Electromagnetic Compatibility Limits Limitation of emission of harmonic currents for equipment connected to medium and high voltage power supply systems [IEC/TR3 61000 3 6] and 'Electromagnetic Compatibility Limits Limitation of voltage fluctuation and flicker for equipment connected to medium and high voltage power supply systems ' [IEC/TR3 61000 3 7];~~

WFPS1.6.2.2

Under steady state conditions, the **Voltage Regulation System** shall be capable of implementing the following **Reactive Power** control modes which shall be available to the **TSO**:


- c) The **Controllable WFPS** shall be capable of receiving a **Voltage Regulation (kV) Set-point** for the **Voltage** at the **Connection Point**. The **Voltage Regulation System** shall act to regulate the **Voltage** at this point by continuous modulation of the **Controllable WFPS's Reactive Power** output, without violating the **rapid Voltage change Voltage Step Emissions** limits as set out in CC.10.13.1 ~~the IEC~~

FORM GC1

~~standard 61000 3 7:1996 Assessment of Emission limits for fluctuating loads in MV and HV power systems.~~

WFPS1.6.4 VOLTAGE STEP EMISSIONS

Emission limits for **Voltage** changes are defined in CC.10.13.1. ~~IEC 61000 3 7:1996 Assessment of Emission limits for fluctuating loads in MV and HV power systems, gives a table of the emission limits for Voltage changes as a function of the number of changes, R, per hour.~~ This standard shall also apply to **Controllable WFPSs**.

Allocated Harmonic Distortion Limit (AHDL)	The Allocated Harmonic Distortion Limit to a User's connection is the maximum Incremental Harmonic Voltage Distortion Level that the User's facility is allowed to introduce in the Transmission System Voltage . The AHDL is assessed at the Connection Point and it is expressed as a percentage of the RMS value of the fundamental Frequency Voltage . The AHDL applies to the THD and to each individual harmonic order from the 2 nd up to, and including, the 40 th .
Harmonic Voltage Distortion Level	The Harmonic Voltage Distortion Level of the h^{th} order is the RMS value of the steady-state sinusoidal Voltage waveform at a Frequency of $(50 \times h)$ Hz which is present in the Voltage waveform in addition to its fundamental Frequency component. The Harmonic Voltage Distortion Level is expressed as a percentage of the RMS value of the fundamental Frequency Voltage .
Incremental Harmonic Voltage Distortion Level	The incremental change in magnitude of the Harmonic Voltage Distortion Level attributed to the User's facility as measured at the Connection Point which is solely caused by the connection of the User's facility. The Incremental Harmonic Voltage Distortion Level is a combination of: (a) Distortion caused by harmonic Voltages or currents generated by the User's facility and (b) Amplification of the existing Harmonic Voltage Distortion Level caused by an interaction between the User's facility and the Transmission System harmonic impedance (for example due to resonances).
Impedance Loci	A set of diagrams characterising the Transmission System impedance vector for a range of frequencies at the Connection Point from the 2 nd up to, and including, the 40 th harmonic. These diagrams will contain polygons, whose envelopes outline the bounds of the Transmission System impedance under intact network and appropriate single contingency conditions.
Temporary Voltage Depression	A rapid change in fundamental Frequency RMS or peak Voltage over several cycles and remaining within the normal operating voltage range. This form of disturbance can manifest as an RMS Voltage depression with a slow recovery to nominal Voltage . The RMS Voltage depression is attributable to starting motors or the energisation of transformers or reactors and is characterised by the following diagram:  The diagram shows a step-down in voltage followed by a smooth, exponential-like recovery. A vertical double-headed arrow indicates the magnitude of the voltage drop, labeled as ΔV.
Total Harmonic Voltage Distortion (THD)	The Total Harmonic Voltage Distortion is the RMS value of the sum of all individual Harmonic Voltage Distortion Levels up to a specified order H , where H is set to be 40.
Voltage Flicker	The impression of unsteadiness of visual sensation induced by a light stimulus whose luminance or spectral distribution fluctuates with time.