

**Grid Code
Modification
Recommendation Form**



Title of Recommended Proposal: MPID 302 Correction of 220kV P/Q graph for remote-end Interconnector Converter Stations

MPID: 302

Date:	26/01/2023
Recommended at GCRP Meeting No.:	GCRP Meeting 09/11/2022
Grid Code Version:	Version 11
Grid Code Section(s) Impacted by Recommended Proposal:	CC.7.5.10 (f)

The Reason for the Recommended Modification:

The purpose of this Grid Code modification proposal is to correct an error in Grid Code clause CC.7.5.10 (f).

The graphs within clause CC.7.5.10(f) show a maximum voltage withstand capability of 1.118p.u. for connections at 110 kV and at 220 kV. In the case of 220 kV, this would require equipment to have the capability to continually withstand 246.4 kV. As per clause CC.8.3.2, the maximum transmission system voltages during a transmission fault for 220 kV are nominally 245 kV. This equates to an upper voltage limit of 1.114p.u. for 220 kV transmission systems.

To rectify this error in clause CC.7.5.10(f), we propose separating out the graphs for 110 kV and 220 kV, retaining the upper voltage limit for 110 kV systems of 1.118 p.u. and correcting the upper voltage limit for 220 kV systems to 1.114 p.u.

It should also be noted that Articles 18.1 and 40.1 of Commission Regulation (EU) 2016/1447 of 26 August 2016 establishing a network code on requirements for grid connection of high voltage direct current systems and direct current-connected power park modules (hereafter referred to as HVDC) outline that the maximum voltage limit for 110kV to 300kV inclusive is set at 1.118p.u, which would require a continuous voltage rating of 246 kV for 220 kV plant. We requested and were granted a [derogation](#) from the CRU to ensure that the correct voltage limit at 220 kV is applied.

History of Progression through GCRPs, Working Group and/or Consultation:

MPID 302 was presented as a proposal at the EirGrid GCRP meeting, 09 November 2022.

No comments or objections were raised from the GCRP members.

The Grid Code modification was fully supported for issue to the CRU for their approval.

Summary Note of any Objections to the Recommended Change from GCRP Members or Consultation Responses:

No objections were raised at the meeting.

Outcome of any GCRP Meeting Actions Relating to the Recommended Modification:

No actions were raised at the meeting.




Red-line Version of Impacted Grid Code Section(s) - show recommended changes to text:

Deleted text in ~~strike-through red font~~ and new text highlighted in **blue font**

CC.7.5.10 Interconnector Reactive Power



- (f) A remote end **Interconnector Converter Station** shall be capable of providing **Reactive Power** as per the following requirement at its maximum **Active Power** transmission capacity (P_{max}) at the **Connection Point**:




Green-line Version of Impacted Grid Code Sections – show recommended final text:

CC.7.5.10 Interconnector Reactive-Power



(f) A remote end **Interconnector Converter Station** shall be capable of providing **Reactive Power** as per the following requirement at its maximum **Active Power** transmission capacity (P_{max}) at the **Connection Point**:

110kV Connection Voltage



220kV Connection Voltage

