



An Coimisiún
um Rialáil Fóntas
**Commission for
Regulation of Utilities**

The Grain House
The Exchange
Belgard Square North
Tallaght, Dublin 24
D24 PXW0

T +353 1 4000 800
F +353 1 4000 850
E info@cru.ie
www.cru.ie

Miriam Ryan
Chair of Grid Code Review Panel
EirGrid
The Oval
160 Shelbourne Road
Dublin 4
D04 FW28

Date: 22/09/2026

Our Ref: CRU2026145c

Subject: Grid Code Modification MPID 345 'Fault Ride Through, Rate of Change of Frequency and Post Fault Active Power Recovery for Demand Facilities'

Dear Miriam,

I refer to EirGrid's submission of a recommendation paper to the CRU on the 01 April 2026 seeking approval of Grid Code Modification MPID 345, as recommended following the Grid Code Review Panel meeting on the 03 December 2025.

CRU Decision

MPID 345 will introduce Fault Ride Through, Rate of Change of Frequency and Active Power Recovery requirements into the Grid Code for all transmission-connected demand facilities.

The CRU's decision is to approve MPID 345. In reaching this decision, the CRU has considered the MPID 345 recommendation paper, supporting documentation provided by EirGrid and the views of stakeholders and industry, including representations made directly to the CRU and views expressed through the GCRP process and at wider industry meetings.

The CRU has published a Decision Paper CRU2026145 which sets out further detail regarding the CRU's decision to approve MPID 345. This paper is published on the CRU website.

Pursuant to Section 33 of the Electricity Regulation Act, 1999, the CRU now directs EirGrid to revise the Grid Code to take account of the approval of the MPID 345 modification. The Grid Code will be deemed to be amended five weeks from the date of this decision letter.



An Coimisiún
um Rialáil Fóntas
Commission for
Regulation of Utilities

Yours sincerely,

Sent by email and accordingly bears no signature

Deirdre O'Leary
Utility Performance Manager

cc.

Arlene Chawke, Secretary of GCRP
Mark Phelan, Secretary of DCRP
Jody O' Boyle, Utility Regulator
Ben Harris, Utility Regulator