



OVERHEAD LINE GROUND CLEARANCES	
Voltage	Clearance
110kV	7.0 m
220kV	8.0 m
400kV	9.0 m

EXCLUSION ZONE FROM CONDUCTOR	
Voltage	Clearance
110kV	4.5 m
220kV	6.0 m
400kV	8.0 m

Section C-C

- Notes
- All dimensions in millimetres.
  - Overhead line clearances derived from EirGrid functional specification for overhead lines LDS-EFS-00-001-R0.
  - Exclusion zone clearances derived from ESBN Code of practice for avoiding danger from overhead lines.
  - Conductor swing path based on midspan blow out at minimum ground clearance.
  - This drawing does not specify clearances at structures. Refer to drawing MMD-373966-E-SK-00-XX-0013 for clearance at structures.
  - There is a statutory obligation for the developer to notify ESB prior to the erection of any structure within a 46 metre corridor of an overhead line. This notification shall be made in writing at least two months prior to commencement of construction works.

Key to symbols

- Clear area for placement of Solar panels
- 3 metre height restriction on Solar panels

Reference drawings

Proposed 400kV setback distances plan view: MMD-373966-E-SK-00-XX-0013

P1	17/11/2017	SHY	Issued for Comment	DMC	DMC
Rev	Date	Drawn	Description	Ch'k'd	App'd

**MOTT MACDONALD**

South Block  
Rockfield  
Dundrum  
Dublin, 16  
Ireland  
T +353 (0) 1 2916700  
F +353 (0) 1 2916747  
W mottmac.com



Title

Transmission Line and Solar Farm Clearances  
Proposed 400kV Setback Distances  
Section Drawing

Designed	E. Halpenny	Eng check	D. McCormack
Drawn	S.Healy	Coordination	G. McCarthy
Dwg check	D. McCormack	Approved	D. McCormack
Scale at A1	Status	Rev	Security
1:200	PRE	P1	STD

Drawing Number

MMD-373966-E-SK-00-XX-0023

