



**Notes**

- All dimensions are in metres.
- Arrangement based on typical 110kV conductor spacings and spans.
- There is a statutory obligation for the developer to notify ESB prior to the erection of any structure within a 46 metre corridor of an overhead line. This notification shall be made in writing at least two months prior to commencement of construction works.

**Key to symbols**

- Transmission line
- Transmission tower
- Wood pole set
- Stay Wire
- Exclusion zone
- 3 metre height restriction on panels
- Panels to be demountable
- No restrictions on solar panels

**Reference drawings**

Refer to drawing MMD-373966-E-SK-00-XX-0021 for section AA.

P01	17/11/2017	SHY	Issued for Comment	DMC	DMC
Rev	Date	Drawn	Description	Ch'k'd	App'd

**MOTT MACDONALD**

South Block  
Rockfield  
Dundrum  
Dublin, 16  
Ireland  
T +353 (0) 1 2916700  
F +353 (0) 1 2916747  
W mottmac.com

**Client**

**Title**

Transmission Line and Solar Farm Clearances  
Proposed 110kV Setback Distances  
Layout Drawing

Designed	E. Halpenny	Eng check	D. McCormack
Drawn	S.Healy	Coordination	G. McCarthy
Dwg check	D. McCormack	Approved	D. McCormack
Scale at A1	Status	Rev	Security
1:1000	PRE	P01	STD

Drawing Number  
**MMD-373966-E-SK-00-XX-0011**

