



**Transmission  
Development Plan  
2019-2028**



**The current. The future.**

## Disclaimer

While all reasonable care has been taken to prepare this document, we can make no guarantee to the quality, accuracy and completeness of the information herein. We do not accept responsibility for any loss associated with the use of this information. Use of this document and the information it contains is at the user's own risk.

Information in this document does not amount to a recommendation as regards to any possible investment. Before taking a business decision based on the content of this document, we advise that interested parties seek separate and independent opinion in relation to the matters covered by this document.

## Copyright Notice

All rights reserved. This entire publication is subject to the laws of copyright. This publication may not be reproduced or transmitted in any form or by any means, electronic or manual, including photocopying without the prior written permission of EirGrid plc.

# Table of Contents

<b>Executive Summary</b> .....	<b>1</b>
<b>Document Structure</b> .....	<b>2</b>
<b>Abbreviations and Glossary of Terms</b> .....	<b>3</b>
Abbreviations .....	3
Glossary of Terms .....	5
<b>1. Introduction</b> .....	<b>9</b>
1.1. Statutory and Licence Requirements .....	10
1.2. Transmission Development Plan 2019 .....	10
1.3. Process for developing the Transmission Development Plan .....	11
1.4. Context of the Plan .....	11
1.4.1. All-Island and European Context .....	11
1.4.2. Tomorrow’s Energy Scenarios .....	12
1.4.3. Grid Development Strategy .....	12
1.4.4. Capital Expenditure .....	12
1.4.5. United Kingdom’s referendum on EU membership .....	13
1.4.6. Climate Action Plan .....	13
1.5. Planning Area Categorisation .....	14
<b>2. Approach and Methodology</b> .....	<b>16</b>
2.1. Development Objectives and Strategies .....	17
2.2. The Transmission System Security and Planning Standards (TSSPS) .....	17
2.3. Public Planning and Environmental Considerations .....	18
2.3.1. Overview .....	18
2.3.2. Public Planning Considerations .....	18
2.3.3. Environmental Considerations .....	19
2.3.4. Strategic Environmental Assessment .....	20
2.4. Six-Step Process for Developing the Grid .....	20
2.4.1. Step 1: How do we identify the future needs of the electricity grid? .....	20
2.4.2. Step 2: What technologies can meet these needs? .....	21
2.4.3. Step 3: What’s the best option and what area may be affected? .....	21
2.4.4. Step 4: Where exactly should we build? .....	22
2.4.5. Step 5: The planning process .....	22
2.4.6. Step 6: Construction, energisation and benefit sharing .....	22
<b>3. Investment Needs</b> .....	<b>23</b>
3.1. Strategic Context of Transmission Network Investment .....	24
3.2. National and European Energy Policy .....	24

3.2.1. Security of Supply .....	24
3.2.2. Competitiveness .....	24
3.2.3. Sustainability .....	25
3.3. Policy Drivers of Transmission Network Investment .....	25
3.3.1. Security of Transmission Network .....	25
3.3.2. Market Integration .....	25
3.3.3. Renewable Energy Sources Integration .....	26
3.4. Technical Drivers for Transmission Network Investment .....	26
3.4.1. Demand, Generation and Interconnection .....	26
3.4.2. Changes in Inter-Regional Power Flows .....	28
3.4.3. Changes in Asset Condition .....	28
3.5. Network Development Needs .....	28
<b>4. Changes to the Plan Since 2018 .....</b>	<b>30</b>
4.1. Projects Completed since TDP 2018 .....	31
4.2. Projects Added to “On-going Projects” in 2018 .....	32
4.3. Projects On Hold .....	33
<b>5. Planned Network Developments .....</b>	<b>34</b>
5.1. Overview of the Plan .....	35
5.2. Summary of Step of Projects .....	35
5.2.1. Works Outside Scope of This Plan .....	35
5.3. Project Delivery .....	37
<b>6. Regional View .....</b>	<b>38</b>
6.1. Overview .....	39
6.2. The Border, Midlands and West Planning Area .....	39
6.3. The South-West and Mid-West Planning Area .....	46
6.4. The South-East, Mid-East and Dublin Planning Area .....	52
<b>7. Summary of Environmental Appraisal Report .....</b>	<b>58</b>
<b>Appendix A: Project Terms .....</b>	<b>60</b>
<b>Appendix B: Planned Network Developments .....</b>	<b>61</b>
Projects in the Border, Midlands and West Planning Area .....	62
Projects in the South-West and Mid-West Planning Area .....	66
Projects in the South-East, Mid-East and Dublin Planning Area .....	71
National Projects .....	78
<b>Appendix C: Irish Projects in European Plans .....</b>	<b>79</b>
How are Irish transmission projects included in ENTSO-E’s TYNDP? .....	79
<b>Appendix D: References .....</b>	<b>82</b>

# Executive Summary

The Transmission Development Plan (TDP) 2019-2028 is the plan for the development of the Irish transmission network and interconnection over the ten years from 2019. The TDP contains a list of the committed projects as at 01 January 2019. Other projects may be included in subsequent TDPs as a result of our assessment of the impact of the Government's Climate Action Plan which was published in June 2019.

The TDP 2019-2028 succeeds the TDP 2018-2027. This ten year plan presents projects that are needed for the operation of the transmission network. In addition, future needs that may drive future potential projects are also discussed.

The plan has been prepared in accordance with our statutory and licence obligations.

## Transmission Network Development

The development of the Irish electricity sector is guided by a number of national and European Union (EU) policy and strategic objectives. These objectives guide investment in the Irish transmission network and are summarised as follows:

- Ensuring the security of electricity supply;
- Ensuring the competitiveness of the national economy; and
- Ensuring the long-term sustainability of electricity supply in the country.

In order to achieve these strategic objectives, we must invest in the development and maintenance of the electricity transmission network. Drivers of investment include:

- Securing transmission network supplies;
- Supporting market integration; and
- Supporting the integration of Renewable Energy Sources (RES) and complementary thermal generation and devices that provide system services.

As demand or generation changes, or as the transmission network becomes more interconnected with neighbouring transmission networks<sup>1</sup>, the flow of electrical energy throughout the transmission network changes. To accommodate these changes in power flows, it is often necessary to modify or strengthen the transmission network to ensure performance and reliability levels are upheld.

In addition, the condition of transmission network assets is a factor. The timely maintenance or replacement of assets is required to provide the necessary level of security of supply.

## Changes to the Plan since TDP 2018

There were 109 active projects in TDP 2018. Since then 22 projects have been completed and 23 projects have been added to the development plan.

There are 104 active projects in this development plan. The changes since TDP 2018 are described in greater detail in Chapter 4.

---

<sup>1</sup> The European electric power transmission networks are interconnected, so as to be able to transmit energy from one country to the other.

# Document Structure

This document contains:

- An Abbreviations and Glossary of Terms section;
- An Executive Summary;
- Seven main sections; and
- Four appendices.

The structure of the document is as follows:

The **Abbreviations and Glossary of Terms** provides a glossary of terms used in the document.

The **Executive Summary** gives an overview of the main highlights of the document and presents the plan in summary terms.

## **Section 1: Introduction**

Our statutory and legal obligations are introduced. The purpose and context of the Transmission Development Plan (TDP) is outlined.

## **Section 2: Approach and Methodology**

Describes our approach to the network planning process and our strategies.

## **Section 3: Investment Needs**

The drivers of network development are introduced and discussed, as are the needs of the network which result from these drivers. The needs are identified through the application of the transmission development approach discussed in Section 2.

## **Section 4: Changes to the Plan since 2018**

Provides information on the changes to the plan between TDP 2018 and TDP 2019.

## **Section 5: Planned Network Developments**

Summarises the development projects that are currently in progress. These are the transmission projects which solve the network needs identified and discussed in Section 3.

## **Section 6: Regional View**

Summarises and categorises the development projects that are currently in progress by location.

## **Section 7: Summary of Environmental Appraisal Report (EAR)**

Summarises the EAR of TDP 2019.

## **Appendix A: Project Terms**

## **Appendix B: Planned Network Developments**

## **Appendix C: Irish Projects in European Plans**

## **Appendix D: References**

# Abbreviations and Glossary of Terms

## Abbreviations

AA	Appropriate Assessment
ABP	An Bord Pleanála
ATR	Associated Transmission Reinforcement(s)
CER	Commission for Energy Regulation
CP No.	Capital Project Identification Number
CPP	Committed Project Parameters
CRU	Commission for Regulation of Utilities
DSO	Distribution System Operator
EAR	Environmental Appraisal Report
EC	European Commission
ECD	Estimated Completion Date
EIA	Environmental Impact Assessment
EIS	Environmental Impact Statement
ENTSO-E	European Network of Transmission System Operators for Electricity
ER	Environmental Report
ESB	Electricity Supply Board
EU	European Union
EWIC	East West Interconnector
GCS	Generation Capacity Statement
GIS	Gas Insulated Switchgear
GW	Gigawatt
HV	High Voltage
HVDC	High Voltage Direct Current
IA	Infrastructure Agreement
IP	Implementation Programme
LPA	Local Planning Authority
MEC	Maximum Export Capacity
MIC	Maximum Import Capacity
MW	Megawatt
NIS	Natura Impact Statement

PA	Project Agreement
RegIP	Regional Investment Plan
RES	Renewable Energy Sources
RGNS	Regional Group North Sea
RIDP	Renewable Integration Development Project
SAC	Special Area of Conservation
SEA	Strategic Environmental Assessment
SI60	Statutory Instrument No. 60 of 2005
SI147	Statutory Instrument No. 147 of 2011
SI445	Statutory Instrument No. 445 of 2000
SONI	System Operator Northern Ireland
SPA	Special Protection Areas
TAO	Transmission Asset Owner
TDP	Transmission Development Plan
TSO	Transmission System Operator
TSSPS	Transmission System Security and Planning Standards
TYNDP	Ten-Year Network Development Plan
TYTFS	Ten Year Transmission Forecast Statement



## Glossary of Terms

Bay	A connection point to a busbar and comprises switchgear and measurement equipment.
Busbar	An electrical conductor located in a station that makes a common connection between several circuits.
Capacitor	An item of plant normally used on the electrical network to supply reactive power to loads (generally locally) and thereby support the local area voltage.
Circuit	A line or cable, including associated switchgear, which carries electrical power.
Circuit Breaker	A device used to open a circuit that is carrying electrical current.
Constraint	A change in the output of generators from the market schedule due to transmission network limitations - specifically the overloading of transmission lines, cables and transformers.
Contingency	An unexpected failure or outage of a network component, such as a generation unit, transmission line, transformer or other electrical element.
Coupler	This is a device which can be used to either connect or disconnect sections of busbars. A coupler increases security of supply and flexibility under both fault and maintenance conditions. A coupler can also be known as a Sectionalising Circuit Breaker.
Deep Reinforcement	Refers to network reinforcement additional to the shallow connection that is required to allow a new generator or demand to operate at maximum export or import capacity respectively.
Demand	The amount of electrical power that is consumed by a customer and is measured in Megawatts (MW). In a general sense, the amount of power that must be transported from transmission network connected generation stations to meet all customers' electricity requirements.
Demand-Side Management	The modification of normal demand patterns usually through the use of financial incentives.
Deterministic Methodology	The deterministic methodology is often referred to as the N-1 criterion. This means that the system must have sufficient capacity so that in the eventuality of a probable system outage, there are no resulting system problems such as overloading, under-voltage, over-voltage or instability.
Distribution System Operator	In the electrical power business, a distribution system operator is the licensed entity responsible for: <ul style="list-style-type: none"><li>• Operating and ensuring the maintenance and development of the distribution system in a given area (and its interconnections), if necessary and where applicable; and</li><li>• Ensuring the long term ability of the system to meet reasonable demands for electrical power.</li></ul>
EirGrid	The independent statutory electricity Transmission System Operator in Ireland.
Embedded Generation	Refers to generation that is connected to the distribution network or at a customer's site.

Gas Insulated Switchgear (GIS)	A compact form of switchgear where the conductors and circuit breakers are insulated by an inert gas (that is, typically SF <sub>6</sub> ).
Gate	A group processing mechanism to efficiently process large volumes of connection applications from renewable and conventional generators wishing to connect to the transmission or distribution systems. This is a CRU approved and directed approach.
Generation Dispatch	The configuration of outputs from the connected generation units.
Grid	A network of high voltage lines and cables (400 kV, 275 kV, 220 kV and 110 kV) used to transmit bulk electricity supplies around Ireland. The terms grid, electricity transmission network, and transmission system are used interchangeably in this Development Plan.
Intact Network	The transmission network with no network element removed for maintenance, replacement or repair.
Interconnector	The electrical link, facilities and equipment that connect the transmission network of one EU member state to another.
Maintenance trip conditions	This condition occurs when a network component (generation unit, transmission line, transformer or other electrical element) is out of service for maintenance, and there is an unexpected failure or outage of another network component.
Maximum Export Capacity (MEC)	The maximum export value (MW) provided in accordance with a generator's connection agreement. The MEC is a contract value which the generator chooses as its maximum output.
Maximum Import Capacity (MIC)	The maximum import value (MW) provided in accordance with a customer's connection agreement. The MIC is a contract value which a customer chooses to cater for maximum demand at their site.
Network Development Driver	A factor based on national and European energy policy objectives that influences or "drives" the investment in the transmission network.
Network Development Need	A deficiency or problem on the network which arises as a result of one or a number of network development drivers. Network reinforcement is required to solve a network development need.
Power Flow	The physical flow of electrical power. It is typically measured in Megavolt-Amperes (MVA) which is the product of both 'active' and 'reactive' electrical power. The flow of 'active' power is measured in Megawatts (MW); the flow of 'reactive power' is measured in Megavars (Mvar).
Phase Shifting Transformer (PST)	A type of plant employed on the electrical network to control the flow of active power.
Reactive Compensation	The process of supplying reactive power to the network to compensate for reactive power usage at a point in time.
Reactive Power	The portion of electricity that establishes and sustains the electric and magnetic fields of alternating current equipment. Reactive power is measured in Megavars (Mvar).

Reactor	An item of plant comprising a coil of electrical wire. It is typically employed on the electrical network to either: <ul style="list-style-type: none"> <li>• Limit short circuit levels; or</li> <li>• Prevent voltage rise,</li> </ul> depending on its installation and configuration.
Series Compensation	A technology that boosts flows on very long transmission lines. There have been recent advances in this technology and its control systems. This allows for greater flexibility and more benefits when using series compensation.
Shallow Connection	The local connection assets required to connect a customer, or customers, to the transmission network. These types of connections are typically for the specific benefit of that particular customer or group of customers.
Single contingency conditions	This condition occurs when the transmission network is intact and there is an unexpected failure or outage of one network component (generation unit, transmission line, transformer or other electrical element).
Summer Valley	The annual minimum electrical demand that usually occurs in August. Annual minimum demand is typically 35% of the winter peak.
Summer Peak	The week-day peak electrical demand value between March and September, inclusive, which is typically 80% of the winter peak.
Switchgear	A combination of electrical equipment such as disconnects and/or circuit breakers used to isolate equipment in or near an electrical station.
Transformer	An item of electrical equipment that allows electrical power to flow between typically two different voltage levels in an alternating current (AC) power system.
Transmission Losses	A small proportion of energy is lost as heat or light whilst transporting electricity on the transmission network. These losses are known as transmission losses.
Transmission Peak	The peak demand that is transported on the transmission network. The transmission peak includes an estimate of transmission losses.
Transmission System Security and Planning Standards	The set of standards that the transmission system is designed to meet. The criteria are deterministic as is the norm throughout the world. They set out objective standards which have been found to deliver an acceptable compromise between the cost of development and the transmission service provided. The Transmission System Security and Planning Standards were previously referred to as the Transmission Planning Criteria.
Transmission System Operator	In the electrical power business, a transmission system operator is the licensed entity that is responsible for: <ul style="list-style-type: none"> <li>• Operating and ensuring the maintenance and development of the transmission system in a given area (and its interconnections), if necessary and where applicable; and</li> <li>• Ensuring the long term ability of the system to transmit electrical power from generation plants to transmission connected demand and regional or local electricity distribution operators.</li> </ul>

Upgrade

To increase the capacity or rating of electrical equipment.

Winter Peak

This is the maximum annual system demand. It occurs in the period October to February of the following year, inclusive. Thus, for transmission planning purposes the winter peak 2019, the first year of this plan, may occur in early 2020. The winter peak figures take account of the impact of projected Demand-Side Management initiatives.



# 1. Introduction

1



# 1. Introduction

The transmission system is a network of 400 kV, 275 kV, 220 kV and 110 kV high voltage lines and cables. It is the backbone of the power system; efficiently delivering large amounts of power from where it is generated to where it is needed, safely and reliably.

Electricity supply is essential, and a reliable electricity network is the means by which we move electricity around the country. The development of transmission network infrastructure is therefore, of national strategic importance.

The Transmission Development Plan (TDP) outlines the:

- Drivers of network development;
- Network investment needs; and
- Projects required to address these needs.

This TDP covers Ireland only as it is not an all-island plan. SONI, the electricity System Operator for Northern Ireland, produces the TDP for Northern Ireland<sup>2</sup>.

## 1.1. Statutory and Licence Requirements

We are responsible for the operation and development of the transmission network in Ireland. We have both statutory and licence obligations to produce a TDP annually, these are:

- Regulation 8(6) of Statutory Instrument (SI) No. 445 of 2000<sup>3</sup> as amended;
- Condition 8 of EirGrid's Transmission System Operator (TSO) Licence; and
- Article 22 of Directive 2009/72/EC<sup>4</sup>.

## 1.2. Transmission Development Plan 2019

TDP 2019 presents our view of future transmission needs and our plan to develop the network through specific projects, to meet these needs over the next ten years.

It is possible that changes will occur in the need for, scope of, and timing of the listed developments. Similarly, it is likely, given the continuously changing nature of electricity requirements, that new developments will emerge that could affect the plan as presented. These changes will be identified in future studies and accommodated in future TDPs. As such, the long-term development of the network is under review on an ongoing basis.

Other projects may be required and will be included in subsequent TDPs once the latest version of the TES is concluded and the impact of the climate action plan is fully assessed.

This TDP presents the projects which are currently being advanced to solve the needs of the transmission network. In addition, future needs that drive future potential projects are also discussed. To help the comparison of network development projects year-on-year and in the interest of routine reporting, data is represented at a fixed point in time – the data freeze date. The freeze date for project inclusion for this TDP is 01 January 2019. The previous TDP, TDP 2018, had a freeze date of 01 January 2018. The freeze date aligns with the freeze date for other documents and processes<sup>5</sup>.

In this TDP we report projects according to our six-step process for developing the grid. The six-step process is set out in Section 2.4 and in our “Have Your Say” document<sup>6</sup>.

2 <http://www.soni.ltd.uk/the-grid/projects/tdpni-2018-27/the-project/>

3 SI No. 445 of 2000, European Communities (Internal Market in Electricity) Regulations

4 Article 51 of Directive 2019/944 replaces this article and comes into force in 2020.

5 All Island Ten Year Transmission Forecast Statement (TYTFS), PR4 Capex Reporting and Transmission Development Plan for Northern Ireland

6 [http://www.eirgridgroup.com/\\_\\_uuid/7d658280-91a2-4dbb-b438-ef005a857761/EirGrid-Have-Your-Say\\_May-2017.pdf](http://www.eirgridgroup.com/__uuid/7d658280-91a2-4dbb-b438-ef005a857761/EirGrid-Have-Your-Say_May-2017.pdf)

The estimated completion date (ECD) and step in the six-step process for some transmission projects, known as Associated Transmission Reinforcements (ATRs), are available and updated on a quarterly basis on our website [here](#)<sup>7</sup>.

### 1.3. Process for developing the Transmission Development Plan

This TDP covers a period of ten years. As part of the preparation of the TDP, we consult with SONI to ensure that the information is accurate. A public consultation on the draft TDP is held by the CRU. Following feedback received from the public consultation we update the TDP, as required, and provide a report to the CRU on feedback received. We prepare the final version of the TDP and submit it to the CRU for approval.

The Transmission Asset Owner (TAO), ESB Networks Limited, is responsible for the construction of projects. This document provides them with our future plans to develop the network, which they can use to plan construction and maintenance on the network.

### 1.4. Context of the Plan

The development of the transmission network involves forecasting future needs. Solutions to address these needs must strike a balance between network reliability, costs and environmental impacts. The process is flexible to enable the long-term development of the network.

Considerations that shape the medium and long-term development of the transmission network are outlined below.

#### 1.4.1. All-Island and European Context

Our TSO licence obliges us to carry out transmission planning on a coordinated all-island basis with SONI. This requirement is met by the System Operator Agreement in place between EirGrid and SONI.

Each year EirGrid and SONI jointly prepare the All-Island Generation Capacity Statement (GCS). The GCS outlines demand forecasts and assesses the generation adequacy of the island of Ireland over the ten year period covered by the GCS.

Each year EirGrid and SONI also jointly prepare the All-Island Ten Year Transmission Forecast Statement (TYTFS). The TYTFS provides detailed data and models of the transmission system. The TYTFS is designed to assist users and potential users of the transmission system to identify opportunities to connect to and make use of the transmission system. The demand forecast in the TYTFS is based on the demand forecast in the GCS.

As mentioned above, SONI publishes the Transmission Development Plan for Northern Ireland. The TDPs for Ireland and Northern Ireland provide details of the transmission system developments expected to be progressed in Ireland and Northern Ireland in the coming 10 years. These transmission system developments are also included in the data, assumptions and analyses in the TYTFS.

European legislation requires all European TSOs to cooperate through the European Network of Transmission System Operators for Electricity (ENTSO-E). ENTSO-E has six regional groups that coordinate network planning and development at regional level. We are members of the Regional Group North Sea (RGNS). ENTSO-E publishes a Ten Year Network Development Plan (TYNDP) every two years. The TYNDP outlines projects of European significance.

It is important that readers of this TDP are aware of the all-island and European context. Readers should consider these other documents and also our approach to scenario planning detailed in the next section.

---

<sup>7</sup> <http://www.eirgridgroup.com/customer-and-industry/general-customer-information/operational-constraints/>

Readers, in particular users or potential users of the transmission system, may also find it beneficial to consult specific sections in the TYTFS. The specific sections ‘How to Use the Information for Generation’ and ‘How to Use the Information for Demand’ are in Sections 7 and 8 of the TYTFS respectively. The sections outline how generation and demand customers can use the ‘opportunities to connect’ information in the TYTFS.

### 1.4.2. Tomorrow’s Energy Scenarios

In 2017, to cater for the increased level of uncertainty over the future usage of the grid, we introduced scenario planning into our grid development process. We call our scenarios Tomorrow’s Energy Scenarios<sup>8</sup> (TES).

Our scenarios detail credible futures for the electricity sector in Ireland, with specific focus on what this means for the electricity transmission system over the next twenty years and beyond. The underlying assumptions in the scenarios are validated using feedback received from policy makers, industry and the general public as part of an open consultation.

When the scenarios are finalised, we use them to test the performance of the electricity transmission grid and publish the results in the TES System Needs Assessment (SNA)<sup>9</sup>. The TES process occurs every 2 years.

The need and requirement for transmission services is continuously evolving. Therefore, in addition to needs identified in TES SNA, further system needs may be identified in the two year period between iterations of the Tomorrow’s Energy Scenarios. Examples of changes that may arise that could result in further needs include plant closures and new connections that arise through the connection offer process.

The needs identified in the TES process are brought through our six-step process for developing the grid. As needs and projects progress through the six-step process they are included in the TDP.

### 1.4.3. Grid Development Strategy

We published our grid development strategy in January 2017<sup>10</sup>. In it we outline our three strategy statements:

- Inclusive consultation with local communities and stakeholders will be central to our approach;
- We will consider all practical technology options; and
- We will optimise the existing grid to minimise the need for new infrastructure.

Our strategy statements guide and influence how we develop the grid.

### 1.4.4. Capital Expenditure

This plan considers 104 projects that are underway. These projects need funding for the timeframe addressed by this TDP (2019-2028) and beyond. The Commission for Regulation of Utilities<sup>11</sup> (CRU) has approved allowable capital expenditure of €984 million on network projects in the current price review period (2016-2020, CER/15/296)<sup>12</sup>.

<sup>8</sup> The latest Tomorrow’s Energy Scenarios information is available at the following link:

<http://www.eirgridgroup.com/customer-and-industry/energy-future/>

<sup>9</sup> TES 2017 System Needs Assessment Report:

<http://www.eirgridgroup.com/site-files/library/EirGrid/tes-2017-system-needs-assessment-final.pdf>

TES 2019 System Needs Assessment Report:

[http://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid-TES-2019-System-Needs-Assessment-Report\\_Final.pdf](http://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid-TES-2019-System-Needs-Assessment-Report_Final.pdf)

<sup>10</sup> <http://www.eirgridgroup.com/the-grid/irelands-strategy/>

<sup>11</sup> Formerly the Commission for Energy Regulation (CER).

<sup>12</sup> <https://www.cru.ie/wp-content/uploads/2015/07/CER15296-Decision-on-TSO-and-TAO-Transmission-Revenue-for-2016-to-2020-1.pdf>



The CRU and EirGrid have a framework in place for monitoring transmission capital expenditure. This framework provides flexibility to respond to the identified needs which are influenced by external factors; including changes in generation and demand, amongst others. Expenditure beyond 2020 will be considered and approved in future price reviews.

#### **1.4.5. United Kingdom's referendum on EU membership**

The United Kingdom's June 2016 referendum on EU membership has presented undoubted challenges and uncertainties for the Irish energy market. However, most issues covered by our grid development strategy and this development plan relate to Ireland only, and are unaffected.

Regardless of the UK leaving the EU, there will always be many shared benefits of working closely with our nearest neighbours. We aim to maintain a strong relationship between Ireland, Northern Ireland and Great Britain on electricity matters.

#### **1.4.6. Climate Action Plan**

In June 2019 the Irish Government launched its Climate Action Plan 2019<sup>13</sup>. The Action Plan sets out an ambitious course of action over the coming years. Specifically for the electricity sector it sets a target that 70% of our electricity will come from renewable energy sources by 2030.

In order to meet this target, investment will be needed in new renewable generation capacity, system service infrastructure and electricity networks. The transition to low-carbon and renewable energy will have widespread consequences, indeed it will require a significant transformation of the electricity system.

In September 2019 we launched our Strategy 2020-2025<sup>14</sup> which is shaped by two factors: climate change and the impending transformation of the electricity sector. We are committed to leading the change towards a carbon-free electricity system and achieving the 70% renewable energy target by 2030.

The TDP contains a list of the committed projects as at 01 January 2019. Other projects may be included in subsequent TDPs as a result of our assessment of the impact of the Government's Climate Action Plan.

<sup>13</sup> <https://www.gov.ie/en/publication/5350ae-climate-action-plan/>

<sup>14</sup> <http://www.eirgridgroup.com/about/strategy-2025/>

## 1.5. Planning Area Categorisation

Power flows on the transmission network are not contained within specific counties. To help project reporting and give a regional perspective to our TDP we group counties together to create what we call planning areas. We use three planning areas to help communicate the development of the transmission system in Ireland:

1. The Border, Midlands and West;
2. The Mid-West and South-West; and
3. The South-East, Mid-East and Dublin.

These three planning areas are made up of eight underlying regions and associated counties as follows:

1. Border: Donegal, Sligo, Leitrim, Cavan and Monaghan;
2. Midlands: Longford, Westmeath, Offaly and Laois;
3. West: Mayo, Galway and Roscommon;
4. South-West: Kerry and Cork;
5. Mid-West: Clare, Limerick and Tipperary<sup>15</sup>;
6. South-East: Waterford, Wexford, Kilkenny and Carlow;
7. Mid-East: Wicklow, Kildare, Meath and Louth<sup>16</sup>;
8. Dublin.

These eight regions are Ireland's regions as per the Nomenclature of Territorial Units for Statistics (NUTS) 3 classification. These regions are also used by government agencies in Ireland, including IDA Ireland and the Central Statistics Office.

The eight regions are illustrated in Figure 1-1 below.

---

<sup>15</sup> Formerly Tipperary was split into North Tipperary, which was in the Mid-West region, and South Tipperary which was in the South-East region.

<sup>16</sup> Formerly Louth was in the Border region.



**Figure 1-1: Illustration of Ireland’s regions as per the Nomenclature of Territorial Units for Statistics (NUTS) 3 classification**

Planned projects are categorised in Chapter 6 “Regional View” on a planning area basis, as defined above.

The background is a composite image. The top half shows a dark sky filled with numerous glowing, wavy lines in shades of purple, blue, and white, resembling a digital or data visualization. The bottom half shows a landscape with a river flowing through a forest of trees with autumn foliage, and a large, rounded mountain in the background under a clear sky.

## 2. Approach and Methodology

2

## 2. Approach and Methodology

### 2.1. Development Objectives and Strategies

As TSO, we are obliged to develop a safe, secure, reliable, economical, and efficient transmission network to meet all reasonable demands for electricity, in accordance with legal obligations.

We plan the development of the transmission network taking account of the needs of the transmission system. The need for development is determined by assessing long-term future network performance against technical standards. These technical standards are embodied in the Transmission System Security and Planning Standards<sup>17</sup> (TSSPS). When it is established that changes on the network cannot be accommodated without violating the performance criteria outlined in the TSSPS, a range of issues are considered when selecting a transmission reinforcement strategy.

When assessing development options to address future potential network needs, we use our six-step process for developing the grid. This TDP presents data relating to all on-going projects that are in Steps 4-6 of our six-step process on the freeze date of 01 January 2019. This TDP also includes information on investigations and projects that are in the early stages of development, that is Steps 1-3. We include the information in Chapter 6 in the 'Future Needs Driving Potential Projects' sections. In addition, our Associated Transmission Reinforcement (ATR) quarterly update includes the step that each project is in. Our ATR update is published quarterly on our website [here](#)<sup>18</sup>.

Within our six-step process, we consider the impacts of each possible option on other potential development needs. Sometimes by making more effective use of the existing network, we can delay large investment or avoid the need for additional circuits.

In some cases a proposed project may meet more than one development requirement and prove more economic and have less impact on the environment than multiple projects. Where possible, we seek to find single development projects to meet multiple network requirements.

Public planning and environmental considerations assist in the development of transmission infrastructure projects. An overview of the public planning and environmental considerations, as well as the TSSPS can be found below.

### 2.2. The Transmission System Security and Planning Standards (TSSPS)<sup>19,20</sup>

The requirement for network development is identified when the simulation of future conditions indicates that the TSSPS would be breached. These standards are in line with international standards.

The standards are deterministic<sup>21</sup> – as are those generally used throughout the world in transmission planning. They set out an objective standard which delivers an acceptable compromise between the cost of development and service delivered. Rather than conducting subjective benefit analysis in each case, it is preferable to plan to meet an objective standard and carry out analysis of the options available to meet the standard.

17 <http://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid-Transmission-System-Security-and-Planning-Standards-TSSPS-Final-May-2016.pdf>

18 <http://www.eirgridgroup.com/customer-and-industry/general-customer-information/operational-constraints/>

19 Previously referred to as the Transmission Planning Criteria

20 <http://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid-Transmission-System-Security-and-Planning-Standards-TSSPS-Final-May-2016-APPROVED.pdf>

21 The deterministic methodology is often referred to as the N-1 criterion. The system must have sufficient capacity so that in the eventuality of a probable system outage, there are no resulting system problems such as overloading, under-voltage, over-voltage or instability.

## 2.3. Public Planning and Environmental Considerations

### 2.3.1. Overview

We have a team of experienced, professional planning and ecological consultants embedded in our Grid Development and Interconnection Department. These consultants assist in the development of transmission infrastructure projects and in other aspects of network development from a planning and environmental perspective. This section provides an overview of the approach taken on individual projects, taking into account best practice and legal requirements. In addition, Section 2.3.4 outlines our approach to Strategic Environmental Assessment (SEA) for Grid Implementation Plans. These plans are based on broader strategy approaches to grid development but include aspects of any relevant Transmission Development Plans. An Environmental Appraisal Report accompanies this TDP to ensure that it is in accordance with the provisions of the Strategic Environmental Objectives detailed in the SEA for the Grid Implementation Plan 2017-2022. A summary of the results of this appraisal is presented in Section 7 of this report.

### 2.3.2. Public Planning Considerations

Statutory consent for transmission projects is sought on a project-by-project basis, as required under the Planning and Development Acts. At the outset, our public planning specialists determine whether permission is needed for a proposed development, or whether, under the current planning and development legislation, such works may comprise exempted development – that which does not require a prior grant of approval or permission. These in particular might include uprate, whereby the capacity or rating of electrical equipment is increased, refurbishment and maintenance works.

We currently undertake a process to confirm our consideration of the exempted status of such works. This process also involves Screening for Appropriate Assessment (AA), which is a statutory obligation under Article 42 of the European Communities<sup>22</sup> Regulations 2011-15. Where it is determined that planning permission is required, we engage with An Bord Pleanála (ABP) which determines if a proposed development falls within the scope of Section 182A of the Planning and Development Acts 2000 to 2014, which relates to Strategic Infrastructure Development (SID). If it does fall within Section 182A, an application for approval is made directly to the Strategic Infrastructure Division of ABP. If ABP determines that the proposal does not fall within Section 182A, it directs us to make an application for permission to the relevant Local Planning Authority (LPA).

The decision-making authority (ABP or LPA) will determine whether the application for development is in accordance with the principles of proper planning and sustainable development. Considerations in this regard include:

- EU directives and governing statutory and strategic policy;
- Conformity with the provisions of key documents such as relevant development plans and Regional Planning Guidelines;
- Input from Prescribed Bodies, such as the:
  - Relevant LPA (if the decision-maker is ABP);
  - Department of Communications, Climate Action and Environment;
  - Department of Housing, Planning, Community and Local Government; and
  - National Parks and Wildlife Service of the Department of Arts, Heritage and Gaeltacht.
- Requirements to protect designated areas on account of their ecological, cultural, archaeological, visual, or other sensitivity and/or significance.

---

<sup>22</sup> Birds and Natural Habitats

### 2.3.3. Environmental Considerations

The requirements for Environmental Impact Assessment (EIA) and Appropriate Assessment (AA) are transposed into Irish law in the Planning and Development Acts and associated regulations.

Where necessary, applications for statutory consent are accompanied by an Environmental Report (ER) or Environmental Impact Assessment Report (EIAR) - the need for a statutory EIAR is informed by way of an EIA Screening report.

Similarly, screening for the need for AA for impacts on European sites, designated Special Conservations Areas (SAC) or Special Protection Areas (SPA), is routinely undertaken for all our grid projects.

#### Environmental Impact Assessment (EIA)

Projects where EIA is mandatory are identified on Annex I of the EIA Directive (2014) and in Irish legislation under the Planning and Development Acts and relevant regulations. For transmission infrastructure, this includes transmission of electricity by overhead lines where:

- The voltage is 220 kV or more; and
- The circuit length is more than 15 km.

An EIS may be required for sub-threshold development where likely significant impacts on the environment are identified by the relevant LPA or ABP.

The content and scope of the EIAR is defined by the EIA Directive (2014). However, detail varies between projects depending on local environmental sensitivities.

#### Appropriate Assessment (AA)

In accordance with the provisions of Article 6 (3) of the EU Habitats Directive, any plan or project not directly connected to a Natura 2000 site (Special Area of Conservation (SAC) or Special Protection Area (SPA)), that is likely to have a significant effect on the site is subject to Appropriate Assessment (AA) of its implications on the site.

The requirements for AA are set out in:

- Article 6 (3) of the EU Habitats Directive (92/43/EEC);
- The European Communities (Birds and Natural Habitats) Regulations 2011-2015; and
- Part XAB of the Planning and Development Act.

Both the habitats and birds directives have been fully transposed into Irish law. The provisions of Part XAB of the Planning and Development Act require, among other things, that an AA “shall include a determination by the competent authority under Article 6.3 of the Habitats Directive as to whether or not a proposed development would adversely affect the integrity of a European site.”

The overall AA process is different from EIA as it is only focused on the conservation objectives of European sites. The process is made up of separate stages of assessment, the results of each stage determining the need for the next.

It should be noted that EirGrid has responsibility for screening projects that we wish to undertake. In accordance with Regulation 42(1) of the European Communities (Birds and Natural Habitats) Regulations 2011 as amended, EirGrid is required to screen for the need for AA of plans and projects it wishes to undertake or adopt to assess in view of best scientific knowledge and the conservation objectives of the site(s), if, individually or in combination with other plans or projects is likely to have a significant effect on a European site(s).

## 2.3.4. Strategic Environmental Assessment

Strategic Environmental Assessment (SEA) is a systematic process of predicting and evaluating the environmental effects of a proposed plan or programme in order to ensure that these effects are adequately addressed at the earliest stage. The EU Directive (2001/42/EC) on the Assessment of Effects of Certain Plans and Programmes on the Environment (more usually referred to as the SEA Directive) sets out the types of plans (such as sectoral plans, including energy) that may require formal SEA. To date EirGrid has prepared two SEAs for Grid Implementation Plans which set out the manner in which grid projects will be developed in line with the overarching Grid Development Strategy.

The purpose of the SEA is to ensure that environmental considerations form part of the preparation of plans and programmes before their completion. It aims to provide a high level of protection for the environment and to promote sustainable development.

The Grid Implementation Plans and associated SEA have a nominal five year lifespan. EirGrid has recently approved the 2017-2022 Grid IP and SEA statement. This Grid IP updates the environmental objectives set out in the previous Grid 25 IP 2011-2016 and sets out the manner in which grid projects will be developed over the next five years.

The documents can be found on our website:

<http://www.eirgridgroup.com/about/in-the-community/environment/>

## 2.4. Six-Step Process for Developing the Grid

The TDP is a snapshot of the development of the transmission network at a particular point in time. These needs are presented in a manner consistent with our approach to developing the grid. Our approach has six steps and helps to determine whether and how we develop the grid. The six steps are illustrated in the figure below.




Figure 2-1: Six-step process for our grid projects

At each step in this process we make decisions that narrow our focus for the choices required in the next step.

### 2.4.1. Step 1: How do we identify the future needs of the electricity grid?

We start to identify the future needs of the electricity grid by considering potential changes in the demand for electricity.

These changes are influenced by factors such as how and where electricity is generated and changes in demand for electricity.

We consider these changes by developing a set of scenarios, known as Tomorrow's Energy Scenarios<sup>23</sup>, that explore the future of electricity.

Considering these scenarios helps us to plan and identify grid improvements that may be necessary. This in turn helps us to identify projects to meet potential future needs.

The scenarios respond to many factors including Government policy, stakeholder feedback, the economy and expected growth in electricity demand.

We review the scenarios to consider new trends, changes in the industry, and other factors.

<sup>23</sup> <http://www.eirgridgroup.com/customer-and-industry/energy-future/>



The outcome of this work may propose a potential need to reinforce the grid, or a need for an asset refurbishment.

When we have identified and confirmed a need, we start a formal process of project development. At this point, the only decision that has been made is to confirm that there is a need for a grid development project.

### **2.4.2. Step 2: What technologies can meet these needs?**

In Step 2 we look at a range of technical options that can meet the need or needs we confirmed in Step 1.

As part of this process, we seek feedback from the public and stakeholders on a list of potential technical solutions, to understand which options are considered suitable.

From this feedback we produce a shortlist of options to consider in more detail.

In Step 2, options are assessed based on:

- Which technologies are available for use?
- Which option would be preferable - overhead lines or underground cables?
- What related upgrades will the existing network need as a result of new infrastructure?
- Which substations may need an upgrade?
- What does this mean for the lines connecting these substations?

At this point, we publish the options we think should go forward, and the ones we have ruled out. We ask the public for their views on these options, which are considered along with other factors.

We will then make a decision on the most appropriate technical solutions to bring forward to the next step.

### **2.4.3. Step 3: What's the best option and what area may be affected?**

During this step, we study the potential benefits and impacts of the different options we could build, and where we could build them.

For our largest projects, we are likely to spend over a year at this step.

When we are considering where we may build a project, we start by looking at a study area. This is a broad area within a region, rather than a specific, detailed route.

During Step 3 we will ask for the public's views on a specific technology option and on the study area where we want to locate the project.

We may consider more than one technical option, such as developing a new or upgraded line, or upgrading or extending a substation.

Where there are choices like this, we will consult with the public. These issues could include environmental concerns, questions about land use, or other topics that could affect the technology options.

As part of this process, we will publish information about all the technologies and areas and give our opinion on their suitability. We will identify the best performing solution.

At the end of Step 3, we will base our decision on a detailed analysis of feedback and on economic, technical, social, deliverability and environmental factors.

#### **2.4.4. Step 4: Where exactly should we build?**

Following consultation and engagement in Steps 1, 2, and 3 we have made some key decisions on the technology we will use, and roughly where the project will be built.

We will continue to examine and consider both an overhead line option and an underground cable option if a new line is needed.

In Step 4, we will assess the most appropriate place to build the project.

At this step, the public can significantly influence exactly where we build the project. During this step we work closely with local people – especially landowners who will be directly affected by a project.

We will engage with landowners and the wider community to understand which locations for new infrastructure are preferred by local people.

At this stage, our aim is to collaborate on an agreed route or site, once it is possible and practical.

We will consider all the information gathered in this step, including local knowledge. We will then decide on a preferred route or site to include in our planning application.

#### **2.4.5. Step 5: The planning process**

Where a project requires planning permission, we will submit an application to the planning authority – either An Bord Pleanála or the Local Planning Authority.

We will publish a notice in the newspapers when we lodge this application. We will also continue to provide regular project updates.

Once we make an application to An Bord Pleanála, it may decide to hold an oral hearing. This will give those who submitted a written opinion a chance to share their views about the project.

Where possible, we will respond to submissions from those who are directly affected by our plans.

When the planning process ends, the planning authority will do one of the following:

- Grant permission;
- Grant permission on the basis that EirGrid makes some changes to its application; or
- Refuse permission.

#### **2.4.6. Step 6: Construction, energisation and benefit sharing**

We continue to engage with the public and stakeholders throughout the construction phase of the project.

Though EirGrid plans the future of the electricity grid, it is ESB Networks that builds new grid infrastructure.

EirGrid and ESB Networks will work together to minimise any impact during construction.

EirGrid will continue to engage with the public on issues such as road access, or planning the schedule of works.

We will also inform the wider community of the progress of the project, up to the final process of testing and completion.

When we build new transmission infrastructure in an area, we set up a Community Fund and establish Proximity Payments for the project. We make Proximity Payments when new transmission infrastructure is built within 200 m of homes in a rural location.

The Community Fund awards grants to local organisations and other good causes in a project area.



## 3. Investment Needs

3

## 3. Investment Needs

The Government Energy White Paper<sup>24</sup> released in December 2015 sets out Ireland's energy future and continues to be valid. The Climate Action Plan published in June 2019 is the latest and most up to date Government policy framework and reflects the more recent national and European policy developments. Investment in the transmission system is necessary to enable Ireland's transition to a low carbon energy future. In this regard, the TDP is developed to support Government objectives and enable this energy transition.

### 3.1. Strategic Context of Transmission Network Investment

The ability to provide all customers with a secure, efficient, reliable and stable electricity supply is essential for Irish society and to enabling economic activity and economic growth.

The Irish electricity industry and its development take direction from a number of broad national and European<sup>25</sup> strategic objectives. These objectives guide investment in the Irish transmission network and are summarised as follows:

- Ensuring the security of electricity supply;
- Ensuring the competitiveness of the national economy; and
- Ensuring the long-term sustainability of electricity supply in the country.

To ensure these objectives are met we must provide ongoing and timely reinforcement of the Irish transmission network.

As the TSO for Ireland, we have a statutory duty to support the development of the Irish economy and society by ensuring the transmission network is able to support all reasonable demands for electricity. In addition, we are required to enter into agreement for connection with parties seeking to connect to the network under terms approved by the CRU.

Changes to demand, generation, or to interconnection with neighbouring transmission networks may alter the flow of electrical power throughout the Irish transmission network. To accommodate these changes in power flows it is often necessary to reinforce the transmission network to ensure adequate performance and reliability levels are maintained.

### 3.2. National and European Energy Policy

#### 3.2.1. Security of Supply

Security of supply deals with generation adequacy and the availability of generation to meet the fluctuating demand needs over time. Hence, electricity policy seeks to promote broadening the country's access to generation and promotes further interconnections with neighbouring countries.

Security of supply is also concerned with the reliability and security of the transmission network. Policy therefore also seeks to promote the timely development of the transmission network to maintain an acceptable level of performance and reliability.

#### 3.2.2. Competitiveness

Low or competitively priced electricity is viewed as the product of a competitive electricity market. As a result, electricity policy generally seeks to promote increased competition. This is achieved through further market integration, by removing network constraints and broadening the market by interconnecting to neighbouring electricity markets.

<sup>24</sup> <http://www.dcenr.gov.ie/energy/SiteCollectionDocuments/Energy-Initiatives/Energy%20White%20Paper%20-%20Dec%202015.pdf>

<sup>25</sup> <http://ec.europa.eu/energy/en/topics/energy-strategy/2030-energy-strategy>

### 3.2.3. Sustainability

Ireland is heavily reliant on imported fossil fuels for the generation of electricity. The long-term sustainability of the Irish economy is impacted by the sustainability of the fossil fuels upon which it relies. Furthermore, burning fossil fuels produces greenhouse gasses. This has a long-term environmental impact and is not environmentally sustainable. Electricity policy therefore attempts to address these two factors and drives the integration of energy produced from renewable energy sources (RES).

In September 2019 we launched our Strategy 2020-2025 which is shaped by climate change and the impending transformation of the electricity sector. We are committed to leading the change towards a carbon-free electricity system and achieving the 70% renewable energy target by 2030.

## 3.3. Policy Drivers of Transmission Network Investment

In order to achieve the identified strategic objectives laid out by national and EU policies, we must continue to invest in the development and maintenance of the electricity transmission network. Specific drivers of investment in transmission network infrastructure are identified, and described in the following sections.

### 3.3.1. Security of Transmission Network

Security of supply generally addresses two separate issues:

- The availability of primary energy resources to generate sufficient electricity to meet demand; and
- The ability of the transmission network to reliably transport electrical energy from the generators, where it is generated, to the demand centres, where it is consumed.

The TDP is aimed at addressing the security of supply issues that relate to the transmission network.

Therefore, for this document, security of supply means the ability of the transmission network to reliably and securely transport electrical energy from where it is generated to the demand centres where it is consumed.

### 3.3.2. Market Integration

With increased market integration, electrical power can flow from areas where it is cheap to produce to areas where it is more highly valued. Therefore, the aim is to make the EU electricity markets more integrated.

The integration of RES and other forms of low carbon generation significantly increases the power exchange opportunities across the region. Differences in national targets combined with varying availabilities of renewable sources across Europe will lead to greater penetration of RES in certain areas compared to others. Therefore, there is a need to reinforce the transmission networks between and within EU countries.

### 3.3.3. Renewable Energy Sources Integration

Developing renewable energy is an integral part of Ireland’s sustainable energy objectives and climate change strategy. In comparison to fossil fuels, RES has lower or no net emissions. RES contribute to the decarbonisation of the energy supply and reduction in greenhouse gases emissions. They also contribute to energy security, being, for the most part, an indigenous energy source. In a period of volatile energy costs RES can also contribute to cost competitiveness by reducing dependence on imported fossil fuels. At the moment windfarms and hydro stations are the main sources of renewable electricity generation in Ireland. However, as Ireland moves to fully decarbonise its energy system, it is expected that additional forms of renewable energy will be further developed e.g. solar, biomass, wave and tidal. It is also expected that energy storage facilities will be a necessary part of the future energy system, helping to ensure the safe secure operation of a power system with high levels of variable RES generation.

In order to fulfil both European and national renewable targets, many RES-related projects are expected to be initiated throughout the period of this TDP. Many of these projects are located in rural areas where the transmission network is less developed. This places pressure on the electricity transmission network in these rural areas. Significant challenges will arise in extending and reinforcing the network to connect new RES.

## 3.4. Technical Drivers for Transmission Network Investment

Technical drivers of transmission network investment include changes in demand, generation and interconnection, inter-regional power flows and changes in asset conditions.

### 3.4.1. Demand, Generation and Interconnection

#### Changes in Demand and Generation

Demand growth and the connection of new demand can give rise to higher power flows which may trigger the need to reinforce the network as a result. Closure or reduction in the size of demand facilities can reduce the power flows on lines feeding the load. However, in certain cases where the demand is absorbing local generation and reducing the amount of generation exported from the area, the closure can lead to increased power flows.

Our All-Island Generation Capacity Statement 2019-2028 (GCS), available [here](#)<sup>26</sup>, details the forecast electricity demand for the years 2019 to 2028. The peak demand in Table 3-1 is the forecast median transmission system peak demand published in the GCS.

Table 3-1 also shows how generation capacity is expected to change over the period of this TDP. The generation capacity is the connected and contracted generation at the data freeze date, 01 January 2019. It also takes into account the generation closures noted in GCS 2019-2028<sup>27</sup>.

The East-West Interconnector (EWIC), which can act as a 500 MW generation source when importing or a 530 MW demand source when exporting, is not included in the figures.

<sup>26</sup> <http://www.eirgridgroup.com/site-files/library/EirGrid/EirGrid-Group-All-Island-Generation-Capacity-Statement-2019-2028.pdf>

<sup>27</sup> In November 2019, ESB announced that two peat-powered generating plants will stop generating electricity at the end of December 2020. The plants are located at Shannonbridge in Offaly and Lanesboro in Longford. These changes will be captured in the next TDP.

**Table 3-1: Forecast demand and generation over the period 2019 to 2028**

<b>Year</b>	<b>Peak Demand (GW)</b>	<b>Generation Capacity (GW)</b>
2019	5.35	11.48
2020	5.54	12.06
2021	5.71	13.18
2022	5.86	13.72
2023	6.05	13.83
2024	6.17	13.11
2025	6.26	13.14
2026	6.37	12.22
2027	6.47	12.22
2028	6.54	12.22

This comparison of generation and demand is not an assessment of generation adequacy, which is addressed separately in our Generation Capacity Statement.

Generation and demand by regional planning area is provided in Chapter 6 Regional View.

Our All-Island Ten Year Transmission Forecast Statement, available on the EirGrid website, includes information on how the GCS demand forecast relates to each individual demand centre node over the period covered by this TDP.

Because of the relative size of individual generators, changes in generation installations, whether new additions or closures can have a more significant impact on power flows than demand. This is equally so in the case of interconnectors which are treated as generators during periods when power is imported.

The addition of new generation capacity requires network development to connect the new generator to the network. This provides a path for electric power flow between the new generator and the transmission network. This is commonly known as the shallow connection. The new generation capacity will inevitably alter the power flows across the network, which has the potential to create overload problems deep into the network. To resolve these overloads we need further reinforcements (known as deep reinforcements) to allow full network access.

The connection of large generators, or groups of generators, combined with the increasingly meshed nature of the transmission network results in lower network impedance, which is the measure of resistance to the flow of electric current, and consequently increased short circuit levels. This is a safety issue, as under fault conditions such high short circuit levels may cause catastrophic failure of high-voltage equipment. We monitor fault levels on the network and take measures to prevent such conditions occurring.

### **Changes in Interconnection**

EU policy recognises the economic and technical benefits associated with increased interconnection and therefore seeks to promote interconnection between European transmission systems. Increased interconnection between transmission networks results in a larger energy market. With increased market integration there is greater competition and the potential for prices to be reduced. With increased interconnection there is also access to a broader generation base, which enhances the networks' security of supply. This can potentially defer the need for additional generation to be constructed to meet security of supply standards or requirements.

The following interconnections are noted in this TDP:

- North South Interconnector between Ireland and Northern Ireland;
- A possible interconnector between Ireland and France, known as the Celtic Interconnector; and
- A possible interconnector between Ireland and Great Britain, known as the Greenlink Interconnector.

### 3.4.2. Changes in Inter-Regional Power Flows

The following factors have the potential to significantly change the flow of electrical power throughout the transmission network:

- Changes in demand;
- Further internal integration of the All-Island Single Electricity Market;
- Further integration with neighbouring countries; and
- Integration of significant levels of new generation (both conventional and renewable).

These factors drive the need for network reinforcements over the next ten years and beyond.

### 3.4.3. Changes in Asset Condition

Transmission network assets have a finite lifespan. The useful life of transmission assets are impacted by a number of factors:

- The age of the asset;
- The type of technology used;
- The level of maintenance;
- The environment in which it operates; and
- Utilisation.

In order to ensure that security of supply is not compromised, routine condition assessments are carried out. These assess the condition of the assets and estimate remaining useful life.

Typically, where asset condition is poor, assets are:

- Refurbished;
- Replaced on a like-for-like basis; or
- Replaced with higher rated equipment to cater for future needs.

## 3.5. Network Development Needs

The technical drivers of transmission network investment listed above result in network development needs. To address these needs, we must provide ongoing and timely reinforcement of the Irish electricity transmission network.

The primary measure of network development needs is assessed by comparing transmission network performance with the required performance levels set out in the TSSPS.

Our TSO licence, granted by the CRU, specifically requires us to ensure the maintenance of and, if necessary, develop the transmission network in accordance with the TSSPS.



It is possible to categorise the resulting reinforcement needs:

- Reinforcements required to support changes in, or connection of new demand and generation;
- Reinforcements related to interconnection;
- Reinforcements to facilitate inter-regional power flows; and
- Reinforcements to address the condition of existing assets.



## 4. Changes to the Plan Since 2018

4

## 4. Changes to the Plan Since 2018

TDP 2019 has a data freeze date of 01 January 2019 while TDP2018 had a freeze date of 01 January 2018.

There were 109 active projects in TDP 2018<sup>28</sup>. Since then 22 projects have been completed, these are listed in Table 4-1 below. 23 projects have been added to the development plan; these are listed in Table 4-2 below. This would imply that there would be 110 projects in TDP 2019.

However, there are 104 active projects in this development plan. These are identified by Planning Area in Chapter 6 and Appendix B. The difference of six projects is explained as follows:

- Three projects that were active in TDP 2018 are now on hold. The three projects are CP0837, CP0999 and CP1012. They are listed in Table 4-3 below.
- In TDP 2018 there were two CP numbers (CP0490 and CP0894) associated with one DSO connection (Great Island 220/110 kV Station - New DSO Bay). This has been consolidated into one CP number (CP0894) in TDP 2019.
- In TDP 2018 there were two CP numbers (CP0997 and CP1009) associated with one customer connection (Cruiserath 220 kV Station – Demand Connection). This has been consolidated into one CP number (CP1009) in TDP 2019.
- In TDP 2018 one project (CP0788, Micafil Bushings Replacement) was correctly in the ‘Projects Completed’ table in Chapter 4. However, it was also incorrectly included as one of the 109 active projects and included in Appendix B (National Programmes table) in TDP 2018.

### 4.1. Projects Completed since TDP 2018

Since TDP 2018, 22 projects have been completed up to the data freeze date; they are listed in Table 4-1. Projects completed since the data freeze date will be captured in the next TDP.

**Table 4-1: Projects Completed since TDP 2018**

No.	CP No.	Project Title	Date Project Completed
1	CP0054	Ardnacrusha 110 kV Station Redevelopment	Q2 2018
2	CP0606	Knockacummer Wind Farm Permanent Connection	Q4 2018
3	CP0729	Great Island 110 kV Station Redevelopment	Q4 2018
4	CP0731	Bellacorick - Castlebar 110 kV Line Uprate	Q2 2018
5	CP0756	Cauteen - Tipperary 110kV Line Uprate	Q3 2018
6	CP0760	Poolbeg 220kV Station Installation of 2 x 50 MVar reactive support	Q4 2018
7	CP0770	Poolbeg 220 kV Station - Fencing and bunding	Q4 2018
8	CP0778	Castlebar 110 kV Station - Transmission Works Associated with Installation of New 38 kV GIS	Q4 2018
9	CP0779	Dungarvan 110 kV Station - Transmission works associated with installation of new 38 kV GIS	Q3 2018
10	CP0821	HV Line Tower Painting – North Region	Q2 2018
11	CP0830	Raffeen – Trabeg No. 1 110 kV Line Uprate	Q4 2018

<sup>28</sup> TDP 2018 is available on the EirGrid website: <http://www.eirgridgroup.com/site-files/library/EirGrid/Transmission-Development-Plan-2018-2027.pdf>. TDP 2018 had a data freeze date of 01 January 2018.

**Table 4-1: Projects Completed since TDP 2018**

No.	CP No.	Project Title	Date Project Completed
12	CP0834	Carrick-on-Shannon 110 kV Station – Uprate four 110 kV circuit breakers	Q3 2018
13	CP0870	Carrick-on-Shannon – Arigna T – Corderry 110 kV Line Uprate	Q4 2018
14	CP0895	Knockalough Wind Farm Shallow Connection Works	Q4 2018
15	CP0904	Bandon - Raffeen No. 1 110 kV Line Refurbishment	Q3 2018
16	CP0914	Meath Hill 110 kV Station – Uprate two DSO transformer bays for shallow connection works	Q1 2018
17	CP0926	Slievecallan 110 kV New Station Shallow Connection Works	Q3 2018
18	CP0974	Cloon - Lanesboro 110 kV Line Diversion	Q1 2018
19	CP0987	Snugborough 110 kV New Station – New Demand Connection	Q3 2018
20	CP0991	Kilpaddoge 220/110 kV Station - Kelwin Power Plant Shallow Connection Works	Q3 2018
21	CP0998	Dunstown 400/220 kV Station - DC Systems	Q4 2018
22	CP1018	Oldstreet - Tynagh 220 kV Line Fibre Wrap	Q3 2018

## 4.2. Projects Added to “On-going Projects” in 2018

23 projects have been added to the list of “On-going Projects”; they are listed in Table 4-2.

**Table 4-2: Projects Added to “On-going Projects”**

No.	CP No.	Project Name
1	CP0919	Lanesboro 110 kV Station Redevelopment
2	CP0930	Carrigdangan 110 kV New Station - Wind farm connection
3	CP1014	Snugborough 110 kV Station – Demand connection phase 2
4	CP1020	Blundelstown 110 kV New Station – Solar farm connection
5	CP1022	Maynooth – Turlough Hill 220 kV Circuit Power Line Carrier (PLC) Replacement
6	CP1025	Corduff 220/110 kV Station – Two new DSO transformer bays for demand
7	CP1031	Flagford 220/110 kV Station – Circuit breaker replacement
8	CP1032	Cashla 220/110 kV Station – Circuit breaker replacement
9	CP1034	Athea 110 kV Station – Wind farm connection
10	CP1035	N6 Line Diversions
11	CP1036	Transformers Protection Upgrade
12	CP1037	Kilbarry Line Conflicts
13	CP1040	Rosspile 110 kV New Station – Solar farm connection
14	CP1041	Timahoe North 110 kV New Station – Solar farm connection
15	CP1043	Gafney 110 kV New Station – Generator temporary connection
16	CP1044	Finglas – Shellybanks 220 kV Cable Diversion
17	CP1046	Clahane 110 kV Station - Banemore solar farm connection

**Table 4-2: Projects Added to “On-going Projects”**

No.	CP No.	Project Name
18	CP1048	Richmond 110 kV Station Power Flow Control Scheme
19	CP1051	Gallanstown 110 kV New Station – Solar farm connection
20	CP1052	Knocknamona 110 kV New Station - Wind farm connection
21	CP1053	220 kV Cable Sealing End Replacement at three transmission stations
22	CP1054	Kinnegad – Mullingar 110 kV Line Diversion
23	CP1055	Harristown 110 kV New Station – Solar farm connection

### 4.3. Projects On Hold

As of 01 January 2019 there were 16 projects on hold; they are listed in Table 4-3 below. Projects that are on hold may be on hold for a variety of reasons, such as awaiting works to be progressed by customers connecting to either the transmission or distribution system.

**Table 4-3: Projects on Hold**

No.	CP No.	Project Title	System
1	CP0041	Macroom 110 kV Station – New 110 kV Bay For Hartnett’s Cross 110 kV New Station	Distribution
2	CP0404	Mullagharlin 110 kV Station - New 110 kV Transformer Bay	Distribution
3	CP0644	Bracklone 110 kV New Station & Loop-in	Distribution
4	CP0645	Portlaoise 110 kV Station – Two New 110 kV Transformer Bays	Distribution
5	CP0693	Baroda 110 kV Station – Two New 110 kV Transformer Bays	Distribution
6	CP0707	Barrymore 110 kV Station Extension and Loop in	Distribution
7	CP0741	Trabeg 110 kV Station – Uprate Two 110 kV Transformer Bays	Distribution
8	CP0743	Cow Cross 110 kV Station – New 110 kV Transformer Bay	Distribution
9	CP0836	Derryiron 110 kV Station - New 110 kV Transformer Bay	Distribution
10	CP0837	Bellacorick 110 kV Station – Uprate DSO Transformer Bay	Distribution
11	CP0879	Letterkenny 110 kV Station - New 110 kV Transformer Bay	Distribution
12	CP0908	Castletownmoor 110 kV New Station – Castletownmoor Wind Farm	Transmission
13	CP0976	Portlaoise 110 kV Station – Uprate Two DSO Transformer Bays	Distribution
14	CP0999	Cauteen 110 kV Station – Permanent Connection Works	Transmission
15	CP1011	Carrickalangan 110 kV New Station – Wind Farm Connection	Transmission
16	CP1012	Carrickaduff 110 kV New Station – Wind Farm Connection	Transmission



## 5. Planned Network Developments

5

# 5. Planned Network Developments

## 5.1. Overview of the Plan

This chapter summarises the network development projects arising from the transmission network development planning process (outlined in Section 2.4). Projects are described in greater detail in Chapter 6 and Appendix B.

The TDP includes a total of 104 projects that are currently in progress. These projects are categorised as either; New Build; Uprate/Modify; Refurbish/Replace related projects or Other.

**New Build projects:** are projects that involve the construction of new stations or new circuits. This category also includes projects that involve the installation of new equipment in existing stations.

An example of a new build project is the installation of new transformers or new reactive support devices within existing stations.

**Uprate/Modify projects:** are projects that involve the uprating of existing assets. An example of an uprate project is changing equipment to increase the capacity rating of circuits or busbars.

This category also includes projects that involve the modification of existing assets.

An example of a modification project is the installation of new couplers or new bays in existing stations. Reconfiguration of existing stations is also included in this category.

**Refurbish/Replace projects:** are projects that involve the refurbishment of existing stations or existing circuits. This category also includes projects that involve the replacement of existing assets. For example the replacement of stations at or close to the end of their useful life or replacement and upgrading of protection in existing stations.

**Other:** are projects that do not fall naturally into any of the three categories above.

Table 5-1 below summarises the active projects into their respective categories.

**Table 5-1: Summary of Projects by Category**

Project Category	No. of Projects
New Build	36
Uprate/Modify	36
Refurbish/Replace	29
Other	3
<b>TOTAL</b>	<b>104</b>

## 5.2. Summary of Step of Projects

Figure 5-1 shows all projects in Step 4 – Step 6. All new developments shown in the figure are subject to environmental assessment as appropriate in accordance with the relevant planning requirements. For those projects not yet in the planning process, the lines shown on the map are indicative only and do not represent a preferred line route. A full list of projects and their corresponding steps of development is given in Appendix B.

### 5.2.1. Works Outside Scope of This Plan

In addition to the projects summarised in this chapter, we also coordinate capital projects which are classified as minor capital works with the TAO, such as minor station alterations. These projects are numerous and generally deal with the day-to-day operation and maintenance of the network. These are not included in this chapter.

**Transmission System: 400 kV, 275 kV, 220 kV and 110 kV  
 Indicating Developments in Step 4 to Step 6 as of 01 January 2019**



**Figure 5-1: Planned Network Developments in Steps 4 to 6 of our six-step process**



### 5.3. Project Delivery

The development of the transmission network is subject to delivery risk. We use risk management plans and processes to identify, analyse, monitor and manage project and programme risks. These plans and processes facilitate the management of project dependencies and critical path issues within the context of a changing environment.

Project Estimated Completion Dates (ECDs) in the TDP are forecasts based on the best project information available at the time of the data freeze, 01 January 2019. Certainty with regard to completion dates increases as a project moves through the six steps.

The project schedule is developed initially using standard lead times for generic project types. As a project moves forward through the six steps a detailed schedule is developed and maintained, milestones are achieved and there is therefore greater certainty regarding the completion date.

The following points need to be taken into account when considering project progression and risk:

- Current level of project maturity;
- Outage availability;
- Land access, planning and consent risks; and
- Project complexity.

A Multi-Year Delivery Programme (MYDP) has been developed as a single source of information for project completion dates. The MYDP is a five year plan detailing the delivery of all projects in the capital programme in Ireland. The MYDP ensures a realistic delivery pipeline for the programme of projects in the next five years by taking current project step, outage availability and project readiness into consideration, therefore improving the certainty regarding completion dates.

We differentiate between moderate and high risk projects based on project type and project step. Projects that are due for completion in the near-term generally carry less risk than those due for completion in later years. Line and station busbar uprate projects which are due to be completed by 2020 are considered to be within the moderate risk category. Large-scale linear developments, scheduled to be completed post 2020 have a higher level of risk.

When inter-dependent projects take place at the same time, care has to be taken scheduling the required outages. Therefore, the region or location of a project also has an impact on its risk profile. The MYDP identifies an optimum programme by aligning projects with similar outage requirements and by prioritising projects according to our prioritisation processes. This programme risk review may drive changes to the way projects are sequenced and the timing of project delivery in a region.

We regularly review the network development programme which may result in project delivery changes for the reasons cited above. In such cases we endeavour to communicate with and mitigate impacts on customers.

In summary, completion dates are subject to change and the level of change typically depends on:

- The type of project;
- Framework step-specific project and programme risks; and
- The region a project is in.

## 6. Regional View

6



# 6. Regional View

## 6.1. Overview

As described in Chapter 1, planned projects are categorised on a planning area basis, as per Figure 1-1.

Table 6-1 below summarises the number of active projects by planning area. More information related to the projects is provided in this chapter and in Appendix B<sup>29</sup>.

**Table 6-1: Summary of Active Projects by Planning Area**


Active TDP Projects by Planning Area	
Planning Area	No. of Active Projects
Border, Midlands and West (B-M-W)	27
South-West and Mid-West (SW-MW)	32
South-East, Mid-East and Dublin (SE-ME-D)	39
National Projects <sup>30</sup>	6
<b>Total</b>	<b>104</b>

Some projects are in multiple planning areas. For ease of reporting these projects are assigned to one planning area.

Projects of European significance in Ireland are identified in ENTSO-E’s most recent TYNDP<sup>31</sup> and RegIP documents.

## 6.2. The Border, Midlands and West Planning Area

Summary of Projects	
Project Category	No. of Projects
New Build	6
Uprate/Modify	12
Refurbish/Replace	9
<b>Total</b>	<b>27</b>



<sup>29</sup> Prior to reviewing Appendix B consult Appendix A which explains some of the terms that are used to describe projects.

<sup>30</sup> These involve multiple individual projects at various locations across the country.

<sup>31</sup> <http://tyndp.entsoe.eu/>

## Regional Description

The Border, Midlands and West planning area has a wide variety of generation sources. These are dispersed around the planning area and include wind; hydro; gas; and peat burning power stations.

The planning area has considerably more generation than demand. The existing transmission network is predominantly 110 kV and 220 kV. There is limited high capacity 400 kV infrastructure in the southern part of the planning area. The existing local transmission network allows limited power flows between Northern Ireland and Ireland via the existing 275 kV Tandragee-Louth interconnector.

There is a 110 kV transmission network in the area which supplies a relatively low local demand. Development of this network is mainly required to connect a high level of renewable generation.

The excess of generation in the area is set to increase significantly in the coming years. This is due to generators that currently have connection agreements and live connection offers connecting to the transmission and distribution networks.

To cater for the high levels of generation described above, network reinforcement is necessary. This will enable the efficient export of generation from this area towards areas with high load, such as the eastern seaboard.

There are also reinforcement needs due to:

- Local constraints related to a shortage of transmission capacity and voltage support;
- Asset condition; and
- To accommodate further market integration with Northern Ireland.

The projects described in this section will enable the transmission network to safely accommodate the more diverse power flows which are a result of excess regional generation. They will also provide benefits to existing and future users of the transmission network in the planning area and facilitate broad future regional load growth.

The projects in the Border, Midlands and West planning area are discussed in more detail below. The status of the network development projects is noted in Appendix B.

Please refer to Figure 5-1 for locational information of planned network developments in the Border, Midlands, and West Planning Area in Steps 4 to 6.

### Reinforcement of the Transmission Network between Ireland and Northern Ireland

#### Project

- North South Interconnection Development (CP0466) – 400 kV Circuit from Woodland Transmission Station in Co. Meath to Turleenan Transmission Station in Northern Ireland<sup>32</sup>

#### Description

The drivers for this project are market integration, security of supply and RES integration. There is a requirement for increased power to flow between Ireland and Northern Ireland. This is mainly driven by changes to the all-island generation portfolio, plant retirements and the relative operational costs of generation plants in each jurisdiction.

The capacity for power flows between Ireland and Northern Ireland is limited by the existing infrastructure. In particular, there is a risk that a single event could take the existing 275 kV interconnector out of service. This would lead to a system separation of Ireland and Northern Ireland, requiring each system to instantly adjust to achieve a new demand-supply balance.

<sup>32</sup> More information is available at the project website: <http://www.eirgridgroup.com/the-grid/projects/north-south/the-project/>

The North South Interconnection Development will remove this risk of system separation and significantly increase cross-border transmission capacity. The North South Interconnection Development will offer significant economic benefits, by:

- Improving security of supply, by:
  - allowing sharing of generation across the island; and
  - removing the scenario where a single event could lead to system separation of Ireland and Northern Ireland;
- Improving competition and economic operation by removing constraints;
- Providing the required flexibility for renewable generation; and
- Ensuring security of supply for the North East of Ireland.

This is a joint EirGrid and SONI project.

### **Reinforcement of the Transmission Network in the North West**

#### **Project**

- The North West Project (CP0800<sup>33</sup>)

#### **Description**

In association with SONI we carried out an assessment of north-west Ireland and western Northern Ireland. This investigation resulted in a submission to the European Commission (EC) requesting Project of Common Interest (PCI) status for a project titled the Renewable Integration Development Project (RIDP). The EC has since accepted that application.

The North West Project comprises reinforcement of the grid in the north-west. We are reviewing the need, solutions, technology and timing of this work in line with our grid development strategy<sup>34</sup> and six-step process for developing the grid.

The driver of this project is RES integration. The amount of renewable generation seeking to connect in Donegal is in excess of the local demand. This generation therefore needs to be transferred out of the area to relieve congestion on the network.

### **Reinforcement of the Transmission Network in Donegal**

#### **Project**

- Tievebrack/Ardnagappary 110 kV Development (CP0421)<sup>35</sup>

#### **Description**

The driver for this project is security of supply. The DSO requested that North West Donegal (the Derrybeg/Gweedore area) be reinforced with 110 kV infrastructure.

<sup>33</sup> CP0800 is the North West Project only i.e. the first phase of RIDP.

<sup>34</sup> Our updated grid development strategy was published in January 2017 - Strategy Statement 2 "We will consider all practical technology options".

<sup>35</sup> This is the final element of the Binbane – Letterkenny 110 kV project.

## **Reinforcement of the Transmission Network within and out of Mayo**

### **Project**

- North Connacht 110 kV Project (CP0816)

### **Description**

The driver for this project is RES integration. The need for reinforcement arises due to the requirement to connect new RES generation. The level of generation is greater than the capacity of the local 110 kV network, even when uprated. The generation contracted to connect in the area could result in overloads on the existing infrastructure, under both intact network and single contingency conditions.

We are progressing this project through our six step process for developing the grid. We are continuing technical studies on the project and are engaging with landowners, communities and stakeholders in the region. In line with our grid development strategy<sup>36</sup> we are investigating all practical technology options.

For the most up to date information on the project please visit the project website on the EirGrid website<sup>37</sup>.

## **Reinforcement of the Transmission Network in Mayo and Sligo**

### **Projects**

- Castlebar 110 kV Station – Busbar Uprate, New Coupler and Refurbishment Works (CP0771)
- Moy 110 kV Station – Busbar Uprate, New Coupler and Refurbishment Works (CP0839)
- Bellacorick - Moy 110 kV Line Uprate (CP0819)

### **Description**

The drivers for these projects are RES integration and security of supply.

The need for these reinforcements arises due to a shortage of transmission capacity. The existing infrastructure could overload under single contingency and maintenance-trip conditions. This overload could occur primarily as a result of the planned connection of new generation.

In addition, the projects also involve refurbishment works due to the condition of the assets. Refurbishment works will be carried out at the same time as the uprating works.

New couplers will be installed in Castlebar and Moy 110 kV stations. These works will improve security of supply and increase operational flexibility. This is something which is of particular relevance during the outage season, which is when maintenance and construction works are scheduled.

## **New Generation Connections in the Border, Midlands and West Planning Area**

### **Projects**

- Tawnaghmore and Moy 110 kV Stations – Mayo Renewable Power Connection (CP0833)
- Shranakilly (previously referred to as Oweninny) 110 kV New Station – Wind farm connection (CP0850)

### **Description**

The driver for these projects is RES integration. These projects are needed to connect new generation.

<sup>36</sup> Our updated grid development strategy was published in January 2017.

<sup>37</sup> <http://www.eirgridgroup.com/the-grid/projects/north-connacht/the-project/>

## **New and Modified Demand Connections in the Border, Midlands and West Planning Area**

### **Project**

- Letterkenny 110 kV Station – Relocation of 110 kV Bay and 2 New Couplers (CP0740)

### **Description**

The driver for this project is security of supply.

The DSO requested that the Trillick 110 kV bay in Letterkenny be relocated to another section of the Letterkenny busbar in order to improve the security of supply to the 38 kV distribution network in Donegal.

## **Reinforcement of the Transmission Network in Galway**

### **Projects**

- Cashla – Salthill 110 kV Circuit Refurbishment and 110 kV Bay Uprate (CP0865)
- Galway 110 kV Station Redevelopment (CP0871)

### **Description**

The drivers for these projects are RES integration and security of supply.

The need for reinforcement arises due to a shortage of transmission capacity.

Network studies have indicated future overloads on the Cashla - Salthill 110 kV circuit under single contingency conditions. This overload could occur primarily as a result of the planned connection of new generation. In addition, a Line Condition Assessment and Line Project Assessment Report identified the need for refurbishment due to the condition of the line. Refurbishment works will be carried out at the same time as the uprating works.

Similarly, Galway 110 kV station needs to be redeveloped to cater for power flows in excess of the rating of the busbar which are driven by the connection of new generation in the area.

## **Reinforcement of the Transmission Network in Leitrim**

### **Project**

- Corderry - Srananagh 110 kV Line Uprate (CP0942)

### **Description**

The drivers for this project are RES integration and security of supply.

The need for reinforcement arises due to a shortage of transmission capacity. The connection of renewable generation drives higher flows on the 110 kV network. These higher flows may result in loading of the Corderry - Srananagh 110 kV line above its rating under single contingency conditions. In addition, Line Condition Assessment and Line Project Assessment Reports identified the need for refurbishment due to the condition of the line.

## Reinforcement of the Transmission Network in the Offaly Area

### Projects

- Mount Lucas - Thornsberry 110 kV New Circuit (CP0197)<sup>38</sup>
- Thornsberry 110 kV Station – Busbar Uprate (CP0724)

### Description

The driver for these projects is security of supply.

The DSO requested a second connection to the existing Thornsberry 110 kV station. This is provided by the new Mount Lucas - Thornsberry 110 kV circuit (CP0197).

Planning studies indicate that the connection of new generation and the building of new infrastructure will increase the power flowing through the area. This could potentially overload the existing busbar in Thornsberry 110 kV station. Therefore, the busbar needs to be updated.

## Reinforcement of the Transmission Network in Laois

### Project

- Coolnabacky - Portlaoise 110 kV Line Uprate (CP0835)

### Description

The drivers for this project are security of supply and RES integration. This project is related to the Laois - Kilkenny Reinforcement Project (CP0585) which is required to address quality of supply and provide security of supply in the area.

The need for reinforcement arises due to a shortage of transmission capacity. Studies have indicated overloading for an intact network, single contingency and maintenance trip conditions.

In addition, refurbishment works due to the condition of the circuit will be undertaken at the same time as the uprating works.

## Reinforcement of the Transmission Network in Longford

### Projects

- Lanesboro 110 kV Station Redevelopment (CP0919)
- Richmond 110 kV Station Power Flow Control Scheme (CP1048)

### Description

The drivers for these projects are RES integration and security of supply.

The need for these projects arises due to a shortage of transmission capacity. Lanesboro 110 kV station needs to be redeveloped to cater for power flows in excess of the rating of the existing busbar. The increased power flows arise due to the planned connection of new generation.

The redevelopment of Lanesboro 110 kV station will also improve security of supply and increase operational flexibility as it will allow existing restrictions in outage planning to be removed. This is something which is of particular relevance during the outage season, which is when maintenance and construction works are scheduled.

The Richmond power flow control scheme is an interim measure until Lanesboro redevelopment is complete. The Richmond project would redistribute power flows between Lanesboro and Richmond 110 kV stations and thus reduce power flows on the Lanesboro busbar.

---

<sup>38</sup> Formerly Cushaling – Thornsberry 110 kV New Circuit.



## Other Approved Projects

In addition to the network reinforcement projects described above, there are also other projects in the Border, Midlands and West planning area, namely:

- Flagford - Louth 220 kV Line Refurbishment (CP0867);
- Louth – Ratrussan 110 kV No. 1 Line Refurbishment (CP0905);
- Cloon – Lanesboro 110 kV Line Refurbishment (CP0903);
- Flagford – Sligo 110 kV Line Conflict (N4 Road Realignment) and Station End Works (CP0913);
- Cashla - Tynagh 220 kV Line Fibre Wrap (CP1019);
- Flagford 220/110 kV Station – Circuit Breaker Replacement (CP1031);
- Cashla 220/110 kV Station – Circuit Breaker Replacement (CP1032);
- N6 Line Diversions (CP1035); and
- Kinnegad – Mullingar 110 kV Line Diversion (CP1054).

## Future Needs Driving Potential Projects

At the time of the data freeze date, there are projects that are at an early stage of development and investigation. The needs assessment (as part of our six step process for developing the grid) has identified that the transmission system needs to be reinforced to integrate RES in this planning area. Our six step process is described in our Have Your Say document which is available on our website<sup>39</sup>.

We expect to progress projects that address these identified needs. This is likely to include line and station developments. Detailed studies will determine whether these projects are required. Future TDPs will report on the specific projects resulting from studies.

At this stage we have confirmed the need for further potential investment in this planning area. These are at an earlier stage of development and may lead to projects that will be implemented. These potential investments are:

- Flagford – Sligo 110 kV circuit thermal capacity (CP0982), in Step 2; and
- Letterkenny 110 kV busbar thermal capacity (CP1023), in Step 2<sup>40</sup>.

In addition, since the data freeze date we have confirmed the need for further investment in this planning area:

- Arva – Carrick-on-Shannon 110 kV circuit thermal capacity (CP0841);
- Binbane – Cathleen’s Fall 110 kV circuit thermal capacity (CP1079);
- Cashla – Dalton 110 kV circuit thermal capacity (CP0898);
- Castlebar – Cloon 110 kV circuit thermal capacity (CP0848);
- Castlebar – Dalton 110 kV circuit thermal capacity (CP0899);
- Flagford – Sliabh Bawn 110 kV circuit thermal capacity (CP0817);
- Lanesboro – Sliabh Bawn 110 kV circuit thermal capacity (CP1078);
- Lanesboro – Mullingar 110 kV circuit thermal capacity (CP1000); and
- Dalton 110 kV busbar thermal capacity (CP0907).

All these developments are in Step 2 as of October 2019.


<sup>39</sup> <http://www.eirgridgroup.com/the-grid/have-your-say/>

<sup>40</sup> Since the data freeze date this development has progressed to Step 3.

## 6.3. The South-West and Mid-West Planning Area

Summary of Projects	
Project Category	No. of Projects
New Build	12
Uprate/Modify	10
Refurbish/Replace	10
<b>Total</b>	<b>32</b>

### Forecast Regional Generation and Demand in 2028



### Regional Description

The South-West and Mid-West planning area has a wide variety of generation sources dispersed around the planning area. These include: wind, hydro, gas, and coal burning power stations. The planning area has considerably more generation than demand. The existing transmission network is composed of 110 kV, 220 kV and 400 kV infrastructure. The high capacity 220 kV and 400 kV circuits facilitate high inter-regional power flows from the planning area.

The development of the transmission network in the area is characterised by the connection of high levels of wind generation in the Co. Cork and Co. Kerry areas. These high levels of generation result in transmission network constraints as power is exported out of the area towards the Moneypoint and Knockraha transmission stations. Generation levels in the area are set to increase in the coming years. This is due to generators that currently have connection agreements and live connection offers connecting to the transmission and distribution networks.

We are undertaking a joint project with the French TSO, Réseau de Transport d'Électricité (RTE), to investigate the development of a HVDC interconnector between Ireland and France that could connect in Cork. To cater for the high levels of generation relative to local demand, network reinforcement is needed to enable the efficient export of generation from the area.

There are also reinforcement needs due to:

- Local constraints related to a shortage of transmission capacity and voltage support; and
- Asset condition.

The projects described in this section will enable the transmission network to safely accommodate the power flows, resulting from an excess of regional generation. They will also provide benefits to existing and future users of the transmission network in the planning area and facilitate broad future regional load growth.

The projects in the South-West and Mid-West planning area are discussed in more detail below. The status of the network development projects is noted in Appendix B.

Please refer to Figure 5-1 for locational information of planned network developments in the South-West & Mid-West Planning Area in Steps 4 to 6.

## **Reinforcement of the 220 kV Transmission Network out of Kerry and West Cork towards the North and East directions**

### **Projects**

- Kilpaddoge - Knockanure and Ballyvouskill - Clashavoon 220 kV Line Uprates and Kilpaddoge - Tarbert 220 kV Line Refurbishment (CP0763)
- Ballynahulla - Ballyvouskill and Ballynahulla - Knockanure 220 kV – Line Uprates (CP0883)

### **Description**

The driver for the line uprate projects is RES integration and the driver for the line refurbishment is security of supply.

The need for refurbishment arises due to asset condition. The need for uprating arises due to the connection of large amounts of wind generation in Kerry, west Cork and west Limerick. This results in higher power flows on the transmission network. Studies have indicated overloading of these circuits under single contingency and maintenance-trip conditions.

These projects are part of an overall strategy to increase the capacity for the potentially large power flows out of the area. The power will flow north towards Moneypoint and east towards Knockraha transmission stations and onwards to the large demand centres of Cork and Dublin.

## **Reinforcement of the Transmission Network in North Kerry**

### **Projects**

- Kilpaddoge 220/110 kV Station – New Station to the West of Tarbert 220/110 kV Station (CP0647)
- Tarbert 220/110 kV Station Refurbishment (CP0622)

### **Description**

The driver for these projects is security of supply.

The need for reinforcement arises due to local constraints on the transmission network. The physical capacity of Tarbert 220/110 kV station is close to being reached. The new Kilpaddoge station will replace many of the functions of the existing Tarbert station.

The new Kilpaddoge station is necessary to allow for the essential expansion of transmission connections in north Kerry. The existing Tarbert transmission station is being retained. However, due to the age and condition of the assets in Tarbert station, a project involving the refurbishment of the 220 kV assets is progressing.

## **Reinforcement of the Transmission Network across the Shannon Estuary between North Kerry and Clare**

### **Project**

- Moneypoint – Kilpaddoge - Knockanure 220 kV Project (CP0726)<sup>41</sup>

### **Description**

The drivers for this project are RES integration and security of supply.

The need for reinforcement arises due to the connection of large amounts of wind generation in Kerry, west Cork and west Limerick. This results in higher power flows on the transmission network. Studies have indicated overloading of circuits in the area under single contingency and maintenance-trip conditions.

The project will relieve constraints and allow for the increased power flows in the Mid-West and South-West that arise from the connection of renewable and conventional generation.

These projects are part of an overall strategy to increase the capacity for the potentially large power flows out of the area. The power will flow north towards Moneypoint and east towards Knockraha transmission stations and onwards to the large demand centres of Cork and Dublin.

## **Reinforcement of the Transmission Network in Clare**

### **Projects**

- Moneypoint 400/220/110 kV GIS Development (CP0688)
- Booltiagh 110 kV Station Extension (CP0874)

### **Description**

The drivers for these projects are security of supply and RES integration.

The need for reinforcement arises due to a shortage of transmission capacity and the need for voltage support in the area.

These needs were identified through network studies. These indicated potential overloading of circuits and violations of voltage limits in the Clare area under single contingency and maintenance-trip conditions.

The preferred solution to address voltage violations in the area is a new 220/110 kV transformer in Moneypoint 400 kV station. The new transformer and the recent uprate of the Ennis – Booltiagh – Tullabrack T – Moneypoint 110 kV circuit will help address the shortage of transmission capacity in the area.

The 400 kV transmission equipment in Moneypoint transmission station needs to be replaced because of the condition of the assets. This project will also contribute to facilitating the growing number of renewable generators in west Clare.

The Booltiagh 110 kV station extension is to accommodate two new transformer bays for new generation, the relocation of the Ennis line bay and a new 110 kV sectionalising circuit breaker cubicle.

---

<sup>41</sup> Moneypoint – Kilpaddoge cable section has been completed.

## Reinforcement of the Transmission Network in West Cork

### Projects

- Clashavoon - Dunmanway 110 kV New Line (CP0501)<sup>42</sup>
- Clashavoon - Macroom No. 2 New 110 kV Circuit and Increased Transformer Capacity in Clashavoon (CP0829)

### Description

The drivers for these projects are security of supply and RES integration.

The need for the new Clashavoon - Dunmanway and Clashavoon - Macroom 110 kV circuits, and increased transformer capacity in Clashavoon 220 kV station arises due to a shortage of transmission capacity in the area. Studies have indicated overloading of existing circuits and of a transformer in the area under maintenance-trip conditions. The new Clashavoon - Dunmanway and Clashavoon - Macroom 110 kV circuits will provide other routes into the west Cork area. This will secure supplies to the area and enable export of excess generation.

## Reinforcement of the Transmission Network in the Cork City area

### Projects

- Aghada 220/110 kV Station Upgrade (CP0794)
- Knockraha 220 kV Station Upgrade (CP0796)
- Knockraha Short Circuit Rating Mitigation (CP0973)
- New 110 kV Station near Kilbarry (CP0949)

### Description

The driver for these projects is security of supply. Together they will create and maintain the requisite levels of reliability and flexibility in the transmission network.

The need for the Aghada and Knockraha 220/110 kV station upgrade projects arises due to a number of local constraints on the transmission network. Studies have indicated the potential unacceptable loss of generation and voltage violations without these projects. In addition, without these projects, potential overloading of equipment within Aghada station and of circuits in the Cork and Waterford area have been identified.

The Aghada project also involves refurbishment works due to the condition and age of assets in the station.

Knockraha Short Circuit Rating Mitigation project addresses safety and security of supply. It will strengthen the capability of the support structures for strung busbar and bay conductor equipment to withstand the mechanical forces created by short circuit currents flowing through busbar and bay conductor.

A new 110 kV station near Kilbarry is being progressed to accommodate increased demand in the area and also to improve the security of supply. This new station, in combination with the existing Kilbarry 110 kV station, will divide the load between them and improve security of supply for Cork city and the vicinity of North Cork.

---

<sup>42</sup> More information is available at <http://www.eirgridgroup.com/the-grid/projects/clashavoon-dunmanway/the-project/>

## **Reinforcement of the Transmission Network in Limerick**

### **Project**

- Killonan 220/110 kV Station Redevelopment (CP0624)

### **Description**

The driver for the Killonan 220/110 kV project is security of supply.

The Killonan station forms the main bulk supply point for the Mid-West region and is an important node on the network.

The project involves the redevelopment of the entire station. This is required because of the condition and age of the transmission equipment in the station.

## **New Generation Connections in the South-West and Mid-West Planning Area**

### **Projects**

- Coomataggart 110 kV New Station – Wind farm connection (CP0932)
- Athea 110 kV Station – Wind farm connection (CP1034)
- Clahane 110 kV Station - Banemore solar farm connection (CP1046)
- Carrigdangan 110 kV New Station - Wind farm connection (CP0930)

### **Description**

The driver for these projects is RES integration. These projects are needed to connect new generation.

## **New and Modified Demand Connections in the South-West and Mid-West Planning Area**

### **Project**

- Midleton 110 kV Station – New 110 kV Bay for DSO Transformer (CP0863)

### **Description**

The driver for this project is security of supply.

The need for reinforcement is because of the requirement for new and modified demand connections. This project is a shallow connection for a DSO demand connection.

## **Reinforcement of the Transmission Network in the South-West and Mid-West Planning Area for Reactive Power Support**

### **Projects**

- Ballynahulla 220/110 kV Station – New Statcom (CP0934)
- Ballyvouskill 220/110 kV Station – New Statcom (CP0935)
- Knockanure 220/110 kV Station – New Reactor (CP0936)
- Thurles 110 kV Station – New Statcom (CP0933)

### **Description**

The driver for these projects is RES integration and security of supply.

The need for reinforcement arises due to a shortage of voltage support across the south west region and around the Thurles area. These needs were identified through network studies.

Both capacitive and inductive reactive support is required in the south west across three separate 220 kV stations; Knockanure, Ballynahulla and Ballyvouskill. The planned reactive support at the three stations makes up an overall solution for the South-West and the works at all three stations are required for the solution to perform adequately.

The need for additional reactive support in the Thurles area is due to the connection of distribution wind farms in the area and heavily loaded transmission lines during contingencies.

### **Other Approved Projects**

In addition to the network reinforcement projects described above, there are also other projects in the South-West and Mid-West planning area, namely:

- Moneypoint - Oldstreet 400 kV Line Refurbishment (CP0824);
- Tarbert - Tralee No. 1 Line Refurbishment (CP0864);
- Dunstown - Moneypoint 400 kV Line Refurbishment (CP0873);
- Tarbert – Trien 110 kV No. 1 Line Refurbishment (CP0902);
- Bandon 110 kV Station – Protection Upgrade (CP1015)<sup>43</sup>;
- Knockraha – Raffeen 220 kV Line Refurbishment (CP0868);
- Glanagow 220 kV Station - Point on Wave Controller (CP0983);
- Clashavoon - Clonkeen 110 kV Line Diversion (CP0996); and
- Kilbarry Line Conflicts (CP1037).

### **Future Needs Driving Potential Projects**

At this stage we have confirmed the need for further potential investment in this planning area. This is at an earlier stage of development and may lead to a project that will be implemented. This potential investment is:

- Prospect – Tarbert 220 kV Cable Replacement (CP0917), in Step 3.

In addition, since the data freeze date we have confirmed the need for further investment in this planning area:

- Ballyvouskil 220/110 kV Station – Temporary 50 Mvar Reactor (CP1077), in Step 4.

We are also currently working on a joint project with the French TSO Réseau de Transport d'Électricité (RTE). We are investigating an interconnector between Ireland and France that will land on the southern coast of Ireland with the potential connection point in Cork. This interconnector is deemed a Project of Common Interest (PCI) by the European Commission. PCIs are intended to help the EU achieve its energy policy and climate objectives: affordable, secure and sustainable energy for all citizens. In October 2019 the Celtic Interconnector secured EU funding under the EU's Connecting Europe Facility. See Appendix C Irish Projects in European Plans for more information.

---


<sup>43</sup> This previously came under CP0627.

## 6.4. The South-East, Mid-East and Dublin Planning Area

Summary of Projects	
Project Category	No. of Projects
New Build	18
Uprate/Modify	14
Refurbish/Replace	7
<b>Total</b>	<b>39</b>

Forecast Regional Generation and Demand in 2028	
---	--



### Regional Description

The South-East, Mid-East and Dublin planning area has a wide variety of generation sources dispersed around the planning area including pumped storage; gas burning power stations; and the 500 MW East West Interconnector (EWIC).

The greater Dublin area is the major load centre on the Irish transmission network. In contrast to the other planning areas the South-East, Mid-East and Dublin planning area does not have a substantial excess of generation relative to demand.

As demand grows in Dublin, there are transmission capacity constraints getting power into and around Dublin. To address potential issues, the SEM Committee which oversees the Single Electricity Market has introduced a mechanism which is expected to deliver a minimum amount of generation in the Dublin area to ensure security of supply.

The existing regional transmission network is comprised of 110 kV, 220 kV and 400 kV infrastructure. The transmission network has to meet a number of diverse power flows that can vary depending on:

- The generation dispatch;
- Network demand;
- Interconnector flows; and
- Network topology.

The network must accommodate high density demand in the area, and local generation exports. Additionally the network can be subject to high inter-regional power transfers from both north to south and south to north.

The development of the transmission network in the area is characterised by the displacement of thermal generation in Dublin for wind generation. This wind generation is coming from the West and South-West in particular. The effect of this is an increase in power flows through the South-East.



## Regional Description

A third party is undertaking the development of a HVDC interconnector between Ireland and Great Britain that could connect in the South-East.

Network reinforcement will be required to cater for the power flows resulting from additional demand, generation and interconnection. This will enable the efficient transfer of power to the load centres of the eastern seaboard and the Dublin area.

There are also reinforcement needs due to:

- Local constraints related to a shortage of transmission capacity and voltage support;
- Asset condition; and
- The need to accommodate further market integration.

The projects described in this section will enable the transmission network to safely accommodate more diverse power flows. They will also provide benefits to existing and future users of the transmission network in the planning area and facilitate broad future regional load growth.

The projects in the South-East, Mid-East and Dublin planning area are discussed in more detail below. The status of the network development projects is noted in Appendix B.

Please refer to Figure 5-1 for locational information of planned network developments in the South-East, Mid-East & Dublin Planning Area in Steps 4 - 6.

### Reinforcement of the Transmission Network between Munster and Leinster

#### Project

- Regional Solution, comprising:
  - Series Compensation on the existing 400 kV overhead lines that cross the country from Moneypoint in County Clare to Dunstown in County Kildare and Woodland in County Meath. The series compensation devices are planned for:
    - Moneypoint 400 kV Station Series Compensation (CP0967)<sup>44</sup>
    - Oldstreet 400 kV Station Series Compensation (CP0969)<sup>44</sup>
    - Dunstown 400 kV Stations Series Compensation (CP0968)
  - Cross-Shannon 400 kV Cable (CP0970)<sup>44</sup>
  - Great Island - Wexford 110 kV Line Uprate (CP0844)
  - Great Island - Kilkenny 110 kV Line Uprate (CP0945)
  - Wexford 110 kV Station - Busbar Uprate (CP0972)

#### Description

There is a significant amount of existing, new and contracted conventional and renewable generation connected or seeking to connect in the south and south west.

As a result, the main flow of electricity in the southern half of the Irish network is from the south and south-west towards the demand centres on the east coast.

There is a risk to the security of supply in the south - eastern area of the country. This is largely caused by heavy power flows through the network.

<sup>44</sup> This project is located in the South-West and Mid-West Planning Area. It is included here as it is part of the Regional Solution.

Network studies indicate the existing network cannot manage such large power flows. Numerous contingency scenarios result in widespread voltage violations and voltage collapse.

Large changes in system voltage phase angle can also prevent automatic reclosing of lines. This has a serious impact on circuit availability and system reliability, hence reducing security of supply.

There are also some overloads of transmission circuits. Thus the network between Munster and Leinster needs to be strengthened.

For more information on the Regional Solution and the need for it please see the report prepared for the Government appointed Independent Expert Panel<sup>45</sup>.

## **Reinforcement of the Transmission Network in the Midlands and South-East Regions including Kildare**

### **Project**

- Laois - Kilkenny Reinforcement Project (CP0585), comprising:
  - A new 400/110 kV station at Coolnabacky near Portlaoise (looped into the existing Dunstown - Moneypoint 400 kV and Athy - Portlaoise 110 kV lines);
  - A new 110 kV circuit from this station to a new 110 kV station at Ballyragget, Co. Kilkenny;
  - A 80 Mvar 400 kV shunt reactor relocated from Dunstown; and
  - A 110 kV uprate to the existing Ballyragget - Kilkenny line which is currently operated at 38 kV<sup>46</sup>.

### **Description**

This project is required to address quality of supply issues and provide security of supply in Kilkenny, Carlow, Kildare and Laois.

The need for reinforcement arises due to a shortage of transmission capacity and voltage support across the planning area. These needs were identified through network studies. These studies indicated potential violations of voltage limits throughout the area under single contingency conditions and loss of load violations in Kilkenny under maintenance-trip conditions.

The installation of a capacitor in Kilkenny 110 kV station was a short term measure to maintain supply standards to the area. The Laois - Kilkenny reinforcement addresses the medium to long term quality and security of supply concerns.

## **Reinforcement of the Transmission and Distribution Networks in the Greater Dublin Area**

### **Projects**

- Belcamp 220/110 kV Project – New 220/110 kV Station to the East of Finglas 220/110 kV Station<sup>47</sup> (CP0437)<sup>48</sup>
- Carrickmines 220/110 kV Station –GIS Development (CP0580)
- Finglas 110 kV Station Redevelopment (CP0646)
- Inchicore 220 kV Station Upgrade (CP0692)
- Finglas 220 kV Station Upgrade (CP0792)
- Castlebagot New 220/110 kV Station (CP0872)<sup>49</sup>
- Belcamp - Shellybanks New 220 kV Cable (CP0984)<sup>50</sup>

45 <http://www.eirgridgroup.com/site-files/library/EirGrid/Grid-Link-Report-to-IEP.pdf>

46 More information is available at <http://www.eirgridgroup.com/the-grid/projects/laois-kilkenny/the-project/>

47 This project is also known as “Dublin North Fringe”. More information is available at <http://www.eirgridgroup.com/the-grid/projects/dublin-north-fringe/the-project/>

48 This includes sub-project CP0978, which is a new 220 kV cable bay in Finglas 220/110 kV station to connect the new Belcamp – Finglas 220 kV cable and the new Belcamp 220 kV station to the transmission system. CP0978 has been completed.

49 More information is available at <http://www.eirgridgroup.com/the-grid/projects/west-dublin/the-project/>

50 This project also includes the fit-out of the 220 kV GIS station building built as part of CP0437.

## Description

The driver for these projects is security of supply.

The need for reinforcement arises due to local constraints on the transmission and distribution networks. There is a requirement for additional capacity at a number of locations in the Greater Dublin Area due to load growth. This is primarily at:

- The existing Carrickmines 220/110 kV station;
- The new Belcamp 220/110 kV station to the east of the existing Finglas 220/110 kV station; and
- The new Castlebagot (formerly West Dublin) 220/110 kV station between Inchicore and Maynooth 220/110 kV stations.

These needs were identified through co-ordinated TSO and DSO network studies. These studies indicated the overloading of a number of existing circuits and transformers under single contingency conditions.

Replacement of substation equipment works are progressing in Inchicore and Carrickmines 220/110 kV stations to address the condition and age of the assets. These stations are major bulk supply points in Dublin.

Inchicore and Finglas 220 kV stations also have their own specific needs. The need for these stations' upgrade projects arises due to a number of local constraints on the transmission network.

In the case of Inchicore, network studies have indicated that the capacity of some of the existing switchgear is close to being exceeded. While in Finglas 220 kV station, studies have indicated the potential for loss of load without this project.

The Belcamp – Shellybanks new 220 kV cable will provide a second 220 kV connection to the new Belcamp 220 kV station which lies to the east of Finglas 220/110 kV station.

## Reinforcement of the Transmission Network in the Greater Dublin Area

### Projects

- Corduff - Ryebrook 110 kV Line Uprate and Ryebrook 110 kV Station Busbar Uprate (CP0668)
- Inchicore - Maynooth No. 1 and 2 220 kV Line Uprate (CP0667)
- Maynooth 220 kV Station Reconfiguration (CP0808)

### Description

The driver for these projects is security of supply.

The need for the uprate projects arises due to local constraints on the transmission network. There is a requirement for additional capacity in the Greater Dublin Area.

The capacity needs were identified by network studies. These indicated the overloading of a number of existing circuits under single and maintenance-trip contingency conditions.

The need for the Maynooth station project arises due to the condition and age of the assets, and local constraints. The project involves refurbishment of the 220 kV and 110 kV busbars, reconfiguration of both the 220 kV and 110 kV busbars to an enhanced ring configuration, and an increase in the short circuit rating of both busbars. Series reactors will be incorporated into the 110 kV wing couplers to manage short circuit levels within limits.

## **New and Modified Demand Connections in the South-East, Mid-East and Dublin Planning Area**

### **Projects**

- Wexford 110 kV Station – New 110 kV Bay for DSO Transformer and New Coupler (CP0486)
- Great Island 220/110 kV Station – New DSO 110 kV Transformer Bay for DSO Connection to Knockmullen (New Ross) (CP0894<sup>51</sup>)
- Clonee 220 kV Station – Station Extension (CP0995)
- Cruiserath 220 kV Station - Permanent Connection for Demand Customer (CP1009<sup>52</sup>)
- Darndale 110 kV Station - New Station for Demand Customer (CP1013)
- Snugborough 110 kV Station – Demand Connection Phase 2 (CP1014)
- Corduff 220/110 kV Station – Two New DSO 110 kV Transformer Bays (CP1025)

### **Description**

The driver for these projects is security of supply.

The need for reinforcement arises due to the requirement for new and modified demand connections. These are the shallow connections for a number of DSO connections and directly connected large scale transmission demand customers.

## **Reinforcement of the Transmission Network within and out of Louth**

### **Project**

- Louth 275/220/110 kV Station Refurbishment – 110 kV Busbar Re-configuration and New Couplers (CP0799)

### **Description**

The driver for this project is security of supply.

There are two areas of need for the project:

- The need for network reinforcement; and
- The need for refurbishment works due to the condition of the 220 kV and 110 kV assets.

The need for reinforcement arises due to:

- A shortage of transmission capacity; and
- Possible overload of the 110 kV busbar and some circuit breakers.

In addition, the station works also involve refurbishment works due to the condition of the assets and replacement of strung bay conductors with tubular conductor to accommodate mechanical forces from short circuit currents. These works will be undertaken at the same time as the uprating works.

## **New Generation Connections in the South-East, Mid-East and Dublin Planning Area**

### **Projects**

- Rosspile 110 kV New Station – Solar Farm Connection (CP1040)
- Timahoe North 110 kV New Station – Solar Farm Connection (CP1041)

<sup>51</sup> In TDP 2018 there were two CP numbers associated with this DSO connection, CP0490 and CP0894. This has been consolidated into one CP number, CP0894.

<sup>52</sup> In TDP 2018 there were two CP numbers associated with this customer connection, CP0997 and CP1009. This has been consolidated into one CP number, CP1009.

- Gafney 110 kV New Station – Generator Temporary Connection (CP1043)
- Gallanstown 110 kV New Station – Solar Farm Connection (CP1051)
- Knocknamona 110 kV New Station - Wind Farm Connection (CP1052)
- Harristown 110 kV New Station – Solar Farm Connection (CP1055)
- Blundelstown 110 kV New Station – Solar Farm Connection (CP1020)

### Description

The driver for these projects is RES integration and security of supply. These projects are needed to connect new generation.

### Other Approved Projects

In addition to the network reinforcement projects described above, there are also other projects in the South-East, Mid-East and Dublin planning area, namely:

- Oldstreet - Woodland 400 kV Line Refurbishment (CP0825);
- Maynooth - Woodland 220 kV Line Refurbishment (CP0869);
- Maynooth - Turlough Hill 220 kV Line Refurbishment (CP0823);
- Great Island - Kellis 220 kV Line Refurbishment (CP0866);
- Maynooth - Turlough Hill 220 kV Circuit Power Line Carrier (PLC) Replacement (CP1022); and
- Finglas – Shellybanks 220 kV Cable Diversion (CP1044).

### Future Needs Driving Potential Projects

We have confirmed the need for further investment in the Greater Dublin Area. We are progressing the following two investments through our six step process for developing the grid:

- Capital Project 966, in Step 3<sup>53</sup>; and
- CP1021 North Dublin Corridor Reinforcement, in Step 2.

The system needs in the north Dublin region are dynamic due to potential changes in the connected generation portfolio combined with the connection of new large scale demand customers. These projects represent EirGrid's response to this evolving situation.

In addition, since the data freeze date we have confirmed the need for further investment as follows:

- Maynooth – Woodland 220 kV Line Uprate. This work will be included in Maynooth - Woodland 220 kV Line Refurbishment (CP0869).

The existing 220 kV circuit between Carrickmines and Arklow currently operates at 110 kV. Together with the DSO we are considering operating this line at 220 kV. We are also assessing the impact of providing an alternative 110 kV connection to Ballybeg 110 kV station.

A third party is proposing an additional interconnector between Ireland and Great Britain, known as the Greenlink Interconnector. The potential connection point for the proposed interconnector is in the south-east of the country in this planning area. This interconnector is deemed a Project of Common Interest (PCI) by the European Commission. PCIs are intended to help the EU achieve its energy policy and climate objectives: affordable, secure and sustainable energy for all citizens. See Appendix C Irish Projects in European Plans for more information.

<sup>53</sup> For the most up to date information on the project please visit the project website here: <http://www.eirgridgroup.com/the-grid/projects/capital-project-966/the-project/>



## 7. Summary of Environmental Appraisal Report

7

## 7. Summary of Environmental Appraisal Report

An Environmental Appraisal Report (EAR) has been prepared as an accompanying document to this TDP. The purpose of the EAR is to ensure the TDP 2019-2028 is in line with committed Strategic Environmental Objectives (SEOs). These objectives are set out in the Strategic Environmental Assessment (SEA) prepared for the Grid Implementation Programme (IP) 2017-2022 and integrated into the overall approach to grid development. A series of environmental, planning, social and technical policies and objectives also form a core element of the Grid IP and guide sustainable grid development.

As outlined in the earlier sections, this TDP includes 104 reinforcement projects. Of these, 23 projects are new to TDP 2019 and therefore were not considered in the environmental appraisal carried out for TDP 2018-2027 or as part of the SEA process.

These new projects consist of new build projects, refurbishment/replacement projects and uprate/modification projects. These projects are examined in the EAR and evaluated against the SEOs. Following the implementation of mitigation measures (where necessary) the SEOs will be achieved.

Therefore we consider TDP 2019-2028 to be in accordance with the provisions of the Strategic Environmental Obligations as set out in the Grid IP 2017-2022 and associated SEA.

# Appendix A: Project Terms

This appendix explains terms that are used to describe projects in the following appendices.

**Capital Project Number (CP No.):** each project is referenced with a Capital Project number for coordination between ourselves and the TAO.

**Estimated Completion Date (ECD):** the estimates provided are subject to the:

- Planning process where applicable;
- Construction progress; and
- Availability of transmission outages and commissioning.

ECDs may be liable to change.



# Appendix B: Planned Network Developments

This appendix details active TDP 2019 projects and their driver(s), need(s), location, step and ECD, as at the data freeze date 01 January 2019. Projects are categorised by planning area.

When reviewing the data in this appendix it is important to note the approach to describing the location of projects. If the project involves a circuit then both stations at either end of the circuit, and the counties the stations are located in, are noted.

If the project involves a station only then only one county is listed for that project.

Also please note the following label:

- “\*” included with a project’s circuit length signifies that the circuit length is an estimate at this time.

The ECD and step in the six-step process for some transmission projects, known as Associated Transmission Reinforcements (ATRs), are available and updated on a quarterly basis on our website [here](#)<sup>54</sup>.

---

<sup>54</sup> <http://www.eirgridgroup.com/customer-and-industry/general-customer-information/operational-constraints/>

## Projects in the Border, Midlands and West Planning Area

There are 27 projects in the Border, Midlands and West Planning Area; these projects are listed in Table B-1 below.

**Table B-1: Planned Projects in the Border, Midlands and West Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location	Step	ECD
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition			
1	CP0816	North Connacht 110 kV Project	-	New Build	✓	✓	✓	✓	✓	✓	✓	Mayo, Roscommon	4	2024
2	CP0197	Mount Lucas - Thornsberry New 110 kV Line	18	New Build	✓		✓					Offaly, Offaly	6	2019
3	CP0724	Thornsberry 110 kV Station - Busbar Uprate	-	Uprate/ Modify	✓		✓					Offaly	6	2019
4	CP0421	Trevebrack/Ardhagappary 110 kV Development	34	New Build	✓				✓			Donegal	6	2019
5	CP0740	Letterkenny 110 kV Station - Relocation of 110 kV Bay and 2 New Couplers	-	Uprate/ Modify	✓		✓		✓			Donegal	6	2019
6	CP0466	North South 400 kV Interconnection Development	138*, <sup>55</sup>	New Build	✓	✓	✓	✓	✓	✓		Meath, Cavan, Monaghan, Armagh, Tyrone	5	2023

<sup>55</sup> The total length is 138 km, 103 km in Ireland and 35 km in Northern Ireland.

**Table B-1: Planned Projects in the Border, Midlands and West Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location		Step	ECD	
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition	County/ Counties	County/ Counties			
7	CP0819 Bellacorick - Moy 110 kV Line Uprate	Uprate/ Modify	27	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Mayo, Mayo	6	2019
8	CP0833 Tawnaghmore and Moy 110 kV Stations - Mayo Renewable Power Connection	Uprate/ Modify	-	✓	✓					✓				Mayo	6	2020
9	CP0835 Coolinabacky - Portlaoise 110 kV Line Uprate	Uprate/ Modify	8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Laois, Laois	5	2021
10	CP0839 Moy 110 kV Station - Reconfiguration and Busbar Uprate	Uprate/ Modify	-	✓	✓					✓				Mayo	6	2020
11	CP0771 Castlebar 110 kV Station - Busbar Uprate	Uprate/ Modify	-	✓	✓					✓				Mayo	6	2020
12	CP0850 Shranakilly 110 kV New Station - Wind farm connections	New Build	-		✓						✓			Mayo	5	2019
13	CP0865 Cashla – Salthill 110 kV Circuit Refurbishment and 110 kV Bay Uprate	Uprate/ Modify	-	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Galway, Galway	5	2019

**Table B-1: Planned Projects in the Border, Midlands and West Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location	Step	ECD
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition			
14	CP0867	Flagford - Louth 220 kV Refurbishment Project	110	✓								Roscommon, Leitrim, Longford, Cavan, Meath, Louth	5	2021
15	CP0800	North West Project - Reinforcement of the grid in the north-west <sup>56</sup>	-		✓		✓	✓				Donegal, Leitrim, Sligo	1	2027
16	CP0905	Louth – Ratrussan 110 kV No. 1 Line Refurbishment	39	✓								Louth, Monaghan, Cavan	6	2020
17	CP0871	Galway 110 kV Station Redevelopment	-	✓	✓			✓				Galway	6	2022
18	CP0903	Cloon – Lanesboro 110 kV Line Refurbishment	65	✓								Galway, Roscommon, Longford	6	2020
19	CP0942	Corderry - Srananagh 110 kV Line Upgrade	13		✓				✓			Leitrim, Sligo	5	2020
20	CP1019	Cashla - Tynagh 220 kV Line Fibre Wrap	40	✓								Galway	6	2019

<sup>56</sup> We are reviewing the need, solutions, technology and timing of this work in line with our grid development strategy and six-step process for developing the grid.

**Table B-1: Planned Projects in the Border, Midlands and West Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location	Step	ECD
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition			
21	CP0919 Lanesboro 110 kV Station Redevelopment	Uprate/Modify	-									Longford	4	2024
22	CP1031 Flagford 220/110 kV Station – Circuit Breaker Replacement	Refurbish/Replace	-	✓				✓				Roscommon	5	2022
23	CP1032 Cashla 220/110 kV Station – Circuit Breaker Replacement	Refurbish/Replace	-	✓							✓	Galway	5	2022
24	CP1035 N6 Line Diversions	Refurbish/Replace	-	✓				✓				Galway	4	2022
25	CP1048 Richmond 110 kV Station Power Flow Control Scheme	Uprate/Modify	-	✓						✓		Longford	4	2023
26	CP1054 Kinnegad – Mullingar 110 kV Line Diversion	Refurbish/Replace	-	✓				✓				Westmeath	4	2019
27	CP0913 Flagford – Sligo 110 kV Line Conflict (N4 Road Realignment) and Station End Works	Refurbish/Replace	-	✓						✓		Roscommon, Sligo	6	2019

## Projects in the South-West and Mid-West Planning Area

There are 32 projects in the South-West and Mid-West Planning Area; these projects are listed in Table B-2 below.

**Table B-2: Planned Projects in the South-West and Mid-West Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location	Step	ECD
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition			
1	CP0501 Clashavoon - Dunmanway 110 kV New Line	New Build	35*	✓	✓	✓	✓	✓	✓	✓	✓	Cork	6	2019
2	CP0622 Tarbert 220/110 kV Station Refurbishment	Refurbish/ Replace	-	✓							✓	Kerry	6	2022
3	CP0763 Kilpaddoge – Knockanure and Ballyvouskil - Clashavoon 220 kV Line Uprates and Kilpaddoge - Tarbert 220 kV Line Refurbishment	Uprate/ Modify	37	✓	✓	✓	✓	✓	✓	✓		Cork, Kerry	6	2020
4	CP0647 Kilpaddoge 220/110 kV New Station	New Build	-	✓					✓		✓	Kerry	6	2020
5	CP0688 Moneypoint 400/220/110 kV GIS Development	New Build	-	✓	✓	✓	✓	✓	✓	✓	✓	Clare	6	2019
6	CP0874 Booltiagh 110 kV Station Extension	Uprate/ Modify	-		✓					✓		Clare	6	2019

**Table B-2: Planned Projects in the South-West and Mid-West Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location		Step	ECD
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition	County/ Countries	County/ Countries		
7	CP0824	Moneypoint - Oldstreet 400 kV Line Refurbishment	104	✓								✓	Clare, Galway	6	2020
8	CP0794	Aghada 220/110 kV Station Upgrade	-	✓				✓				✓	Cork	6	2020
9	CP0796	Knockraha 220 kV Station Upgrade	-	✓				✓					Cork	6	2021
10	CP0624	Killonan 220/110 kV Station Redevelopment	-	✓								✓	Limerick	6	2027
11	CP0726	Moneypoint to Knockanure 220 kV Project	26*		✓				✓				Clare, Kerry	6	2019
12	CP0829	Clashavoon - Macroon No. 2 New 110 kV Circuit and Increased Transformer Capacity in Clashavoon 220/110 kV Station	6		✓					✓			Cork, Cork	6	2019
13	CP0883	Ballynahulla - Ballyvouskill and Ballynahulla - Knockanure 220 kV Line Upgrades (formerly part of CP0763)	66		✓				✓				Cork, Kerry	6	2020

**Table B-2: Planned Projects in the South-West and Mid-West Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location	Step	ECD	
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition				
14	CP0863	Midleton 110 kV Station - New 110 kV DSO Transformer Bay		Uprate/ Modify	-	✓	✓						Cork	6	2019
15	CP0864	Tarbert - Tralee No. 1 110 kV Line Refurbishment	42	Refurbish/ Replace		✓					✓		Kerry, Kerry	6	2019
16	CP0933	Thurles 110 kV Station – New Statcom	-	New Build		✓	✓			✓			Tipperary	4	2021
17	CP0934	Ballynahulla 110 kV Station – New Statcom	-	New Build		✓	✓			✓			Kerry	5	2020
18	CP0935	Ballyvouskill 110 kV Station – New Statcom	-	New Build		✓	✓			✓			Cork	5	2020
19	CP0936	Knockanure 110 kV Station – New Reactor	-	New Build		✓	✓			✓			Kerry	6	2020
20	CP0873	Dunstown - Moneypoint 400 kV Line Refurbishment	209	Refurbish/ Replace		✓							Kildare, Laois, Tipperary, Clare	5	2021



**Table B-2: Planned Projects in the South-West and Mid-West Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location	Step	ECD	
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition				
21	CP0902	Tarbert – Trien 110 kV No. 1 Line Refurbishment	21	✓									Kerry	6	2019
22	CP0973	Knockraha Short Circuit Rating Mitigation	-	✓									Cork	5	2020
23	CP0868	Knockraha – Raffeen 220 kV Line Refurbishment	19	✓									Cork	5	2020
24	CP0983	Glanagow 220 kV Station - Point on Wave Controller	-	✓				✓					Cork	6	2022
25	CP0949	New 110 kV Station near Kilbarry	-	✓							✓		Cork	6	2023
26	CP1015	Bandon 110 kV Station – Protection Upgrade	-	✓									Cork	6	2019
27	CP0932	Coomataggart 110 kV Station – New Station	32*		✓								Kerry	6	2019

**Table B-2: Planned Projects in the South-West and Mid-West Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location	Step	ECD	
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition				
28	CP0996	Clashavoon - Clonkeen 110 kV Line Diversion	-	✓						✓			Cork, Kerry	6	2020
29	CP1034	Athea 110 kV Station – Wind farm connection works	-		✓						✓		Limerick	6	2019
30	CP1037	Kilbarry Line Conflicts	-	✓						✓			Cork	5	2020
31	CP1046	Clahane 110 kV Station - Banemore solar farm connection	-		✓						✓		Kerry	4	2021
32	CP0930	Carrigdangan 110 kV New Station - Wind farm connection	-		✓						✓		Cork	3	2020

## Projects in the South-East, Mid-East and Dublin Planning Area

There are 39 projects in the South-East, Mid-East and Dublin Planning Area; these projects are listed in Table B-3 below.

**Table B-3: Planned Projects in the South-East, Mid-East and Dublin Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location	Step	ECD	
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition				
1	CP0667	Inchicore - Maynooth No. 1 and No. 2 220 kV Line Uprate	38	✓			✓			✓			Dublin, Kildare	6	2019
2	CP0668	Corduff - Ryebrook 110 kV Line Uprate and Ryebrook 110 kV Station Busbar Uprate	14	✓			✓						Dublin, Kildare	6	2019
3	CP0486	Wexford 110 kV Station - New 110 kV Transformer Bay and New Coupler	-	✓			✓			✓			Wexford	6	2020
4	CP0646	Finglas 110 kV Station Redevelopment	-	✓			✓						Dublin	6	2020
5	CP0580	Carrickmines 220/110 kV Station GIS Development	-	✓			✓						Dublin	6	2019
6	CP0792	Finglas 220 kV Station Upgrade	-	✓			✓						Dublin	6	2022

**Table B-3: Planned Projects in the South-East, Mid-East and Dublin Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location		Step	ECD
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition	County/ Counties	County/ Counties		
7	CP0585	Laois-Kilkenny Reinforcement Project	New Build	30* + 22 <sup>57</sup>	✓	✓	✓	✓	✓	✓	✓	✓	Laois, Kilkenny	6	2021
8	CP0825	Oldstreet - Woodland 400 kV Line Refurbishment	Refurbish/ Replace	126	✓							✓	Galway, Tipperary, Offaly, Kildare, Meath	6	2019
9	CP0437	Belcamp 220/110 kV Project - New 220/110 kV Station to the East of Finglas 220/110 kV Station	New Build	10*	✓					✓	✓		Dublin	6	2019
10	CP0692	Inchicore 220 kV Station Upgrade	Uprate/ Modify	-	✓					✓		✓	Dublin	4	2025
11	CP0894 <sup>58</sup>	Great Island 220/110 kV Station - New DSO 110/38 kV Transformer	Uprate/ Modify	-	✓							✓	Wexford	6	2020
12	CP0872	Castlebogot 220/110 kV New Station	New Build	-	✓					✓			Dublin	6	2020

<sup>57</sup> 30 km is the length of the proposed new 110 kV circuit between the proposed new Coolnaback 400/110 kV station near Portlaoise and the proposed new 110 kV station at Ballyragget. 22 km is the length of the proposed 110 kV uprate to the existing Ballyragget – Kilkenny line which is currently operated at 38 kV.

<sup>58</sup> In TDP 2018 there were two CP numbers associated with this DSO connection, CP0490 and CP0894. This has been consolidated into one CP number, CP0894.

**Table B-3: Planned Projects in the South-East, Mid-East and Dublin Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location	Step	ECD	
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition				
13	CP0869	Maynooth - Woodland 220 kV Line Refurbishment	22	✓								✓	Dublin, Dublin	5	2020
14	CP0808	Maynooth 220 kV Station Reconfiguration	-	✓				✓				✓	Kildare	5	2027
15	CP0844	Great Island - Wexford 110 kV Uprate	34	✓				✓				✓	Wexford	6	2019
16	CP0945	Great Island - Kilkenny 110 kV Uprate	49	✓				✓				✓	Wexford, Kilkenny	5	2021
17	CP0984	Belcamp - Shellybanks 220 kV New Cable	10*	✓				✓				✓	Dublin	4	2021
18	CP0995	Clonee 220 kV Station – Station Extension	-	✓								✓	Meath	6	2019
19	CP0968	Dunstown 400 kV Station Series Compensation	-	✓				✓				✓	Kildare	4	2022

**Table B-3: Planned Projects in the South-East, Mid-East and Dublin Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location	Step	ECD
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition			
20	CP0972	Wexford 110 kV Station - Busbar Upgrade	-	✓	✓	✓	✓	✓	✓	✓	✓	Wexford	6	2020
21	CP0823	Maynooth - Turlough Hill 220 kV Line Refurbishment	53	✓							✓	Kildare, Wicklow	6	2022
22	CP0866	Great Island - Kellis 220 kV Line Refurbishment	70	✓							✓	Wexford, Carlow	6	2021
23	CP1009 <sup>59</sup>	Cruiserath 220 kV Station - Permanent Connection for Demand Customer	-	✓							✓	Dublin	5	2021
24	CP1013	Darndale 110 kV Station - New Station for Demand Customer	-	✓							✓	Dublin	5	2019
25	CP0967	Moneypoint 400 kV Station Series Compensation <sup>60</sup>	-	✓	✓		✓	✓	✓	✓		Clare	4	2022
26	CP0970	Cross-Shannon 400 kV Cable <sup>60</sup>	6*	✓	✓		✓	✓	✓	✓		Clare, Kerry	4	2022

<sup>59</sup> In TDP 2018 there were two CP numbers associated with this customer connection, CP0997 and CP1009. This has been consolidated into one CP number, CP1009.

<sup>60</sup> This project is located in the South-West and Mid-West Planning Area. It is included here as it is part of the Regional Solution.

**Table B-3: Planned Projects in the South-East, Mid-East and Dublin Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location	Step	ECD	
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition				
27	CP0969 Oldstreet 400 kV Station Series Compensation <sup>60</sup>	New Build	-	✓	✓	✓	✓	✓	✓				Galway	4	2022
28	CP1014 Snugborough 110 kV Station – Demand Connection Phase 2	Uprate/Modify	-	✓						✓			Dublin	6	2020
29	CP1020 Blundelstown 110 kV New Station – Solar farm connection	New Build	-		✓					✓			Meath	5	2020
30	CP1022 Maynooth - Turlough Hill 220 kV Circuit Power Line Carrier (PLC) Replacement	Refurbish/Replace	53	✓								✓	Kildare, Wicklow	5	2020
31	CP1025 Corduff 220/110 kV Station – Two New DSO Transformers for Demand	Uprate/Modify	-	✓						✓			Dublin	6	2020
32	CP1040 Rosspile 110 kV New Station – Solar farm connection	New Build	-		✓					✓			Wexford	5	2021
33	CP1041 Timahoe North 110 kV New Station – Solar farm connection	New Build	-		✓					✓			Kildare	5	2021

**Table B-3: Planned Projects in the South-East, Mid-East and Dublin Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location	Step	ECD
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition			
27	CP0969 Oldstreet 400 kV Station Series Capacitor <sup>59</sup>	New Build	-	✓	✓	✓	✓	✓	✓	✓	✓	Galway	4	2022
28	CP1014 Snugborough 110 kV Station – Demand Connection Phase 2	Uprate/Modify	-	✓						✓		Dublin	6	2020
29	CP1020 Blundelstown 110 kV New Station – Solar farm connection	New Build	-	✓						✓		Meath	5	2020
30	CP1022 Maynooth - Turlough Hill 220 kV Circuit Power Line Carrier (PLC) Replacement	Refurbish/Replace	53	✓							✓	Kildare, Wicklow	5	2020
31	CP1025 Corduff 220/110 kV Station – Two New DSO Transformers for Demand	Uprate/Modify	-	✓						✓		Dublin	6	2020
32	CP1040 Rosspile 110 kV New Station – Solar farm connection	New Build	-		✓					✓		Wexford	5	2021
33	CP1041 Timahoe North 110 kV New Station – Solar farm connection	New Build	-	✓						✓		Kildare	5	2021



**Table B-3: Planned Projects in the South-East, Mid-East and Dublin Planning Area**

CP No.	Project Title	Type	Km	Drivers			Needs					Location		Step	ECD	
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition	County/ Counties	Meath			
34	CP1043 Gafney 110 kV New Station – Generator temporary connection	New Build	-	✓						✓				Meath	5	2020
35	CP1044 Finglas – Shellybanks 220 kV Cable Diversion	Refurbish/ Replace	-	✓				✓						Dublin	5	2019
36	CP1051 Gallanstown 110 kV New Station – Solar farm connection	New Build	-	✓						✓				Dublin	5	2021
37	CP1052 Knocknamona 110 kV New Station - Wind farm connection	New Build	-	✓						✓				Waterford	5	2020
38	CP1055 Harristown 110 kV New Station – Solar farm connection	New Build	-	✓						✓				Meath	5	2021
39	CP0799 Louth 220 kV Station Upgrade	Uprate/ Modify	-	✓					✓					Louth	5	2023

## National Projects

There are six national projects each with elements at various locations around the country; they are listed in Table B-4 below.

**Table B-4: Planned National Projects at Various Locations**

CP No.	Project Title	Type	Km	Drivers			Needs					Step	ECD
				Security of Supply	RES Integration	Market Integration	Inter-Regional Power Flow	Local Constraints	Connection	Inter-connection	Asset Condition		
1	CP0857	Paint Towers Nationwide	-	✓							✓	6	2021
2	CP0939	Strategic Restoration System	-	✓							✓	6	2019
3	CP1016	220 kV Composite Poles Type Testing	-	✓								5	2020
4	CP1017	400 kV Voltage Uprate Trial	-	✓								5	2020
5	CP1036	Transformers Protection Upgrade	-	✓					✓			5	2021
6	CP1053	220 kV Cable Sealing End Replacement at three transmission stations	-	✓							✓	5	2020

# Appendix C: Irish Projects in European Plans<sup>61</sup>

## How are Irish transmission projects included in ENTSO-E's TYNDP?

Licensed TSOs, who are members of ENTSO-E, and third party promoters, propose transmission projects to ENTSO-E for inclusion in ENTSO-E's TYNDP. The technical and administrative criteria for inclusion in the TYNDP are published by ENTSO-E. TYNDP 2020 criteria are available [here](#).

### Technical criteria for inclusion in TYNDP 2020

The technical criteria and required information for inclusion of transmission projects in TYNDP 2020 are summarised below.

The main equipment needs to be:

- a high-voltage overhead transmission line designed for a transmission voltage of 110 kV or more in the case of direct cross-border infrastructure; or
- a high-voltage overhead transmission line designed for a transmission voltage of 220 kV or more in the case of internal infrastructure; or
- a high voltage underground/submarine transmission cable designed for a voltage of 110 kV or more.

The main equipment needs to be at least partially located in one of the countries represented within ENTSO-E.

The initial estimation of the net transfer capacity increase (NTC) expressed in MW needs to be provided to ENTSO-E, where:

- for the cross-border infrastructure: no minimum limit is imposed; or
- for the internal infrastructure: no minimum limit is imposed. If the impact on the NTC is under 100 MW, projects must be planned to ensure security of supply or load growth or to allow new generation connection.

All the project characteristics necessary to model the project in the network tool used by ENTSO-E in the assessment process needs to be provided to ENTSO-E.

The following information also needs to be provided to ENTSO-E:

- Date of commissioning and status of each investment item of the project; and
- Capital and operational expenditure of each investment item of the project.

This is a summary of the technical criteria and required information for inclusion of transmission projects in TYNDP 2020. All criteria and required information for inclusion in TYNDP 2020 can be found in the ENTSO-E document provided in the link above.

### EirGrid projects in TYNDP 2018

Table C-1 below lists the projects we proposed that are in ENTSO-E's most recent TYNDP, TYNDP 2018<sup>62</sup>. Criteria for inclusion in TYNDP 2018 are available [here](#).

Projects which have a CP No. in the table below have achieved internal capital approval. Projects which are labelled "n/a" are currently conceptual and are under investigation.

<sup>61</sup> For the avoidance of doubt, the term "Irish Projects in European Plans" refers to Irish projects in ENTSO-E's TYNDP and RegIP NS and Irish projects designated Projects of Common Interest.

<sup>62</sup> <http://tyndp.entsoe.eu/>

**Table C-1: Our projects in European TYNDP 2018**

TYNDP No.	CP No.	Project Title
81	CP0466	North South 400 kV Interconnection Development
82	CP0800 <sup>63</sup>	Renewable Integration Development Project (RIDP)
107	n/a	Ireland - France Interconnector (Celtic Interconnector)

**Third party projects in TYNDP 2018**

Table C-2 below lists the Irish projects proposed by third parties that are in ENTSO-E's TYNDP 2018.

**Table C-2: Third party projects in European TYNDP 2018**

TYNDP No.	Project Title
286	Greenlink
349	Marex Organic Power Interconnector
1025	Silvermines Hydroelectric Power Station
1030	Marex Organic Power Energy Storage

**Irish Projects of Common Interest (PCIs)**

The European Commission (EC) oversees the designation of Projects of Common Interest<sup>64</sup> (PCI). The PCI selection is a process separate from the TYNDP process. However, to be eligible for PCI status, inclusion in the last available TYNDP is an explicit condition. Table C-3 below lists the Irish PCIs on the fourth PCI list. The fourth list was published by the European Commission in October 2019 and is available [here](#)<sup>65</sup>.

**Table C-3: Irish Projects of Common Interest**

PCI No.	TYNDP No.	Project Title
2.13.1	81	North South 400 kV Interconnection Development
2.13.2	82	Renewable Integration Development Project (RIDP)
1.6	107	Ireland - France Interconnector (Celtic Interconnector)
1.9.1	286	Greenlink

**Irish e-Highway 2050 projects**

The e-Highway2050 project<sup>66</sup> is a study project funded by the EC aimed at building a development plan for the European transmission network from 2020 to 2050. The development plan supports the EU's overall policy objectives with regard to energy and decarbonising the European economy. Table C-4 below lists the Irish projects included in the e-Highway 2050 plan. These e-Highway projects are also identified as such in fourth PCI list referred to above.

**Table C-4: Irish Projects in e-Highway 2050 Plan**

PCI No.	TYNDP No.	Project Title
2.13.1	81	North South 400 kV Interconnection Development
2.13.2	82	Renewable Integration Development Project (RIDP)
1.6	107	Ireland - France Interconnector (Celtic Interconnector)

<sup>63</sup> CP0800 is the North West Project only i.e. the first phase of RIDP, see further details above in Section 6.2 Border, Midlands and West Planning Area.

<sup>64</sup> <https://ec.europa.eu/energy/en/topics/infrastructure/projects-common-interest>

<sup>65</sup> [https://ec.europa.eu/energy/sites/ener/files/c\\_2019\\_7772\\_1\\_annex.pdf](https://ec.europa.eu/energy/sites/ener/files/c_2019_7772_1_annex.pdf)

<sup>66</sup> <https://www.entsoe.eu/outlooks/ehighways-2050/>

### How are Irish and European Plans related?

It is worth highlighting how the Irish TDP and the European plans and designations are related. Figure C-1 below illustrates the relationship. All our capital projects, irrespective of size, are described in the TDP.

Only high voltage projects that involve a large increase in transmission capacity are included in European plans. Of those only a small number of large cross border projects which increase the import and/or export capability of ENTSO-E countries are designated Projects of Common Interest.




Figure C-1: Relationship between Irish and European Plans

# Appendix D: References

## Our published documents

- I. EirGrid's Strategy 2020-2025, September 2019
- II. Transmission Development Plan (TDP) 2018, August 2019
- III. Transmission System Security and Planning Standards (TSSPS), May 2016
- IV. Ireland's Grid Development Strategy – Your Grid, Your Tomorrow, January 2017
- V. All Island Ten Year Transmission Forecast Statement (TYTFS) 2018-2027, September 2019
- VI. All Island Generation Capacity Statement (GCS) 2019-2028, September 2019
- VII. Grid Implementation Plan 2017-2022, April 2019
- VIII. Grid Implementation Plan 2017-2022 - Strategic Environmental Assessment Statement, April 2019

## ENTSO-E published documents

- IX. Ten Year Network Development Plan (TYNDP) 2018, November 2018
- X. Regional Investment Plan North Sea 2017, January 2018

## National Legislation

- XI. Electricity Regulation Act, 1999
- XII. Planning and Development Act, 2000 (as amended)
- XIII. Strategic Infrastructure Act, 2006
- XIV. Statutory Instrument No. 445 of 2000, European Communities (Internal Market in Electricity) Regulations
- XV. Statutory Instrument No. 60 of 2005, European Communities (Internal Market in Electricity) Regulations
- XVI. Statutory Instrument No. 147 of 2011, European Communities (Renewable Energy) Regulations

## European Legislation

- XVII. Birds and Natural Habitats Regulations, 2011
- XVIII. Cross-border Exchanges in Electricity Regulation (EC) No 714/2009
- XIX. Environmental Impact Assessment Directive
- XX. Habitats Directive
- XXI. Internal Market for Electricity Directive 2009/72/EC
- XXII. Internal Market for Electricity Directive 2019/944/EC
- XXIII. Promotion of the Use of Energy from Renewable Resources Directive 2009/28/EC
- XXIV. Energy Efficiency Directive 2012/27/EC

### **CRU published documents**

- XXV. TSO Licence granted to EirGrid
- XXVI. CER/15/296; Decision on TSO and TAO Transmission Revenue for 2016 to 2020, December 2015

### **Government published documents**

- XXVII. Climate Action Plan 2019, June 2019
- XXVIII. Project Ireland 2040, February 2018
- XXIX. Energy White Paper, 2015
- XXX. Government Policy Statement on the Strategic Importance of Transmission and Other Energy Infrastructure, July 2012



The Oval, 160 Shelbourne Road, Ballsbridge, Dublin D04 FW28 • Telephone: 01 677 1700 • [www.eirgrid.com](http://www.eirgrid.com)

