



Other System Charges (OSC) Trip Report
2025/2026

Date	Unit	MW Lost	Pre-incident [Hz]	Frequency Nadir [Hz]	Trip Type
09/12/2025 16:46	Synergen Power Ltd unit DB1	254.28		49.76	Fast Wind-down Trip
12/12/2025 08:46	Synergen Power Ltd unit DB1	413.17		49.76	Fast Wind-down Trip