

**Other System Charges (OSC) Trip Report
2018/2019**

Date	Unit	MW Lost	Pre-incident [Hz]	Frequency Nadir [Hz]	Trip Type
07/10/2018 16:38	WO4	134.71		49.77	Direct Trip
09/10/2018 14:26	Ballylumford CCGT Unit 32	165.456		49.7	Direct Trip
05/11/2018 22:19	AD2	140.02		49.86	Direct Trip
22/11/2018 08:29	HN2	209.52		49.74	Direct Trip
24/11/2018 23:06	TYC	269.84		49.77	Direct Trip
08/11/2018 11:52	Coolkeeragh C30	267.491		49.744	Direct Trip
30/11/2018 13:15	Ballylumford CCGT Unit 31	138.783		49.88	Direct Trip
16/12/2018 15:18	Huntstown Power Co Ltd	114.26		49.87	Direct Trip
22/12/2018 06:48	Bord Gais Energy Ltd	320.37		49.57	Direct Trip
22/12/2018 17:53	SSE Generation Ireland Ltd	101.98		49.86	Direct Trip